



# Wyoming Storage Tank Program Operator's Annual Inspection (OAI)



<b>8 UH'DYfZ:fa YX:</b>	<b>WYOMING FACILITY NUMBER:</b>
<b>FACILITY NAME:</b>	<b>OWNER NAME:</b>
<b>Address:</b>	<b>Mailing Address:</b>
<b>City:</b>	<b>City, State, Zip:</b>
<b>Phone:</b>	<b>Phone:</b>
<b>Tester:</b>	<b>Tester License Number:</b>
<b>Tester Company Name:</b>	<b>Owner/Operator Signature:</b>

**NOTE:** WHEN THE OWNER/OPERATOR SUBMITS COPIES OF THIS OPERATORS ANNUAL INSPECTION FORM TO THE DEQ STORAGE TANK PROGRAM, THEY ARE ALSO REQUIRED TO SUBMIT COPIES OF THE TANK LEAK DETECTION RECORDS FOR THE PRECEDING 12 MONTHS.

<b>LINE AND LINE LEAK DETECTOR TESTING</b>		
Type of line leak detectors installed: MLLD, ELLD, Sump Sensors, Etc.		
Were line leak detectors/sump sensors function tested (if yes, attach testing documentation)	Yes / No	N/A
Did all line leak detectors/sump sensors function properly	Yes / No	N/A
Were lines tightness tested (if yes, attach testing documentation)	Yes / No	N/A
<b>TANK LEAK DETECTION</b>		
Were Automatic Tank Gauging (ATG) systems properly calibrated and operating properly at the time of the inspection.	Yes / No	N/A
Were Interstitial Monitoring (IM) systems properly tested and Interstitial Probes functioning properly at the time of the inspection.	Yes / No	N/A
Any alarm conditions exist at the time of the inspection.	Yes / No	N/A
Are ATG or Interstitial Probes clean and correct for substance stored.	Yes / No	N/A
<b>CORROSION PROTECTION (CP)</b>		
Was the CP system tested (If so, include testing documentation)	Yes / No	N/A
CP Test Date:		
<b>MISCELLANEOUS EQUIPMENT</b>		
Were all openings to the tanks inspected	Yes / No	N/A
Were spill buckets clean and free of debris, water, and fuel or product	Yes / No	N/A
Were dispensers inspected, Fire/Safety/Shear Valves Anchored, and any test equipment removed.	Yes / No	N/A
Is Emergency Shutoff Visible and Clearly Marked. Is it at least 20' from Dispensers and No More Than 100' from Dispensers, and is portable Fire Extinguisher No More Than 75' From Dispensers.	Yes / No	N/A