

**CHECKLIST FOR TRAINING CLASS C OPERATORS**

NAME: \_\_\_\_\_ DATE OF TRAINING: \_\_\_\_/\_\_\_\_/\_\_\_\_

STORE NAME: \_\_\_\_\_ DEQ FACILITY NUMBER: 0-00\_\_\_\_\_

CLASS A OR B OPERATOR (NAME & CERTIFICATION #):

---

Class C Operators must be trained by the Class A or B Operator for that location in all of the following areas:

- Proper procedures to follow in the event of an accident that damages the dispensers or any part of the fuel system, including but not limited to exposed piping and vent lines
- The location and operation of all emergency shutoff switches, breakers, and other controls necessary to completely control all pumps installed on the system
- The limits of maintenance items that can be performed by the Class C Operator and what items must be referred to more qualified individuals.
- Procedures to be followed in the event of a fuel release, regardless of the reason for that release.
- Records that must be kept (if any) on each shift to insure that release detection is properly done
- Delivery procedures and hazards
- Alarm recognition with emphasis on the significance and proper response to each and every alarm on the storage tank system; and
- The location and function of all leak detection and CP devices and systems

Notes:

---

---

---

---

---

---

---

---

- Records shall be maintained on site or off-site at a readily available location within the State of Wyoming.
- Persons who are licensed as UST or AST Operators shall renew their license every five (5) years.