BEFORE THE

DEPARTMENT OF ENVIRONMENTAL QUALITY

STATE OF WYOMING

IN THE MATTER OF THE NOTICE OF VIOLATION ISSUED TO:	)	
Lloyd D. Haslam Crowheart Store 8526 U.S. Highway 26 Crowheart, WY 82513	)	DOCKET NUMBER 4289-08

NOTICE OF VIOLATION

NOTICE IS HEREBY GIVEN THAT:

1. Lloyd D. Haslam owns and operates aboveground storage tanks (ASTs) located at 8526 U.S. Highway 26, Crowheart, Wyoming. The facility is registered as AST facility 0-003968 and does business under the name Crowheart Store. An installation inspection was conducted on June 5, 2008, by personnel from the Department of Environmental Quality. It was discovered that the two new ASTs were put into operation before obtaining written approval of the installation.

2. Wyoming Statute 35-11-1420(b) states that "(b) No person shall install or substantially modify, or cause to be installed or substantially modified, any new or replacement tank without thirty (30) days prior notification to the department. Upon completion of the installation or modification the owner shall notify the department and the department shall within ten (10) days of receiving notification of completion, inspect the site or have the site inspected by a qualified state, local government or private inspector. No tank shall be operated until the department determines the installation or modification meets the applicable standards and the department has issued a written inspection letter to the tank owner stating that the facility, as constructed or modified, meets state standards, except that if the department has not inspected the tank within fifteen (15) days after receiving notice of completion, the tank may be operated without written notification of the department until the tank is inspected."

3. By operating two ASTs without first obtaining written approval from the department, Lloyd D. Haslam has violated W.S. 35-11-1420 (b).

4. This Notice is being sent to you pursuant to W.S. 35-11-701(c)(i), which requires that in any case of the failure to correct or remedy an alleged violation, the director of the Department of Environmental Quality shall cause a written notice to be issued and served upon the person alleged to be responsible.

NOTHING IN THIS NOTICE OF VIOLATION (NOV) shall be interpreted to in any way limit or contravene any other remedy available under the Environmental Quality Act, nor shall this NOV be interpreted as being a condition precedent to any other enforcement action.

SIGNED this 18th day of JUNE, 2008

John V. Corra
Director
Department of Environmental Quality

for
LeRoy C. Feusner, P.E., BCEE
Administrator
Solid and Hazardous Waste Management Division

PLEASE DIRECT ALL INQUIRES TO: Robert Lucht, P.E. & P.G., Storage Tank Program Compliance Supervisor at 122 West 25th Street, Fourth Floor, West Wing, Cheyenne, WY 82002, (307) 777-7095 or (307) 777-5973 FAX for technical matters.