




Department of Environmental Quality



To protect, conserve, and enhance the Quality of Wyoming's environment for the benefit of current and future generations

Dave Freudenthal, Governor

John Corra, Director

December 29, 2010

CERTIFIED 7007 0710 0000 3817 7004

Terry Reach
Elk Ridge Lodge, Inc.
P.O. Box 705
Pinedale, WY 82941

Dear Mr. Reach:

Enclosed you will find a Notice of Violation and Order, Docket Number 4783-10, issued under the provisions of W.S. 35-11-701(c). The retail aboveground storage tank (AST) located at Elk Ridge Lodge has not been upgraded in accordance with Wyoming Water Quality Rules and Regulations (WWQRR), Chapter 17. The annual tank fees for 2010 have not been paid, the AST was to have been upgraded by October 1, 2008, an operator's annual inspection has never been performed, and the facility does not have a licensed Class A or B Storage Tank Operator.


Please be aware that the attached Notice of Violation contains an Order detailing what must be done to eliminate and rectify these violations. This order prohibits the delivery of fuels to the retail AST located at Elk Ridge Lodge until this matter is resolved. If you have any questions about this Notice of Violation please contact Mr. Oma Gilbreth at (307)777-7097.

ANY APPEALS TO THE ENVIRONMENTAL QUALITY COUNCIL FROM THE ATTACHED ORDER MUST BE MADE IN WRITING WITHIN THE TEN (10) DAY TIME LIMIT PRESCRIBED BY W.S. 35-11-701(c). Chapter I, Section 3 of the enclosed Department of Environmental Quality Rules of Practice and Procedure sets forth the requirements for the initiation of appeal proceedings. You are urged to review all provisions of the attached Rules of Practice and Procedures as they relate to this action.

If you appeal this order and request a hearing, please file two (2) copies of your written petition. One copy of the petition should go to the Chairman of the Environmental Quality Council at Room 1714, Herschler Building, 1st Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. The second petition should be sent to John V. Corra, Director, Wyoming Department of Environmental Quality, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. Both petitions must be sent by certified mail, return receipt requested.



John V. Corra
Director
Department of Environmental Quality



Carl Anderson, PhD
Administrator
Solid and Hazardous Waste Division

JVC/CA/KH/OG/

Enclosure: Notice of Violation and Order, Rules of Practice and Procedure



BEFORE THE
ENVIRONMENTAL QUALITY COUNCIL
STATE OF WYOMING

IN THE MATTER OF THE NOTICE OF)
VIOLATION AND ORDER ISSUED TO:)
)
Elk Ridge Lodge, Inc.)
P.O. Box 705)
Pinedale, WY 82941)
)

DOCKET NUMBER: 4783-10

NOTICE OF VIOLATION

AND

ORDER

NOTICE IS HEREBY GIVEN THAT:

1. Elk Ridge Lodge, Inc., owns and operates one aboveground storage tank (AST) that is used to sell fuel retail at the Elk Ridge Lodge, storage tank facility 0-005149, which is located at 125 Rock Creek Road near Cora, Wyoming.
2. Elk Ridge Lodge, Inc., has not paid the 2010 annual storage tank fees for the Elk Ridge Lodge.
Elk Ridge Lodge, Inc., has not fully upgraded the AST at the Elk Ridge Lodge.
Elk Ridge lodge, Inc., has not performed an operator's annual inspection (OAI).
The Elk Ridge Lodge does not have a licensed Class A Storage Tank Operator.
The Elk Ridge Lodge does not have a licensed Class B Storage Tank Operator.
3. The DEQ has determined that the following violations of Wyoming Water Quality Rules and Regulations (WWQRR), Chapter 17, and the Storage Tank Act of 2007 have occurred at The Place:

Count 1: Failure to Pay Annual Tank Fees [WS 35-11-1425(a)]. As owner of the AST, Elk Ridge Lodge, Inc., is in violation of WS 35-11-1425(a) for failure to pay the annual tank fees for 2010.

Count 2: Failure to Upgrade ASTs [WWQRR, Chapter 17, Section 35(o)]. As owner of the AST, Elk Ridge Lodge, Inc., is in violation of WWQRR Chapter 17, Section 35(o), for failure to upgrade the AST by October 1, 2008.

Count 3: Failure to Perform an OAI [WWQRR, Chapter 17, Section 13(e)]. As owner of the AST, Elk Ridge Lodge, Inc., is in violation of WWQRR Chapter 17, Section 13(e), for failure to perform an OAI.

Count 4: Failure to Have a Licensed Class A Storage Tank Operator [WWQRR, Chapter 17, Section 46(a)]. The AST is not under the supervision of a licensed Class A Storage Tank operator, which is a violation of WWQRR, Chapter 17, Section 46(a).

Count 5: Failure to Have a Licensed Class B Storage Tank Operator [WWQRR, Chapter 17, Section 46(b)]. The AST is not under the direct supervision of a licensed Class B Storage Tank operator, which is a violation of WWQRR, Chapter 17, Section 46(B).

4. Any person who violates any provision of the Environmental Quality Act, or any rule, standard, permit, license, or variance adopted thereunder, is liable for a penalty of ten thousand dollars (\$10,000.00) for each day of violation, which penalty may be recovered in a civil action brought by the Attorney General in the name of the people of Wyoming.
5. This Notice is being sent to you pursuant to W.S. 35-11-701(c)(i), which requires that in any case of the failure to correct or remedy an alleged violation, the director of the Department of Environmental Quality shall cause a written notice to be issued and served upon the person alleged to be responsible.

ORDER

BEFORE THE ENVIRONMENTAL QUALITY COUNCIL-STATE OF WYOMING

WHEREFORE IT IS HEREBY ORDERED THAT:

1. Elk Ridge Lodge, Inc., bring this facility into compliance with WWQRR, Chapter 17, as described within 180 days of receipt of this NOV.
2. This is a Red Tagging Order. Immediately after receiving this Notice and Order, Elk Ridge Lodge, Inc., is hereby prohibited from purchasing any fuel for delivery to the registered retail AST at storage tank facility 0-005149, Elk Ridge Lodge, located at 125 Rock Creek Road, near Cora, Wyoming. All fuel suppliers are ordered not to deliver any fuel to this tank until notified by the department that this order has been lifted. The order will be lifted when:

- a. Elk Ridge Lodge, Inc., has paid the past due annual fees; has upgraded the AST in accordance with WWQRR, Chapter 17, Part I; has completed an OAI in accordance with WWQRR, Chapter 17, Section 13(e); and has the AST under the direct supervision of a licensed Class A and B operator in accordance with WWQRR, Chapter 17, Section 46.

OR

- b. Elk Ridge Lodge, Inc., has paid the past due tank fees, and has permanently closed the existing AST in accordance with WWQRR, Chapter 17 Section 31(b).

OR

- c. Elk Ridge Lodge, Inc., has paid the past due annual tank fees, and has changed the service of the existing AST in accordance with WWQRR, Chapter 17 Section 33(c).

(THIS SPACE INTENTIONALLY LEFT BLANK)


THIS ORDER is final unless, not later than ten (10) days after the date this notice is received, it is appealed by filing a written petition for a hearing before the Environmental Quality Council. If a hearing is requested, the petition shall be mailed to Chairman, Wyoming Environmental Quality Council, Room 1714 Herschler Building, 1st Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. The second petition shall be mailed to the Director, Wyoming Department of Environmental Quality, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. Both petitions must be sent by certified mail, return receipt requested.

NOTHING IN THIS ORDER shall be interpreted to in any way limit or contravene any other remedy available under the Environmental Quality Act, nor shall this Order be interpreted as being a condition precedent to any other enforcement action.

ORDERED this 29th day of December, ~~2010~~ ²⁰¹⁰



John V. Corra
Director
Department of Environmental Quality



Carl Anderson, PhD
Administrator
Solid and Hazardous Waste Division

PLEASE DIRECT ALL INQUIRES TO: Oma Gilbreth, Storage Tank Program Compliance Supervisor at 122 West 25th Street, Fourth Floor, West Wing, Cheyenne, WY 82002, (307) 777-7097 or (307) 777-5973 FAX for technical matters.

cc. Hutchinson Oil, P.O. Box 753 Evanston, WY 82931

JVC/CA/KH/OG