



Department of Environmental Quality



To protect, conserve, and enhance the Quality of Wyoming's environment for the benefit of current and future generations

Mathew H. Mead, Governor

Todd Parfitt, Director

January 6, 2014

Jodi Newkirk
P.O. Box 95
Rock River, WY 82083

SUBJ: Letter of Compliance for Notice of Violation (NOV) Docket Number 4840-11 and NOV Docket Number 5006-12.

Dear Ms. Newkirk:

The above mentioned NOV's Ordered you to pay the past due tank fees for the Arlington Outpost in Arlington, WY. The DEQ received your payment for past due tank fees up to calendar year 2013, and you have complied with the Orders outlined in the NOV's. For these reasons the DEQ Storage Tank Program considers these NOV's resolved.

Please be aware that the tank fees for calendar year 2014, totaling \$600.00, were due by January 1, 2014. Also, the tank cathodic protection (CP) system at the Arlington Outpost must be tested by a licensed CP tester by March 2, 2014. Prior to bringing the tanks back into service, you will be required to perform an operator's annual inspection, and you will be required to have a licensed storage tank operator within 90 days of bringing the tanks back into service.

If you have any questions regarding this matter please feel free to contact me at (307)777-7097, or my e-mail address is oma.gilbreth@wyo.gov .

Sincerely,

Oma K. Gilbreth IV
Storage Tank Program Compliance Supervisor
Solid and Hazardous Waste Division

cc. EQC
Facility File 0-000756



