



# Department of Environmental Quality

To protect, conserve, and enhance the Quality of Wyoming's environment for the benefit of current and future generations



Matthew H. Mead, Governor

Todd Parfitt, Director

October 31, 2013

George Lenz  
41 Country Drive  
Worland, WY 82401

RE: Letter of Compliance Kraft's Service Center, Storage Tank Facility Number 0-000580  
Notice of Violation Docket Number 4732-10

Dear Mr. Lenz:

Notice of Violation (NOV) Docket Number 4732-10 was issued to you on September 8, 2010. The NOV was issued to you for failure to perform an operator's annual inspection for the underground storage tanks (USTs), failure to perform line tightness testing, and for failure to perform leak detector function testing. The NOV was affirmed by the Environmental Quality Council (EQC) on November 18, 2010.

After the NOV was issued, you placed the USTs in temporarily out of use status, which relieved you of having to perform these tasks. However, the USTs were still in the ground and if you brought them back into service you would have been required to perform the OAI and line testing as required by the NOV.

Since the NOV was issued and affirmed, you have removed the USTs, thus bringing the site back into compliance. Therefore, the DEQ Storage Tank Program now considers NOV Docket Number 4732-10 resolved.

If you have any questions regarding this matter please feel free to contact me at (307)777-7097, or my e-mail address is [oma.gilbreth@wyo.gov](mailto:oma.gilbreth@wyo.gov).

Sincerely,

Oma K. Gilbreth IV  
Storage Tank Program Compliance Supervisor  
Solid and Hazardous Waste Division

cc. Facility File 0-000580  
EQC

