




Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

Todd Parfitt, Director

CERTIFIED MAIL

May 7, 2013

**Mayor Amy Kania
Town of Basin
209 4th Street
Basin, WY 82410**

RE: Notice of Violation and Order, Docket Number 5152-13

Dear Ms. Kania:

Attached is a Notice of Violation and Order, Docket Number **5152-13**, for recurring effluent violations of the Wyoming Pollution Discharge Elimination System (WYPDES) permit WY0020028 issued to the town of Basin's Waste Water Treatment Facility (WWTF).

ANY APPEALS TO THE ENVIRONMENTAL QUALITY COUNCIL FROM THE ATTACHED ORDER MUST BE MADE IN WRITING WITHIN THE TEN (10) DAY TIME LIMIT PRESCRIBED BY W.S. 35-11-701(c). Chapter I, Section 3 of the Department of Environmental Quality Rules of Practice and Procedure (<http://soswy.state.wy.us/RULES/5675.pdf>) sets forth the requirements for the initiation of appeal proceedings.

To appeal this Order and request a hearing, you must file two (2) copies of your written petition. The first petition shall be mailed to the Chairman of the Environmental Quality Council at Room 1714, Herschler Building, 1st Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. The second petition should be sent to Todd Parfitt, Director, Wyoming Department of Environmental Quality, Herschler Building, 4th West, 122 West 25th Street, Cheyenne, Wyoming 82002. Both petitions must be sent by certified mail, return receipt requested.

THIS SPACE INTENTIONALLY LEFT BLANK

Page L-1

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



Town of Basin
May 7, 2013
Page L-2

PLEASE DIRECT ALL INQUIRIES TO: Kevin M. Wells, WYPDES Natural Resource Program Manager at the Wyoming Department of Environmental Quality, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. Telephone 307-777-8669.



Todd Parfitt
Director
Department of Environmental Quality



Kevin Frederick
Administrator
Water Quality Division

JVC/JFW/KW/bb/13-0409

Enclosure: Notice of Violation and Order

cc: David Gwisdalla, 8ENF-W-NP, EPA Region 8 (PDF)
Bill DiRienzo ► Kevin M. Wells ► Rich Cripe (PDF)
NOV Docket 5152-13
Environmental Quality Council
Keith Guille, DEQ Public Information Officer (PDF)

(A) The identification of the cause of BOD % removal and fecal permit exceedances;

(B) Any necessary modifications to plant design or operations that are needed to bring the plant into consistent compliance with permit limits and a timetable for implementation;


(C) All elements of the corrective action plan must be approved by DEQ.

2. The Town of Basin shall provide necessary operator training to ensure the facility is operating at compliance levels. In addition to the certification requirements provided in Chapter 5 of the Wyoming Water Quality Rules and Regulations, the town shall ensure that the plant operator(s) are properly trained to collect all required water samples, gain an understanding of sampling techniques, holding times, etc., and correctly apply the correct calculations of the analytical results in order to comply with the Discharge Monitoring Reporting (DMRs) requirements within the permit.


This ORDER is final unless, no later than ten (10) days after the date this notice is received; it is appealed by filing two written requests for a hearing before the Environmental Quality Council. If a hearing is requested, the first hearing petition shall be mailed to the Chairman, Wyoming Environmental Quality Council, Room 1714 Herschler Building, 1st Floor West, 122 West 25th St., Cheyenne, Wyoming 82002. The second petition shall be mailed to the Director, Wyoming Department of the Environmental Quality, Herschler Building, 4th Floor West, 122 West 25th St., Cheyenne, Wyoming 82002. Both petitions must be sent by certified mail, return receipt requested.

NOTHING IN THIS NOTICE OF VIOLATION (NOV) AND ORDER shall be interpreted to in any way limit or contravene any other remedy available under the Environmental Quality Act, nor shall this NOV AND ORDER be interpreted as being a condition precedent to any other enforcement action.

Ordered this 23rd day of May, 2013.



Todd Parfitt
Director
Department of Environmental Quality



Kevin Frederick
Administrator
Water Quality Division

PLEASE DIRECT ALL INQUIRIES TO: Kevin M. Wells, WYPDES Natural Resource Program Manager, Wyoming Department of Environmental Quality, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. Telephone 307-777-8669.

TP/KF/KMW/bb/13-0409

cc: David Gwisdalla, 8ENF-W-NP, EPA Region 8 (PDF)
Bill DiRienzo ► Kevin M. Wells ► Rich Cripe (PDF)
NOV Docket 5152-13
Environmental Quality Council
Director, DEQ
Keith Guille, DEQ Public Information Office (PDF)