

Table 1

Quantities of Domestic Sewage Flows

Type of Establishment	Flow (gallons per day per_____)
Residential Units	
Single Family Dwellings	150/bedroom
Multiple Family Dwelling (with laundry capabilities)	150/bedroom
Multiple Family Dwelling (without laundry capabilities)	120/bedroom
Cottages	50/person
Mobile Home Parks	350/home*
Commercial Facilities	
Airports	4/passengers
Bar	3/patron
Bathhouses and swimming pools	10/person
Campgrounds (individual sewer outlets available)	100/site
Campgrounds (service building only)	75/site
Car or truck wash	200/vehicle
Church (no food preparation and/or dishwashing)	5/seat
Church (food preparation and/or dishwashing)	7/seat
Country Club	100/member
Factories	30/employee
Hospital	200/bed
Laundry (self-service)	600/machine or 50/cycle
Motels	80/double bed or 40/single bed
Office building	30/employee
Restaurant (toilet and kitchen wastes)	13/meal
Restaurant (kitchen wastes)	6/meal
Restaurant (additional for bars and lounges)	2/meal
Restaurant (kitchen wastes with disposable service)	2/meal
Rest Home	100/resident
Schools Boarding	100/resident student
Day, without gyms, cafeterias, or showers	15/student
Day, with cafeterias only	20/student
Day, with cafeteria, gym and showers	25/student
Service stations	10/vehicle served
Shopping Center	2/parking space
Store, Retail	30/employee
Theaters: Movie	5/seat
Drive-In	15/vehicle space
Warehouses	30/employee

* Must consider flow into the soil absorption system from mobile homes where taps are allowed to run to prevent freezing.