

THE STATE



OF WYOMING

JIM GERINGER
GOVERNOR



Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

July 29, 1996

Mr. Paul G. Sandler
Ellingford Brothers Inc.
P.O. Box 727
Evanston, WY 82930

RE: Approval of 1,000 gallon septic tank

Dear Mr. Sandler:

The plans you submitted for manufacturing of a 1,000 gallon septic tank have been reviewed by this office of the DEQ/WQD. It has been determined that the proposed plans meet the requirements of the Wyoming Water Quality Rules and Regulations, Chapter XI, Section 39. Tanks manufactured by Ellingford Brothers according to the submitted design will be added to the Wyoming DEQ list of approved 1,000 gallon tanks.


When these tanks are installed risers will need to be installed from both manholes, or from both of the cleanout access ports to allow access from above the ground surface.

Sincerely,

Randall Taylor
Water Quality Division
S.W. Dist. Engr. Supervisor

xc: Larry Robinson, State SPO Manager
Don Mc Kenzie, NE District Supervisor
Gary Steel, SE District Supervisor
Jeff Hermansky, NW District Supervisor
Randall Taylor, SW District Supervisor

file: ^{Lincoln} Lincoln Co. Small Wastewater, Lincoln Co.




CUTAWAY
ISOMETRIC

Volume = 7.5' X 4' X 4.67
= 109.7 gal less
for the pipe loss


NOTE:

- 1) 6 Bag Cement, 4000 PSI.
- 2) Segled With Butyl Rope & Reinforced With Fiber Mesh, or With Optional 6x6 - 6x6 Weidex Wire Fabric.



5" x 9" ✓
INSPECTION
COVER
(Typ.)

TOP VIEW
20% of 4' = 0.8'



ELEV. VIEW

DRN EYLM 7/96	CHK BY
APP BY	
TETON GARD & CARAPICOS EVANSTON, WYOMING 82922-2103	
LINE DESCRIPTION	
1,000 GALLON TWO PIECE SEPTIC TANK	
REF. P & I.D.	CLIENT
REF. PLAN	Eltingford Brc
DWG. NO.	SEPTIC-1