

## STATE OF WYOMING PUBLIC NOTICE

THE PURPOSE OF THIS NOTICE IS TO INDICATE THE STATE OF WYOMING'S INTENTION TO RENEW AN UNDERGROUND INJECTION CONTROL PERMIT AND TO CLASSIFY THE RECEIVING GROUNDWATER OF THE STATE IN THE VICINITY OF THE PERMITTED INJECTION UNDER THE WYOMING ENVIRONMENTAL QUALITY ACT (35-11-101 ET. SEQ. WYOMING STATUTES 1957, CUMULATIVE SUPPLEMENT 1973), AND DEPARTMENT OF ENVIRONMENTAL QUALITY, WATER QUALITY RULES AND REGULATIONS CHAPTERS 8, 11 AND 16. THIS PERMIT WILL ALLOW THE DISPOSAL OF AN AVERAGE OF 2,448 GALLONS PER DAY AND A MAXIMUM OF 4,080 GALLONS PER DAY OF WASTEWATER AND SEWAGE INTO TWO (2) LEACHFIELDS.

PERMIT NUMBER: **14-141**; PERMITTEE NAME: Wyoming Department of Transportation, ATTN: Mr. Tyler Wille, PO Box 1260 Rock Springs, WY 82901; PHONE: (307) 389-5687; FACILITY NAME AND LOCATION: Granger Maintenance Station, located in Section 30, Township 19 North, Range 111 West, of the 6<sup>th</sup> Principal Meridian, Sheridan County.

The permit proposes to authorize the injection of an average of 2,448 gallons per day (gpd) and a maximum of 4,080 gpd of primary treated domestic waste into two (2) leachfields. The leachfields will receive domestic waste from restrooms and employee housing. The primary treated wastewater is injected into the alluvial aquifer along the Black's Fork River. The groundwater is greater than thirty (30) feet below ground surface at the injection locations.

The groundwater in the alluvial aquifer is classified as Class I according to Wyoming Water Quality Rules and Regulations, Chapter 8, because the groundwater is being used for domestic purposes at nearby points of withdrawal.

The proposed permit requires that the permittee monitor groundwater quality and submit periodic reports. Sampling is designed to show that there will not be a groundwater standards violation as a result of this injection. Underground Injection Control regulations require that each permitted injection well be reviewed thoroughly at least every five (5) years in addition to the normal review done annually.

Other tentative determinations have been made by the State of Wyoming relative to conditions to be imposed on the permit. These conditions will assure that useable water of the State will be protected and applicable provisions of State statutes and regulations will be followed.

PUBLIC COMMENTS on the proposed permit and the proposed groundwater classification should be submitted in writing and addressed to: Wyoming Department of Environmental Quality, Water Quality Division, John Passehl, P.G, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; or by FAX to (307) 777-7610. Comments submitted by email *will not* be considered. All written comments received prior to 5:00 P.M, November 13, 2014 in the Cheyenne office will be considered.

Any person may request in writing (prior to the end of the public comment period) that a public hearing be held. Requests should indicate the name and full mailing address of the individual requesting a hearing, the interest that individual has in the project, and the grounds for holding a public hearing. If a hearing is not warranted, the final permit will be issued at the end of the public comment period.

Public Notice **14-141**

Publish on or before October 15, 2014, Rock Springs Rocketminer