

**Wyoming Department of Environmental Quality
Water Quality Division
Wyoming Pollutant Discharge Elimination System (WYPDES) Program**

STATEMENT OF BASIS

RENEWAL

APPLICANT NAME: Kemmerer Operations, LLC

MAILING ADDRESS: PO Box 950
Kemmerer, WY 83101

FACILITY LOCATION: Kemmerer Mine, located in the NESE, Section 2, the NENE, Section 4, the NENE, Section 11, the NENW and NESW, Section 14, the NWSE and NWSW, Section 27, the NESE, Section 34, and the NENE and NENW, Section 35, Township 20 North, Range 117 West, the SESW, Section 16, the SWNE and NESW, Section 17, the NESW, Section 18, the NWSE, Section 21, the SWNE, Section 28, and the NWSE, Section 29, Township 21 North, Range 116 West, Lincoln County. The wastewater discharges to North Fork Little Muddy Creek (3B) directly and via various 3B drainages, Green River Basin, and Twin Creek (3B), via various 3B drainages, Bear River Basin.

PERMIT NUMBER: WY0000051

This permit has been modified in accordance with current WYPDES permitting requirements. All permit effluent limits and monitoring requirements have been updated in accordance with current WDEQ regulations and policy. Specific changes to the permit include the following:

- 1. The permittee has changed from Westmoreland Kemmerer, Inc. to Kemmerer Operations, LLC.*
- 2. Numerous minor language and grammatical changes have been made in the interests of clarity and brevity.*
- 3. In addition to reporting total dissolved solids loading in tons/month, the permittee is also required to report total dissolved solids concentrations in mg/L.*

BACKGROUND: This facility is a large open pit coal mine southwest of Kemmerer, Wyoming. Outfalls 006, 008, and 012 discharge into the Bear River Basin. The remaining outfalls discharge into the Green River Basin and are subject to the conditions of the Colorado River Salinity Forum.

EFFLUENT LIMITS:

In developing effluent limits, all federal and state regulations and standards have been considered. Permit limits are either technology-based or water-quality-based, as described below.

TECHNOLOGY-BASED EFFLUENT LIMITS: For dry weather discharges, technology-based effluent limits include monthly average limits for the following constituents:

- Total Iron, 3.0 mg/L;

- Total Manganese, 2.0 mg/L; and
- Total Suspended Solids, 35 mg/L

Technology-based limits also include instantaneous maximum limits for the following constituents:

- Total Iron, 9.0 mg/L,
- Total Manganese, 6.0 mg/L,
- Total Suspended Solids, 90 mg/L
- pH measurements shall remain within the range of 6.5 to 9.0 standard units

For wet weather discharges, technology-based effluent limits are established as follows:

- All pH measurements shall remain within the range of 6.5 to 9.0 standard units.
- Total Settleable Solids are limited to 0.5 ml/L, daily maximum, based on Chapter 2 and 40 CFR Part 434.

Please refer to Part I.A.1 of the permit for more information. Water-quality-based effluent limits, described below, are also in effect during wet weather discharges. *The operator shall bear the burden of proof in demonstrating that discharges or increases in discharge were caused by the applicable precipitation event.*

Monthly monitoring is required for all technology-based limited constituents except total suspended solids, which requires weekly monitoring.

Technology-based effluent limits are derived from *Chapter 2, Appendix J, Wyoming Water Quality Rules and Regulations* and *40 CFR Part 434, Coal Mining Point Source Category Alkaline Mine Drainage*, whichever is more stringent. *Chapter 2, Appendix J, Wyoming Water Quality Rules and Regulations* is generally more stringent than *40 CFR Part 434, Coal Mining Point Source Category Alkaline Mine Drainage (BPT)*.

WATER QUALITY BASED EFFLUENT LIMITS: Instream standards for water-quality-based contaminants of concern are as follows:

- Dissolved Iron, 1000 µg/L, daily maximum, monthly monitoring;
- Dissolved Manganese, 1462 µg/L, daily maximum, monthly monitoring;
- pH measurements shall remain within the range of 6.5 to 9.0 standard units.

Water-quality-based effluent limits listed above are based upon chronic aquatic life standards, per *Chapter 1, Wyoming Water Quality Rules and Regulations* (which are more stringent than acute standards). Water-quality-based effluent limits are established considering in-stream dilution, if available, so that when facility effluent mixes with available receiving stream flow (if any); in-stream constituent standards are not violated. Since this facility's discharge is to normally dry drainages, the effluent limits established in this permit will be equal to constituent instream standards, as no in-stream dilution is normally available within the receiving water body.

The permit establishes effluent limits at the end of pipe intended be protective of designated uses for class 3B waters as defined in *Chapter 1, Wyoming Water Quality Rules and Regulations*. Designated uses for class 3B waters include aquatic life other than fish, recreation, agriculture, wildlife, industry and scenic value. Water-quality-based effluent limits established in this permit are based upon standards intended to protect for the above-listed designated uses and reflect the application of "tier 1" antidegradation protection. Tier 1 antidegradation protection is the basic level of protection applicable to all waters of the state, as described in the *Wyoming Surface Water Quality Standards "Implementation Policies for*

Antidegradation, Mixing Zones and Dilution Allowances, Turbidity, and Use Attainability Analyses", effective September 24, 2013.

BEST MANAGEMENT PRACTICES: The permit requires disturbed area runoff control using sedimentation ponds or other appropriate measures. Control of potentially contaminated storm water runoff from haul roads, rail spur lines, and ancillary areas shall be accomplished by the permittee under the provisions of the State of Wyoming's general storm water permit associated with industrial activities.

This facility's sedimentation ponds designed to completely contain runoff resulting from a ten-year/24-hour storm event (1.6 inches precipitation or snowmelt equivalent). By containing runoff from a ten-year/24-hour storm event, runoff from disturbed areas is contained and controlled. Because the sedimentation ponds do not normally discharge, they are not specifically identified in this permit, but are covered by operation and maintenance provisions. The mine has stormwater coverage under general permit authorization # WYR000213.

COLORADO RIVER BASIN SALINITY FORUM: Note: Colorado River Salinity forum requirements pertain only to outfalls 001-005, 007-011, and 013-016, because these outfalls discharge into the Green River Basin (tributary to the Colorado River Basin). Outfalls 006, 008, and 012 discharge into the Bear River Basin and are exempt from Colorado River Basin salinity requirements. The State of Wyoming cooperates with other member states of the Colorado River Basin Salinity Control Forum and the government of the United States to maintain salinity levels in the main stem of the Colorado River. According to Chapter 6 of the Wyoming Water Quality Rules and Regulations, all point sources that discharge to the Colorado River must control the salinity concentrations in any effluent discharged to a surface water. The Colorado River Salinity Control Forum policy states that salt loads reaching the main stem of the Colorado River shall be less than one-ton per day per operator (366 tons per year). Because the facility discharges to the Colorado River Basin, the permit requires effluent monitoring and limits for total dissolved solids (TDS). This permit requires that the permittee monitor and report salt loading (quantity) in their discharge in tons per month. Salt loading is a calculated value that utilizes effluent flow and concentration information:

$$\frac{[\text{Total Monthly Flow (MG)}] * [\text{Concentration (mg/L)}] * [8.34(\text{lb/MG})/\text{mg/L}]}{2000 \text{ lb/ton}} = \text{Load (tons/month)}.$$

The permittee shall also report the total salt load discharged annually. TDS shall be monitored monthly and during wet weather conditions when sampling is required under the "alternate limits" requirement.

Antidegradation, impairment review: Effluent limits established in this permit are intended to ensure water quality is maintained within the receiving waterbodies, and their designated uses protected... An antidegradation review conducted by DEQ staff verifies the permit conditions and established effluent limitations provide receiving waterbody protection consistent with Wyoming surface water quality standards and antidegradation provisions. The antidegradation review also verifies that the receiving waterbodies are not on the state of Wyoming's 303(d) list as waterbodies that cannot support their designated uses.

Effluent quality and quantity self-monitoring is required on a regular basis, results shall be reported to the WDEQ on a quarterly schedule. This permit renewal is scheduled to expire on December 31, 2025.

Kathy Shreve
Water Quality Division
Department of Environmental Quality
Drafted: May 19, 2020

AUTHORIZATION TO DISCHARGE UNDER THE
WYOMING POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of the Federal Water Pollution Control Act, (hereinafter referred to as "the Act"), and the Wyoming Environmental Quality Act,

Kemmerer Operations, LLC

is authorized to discharge from the wastewater treatment facilities serving the

Kemmerer Mine

located in the

the NESE, Section 2, the NENE, Section 4, the NENE, Section 11, the NENW and NESW, Section 14, the NWSE and NWSW, Section 27, the NESE, Section 34, and the NENE and NENW, Section 35, Township 20 North, Range 117 West, the SESW, Section 16, the SWNE and NESW, Section 17, the NESW, Section 18, the NWSE, Section 21, the SWNE, Section 28, and the NWSE, Section 29, Township 21 North, Range 116 West, Lincoln County,

to receiving waters named

North Fork Little Muddy Creek (3B) directly and via various 3B drainages, Green River Basin, and Twin Creek (3B), via various 3B drainages, Bear River Basin,

in accordance with effluent limitations, monitoring requirements and other conditions set forth in Parts I, II and III hereof.

This permit renewal shall become effective on January 1, 2021.

This permit renewal and the authorization to discharge shall expire on December 31, 2025 at midnight.

Kevin Frederick, Administrator
Water Quality Division

Todd Parfitt, Director
Department of Environmental Quality

Date of Issuance: _____

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. Effective January 1, 2021 and lasting through December 31, 2025 effluent quality discharged by the permittee shall, at a minimum, meet the limitations established in Table A. The permittee is authorized to discharge from outfall serial number(s) 001-017.

Outfalls 001-017 are authorized to discharge treated mine pit water, water from dewater wells, process wastewater, and/or runoff from disturbed areas.

Such discharges shall be limited and monitored by the permittee as specified below:

a. **If:** There has been no measurable precipitation or snow melt during the previous ten days;

Then: Any discharge shall meet the following effluent limitations and self-monitoring requirements:

Constituent and Required Reporting Units	Discharge Limitations Sampling Schedule				Sampling Schedule	Reporting Schedule	Required Sample Type
	Monthly Average (1) (2)	Daily Maximum (2)	Instantaneous Maximum	Annual Load			
Total Iron, mg/L	3.0	6.0	9.0	N/A	Monthly	Quarterly	Grab
Total Manganese, mg/L(3)	2.0	4.0	6.0	N/A	Monthly	Quarterly	Grab
Dissolved Iron, µg/L	N/A	1000	N/A	N/A	Monthly	Quarterly	Grab
Dissolved Manganese, µg/L(3)	N/A	1462	N/A	N/A	Monthly	Quarterly	Grab
Total Suspended Solids, mg/L	35	70	90	N/A	Weekly	Quarterly	Grab
pH (standard units)	All measurements shall remain within the range of 6.5 to 9.0 s.u.			N/A	Monthly	Quarterly	Grab (Field Measurement)
Flow, MGD	Report	N/A	Report	N/A	Weekly	Quarterly	Instantaneous
Duration of Discharge, days/month (4)	Report	N/A	N/A	N/A	Monthly	Quarterly	Report
Total Dissolved Solids, Total Tons per Year, Total of outfalls 001-005 and 007, 009-011, 013-016 (6)	Report (5)	N/A	N/A	366	Monthly	Annual	Calculated
Total Dissolved Solids, mg/L (6)	Report	Report	Report	N/A	Monthly	Quarterly	Grab
Selenium, Total Recoverable, µg/L	Report	Report	20	N/A	Monthly	Quarterly	Grab

(1) Monthly Average may be determined using only one monthly sample if the sample result meets the monthly average effluent limit.

- (2) Refer to “Definitions”, Part I(C) 3 of permit.
- (3) Applicable only if the discharge pH concentration, prior to any treatment, measures less than 6.0 standard units.
- (4) For the parameter ‘Duration of Discharge’ ONLY, the permittee is to report the total number of days per month that discharges occurred. Report flow and numbers of days discharged for wet weather discharges as well as dry weather discharges on standard DMR forms. If the permittee discharges for three (3) days or less during the month, the no discharge code of “Less than 3 days of discharge; Avg not applicable” may be used for the monthly and weekly averages in place of a numerical value on the Discharge Monitoring Reports (DMRs).
- (5) For TDS results ONLY, the permittee is to report TDS loading in tons/month.
- (6) Total dissolved solids monitoring and reporting is not required for outfalls 006, 008, or 012. Annual and monthly total dissolved solids loads shall be reported under collective monitor point “SUM” in the discharge monitoring reports.

There shall be no discharge of floating solids or foam in other than trace amounts. Nor shall the discharge have a visible sheen or cause formation of a visible sheen or visible deposits on the bottom or shoreline of the receiving water.

All waters shall be discharged in a manner to prevent erosion, scouring, or damage to stream banks, streambeds, ditches, or other waters of the state at the point of discharge. Discharges shall not occur in such a manner that will result in violations of Water Quality Rules and Regulations, Chapter 1, Section 15. In addition, there shall be no deposition of substances in quantities that could result in significant aesthetic degradation or degradation of habitat for aquatic life, plant life or wildlife; or which could adversely affect public water supplies or those intended for agricultural or industrial use.

- b. **If:** During the previous ten days, any discharge or increase in the volume of a discharge caused by precipitation within any 24-hour period less than or equal to the 10-year, 24-hour precipitation event (1.6 inches, or snowmelt of equivalent volume) may comply with the following limitations instead of the otherwise applicable limitations. *The operator shall bear the burden of proof in demonstrating that discharges or increases in discharge were caused by the applicable precipitation event.*
- Then:** Any discharge or increase in the volume of a discharge caused by precipitation within any 24-hour period less than or equal to the 10-year, 24-hour precipitation event (1.6 inches or snowmelt of equivalent volume) must meet an instantaneous maximum settleable solids limitation of 0.5 mL/L and a pH of 6.5 to 9.0. The discharge shall also meet the dissolved iron, dissolved manganese, and total dissolved solids limits established above. Discharge quality (dissolved iron, dissolved manganese, pH, settleable solids and dissolved solids) and quantity shall be measured with a single grab sample on the first day that a discharge occurs following any precipitation or snow melt event.

Pollutant or Pollutant Property	Limitations	Monitoring
Total Settleable Solids, mL/L	0.5 mL/L maximum not to be exceeded	First day of discharge following precipitation event
pH, standard units	Within the range of 6.5 to 9.0 at all times	First day of discharge following precipitation event
Dissolved Iron, µg/L	1000	First day of discharge following precipitation event
Total Dissolved Solids, mg/L and tons	Monitor concentration and load; include load in monthly sum of TDS for each discharging outfall	First day of discharge following precipitation event

c. **If:** During the previous ten (10) days there has been a precipitation and/or snow melt event of any duration within any 24 hour period which results in a precipitation depth more than the 10-year, 24-hour event (1.6 inches). *The operator shall bear the burden of proof in demonstrating that discharges or increases in discharge were caused by the applicable precipitation event.*

Then: Any discharge on the day of the event or on the first and second day following such an event must meet a pH limitation of 6.5-9.0 and no monitoring is required. Any discharge during the third through tenth day following that event must meet an instantaneous maximum settleable solids limitation of 0.5 mL/L and a pH of 6.5 to 9.0. Discharge quality (settleable solids and pH) and quantity must be measured with a single grab sample on the third, fifth and tenth days following the event.

Pollutant or Pollutant Property	Limitations	Monitoring
Total Settleable Solids, mL/L	0.5 mL/L maximum not to be exceeded	Third, fifth, and tenth days following the event
pH, standard units	Within the range of 6.5 to 9.0 at all times	Third, fifth, and tenth days following the event

d. All runoff control facilities shall be operated in a manner to minimize, to the extent practicable, the discharge of suspended solids and sediment. If, after on-site inspection by the Wyoming Department of Environmental Quality and/or the U.S. Environmental Protection Agency, it is determined that a runoff control pond is not being so operated, such finding shall be considered to be a violation of this permit.

e. It shall be the responsibility of the permittee to document runoff and snow melt conditions whenever a discharge occurs.

f. Samples taken to comply with the monitoring requirements of this permit shall be taken at the outfall from the final treatment unit and prior to admixture with diluent water or the receiving stream.

Adverse weather conditions: The permit allows for temporary waivers from sampling based on adverse climatic conditions for effluent limitation sampling. This temporary sampling waiver only applies to insurmountable and/or dangerous weather conditions such as lightning, flooding, or tornadoes. These events tend to be isolated incidents and shall not be used as an excuse for omitting sampling under more favorable conditions associated with other storm events. The

sampling waiver shall not apply to logistical difficulties such as remote facilities, understaffing, or inaccessible outfalls. If a permittee is unable to collect samples within a specified sampling period due to adverse climatic conditions, the permittee shall collect a sample once the adverse condition has subsided. Permittees are not required to obtain advance approval for sampling waivers. The permittee is required to adequately demonstrate and indicate in the Discharge Monitoring report(s) that local conditions were too adverse for sample collection when so indicated.

B. EROSION CONTROL

Effective January 1, 2021 and lasting through December 31, 2025, the permittee shall control erosion from affected land to insure there is no violation of Wyoming's surface water quality standards.

Affected land means areas where overburden is removed, or where overburden, development waste rock or refuse is deposited, or both, access roads, haul roads, mineral stockpiles, mill tailings, impoundment basins, and all other lands whose natural state has been or will be disturbed because of mine operations.

If erosion from affected land is controlled through the use of settling pond(s), the following provisions apply:

1. If a settling pond is not sized to completely contain the runoff resulting from precipitation, an equivalent snow melt or combination of precipitation and resulting snow melt equal to the 10 year/24 hour precipitation event (1.6 inches precipitation or equivalent snowmelt event), the settling pond's outlet must be identified as an outfall under Part I.C.10 of this permit.
2. If a settling pond is sized to completely contain the runoff from the 10 year/24 hour precipitation event as described above, the settling pond's outlet need not be identified as an outfall in Part I.C.10. However, it shall be operated as follows:
 - a. During and immediately following a precipitation or runoff event equal to or greater than the 10 year/24 hour precipitation event as described above, runoff in excess of the design capacity of the pond may be discharged even if the effluent does not meet the quality requirements of Part I.A of this permit.
 - b. If, as the result of any precipitation or runoff event, the volume of water held in the pond exceeds the permanent pool, the water in the pond shall be analyzed at a minimum of once every five (5) days. Once total suspended solids concentrations are less than or equal to the total suspended solids limitations in Part I.A of the permit within the pond, the water volume quantity in excess of the permanent pool shall be discharged within ten (10) days.
 - c. Discharge volume, Total Suspended Solids, Total Iron, and pH concentrations within discharges described in "b" above shall be monitored, single grab samples collected, and the results shall be reported to the permit issuing authority as an addendum to the regular reports described in Part I.C.2 of this permit.
 - d. All runoff control facilities shall be operated in a manner to minimize, to the extent practicable, discharges of suspended solids and sediment. If, after on-site

inspection by the Wyoming Department of Environmental Quality and/or the U.S. Environmental Protection Agency, it is determined that a runoff control pond is not being so operated, such finding shall be considered to be a violation of this permit.

In addition, the permittee shall operate and maintain all runoff control ponds such that:

1. Sluicing of collected sediments does not occur;
2. Scouring or erosion of the bottom of outlet channels does not occur;
3. The ponds shall be designed and maintained to contain at least one-year's worth of accumulated sediment storage as determined by acceptable empirical methods.

C. MONITORING AND REPORTING

1. Representative Sampling

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. All samples shall be taken at the monitoring points specified in this permit and, unless otherwise specified, before the effluent joins or is diluted by any other wastestream, body of water, or substance. Monitoring points shall not be changed without notification to and approval by, the permit issuing authority.

2. Reporting

Effluent monitoring results obtained during the previous three month(s) shall be summarized and reported on a Discharge Monitoring Report Form. If the permit requires whole effluent toxicity (WET) (biomonitoring) testing, WET test results must be reported on the most recent version of EPA Region 8 Guidance for Whole Effluent Reporting. Legible copies of these, and all other reports required herein, shall be signed and certified in accordance with the Signatory Requirements (see Part II.A.11.), and submitted to the state water pollution control agency at the following addresses. The reports must be received by the agency no later than the 28th day of the month following the completed reporting period. The first report following issuance of this permit renewal is due on April 28, 2021.

Wyoming Department of Environmental Quality
Water Quality Division
200 West 17th Street
Cheyenne, WY 82002
Telephone: (307) 777-7781

If no discharge occurs during the reporting period, "no discharge" shall be reported. If discharge is intermittent during the reporting period, sampling shall occur while the facility is discharging.

3. Definitions

- a. A "composite" sample, for monitoring requirements, is defined as a minimum of four (4) grab samples collected at equally spaced two (2) hour intervals and proportioned according to flow.
- b. The "monthly average" shall be determined by calculating the arithmetic mean (geometric mean in the case of the fecal coliform or E. coli) of pollutant sample parameter values collected during a calendar month.
- c. The "daily maximum" shall be determined by the analysis of a properly preserved composite sample composed of a minimum of four grab samples collected at equally spaced two hour intervals and proportioned according to flow at the time of sampling.
- d. A "grab" sample, for monitoring requirements, is defined as a single "dip and take" sample collected at a representative point in the discharge stream.
- e. The "instantaneous maximum" shall be determined by the analysis of a single grab sample.
- f. "MGD", for monitoring requirements, is defined as million gallons per day.
- g. "Net" value, if noted under Effluent Characteristics, is calculated on the basis of the net increase of the individual parameter over the quantity of that same parameter present in the intake water measured prior to any contamination or use in the process of this facility. Any contaminants contained in any intake water obtained from underground wells shall not be adjusted for as described above and, therefore, shall be considered as process input to the final effluent. Limitations in which "net" is not noted are calculated on the basis of gross measurements of each parameter in the discharge, irrespective of the quantity of those parameters in the intake waters.
- h. A "pollutant" is any substance or substances that, if allowed to enter surface waters of the state, causes or threatens to cause pollution as defined in the Wyoming Environmental Quality Act, Section 35-11-103.

4. Test Procedures

Test procedures for the analysis of pollutants, collection of samples, sample containers, sample preservation, and holding times, shall conform to regulations published pursuant to 40 CFR, Part 136, unless other test procedures have been specified in this permit.

5. Results Recording

For each measurement or sample taken pursuant to the requirements of this permit, the permittee shall record the following information:

- a. The exact place, date and time of sampling;
- b. The dates and times the analyses were performed;
- c. The person(s) who performed the analyses and collected the samples;

- d. The analytical techniques or methods used; and
- e. The results of all required analyses including the bench sheets, instrument readouts, computer disks or tapes, etc., used to determine the results.

6. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit, using approved analytical methods as specified above, the results of such monitoring shall be included in the calculation and reporting of the values required in the Discharge Monitoring Report Form. Such increased frequency shall also be indicated.

7. Records Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the administrator at any time. Data collected on site, copies of Discharge Monitoring Reports and a copy of this WYPDES permit must be maintained on site during the duration of activity at the permitted location.

8. Penalties for Tampering

The Act provides that any person who falsifies, tampers with or knowingly renders inaccurate, any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than two (2) years per violation, or both.

9. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on interim and final requirements contained in any Compliance Schedule of this permit shall be submitted no later than 14 days following each schedule date.

10. Discharge Point Identification and Establishment of

According to 40 CFR 122.21(k)(1), the permittee shall identify the expected location of each discharge point on the appropriate NPDES permit application form. The location of the discharge point must be identified to within an accuracy of 15 seconds. This equates to a distance of 1,510 feet.

In order for the permit not to be subjected to additional public notice, the location of the established discharge point must be within 1,510 feet of the location of the discharge point originally identified on the permit application. In addition, the discharge must be within the same drainage and must discharge to the same landowner's property as identified on the original application form. If the three previously stated requirements are not satisfied, modification of the discharge point location(s) constitutes a major

modification of the permit as defined in Part I.B.12. The permittee shall provide written notification of the establishment of each discharge point in accordance with Part I.A.2.a above.

11. Outfall Locations

Requests for modification of the outfalls contained in this permit (see **Tables 1 and 2**), will be processed as follows. If the requested modification satisfies the definition of a minor permit modification as defined in 40 CFR 122.63 modifications will not be required to be advertised in a public notice. A minor modification constitutes a correction of a typographical error, increase in monitoring and/or reporting, revision to an interim compliance schedule date, change in ownership, revision of a construction schedule for a new source discharger, deletion of permitted outfalls, and/or the incorporation of an approved local pretreatment program. A request for a minor modification shall be initiated by the permittee.

The outfalls listed in **Table 1** may be moved from the established location without submittal of a permit modification application provided all of the following conditions are satisfied:

- a. The new outfall location is within 2640 feet of the established outfall location.
- b. The new outfall location is within the same drainage or immediate permitted receiving waterbody.
- c. There is no change in the identity of the landowner(s) located outside the mine permit boundary, who will receive the discharge water.
- d. Notification of the change in outfall location shall be provided to the WYPDES Permits Section in writing within 10 days of the outfall location change. The request shall be provided in duplicate and legible maps showing the previous and new outfall location must be included.

An outfall relocation as described above shall not be allowed if the new outfall location is less than one mile from the confluence of a Class 2 waterbody and the dissolved iron limits established in the permit for the outfall are based upon Class 3 standards.

Table 1: Outfall Locations, WY0000051- Kemmerer Mine

Outfall	Qtr/Qtr	Section	Town-ship	Range	Latitude	Longitude	Receiving Water Description
001	NENE	11	20N	117W	41.7385597	-110.5994642	North Fork Little Muddy Creek (3B) via Skull Point Draw. (3B), Green River Basin
002	NWSE	27	20N	117W	41.690532	-110.620325	North Fork Little Muddy Creek (3B)
003	NWSW	27	20N	117W	41.690998	-110.623029	Elkol Draw (3B), tributary to North Fork Little Muddy Creek (3B), Green River Basin
004	SWNE	28	21N	116W	41.771525	-110.586506	KSB-A Creek (3B), tributary to North Fork Little Muddy Creek (3B), Green River Basin
005	NESE	2	20N	117W	41.723512	-110.609776	Dry Creek (3B), tributary to North Fork Little Muddy Creek (3B), Green River Basin
006	NENE	11	20N	117W	41.799571	-110.6192847	Middle Fork of Twin Creek (3B), Bear River Basin
007	SENE	27	20N	117W	41.743848	-110.600708	North Fork Little Muddy Creek (3B) via an unnamed drainage (3B), Green River Basin
008	SWNE	17	21N	116W	41.8039444	-110.6164111	East Fork Twin Creek (3B), tributary to Middle Fork of Twin Creek (3B), Bear River Basin
009	NESW	17	21N	116W	41.7966	-110.59559	North Fork Little Muddy Creek (3B) via an unnamed drainage (3B), Green River Basin
010	SESW	16	21N	116W	41.793875	-110.5892944	North Fork of Little Muddy (3B), tributary to Little Muddy Creek (3B), Green River Basin
011	NWSE	21	21N	116W	41.7825861	-110.5845194	North Fork of Little Muddy Creek (3B), tributary to Little Muddy Creek (3B), Green River Basin
012	NENE	4	20N	117W	41.7488222	-110.6395972	unnamed ephemeral tributary (3B), tributary to South Fork of Twin Creek (3B), Bear River Basin
013	NENW	35	20N	117W	41.6782	-110.6069861	unnamed ephemeral tributary (3B), tributary to North Fork Little Muddy Creek (3B), Green River Basin
014	SESW	35	20N	117W	41.6756472	-110.6073917	unnamed ephemeral tributary (3B), tributary to North Fork Little Muddy Creek (3B), Green River Basin
015	NESE	34	20N	117W	41.6723917	-110.6168861	unnamed ephemeral tributary (3B), tributary to North Fork Little Muddy Creek (3B), Green River Basin
016	NESW	14	20N	117W	41.714825	-110.6075222	unnamed ephemeral tributary (3B), tributary to North Fork Little Muddy Creek (3B), Green River Basin
017	NWSE	29	21N	116W	41.769356	-110.602803	North Fork of Little Muddy Creek (3B), Green River Basin

Table 2: Detailed Outfall Receiving Water Description		
<u>Outfall #</u>	Narrative Outfall Descriptions	Indicate if outfall discharge is: A. Continuous B. Intermittent C. Seasonal D. No Discharge
001	Outfall 001 will discharge from the I-1 Settling Pond which will receive pit water from the I-Area Pits and adjacent lands; flows ½ mile to the east in Ricky Draw before reaching Little Muddy Creek.	No Discharge
002	Outfall 002 will discharge from the Skull Point Detention Pond which will receive pit water from the Skull Point and 2-UD Pits, tipple facilities, and adjacent disturbed areas; flows 20 feet in Skull Point Draw before reaching Little Muddy Creek.	Intermittent
003	Outfall 003 will discharge from Pond 27 which will receive pit water from the Skull Point and 2-UD Pits; flows 200 feet to the east in Skull Point Draw before reaching Little Muddy Creek.	Intermittent
004	Outfall 004 will discharge from the 1-UD 002 Settling Pond which will receive pit water from the 1-UD Complex Pits and adjacent lands; flows ½ mile to the east in the North Fork of Little Muddy Creek.	Intermittent
005	Outfall 005 will discharge from the Elkol Settling Pond which will receive sump water from the 2-UD pits; flows ½ mile to the east in Elkol Draw before reaching Little Muddy Creek.	Intermittent
006	Outfall 006 will discharge from the 1-UD West Settling Pond which will receive sump water from the 1-UD Complex Pits; flows ½ mile to the north in an unnamed dry gulch before reaching Middle Fork of Twin Creek.	Intermittent
007	Outfall 007 will discharge from the I-2 Settling Pond which will receive sump water from the I-Area pits; flows ½ mile to the east in an unnamed dry gulch before reaching Little Muddy Creek.	Intermittent
008	Outfall 008 will discharge from the TC-B Settling Pond which will receive run off from mostly undisturbed lands and 1-UD Complex Pits; flows 1/4 mile to the North in an unnamed dry gulch before reaching Middle Fork of Twin Creek.	Intermittent
009	Outfall 009 will discharge from the TC-A Settling Pond which will receive run off from mostly undisturbed lands and the 1-UD Complex Pits; flows 2 miles to the east in unnamed dry gulch before reaching the North Fork Little Muddy Creek.	Intermittent
010	Outfall 010 will discharge from KSB-S Settling Pond which will receive run off from the 1-UD out of pit spoil pile; flows 1.5 miles in unnamed dry gulch before reaching the North Fork Little Muddy Creek.	Intermittent
011	Outfall 011 will discharge from the 1-UD 001 Settling Pond which will receive water from the 1-UD out of pit spoil pile; flows directly into the North Fork Little Muddy Creek.	Intermittent
012	Outfall 012 will discharge from 12-UB Settling Pond which will receive runoff from reclaimed 1973 law lands; flows 2.5 west miles in unnamed dry gulch before reaching the South Fork of Twin Creek.	Intermittent
013	Outfall 013 will discharge from Pond 3 or Gabardi Settling Pond which will receive runoff from reclaimed lands; flows 2.5 miles East in an unnamed dry gulch before reaching the North Fork Little Muddy Creek.	Intermittent
014	Outfall 014 will discharge from Pond 4 or Thomas Settling Pond which will receive runoff from reclaimed lands; flows 2.5 miles East in an unnamed dry gulch before reaching the North Fork Little Muddy Creek.	Intermittent

Table 2: Detailed Outfall Receiving Water Description		
<u>Outfall #</u>	Narrative Outfall Descriptions	Indicate if outfall discharge is: A. Continuous B. Intermittent C. Seasonal D. No Discharge
015	Outfall 015 will discharge from Pond 5 Settling Pond which will receive runoff from reclaimed lands; flows 2.5 miles East in an unnamed dry gulch before reaching the North Fork Little Muddy Creek.	Intermittent
016	Outfall 016 will discharge from KSB-Q Settling Pond which will receive runoff from reclaimed lands; flows 2.5 miles East in an unnamed dry gulch before reaching the North Fork Little Muddy Creek.	Intermittent
017	Outfall 017 will discharge from KSB-J Settling Pond which will receive runoff from reclaimed lands and I-Area pit water; flows 2.5 miles east in an unnamed dry gulch before reaching the North Fork Little Muddy Creek.;	Intermittent

PART II

A. MANAGEMENT REQUIREMENTS

1. Changes

The permittee shall give notice to the administrator of the Water Quality Division as soon as possible of any physical alterations or additions to the permitted facility. Notice is required when:

- a. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source as determined in 40 CFR 122.29 (b); or
- b. The alteration or addition could change the nature or increase the quantity of pollutants discharged.

2. Noncompliance Notification

- a. The permittee shall give advance notice of any planned changes in the permitted facility or activity that may result in noncompliance with permit requirements.
- b. The permittee shall report any noncompliance that may endanger health or the environment as soon as possible, but no later than 24 hours from the time the permittee first became aware of the circumstances. The report shall be made to the Water Quality Division, Wyoming Department of Environmental Quality at (307) 777-7781.
- c. For any incidence of noncompliance, including noncompliance related to non-toxic pollutants or non-hazardous substances, a written submission shall be provided within five (5) days of the time that the permittee becomes aware of the noncompliance circumstance.

The written submission shall contain:

- (1) A description of the noncompliance and its cause;
 - (2) The period of noncompliance, including exact dates and times;
 - (3) The estimated time noncompliance is expected to continue if it has not been corrected; and
 - (4) Steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance.
- d. The following occurrences of unanticipated noncompliance shall be reported by telephone to the Water Quality Division, WYPDES Program (307) 777-7781 as soon as possible, but no later than 24 hours from the time the permittee first became aware of the circumstances.

- (1) Any unanticipated bypass that exceeds any effluent limitation in the permit;
 - (2) Any upset which exceeds any effluent limitation in the permit; or
 - (3) Violation of a maximum daily discharge limitation for any toxic pollutants or hazardous substances, or any pollutants specifically identified as the method to control a toxic pollutant or hazardous substance listed in the permit.
- e. The administrator of the Water Quality Division may waive the written report on a case-by-case basis if the Water Quality Division, WYPDES Program ((307) 777-7781), has received the oral report within 24 hours.
- f. Reports shall be submitted to the Wyoming Department of Environmental Quality at the address in Part I under Reporting and to the Planning and Targeting Program, 8ENF-PT, Office of Enforcement, Compliance, and Environmental Justice, U.S. EPA Region 8, 1595 Wynkoop Street, Denver, CO 80202-1129.
- g. The permittee shall report all instances of noncompliance that have not been specifically addressed in any part of this permit at the time the monitoring reports are due.

3. Facilities Operation

The permittee shall, at all times, properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems that are installed by the permittee only when the operation is necessary to achieve compliance with the conditions of the permit. However, the permittee shall operate, as a minimum, one complete set of each main line unit treatment process whether or not this process is needed to achieve permit effluent compliance.

4. Adverse Impact

The permittee shall take all reasonable steps to minimize any adverse impact to waters of the state resulting from noncompliance with any effluent limitations specified in this permit, including such accelerated or additional monitoring as necessary to determine the nature and impact of the noncomplying discharge.

5. Bypass of Treatment Facilities

- a. Bypass means the intentional diversion of waste streams from any portion of a treatment facility.
- b. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of

paragraphs c. and d. of this section. Return of removed substances to the discharge stream shall not be considered a bypass under the provisions of this paragraph.

- c. Notice:
 - (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice at least 60 days before the date of the bypass.
 - (2) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required under Part II.A.2.
- d. Prohibition of bypass.
 - (1) Bypass is prohibited and the administrator of the Water Quality Division may take enforcement action against a permittee for a bypass, unless:
 - (a) The bypass was unavoidable to prevent loss of life, personal injury or severe property damage;
 - (b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - (c) The permittee submitted notices as required under paragraph c. of this section.
- e. The administrator of the Water Quality Division may approve an anticipated bypass, after considering its adverse effects, if the administrator determines that it will meet the three conditions listed above in paragraph d. (L) of this section.

6. Upset Conditions

- a. Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improper designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
- b. An upset constitutes an affirmative defense to an action brought for noncompliance with technology based permit effluent limitations if the requirements of paragraph c. of this section are met.

- c. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that:
- (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated;
 - (3) The permittee submitted notice of the upset as required under Part II.A.2; and
 - (4) The permittee complied with any remedial measures required under Part II.A.4.
- d. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

7. Removed Substances

Solids, sludges, filter backwash or other pollutants removed in the course of treatment or control of wastewaters or intake waters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering waters of the state.

8. Power Failures

In order to maintain compliance with the effluent limitations and prohibitions of this permit, the permittee shall either:

- a. In accordance with a schedule of compliance contained in Part I, provide an alternative power source sufficient to operate the wastewater control facilities; or
- b. If such alternative power source as described in paragraph a. above is not in existence and no date for its implementation appears in Part I, take such precautions as are necessary to maintain and operate the facility under its control in a manner that will minimize upsets and insure stable operation until power is restored.

9. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the federal act and the Wyoming Environmental Quality Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. The permittee shall give the administrator of the Water Quality Division advance notice of any planned changes at the permitted facility or of any activity that may result in permit noncompliance.

10. Duty to Mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit that has a reasonable likelihood of adversely affecting human health or the environment.

11. Signatory Requirements

All applications, reports or information submitted to the administrator of the Water Quality Division shall be signed and certified.

- a. All permit applications shall be signed as follows:
 - (1) For a corporation: by a responsible corporate officer;
 - (2) For a partnership or sole proprietorship: by a general partner or the proprietor, respectively;
 - (3) For a municipality, state, federal or other public agency: by either a principal executive officer or ranking elected official.
- b. All reports required by the permit and other information requested by the administrator of the Water Quality Division shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - (1) The authorization is made in writing by a person described above and submitted to the administrator of the Water Quality Division; and
 - (2) The authorization specified either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility or an individual or position having overall responsibility for environmental matters for the company. A duly authorized representative may thus be either a named individual or any individual occupying a named position.
- c. If an authorization under paragraph II.A.11.b. is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph II.A.11.b must be submitted to the administrator of the Water Quality Division prior to or together with any reports, information or applications to be signed by an authorized representative.
- d. Any person signing a document under this section shall make the following certification:

"I certify, under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the

system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

B. RESPONSIBILITIES

1. A. Providing Access

The permittee shall allow Department of Environmental Quality personnel and their invitees to enter the premises where the facility is located, or where records are kept under the conditions of this permit, and collect resource data as defined by Wyoming Statute § 6-3-414, inspect and photograph the facility, collect samples for analysis, review records, and perform any other function authorized by law or regulation. The permittee shall secure and maintain such access for the duration of the permit.

If the facility is located on property not owned by the permittee, the permittee shall also secure and maintain from the landowner upon whose property the facility is located permission for Department of Environmental Quality personnel and their invitees to enter the premises where a regulated facility is located, or where records are kept under the conditions of this permit, and collect resource data as defined by Wyoming Statute § 6-3-414, inspect and photograph the facility, collect samples for analysis, review records, and perform any other function authorized by law. The permittee shall secure and maintain such access for the duration of the permit.

If the facility cannot be directly accessed using public roads, the permittee shall also secure and maintain permission for Department of Environmental Quality personnel and their invitees to enter and cross all properties necessary to access the facility. The permittee shall secure and maintain such access for the duration of the permit.

B. Access Records

The permittee shall maintain in its records documentation that demonstrates that the permittee has secured permission for Department of Environmental Quality personnel and their invitees to access the permitted facility, including (i) permission to access the land where the facility is located, (ii) permission to collect resource data as defined by Wyoming Statute § 6-3-414, and (iii) permission to enter and cross all properties necessary to access the facility if the facility cannot be directly accessed from a public road. The permittee shall also maintain in its records a current map of the access route(s) to the facility and contact information for the owners or agents of all properties that must be crossed to access the facility. The permittee shall ensure that the documentation, map, and contact information are current at all times. The permittee shall provide the documentation, map, and contact information to Department of Environmental Quality personnel upon request. Upon termination of the permit, the permittee shall maintain such records for a period of three (3) years.

2. Transfer of Ownership or Control

In the event of any change in control or ownership of facilities from which the authorized discharges emanate, the permittee shall notify the succeeding owner or controller of the

existence of this permit by letter, a copy of which shall be forwarded to the regional administrator of the Environmental Protection Agency and the administrator of the Water Quality Division. The administrator of the Water Quality Division shall then provide written notification to the new owner or controller of the date in which they assume legal responsibility of the permit. The permit may be modified or revoked and reissued to change the name of the permittee and incorporate such other requirements as described in the federal act.

3. Availability of Reports

Except for data determined to be confidential under Section 308 of the federal act, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Wyoming Department of Environmental Quality and the regional administrator of the Environmental Protection Agency. As required by the federal act, effluent data shall not be considered confidential. Knowingly making any false statement on any such report may result in the imposition of criminal penalties as provided for in Section 309 of the federal act.

4. Toxic Pollutants

The permittee shall comply with effluent standards or prohibitions established under Section 307 (a) of the federal act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

5. Changes in Discharge of Toxic Substances

Notification shall be provided to the administrator of the Water Quality Division as soon as the permittee knows of, or has reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;
 - (3) Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR 122.21 (g) (7); or
 - (4) The level established by the director of the Environmental Protection Agency in accordance with 40 CFR 122.44 (f).
- b. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in

the permit, if that discharge will exceed the highest of the following "notification levels":

- (1) Five hundred micrograms per liter (500 µg/L);
- (2) One milligram per liter (1 mg/l) for antimony;
- (3) Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR 122.21 (g) (7); or
- (4) The level established by the director of the Environmental Protection Agency in accordance with 40 CFR 122.44 (f).

6. Civil and Criminal Liability

Nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance. As long as the conditions related to the provisions of "Bypass of Treatment Facilities" (Part II.A.5), "Upset Conditions" (Part II.A.6), and "Power Failures" (Part II.A.8) are satisfied then they shall not be considered as noncompliance.

7. Need to Halt or Reduce Activity not a Defense

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

8. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties to which the permittee is or may be subject under Section 311 of the federal act.

9. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable state or federal law or regulation. In addition, issuance of this permit does not substitute for any other permits required under the Clean Water Act or any other federal, state, or local law.

10. Property Rights

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights nor any infringement of federal, state or local laws or regulations.

11. Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The application should be submitted at least 180 days before the expiration date of this permit.

12. Duty to Provide Information

The permittee shall furnish to the administrator of the Water Quality Division, within a reasonable time, any information that the administrator may request to determine whether cause exists for modifying, revoking and reissuing or terminating this permit or to determine compliance with this permit. The permittee shall also furnish to the administrator, upon request, copies of records required by this permit to be kept.

13. Other Information

When the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or any report to the administrator of the Water Quality Division, it shall promptly submit such facts or information.

14. Permit Action

This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

PART III

A. OTHER REQUIREMENTS

1. Flow Measurement

At the request of the administrator of the Water Quality Division, the permittee must be able to show proof of the accuracy of any flow-measuring device used in obtaining data submitted in the monitoring report. The flow-measuring device must indicate values of within plus or minus ten (10) percent of the actual flow being measured.

2. 208(b) Plans

This permit may be modified, suspended or revoked to comply with the provisions of any 208(b) plan certified by the Governor of the State of Wyoming.

3. Reopener Provision

This permit may be reopened and modified (following proper administrative procedures) to include the appropriate effluent limitations (and compliance schedule, if necessary) or other appropriate requirements if one or more of the following events occurs:

- a. The state water quality standards of the receiving water(s) to which the permittee discharges are modified in such a manner as to require different effluent limits than contained in this permit;
- b. A total maximum daily load (TMDL) and/or watershed management plan is developed and approved by the state and/or the Environmental Protection Agency that specifies a wasteload allocation for incorporation in this permit;
- c. A revision to the current water quality management plan is approved and adopted which calls for different effluent limitations than contained in this permit;
- d. Downstream impairment is observed and the permitted facility is contributing to the impairment;
- e. The limits established by the permit no longer attain and/or maintain applicable water quality standards;
- f. The permit does not control or limit a pollutant that has the potential to cause or contribute to a violation of a state water quality standard.
- g. If new applicable effluent guidelines and/or standards have been promulgated and the standards are more stringent than the effluent limits established by the permit.
- h. In order to protect water quality standards in neighboring states, effluent limits may be incorporated into this permit or existing limits may be modified to ensure that the appropriate criteria, water quality standards and assimilative capacity are attained.

4. Permit Modification

After notice and opportunity for a hearing, this permit may be modified, suspended or revoked in whole or in part during its term for cause including, but not limited to, the following:

- a. Violation of any terms or conditions of this permit;
- b. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts;
- c. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge; or
- d. If necessary to comply with any applicable effluent standard or limitation issued or approved under Sections 301(b) (2) (C) and (D), 304 (b) (2) and 307 (a) (2) of the federal act, if the effluent standard or limitation so issued or approved:
 - (1) Contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) Controls any pollutant not limited in the permit.

5. Toxicity Limitation - Reopener Provision

This permit may be reopened and modified (following proper administrative procedures) to include a new compliance date, additional or modified numerical limitations, a new or different compliance schedule, a change in the whole effluent protocol or any other conditions related to the control of toxicants if one or more of the following events occur:

- a. Toxicity was detected late in the life of the permit near or past the deadline for compliance;
- b. The toxicity reduction evaluation (TRE) results indicate that compliance with the toxic limits will require an implementation schedule past the date for compliance and the permit issuing authority agrees with the conclusion;
- c. The TRE results indicate that the toxicant(s) represent pollutant(s) that may be controlled with specific numerical limits and the permit issuing authority agrees that numerical controls are the most appropriate course of action;
- d. Following the implementation of numerical controls on toxicants, the permit issuing authority agrees that a modified whole effluent protocol is necessary to compensate for those toxicants that are controlled numerically;
- e. The TRE reveals other unique conditions or characteristics that, in the opinion of the permit issuing authority, justify the incorporation of unanticipated special conditions in the permit.

6. Severability

The provisions of this permit are severable and if any provision of this permit, or the application of any provision of this permit to any circumstance is held invalid, the application of such provision to other circumstances and the remainder of this permit, shall not be affected thereby.

7. Penalties for Falsification of Reports

The federal act provides that any person who knowingly makes any false statement, representation or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation or by imprisonment for not more than two years per violation or both.