

PERMIT TO CONSTRUCT

- New
- Renewal
- Modified

Permit No. 83-551R  
SEE SPECIAL CONDITION

Wambolt Office - Storage Warehouse  
(Name of Facility)

This permit hereby authorizes the applicant (name and address):

Henry Wamboldt

1112 W. Laughlin Road

Cheyenne, WY 82001

to construct, install, or modify a commercial subsurface wastewater treatment and disposal facility according to the procedures and conditions of the application No. 83-551R. The facility is located in Section 28, T14N, R65W in the County of Laramie, in the State of Wyoming. This permit shall be effective for a period of two (2) years (five (5) years maximum) from the date of issuance of this permit.

The issuance of this permit provides that the Department of Environmental Quality has evaluated and determined that the application meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the applicant, owner, or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming Department of Environmental Quality guarantees or insures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Environmental Quality Act have been met. The State assumes no liability for, and does not in any way guarantee the performance of, the permittee in the exercise of its activities allowed under this permit. The Permittee understands that it is solely responsible to any third parties for any liability arising from the construction or operation of the facility described herein. By the issuance of this permit, the State does not in any way waive its sovereign immunity.


The permittee shall allow authorized representatives from the Department of Environmental Quality, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002; telephone, 777-7781.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
WILLIAM L. GARLAND  
Adminis. Corp. E. # 1479  
Water Quality Division  
REGISTERED PROFESSIONAL ENGINEER  
STATE OF WYOMING

  
Director  
Dept. of Environmental Quality

REGISTERED PROFESSIONAL ENGINEER  
ROBERT E. SUNDIN  
NO. 285  
STATE OF WYOMING

October 20, 1983  
Date of Issuance

This permit does not supercede the requirements for obtaining any permit from local agencies.

Condition to Permit to Construct

The permittee shall notify representatives of the Laramie County Health Unit of the estimated day construction will commence and the estimated day of completion of this project. Inspection of the installed system is required prior to backfilling. The authorized representative in your area can be contacted at the following address:

Don Pack  
Laramie County Health Unit  
1700 Snyder  
Cheyenne, WY 82001  
Telephone: 638-8545

cc: D. M. Hopkins  
D. M. Hopkins & Assoc.  
216 East 17th St.  
Cheyenne, WY 82001

Review of Plans and Specifications

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
1111 East Lincolnway  
Cheyenne, Wyoming 82002

PROJECT: Wambolt Office-Storage Warehouse, Laramie Co.

ARCHITECT OR ENGINEER: D. M. Hopkins  
216 E. 17th Street, Cheyenne, WY 82001

APPLICANT: Henry Wambolt  
1112 West Laughlin Rd., Cheyenne, WY 82001

WATER QUALITY DIVISION REFERENCE NUMBER: 83-551

REVIEWING ENGINEER: Thomas S. Norman *T.S. Norman*

DATE OF REVIEW: October 3, 1983

ACTION: NOT AUTHORIZED FOR CONSTRUCTION

COMMENTS:

1. Three copies of all submittals are required.
2. The owner must sign the application form.
3. The method for computing the percolation rate is incorrect. Only the last time increment should be averaged which computes to be 0.25 inches in 10 minutes or 40 minutes/inch.
4. The application rate is too high. The values used in the Manual of Septic Tank Practice have been found to be too liberal and have been updated. I suggest using either our proposed regulations or the 1980 EPA Design Manual on onsite systems.
5. DEQ regulations require a minimum separation of four feet from the bottom of the trench to the seasonal high groundwater level and impervious layer. This requirement has not been met.
6. A note that "joints to be covered with building paper" is misleading as the entire stone area must be covered.



*Department of Environmental Quality*  
*Water Quality Division*

165 EAST RAILROAD AVENUE

GREEN RIVER, WYOMING 82935

TELEPHONE 307 875-6911

November 14, 1983

Arco Oil & Gas Co.  
P. O. Box 5540  
Denver, CO 80217

Re: "As Built" Wastewater Treatment Facility for Arco Telephone Pass Unit #1  
(DEQ/WQD No. 83-552R)

An application for a "Permit to Construct" the above mentioned facility was submitted to this office on September 28, 1983. On November 8, 1983 I made an on-site inspection of the facility. At that time the wastewater treatment facility was installed and operating.

The Wyoming Environmental Quality Act stipulates that no person except when permit authorized shall: construct, install, or modify any sewage system... , capable of causing or contributing to pollution . . .

Failure to comply with the Environmental Quality Act is a violation of state statutes. To avoid legal action in the future, please obtain a "Permit to Construct" prior to installation of the facility.

After reviewing the plans and making the onsite inspection the facility appears to meet the minimum design standards for the State of Wyoming. A "Permit to Construct" cannot be issued owing to the fact that the facility has already been built. Please retain this letter as verification that the facility has been accepted by the Wyoming Department of Environmental Quality.

Sincerely,

A handwritten signature in cursive script, appearing to read "Jack Bedessem".

Jack Bedessem  
Area III Supervisor

JB/mpm

cc: Cheyenne DEQ/WQD  
Phil Essington-Rio Verde Engineering  
Jay Carlson-USFS, Big Piney  
File (4)  
Carolyn Nield-Lincoln County




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.



The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 210 Lincoln, Lander, Wyoming 82520; telephone, 332-3144.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
WILLIAM J. GARLAND  
Administrative # 1475  
Water Quality Division  


  
Director  
Dept. of Environmental Quality  


November 1, 1983  
Date of Issuance

This permit does not supercede the requirements for obtaining any permit from local agencies.

JH:dcn



THE STATE OF WYOMING

ED HERSCHLER  
GOVERNOR

*Department of Environmental Quality*  
*Water Quality Division*

165 EAST RAILROAD AVENUE

GREEN RIVER, WYOMING 82935

TELEPHONE 307 875-6911

January 3, 1984

ARCO  
P. O. Box 5540  
Denver, CO 80217

Re: "As Built" Wastewater Treatment Plant for Arco-Crow Creek  
DEQ/WQD No. 83-554R

The above mentioned facility is located in Sec. 29, T32N, R116 W, Lincoln County, Wyoming. After reviewing the facility plans, they appear to meet the minimum design standards for the State of Wyoming.

A "Permit to Construct" cannot be issued owing to the fact that the facility has already been built. Please retain this letter as verification that the facility has been accepted by the Wyoming Department of Environmental Quality.

Sincerely,

A handwritten signature in cursive script, appearing to read "Jack Bedessem".

Jack Bedessem  
Area III Supervisor

JB:mpm

cc: Robert Ablondi-Jorgensen Engineering  
Cheyenne DEQ/WQD  
File (2)

PERMIT TO CONSTRUCT

- New
- Renewal
- Modified

Permit No. 83-555RR

Medicine Bow Maintenance Bldg.  
(Name of Facility)

This permit hereby authorizes the applicant (name and address):

Wyoming Highway Department

5300 Bishop Boulevard

Cheyenne, WY 82002

to construct, install, or modify a potable water main and septic tank-soil absorption sewage treatment facility according to the procedures and conditions of the application No. 83-555RR. The facility is located in Section 12, T22N, R79W in the County of Carbon, in the State of Wyoming. This permit shall be effective for a period of two (2) years (five (5) years maximum) from the date of issuance of this permit.

The issuance of this permit provides that the Department of Environmental Quality has evaluated and determined that the application meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the applicant, owner, or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming Department of Environmental Quality guarantees or insures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Environmental Quality Act have been met. The State assumes no liability for, and does not in any way guarantee the performance of, the permittee in the exercise of its activities allowed under this permit. The Permittee understands that it is solely responsible to any third parties for any liability arising from the construction or operation of the facility described herein. By the issuance of this permit, the State does not in any way waive its sovereign immunity.


The permittee shall allow authorized representatives from the Department of Environmental Quality, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002; telephone, 777-7781.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.


The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
Administrator  
Water Quality Division  
February 15, 1984  
Date of Issuance



  
Director  
Dept. of Environmental Quality



This permit does not supercede the requirements for obtaining any permit from local agencies.

cc: Rick Johnston  
Gust and Johnston  
2232 Del Range Blvd., Suite 203  
Cheyenne, WY 82009



THE STATE OF WYOMING

ED HERSCHLER  
GOVERNOR

83-556  
Bill Earland  
Jake Stohman

*Department of Environmental Quality*  
*Water Quality Division*

165 EAST RAILROAD AVENUE

GREEN RIVER, WYOMING 82935

TELEPHONE 307 875-2911

November 1, 1983

James L. Martin  
Clearview Acres Mobile Home Court  
P. O. Box 1540  
Rock Springs, WY 82901

**DRAFT**

Re: Pretreatment Units for Clearview Acres Wastewater Treatment Lagoons  
DEQ/WQD No. 83-556

Dear Mr. Martin:

The purpose of this letter is to acknowledge the receipt of the above mentioned plans and to clarify their status.

On October 14, 1982 you were issued Notice Of Violation and Cease And Desist Order Docket No. 1156-82. In brief, this Order required that Clearview Acres Mobile Home Court sewage system be connected to the Rock Springs Wastewater Treatment Facility. This connection was to have been completed by July 1, 1983.

To date, this department has no record of this connection ever being completed. In correlation with the Order Docket No. 1156-82, the Department of Environmental Quality/Water Quality Division will not review or authorize pretreatment units for Clearview Acres wastewater treatment lagoons (83-556).

If you have any questions please contact Jack Bedessem, Department of Environmental Quality/Water Quality Division, 165 E. Railroad Avenue, Green River, WY 82935, (307) 875-6911.

cc: Cheyenne DEQ/WQD  
Steve Jones - AAG, Cheyenne  
Harry J. Kessner - Bennett-Carder & Associates, Inc.  
P. O. Box 1324  
Rock Springs, WY 82901




ing working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 165 East Railroad Ave., Green River, Wyoming 82935; telephone, 875-6911.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
*William L. Garrison*  
\_\_\_\_\_  
William L. Garrison  
Administrator #1479  
Water Quality Division  
STATE OF WYOMING  
October 27, 1983  
\_\_\_\_\_  
Date of Issuance

  
*Robert E. Sundin*  
\_\_\_\_\_  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.

JB:mpm

cc: Kevin D. Jones  
Carlton & Carlton  
748 Lombard Street  
Evanston, WY 82930

\* CONDITION OF PERMIT \*

The permittee shall notify representatives of the Uinta County Planning Office of the estimated day construction will commence and the estimated day of completion of this project. Inspection of the installed system is required prior to back-filling. The authorized representative in your area can be contacted at the following address:

William Cates  
Uinta County Sanitarian  
P. O. Box 895  
Evanston, WY 82930

PERMIT TO CONSTRUCT

- New
- Renewal
- Modified

Permit No. 83-558  
SEE CONDITIONS ATTACHED TO THIS PERMIT

Boner-Federal SCC-DSU  
(Name of Facility)

This permit hereby authorizes the applicant (name and address):

Phillips Petroleum Co.

P.O. Box 2920

Casper, WY 82602

to construct, install, or modify a produced water disposal facility according to the procedures and conditions of the application No. 83-558. The facility is located in Sections 5, 6, 7, 8, 16, 17 and 18, T34N, R76W in the County of Converse, in the State of Wyoming. This permit shall be effective for a period of one year (five (5) years maximum) from the date of issuance of this permit.

The issuance of this permit provides that the Department of Environmental Quality has evaluated and determined that the application meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the applicant, owner, or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming Department of Environmental Quality guarantees or insures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Environmental Quality Act have been met. The State assumes no liability for, and does not in any way guarantee the performance of, the permittee in the exercise of its activities allowed under this permit. The Permittee understands that it is solely responsible to any third parties for any liability arising from the construction or operation of the facility described herein. By the issuance of this permit, the State does not in any way waive its sovereign immunity.


The permittee shall allow authorized representatives from the Department of Environmental Quality, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.



The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002; telephone, 777-7781.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
  
WILLIAM GARLAND  
Administrator  
Water Quality Division  
October 7, 1989  
Date of Issuance

  
  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.

This permit authorizes you to dispose of 126,000 gallons of produced water on the surrounding \_\_\_\_\_ acres or on approximately 8.75 miles of road, comprising 21.21 acres, a total liquid application of 0.22 inches.

CONDITIONS TO PERMIT TO CONSTRUCT

1. Wastewater shall be applied at a rate which will not produce runoff or ponding. Application shall not be initiated during the spring runoff period or other periods where saturated soil conditions exist.
2. The application site slope shall not exceed 8% for vehicular application or 15% for spray irrigation or irrigation by gated pipe on the contour. Vegetated areas of the site shall not be spray-irrigated where possible plant leaf injury may result from salt residue.
3. Wastewater application shall be terminated within 300 feet of the defineable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
4. To assess the long term effects of the wastewater application on the soil and its relation to revegetation success on denuded areas, the seed mix (% of selected species), seed rate (lbs. of bulk seed/acre and % pure live seed), mulch and fertilizer preferred by the landowner-lessee or land management agency should be forwarded to E. J. Fanning, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002, within 30 days of receipt of this permit.

PERMIT TO CONSTRUCT

- New
- Renewal
- Modified

Permit No. 83-559  
SEE CONDITIONS ATTACHED TO THIS PERMIT

Hyrum Ditch No. 31X-26  
(Name of Facility)

This permit hereby authorizes the applicant (name and address):

FMC Corporation  
City Center Four, Suite 2720  
1801 California St.  
Denver, CO 80202

to construct, install, or modify a produced water disposal facility according to the procedures and conditions of the application No. 83-559. The facility is located in Section 23, T26N, R113W in the County of Lincoln, in the State of Wyoming. This permit shall be effective for a period of one (1) years (five (5) years maximum) from the date of issuance of this permit.

The issuance of this permit provides that the Department of Environmental Quality has evaluated and determined that the application meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the applicant, owner, or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming Department of Environmental Quality guarantees or insures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Environmental Quality Act have been met. The State assumes no liability for, and does not in any way guarantee the performance of, the permittee in the exercise of its activities allowed under this permit. The Permittee understands that it is solely responsible to any third parties for any liability arising from the construction or operation of the facility described herein. By the issuance of this permit, the State does not in any way waive its sovereign immunity.



The permittee shall allow authorized representatives from the Department of Environmental Quality, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.



The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002; telephone, 777-7781.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
  
WILLIAM SABAND  
Administrator  
Water Quality Division  
October 14, 1983  
Date of Issuance

  
  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.

This permit authorizes you to dispose of 118 gallons of produced water every 10 days on adjoining access roads not to exceed a total liquid application of 4.0 inches.

CONDITIONS TO PERMIT TO CONSTRUCT

1. Wastewater shall be applied at a rate which will not produce runoff or ponding. Application shall not be initiated during the spring runoff period or other periods where saturated soil conditions exist.
2. The application site slope shall not exceed 8% for vehicular application or 15% for spray irrigation or irrigation by gated pipe on the contour. Vegetated areas of the site shall not be spray-irrigated where possible plant leaf injury may result from salt residue.
3. Wastewater application shall be terminated within 300 feet of the defineable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
4. To assess the long term effects of the wastewater application on the soil and its relation to revegetation success on denuded areas, the seed mix (% of selected species), seed rate (lbs. of bulk seed/acre and % pure live seed), mulch and fertilizer preferred by the landowner-lessee or land management agency should be forwarded to E. J. Fanning, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002, within 30 days of receipt of this permit. Not applicable to this permit.

11-18-83

PERMIT TO CONSTRUCT

Permit No. 83-560R  
SEE SPECIAL CONDITIONS

- New
- Renewal
- Modified

The Cottonwoods  
(Name of Facility)

This permit hereby authorizes the applicant (name and address):

Bill Lythgoe

P.O. Box 34

Glenrock, WY 82637

to construct, install, or modify a holding tank facility according to the procedures and conditions of the application No. 83-560R. The facility is located in Section 4, T33N, R75W in the County of Converse, in the State of Wyoming. This permit shall be effective for a period of two (2) years (five (5) years maximum) from the date of issuance of this permit.

The issuance of this permit provides that the Department of Environmental Quality has evaluated and determined that the application meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the applicant, owner, or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming Department of Environmental Quality guarantees or insures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Environmental Quality Act have been met. The State assumes no liability for, and does not in any way guarantee the performance of, the permittee in the exercise of its activities allowed under this permit. The Permittee understands that it is solely responsible to any third parties for any liability arising from the construction or operation of the facility described herein. By the issuance of this permit, the State does not in any way waive its sovereign immunity.


The permittee shall allow authorized representatives from the Department of Environmental Quality, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002; telephone, 777-7781.


Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.


The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:



  
WILLIAM R. BARLOW  
Administrator  
Water Quality Division  
P.E. #1479  
November 1983  
Date of Issuance

A circular seal for a Registered Professional Engineer. The outer ring contains the text "REGISTERED PROFESSIONAL ENGINEER" at the top and "STATE OF WYOMING" at the bottom, separated by two stars. The inner circle contains the name "WILLIAM R. BARLOW" and the number "P.E. #1479".

  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.

Condition to Permit to Construct

The permittee shall notify representatives of the Converse County Health Department of the estimated day construction will commence and the estimated day of completion of this project. Inspection of the installed system is required prior to back-filling. The authorized representative in your area can be contacted at the following address:

Chuck Higgins, County Sanitarian  
Converse County Health Department  
Box 1303  
Douglas, WY 82633  
Telephone: 358-2536

cc: John A. Lambert  
Box 34  
Douglas, WY 82633

Review of Plans and Specifications

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
1111 East Lincolnway  
Cheyenne, Wyoming 82002

CERTIFIED

PROJECT: Hogodon Estates, As Builts, Natrona Co.

ARCHITECT OR ENGINEER: Dale A. Johnson, W L & C, Inc., 632 So. David  
Casper, WY 82601

APPLICANT: Gary Whitcomb, P.O. Box 1011  
Casper, WY 82602

WATER QUALITY DIVISION REFERENCE NUMBER: 83-561

REVIEWING ENGINEER: Thomas S. Norman *Thomas S Norman*

DATE OF REVIEW: October 12, 1983

ACTION: NOT AUTHORIZED FOR CONSTRUCTION

COMMENTS:

1. The submittal was inadequate to review to determine if the system meets the minimum standards for a public water supply. I suggest the engineer refer to the "Recommended Standards for Water Works" to determine the type of information and minimum standards necessary to get this system authorized for use. Since the information was inadequate, the following is only a general listing of information necessary for review:
  - a. Well - test data; completion information; plans and specs on casing, pipe, pump, housing, valves, gauges, gravel pack; quality data; determination of quantity.
  - b. Distribution system - blowoffs at dead ends; type and class of pipe; bedding; installation procedures; location and type of valves; disinfection procedure; pressure and leakage testing, air release valves at high points, service connections; thrust blocks.
  - c. Storage - plans and specs on tank (coatings, access, structural capability, drainage, overflow, piping); well to tank level controls; working capacity; access restriction to public; fencing; disinfection.
2. It is inaccurate to compute minimum static elevations from the top of the tank. The minimum working level should be used. Section 7.3.1 of Ten State Standards requires the distribution storage to provide a minimum working pressure of 35 psi. The existing information states that this requirement is not met. Also noted is that static pressures are not the same as working pressures.
3. More information is necessary on the design flows. The average daily flow, peak daily flow, and peak hourly flow should be identified and justified. The system should be designed to consistently meet peak daily flows as would occur during the summer and also to have storage capacity to meet peak hourly flow rates. It is not known if adequate working storage capacity is available.

4. An application form was not submitted.
5. The owner is reminded that a violation is still in affect and fines are based on daily violations. Failure to work in a timely manner towards an authorized system will result in further legal action. I suggest that the owner allow the engineer to proceed with designing the necessary modifications to bring the system into compliance and proceed with obtaining the necessary permits.

The files indicate that the owner has not been punctual in replying to our requests. Therefore a 30 day period should be sufficient to submit additional information.

cc: Steve Jones, Assistant Attorney General




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.



The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
WILLIAM J. GARLAND  
Administrator  
Water Quality Division  
NOV 11 1983  
Date of Issuance  


  
ROBERT E. SUNDIN  
Director  
Dept. of Environmental Quality  


This permit does not supercede the requirements for obtaining any permit from local agencies.

xc: Western Water Consultants  
410 Grand Avenue, Suite 213  
Laramie, Wyoming 82070




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
\_\_\_\_\_  
Administrator  
Water Quality Division  
PE # 1479  
November 15, 1983  
Date of Issuance  


  
\_\_\_\_\_  
Director  
Dept. of Environmental Quality  


This permit does not supercede the requirements for obtaining any permit from local agencies.

xc: Western Water Consultants  
410 Grand Avenue, Suite 213  
Laramie, Wyoming 82070



during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.


The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

*William L. Garland*  
 \_\_\_\_\_  
 WILLIAM L. GARLAND  
 Administrator # 1479  
 Water Quality Division  
 November 1983  
 \_\_\_\_\_  
 Date of Issuance



*Robert E. Sundin*  
 \_\_\_\_\_  
 Director  
 Dept. of Environmental Quality



This permit does not supercede the requirements for obtaining any permit from local agencies.

xc: Western Water Consultants  
 410 Grand Avenue, Suite 213  
 Laramie, Wyoming 82070



during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.


Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.


The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
\_\_\_\_\_  
Administrator  
Water Quality Division  
PE # 1479  
November 16, 1983  
\_\_\_\_\_  
Date of Issuance



  
\_\_\_\_\_  
Director  
Dept. of Environmental Quality



This permit does not supercede the requirements for obtaining any permit from local agencies.



during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.


Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.


The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
WILLIAM GARLAND  
Administrator 479  
Water Quality Division  
November 16, 1993  
Date of Issuance



  
Robert E. Sunden  
Director  
Dept. of Environmental Quality



This permit does not supercede the requirements for obtaining any permit from local agencies.




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
*William L. Garland*  
\_\_\_\_\_  
Adminis. # 9479  
Water Quality Division  
November 16, 1983  
\_\_\_\_\_  
Date of Issuance

  
*Robert E. Sundin*  
\_\_\_\_\_  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
*William J. Garland*  
\_\_\_\_\_  
WILLIAM J. GARLAND  
Administrator # 1479  
Water Quality Division  
November 16<sup>th</sup> 1983  
\_\_\_\_\_  
Date of Issuance

  
*Robert E. Sundin*  
\_\_\_\_\_  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
  
Administrator #1479  
Water Quality Division  
November 16, 1983  
Date of Issuance

  
  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:



*Robert E. Sundin*  
\_\_\_\_\_  
Director  
Dept. of Environmental Quality

*William J. [Signature]*  
\_\_\_\_\_  
Administrator  
Water Quality Division  
PE # 1479  
November 16, 1983  
Date of Issuance

A circular seal for a Registered Professional Engineer in the State of Wyoming. The outer ring contains the text "REGISTERED PROFESSIONAL ENGINEER" at the top and "STATE OF WYOMING" at the bottom, separated by two stars. The inner circle contains the name "WILLIAM J. [Signature]" and the number "PE # 1479".

This permit does not supercede the requirements for obtaining any permit from local agencies.




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.



The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
  
WILLIAM L. GARLAND  
Administrator  
Water Quality Division  
November 16, 1983  
Date of Issuance

  
  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.



during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
\_\_\_\_\_  
WILLIAM L. GARLAND  
Administrator 1479  
Water Quality Division  
STATE OF WYOMING  
November 6, 1988  
Date of Issuance

  
\_\_\_\_\_  
ROBERT E. SUNDIN  
NO. 285  
REGISTERED PROFESSIONAL ENGINEER  
STATE OF WYOMING  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
  
Administrator # 1479  
Water Quality Division  
December 28, 1988  
Date of Issuance

  
  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
WILLIAM L. GARLAND  
Administrator # 1479  
Water Quality Division  
December 1983  
Date of Issuance



  
ROBERT E. SUNDIN  
Director  
Dept. of Environmental Quality



This permit does not supercede the requirements for obtaining any permit from local agencies.




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
  
WILLIAM L. GARLAND  
Administrator # 1479  
Water Quality Division  
December 25, 1988  
Date of Issuance

  
  
ROBERT E. SUNDIN  
NO. 285  
STATE OF WYOMING  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:



*William L. Garland*  
\_\_\_\_\_  
Administrator  
Water Quality Division  
RE # 1478  
December 28, 1983  
\_\_\_\_\_  
Date of Issuance

A circular seal for a Registered Professional Engineer. The outer ring contains the text "REGISTERED PROFESSIONAL ENGINEER" at the top and "STATE OF WYOMING" at the bottom, separated by two stars. The inner circle contains the name "WILLIAM L. GARLAND" and the number "RE # 1478".

*Robert E. Sundin*  
\_\_\_\_\_  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.





during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.



The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
  
Administrator # 1479  
Water Quality Division  
December 28, 1983  
Date of Issuance

  
  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
*William E. Garland*  
\_\_\_\_\_  
William E. Garland  
Administrator  
Water Quality Division  
December 28, 1983  
\_\_\_\_\_  
Date of Issuance

  
*Robert E. Sundin*  
\_\_\_\_\_  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.



The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
  
Administrator 1479  
Water Quality Division  
December 29, 1983  
Date of Issuance

  
  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.

REVIEW OF PLANS AND SPECIFICATIONS

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
2161 COFFEEN AVE., SUITE 301  
SHERIDAN, WYOMING 82801

WATER QUALITY DIVISION  
WYOMING

PROJECT: EBNPDES 012A, 012B, 012C, 012D, 013, 014  
and 015 Reservoirs

ARCHITECT OR ENGINEER: AMAX Coal Company  
Attention: Frank Ferris  
P.O. Box 3005  
Gillette, Wyoming 82716

WATER QUALITY DIVISION  
REFERENCE NUMBERS: 83-573R through 83-579R

REVIEWING ENGINEER: Tom Mueller *TJM*

DATE OF REVIEW: November 16, 1983

ACTION: Not Authorized for Construction

1. Please provide specifications for the pumps and floating suction heads for ponds 012C and 014.
2. Please indicate how flow will be monitored at discharges 012, 013 and 014.
3. Permits to Construct for sediment reservoirs EB73 through EB80 have been prepared and should be issued in the immediate future.
4. There are some minor discrepancies between the plans and the NPDES permit. These will not prevent issuance of the Permits to Construct, but should be addressed by AMAX:
  - Discharge 012 does not appear to be in the location shown by the NPDES permit;
  - Discharge 014 is not shown in the NPDES permit as receiving process wastewater;
  - Discharge 009 is shown in the permit as receiving sanitary sewage as well as pit water.

*ABC*

REVIEW OF PLANS AND SPECIFICATIONS

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
2161 COFFEEN AVE., SUITE 301  
SHERIDAN, WYOMING 82801

PROJECT: Frontier Lanes Sewage System

ARCHITECT OR ENGINEER: Robert L. Kumpe, P.E.  
c/o Mr. Bill Jacobson  
1971 East Yellowstone  
Casper, Wyoming 82601

WATER QUALITY DIVISION  
REFERENCE NUMBER: 83-580

REVIEWING ENGINEER: Tom Mueller *TDM*

DATE OF REVIEW: November 15, 1983

ACTION: Not Authorized for Construction

COMMENTS:

Before the application can be approved, complete drawings and specifications for whatever treatment system is proposed must be submitted. Three copies are required.

Your drawing, due to its incompleteness, is returned herewith.

xc: Mr. Tom Svelina




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.



The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 210 Lincoln, Lander, Wyoming 82520; telephone, 332-3144.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
WILLIAM L. GARLAND  
Administrator #1479  
Water Quality Division  


  
Director  
Dept. of Environmental Quality  


November 18, 1983

Date of Issuance

This permit does not supercede the requirements for obtaining any permit from local agencies.

\* CONDITIONS ON PERMIT \*

This "Permit" is issued with the requirement that the following conditions be followed:

1. The sedimentation ponds are to be used for process water from gravel washing only.
2. The sedimentation ponds must be non-discharging to surface water.
3. The sedimentation ponds must be reclaimed as the mining operation progresses--in accordance with the authorized Department of Environmental Quality/Land Quality Division mining plan.

JH:dcn

17-19-13

PERMIT TO CONSTRUCT

- New
- Renewal
- Modified

Permit No. 83-582R  
\* SEE SPECIAL CONDITIONS \*

Greybull Baseball Field Septic System  
(Name of Facility)

This permit hereby authorizes the applicant (name and address):

Town of Greybull

24 S. 5th St.

Greybull, WY 82426

to construct, install, or modify a septic tank - leach bed facility according to the procedures and conditions of the application No. 83-582R. The facility is located in Lot 2, Section 17, T52N, R93W in the County of Big Horn, in the State of Wyoming.

This permit shall be effective for a period of two (2) years (five (5) years maximum) from the date of issuance of this permit.

The issuance of this permit provides that the Department of Environmental Quality has evaluated and determined that the application meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the applicant, owner, or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming Department of Environmental Quality guarantees or insures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Environmental Quality Act have been met. The State assumes no liability for, and does not in any way guarantee the performance of, the permittee in the exercise of its activities allowed under this permit. The Permittee understands that it is solely responsible to any third parties for any liability arising from the construction or operation of the facility described herein. By the issuance of this permit, the State does not in any way waive its sovereign immunity.


The permittee shall allow authorized representatives from the Department of Environmental Quality, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 210 Lincoln, Lander, Wyoming 82520; telephone, 332-3144.


Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.


The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
WILLIAM L. GARLAND  
Administrator P.E. # 1479  
Water Quality Division  
December 8, 1988  
Date of Issuance



  
Director  
Dept. of Environmental Quality



This permit does not supercede the requirements for obtaining any permit from local agencies.

\* Conditions to Permit to Construct \*

This permit is issued with the intent of providing an interim on site wastewater treatment facility until such time that treatment is available through the Town of Greybull's wastewater system.

The facility authorized by this permit can be operated until the Town's system is made available. At that time, the facility authorized by this permit will be abandoned and connection made to the Town's system.

The permittee shall notify the Big Horn County Engineer of the estimated day construction will commence and the estimated day of completion of this project. Inspection of the installed system is required prior to backfilling. The authorized representative in your area can be contacted at the following address:

Herb Jenerich  
Big Horn County Engineer  
Box 228  
County Courthouse  
Basin, WY 82410  
Telephone: 5678-2566

JH/dcn/nc

REVIEW OF PLANS AND SPECIFICATIONS

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY

WATER QUALITY DIVISION  
210 LINCOLN  
LANDER, WYOMING 82520  
PHONE: (307) 332-3144

PROJECT: Greybull Baseball Field Septic System

ENGINEER: Herbert J. Jennerich  
P. O. Box 601  
Worland, WY 82401

OWNER: Town of Greybull  
24 South 5th St.  
Greybull, WY 82426

WATER QUALITY DIVISION REFERENCE NUMBER: #83-582

REVIEWING EVALUATOR: Jeff Hermansky



DATE OF REVIEW: November 15, 1983

NOTATION: Not authorized.

COMMENTS: A standard leach field should not be used when you need to place a fine sand under a disposal field to "slow down" the percolation.


The objective of this design is to force all the wastewater to percolate through the fine sand. If sand is placed under the gravel in leach trenches, then the wastewater will simply percolate out the sidewalls of the trench, thus defeating the purpose of the sand.

Therefore, a leach bed must be constructed with the fine sand forming a "bowl" under and around the gravel. This design will force all the wastewater through the fine sand.

Please note the sketch that I have enclosed for your reference. Feel free to contact me if you have any questions.

JH:dcn

AC



Herb,  
 Three feet of sand under the gravel will be unnecessary. Between 6" and 12" of sand will do the job.

JCH.

3-21-84

THE STATE



OF WYOMING

ED HERSCHLER  
GOVERNOR

*Department of Environmental Quality*  
*Water Quality Division*

1111 EAST LINCOLNWAY

CHEYENNE, WYOMING 82002

TELEPHONE 307 777-7781

March 21, 1984

Homax Oil Sales, Inc.  
605 South Poplar  
Casper, WY 82601

Gentlemen:

On February 13, 1984, a status letter was sent to you concerning a permit to construct, reference number 83-583, facility name Homax Convenience/Liquor Store. The application is considered inactive and is being returned under the assumption that the applicant does not wish to proceed with the permit to construct process.

This project has not been permitted. Construction of this facility without a permit is a violation of the Environmental Quality Act and punishable with fines not to exceed \$10,000 per day of violation. If this project has already been constructed, it is your responsibility to immediately contact this office for further instruction. If you wish to reconsider construction of this facility, then application procedures pursuant to Chapter III, Water Quality Rules & Regulations, must be followed.

Sincerely,

LeRoy C. Feusner, P.E.  
Southeast District Supervisor  
Water Quality Division

LCF/nc

cc: Ronald J. Nelson, Nelson, Melius & Assoc., 100 W "B" St., Casper, WY 82601  
Converse Co. Health Dept., 127 N. 5th St., Douglas, WY 82633



# Department of Environmental Quality



## Water Quality Division

1111 EAST LINCOLNWAY

CHEYENNE, WYOMING 82002

TELEPHONE 307 777-7781

Homax Oil Sales, Inc.  
605 S. Poplar  
Casper, WY 82601



Gentlemen:

Our records indicate your application for a permit to construct has not been resubmitted to this office for review and authorization. The specific information for your proposed project are:

Facility name:	Homax Convenience/Liquor Store
DEQ/WQD Reference Number:	83-583
Engineering Consultant:	Nelson, Meius & Assoc.
DEQ/WQD Reviewing Engineer:	Theodore D. Coyer
Date of DEQ/WQD Review:	October 5, 1983

Please indicate below the status of your application and return this form to our office:

The application will not be resubmitted as the proposed project has been cancelled.

The application will be resubmitted within 30 days.

The facility has been constructed, or is under construction. As built construction plans and specifications will be submitted within 30 days.

Other remarks \_\_\_\_\_

You are reminded that the construction, installation, or modification of any sewerage system, treatment works, disposal system, or other facility capable of causing or contributing to pollution, or public water supply system without a Permit to Construct is a violation of Wyoming State Statutes. Unless the Water Quality Division reviewing engineer receives this information within 15 days of the receipt of this letter, follow-up action will be taken.

Sincerely,



Leroy C. Feusner, P.E.  
Southeast District Supervisor  
Water Quality Division

cc: ✓ Ronald J. Nelson  
Nelson, Melius & Assoc.  
100 West "B" Street  
Casper, WY 82601

2-15-84



THE STATE OF WYOMING

ED HERSCHLER  
GOVERNOR

*Department of Environmental Quality*  
*Water Quality Division*

1111 EAST LINCOLNWAY

CHEYENNE, WYOMING 82002

TELEPHONE 307 777-7781

February 13, 1984

Homax Oil Sales, Inc.  
605 S. Poplar  
Casper, WY 82601

Gentlemen:

Our records indicate your application for a permit to construct has not been resubmitted to this office for review and authorization. The specific information for your proposed project are:

Facility name:	Homax Convenience/Liquor Store
DEQ/WQD Reference Number:	83-583
Engineering Consultant:	Nelson, Meius & Assoc.
DEQ/WQD Reviewing Engineer:	Theodore D. Coyer
Date of DEQ/WQD Review:	October 5, 1983

Please indicate below the status of your application and return this form to our office:

The application will not be resubmitted as the proposed project has been cancelled.

The application will be resubmitted within 30 days.

The facility has been constructed, or is under construction. As built construction plans and specifications will be submitted within 30 days.

Other remarks \_\_\_\_\_

You are reminded that the construction, installation, or modification of any sewerage system, treatment works, disposal system, or other facility capable of causing or contributing to pollution, or public water supply system without a Permit to Construct is a violation of Wyoming State Statutes. Unless the Water Quality Division reviewing engineer receives this information within 15 days of the receipt of this letter, follow-up action will be taken.

Sincerely,



LeRoy C. Feusner, P.E.  
Southeast District Supervisor  
Water Quality Division

cc: Ronald J. Nelson  
Nelson, Melius & Assoc.  
100 West "B" Street  
Casper, WY 82601

10-7-83

Review of Plans and Specifications

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
1111 East Lincolnway  
Cheyenne, Wyoming 82002

PROJECT: Homax Convenience and Liquor Store, Converse Co.

ARCHITECT OR ENGINEER: Ronald J. Nelson, Nelson, Melius & Assoc.  
100 W "B" St., Casper, WY 82601

APPLICANT: Homax Oil Sales, Inc.  
605 S. Poplar, Casper, WY 82601

WATER QUALITY DIVISION REFERENCE NUMBER: 83-583

REVIEWING ENGINEER: Theodore D. Coyer, P.E.



DATE OF REVIEW: October 5, 1983

ACTION: NOT AUTHORIZED FOR CONSTRUCTION

COMMENTS:

1. The septic tank and soil absorption system must be protected from vehicular traffic. It appears this will be a problem.
2. What is the depth to the seasonally high groundwater table?
3. The 6" layer of sand under the absorption system stone is not necessary. However, if you leave it, what will its percolation rate be?
4. At least two set of plans must be submitted.

cc: Gerald A. Amundsen, 226 East Second, Casper, WY 82601  
Converse Co. Health Dept., 127 North 5th St., Douglas, WY 82633

PERMIT TO CONSTRUCT

- New
- Renewal
- Modified

Permit No. 83-584

Fenway Water Line Improvements  
 (Name of Facility)

This permit hereby authorizes the applicant (name and address):

Casper Board of Public Utilities

200 N. David

Casper, WY 82601

to construct, install, or modify a municipal water distribution system facility according to the procedures and conditions of the application No. 83-584. The facility is located in NE1/4 Section 10, T33N, R79W in the County of Natrona, in the State of Wyoming. This permit shall be effective for a period of two (2) years (five (5) years maximum) from the date of issuance of this permit.

The issuance of this permit provides that the Department of Environmental Quality has evaluated and determined that the application meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the applicant, owner, or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming Department of Environmental Quality guarantees or insures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Environmental Quality Act have been met. The State assumes no liability for, and does not in any way guarantee the performance of, the permittee in the exercise of its activities allowed under this permit. The Permittee understands that it is solely responsible to any third parties for any liability arising from the construction or operation of the facility described herein. By the issuance of this permit, the State does not in any way waive its sovereign immunity.

The permittee shall allow authorized representatives from the Department of Environmental Quality, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002; telephone, 777-7781.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.


The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.


AUTHORIZED BY:

  
\_\_\_\_\_  
Administrator # 1479  
Water Quality Division



October 12, 1983  
\_\_\_\_\_  
Date of Issuance

  
\_\_\_\_\_  
Director  
Dept. of Environmental Quality



This permit does not supercede the requirements for obtaining any permit from local agencies.

cc: Russell L. Donley  
Russel L. Donley & Assoc.  
240 South Wolcott  
Casper, WY 82601

*Department of Environmental Quality**Water Quality Division*

165 EAST RAILROAD AVENUE

GREEN RIVER, WYOMING 82935

TELEPHONE 307 875-6911

February 9, 1984

David Mills  
Utah Power & Light Co.  
P. O. Box 899  
Salt Lake City, UT 84110

Re: West Dike Extension on Ash Pond No. 1 Decanting Basin  
DEQ/WQD Reference No. 83-586R

Dear Mr. Mills:

The above referenced facility plans have been reviewed and they appear to meet the minimum design standards for the State of Wyoming. A "Permit to Construct" cannot be issued owing to the fact that the facility has already been built.

Please retain this letter as verification that the dike extension has been accepted by the Wyoming Department of Environmental Quality. This letter of acceptance pertains only to the dike extension and not the deposition of dewatered ash.

The deposition and stabilization of the dewatered ash will be regulated by the DEQ/Solid Waste Division. The ash should be deposited such that the surface area of the Ash Pond No. 1 is not decreased.

If you have any questions regarding these stipulations, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script, appearing to read "Jack Bedessem".

Jack Bedessem  
Area III Supervisor

JB:mpm

cc: ~~Cheyenne DEQ/WQD~~  
F. J. Brozovich  
Marge Knight-DEQ/SWD  
File (5)



THE STATE OF WYOMING

ED HERSCHLER  
GOVERNOR

*Department of Environmental Quality*  
*Water Quality Division*

HERSCHLER BUILDING

CHEYENNE, WYOMING 82002

TELEPHONE 307 777-7781

May 16, 1986

Sun Exploration and Production  
Attn: Vernon Hale  
P.O. Box 5940 T.A.  
Denver, CO 80112

To whom it may concern:

Your statewide permit number 83-587, for small wastewater facilities has expired. If you intend to construct such facilities it will be necessary to renew your permit. Construction of facilities without the required permit is a violation of W. S. 35-11-301 (a) (iii).

Sincerely yours,

A handwritten signature in cursive script that reads "Lawrence Robinson".

Lawrence Robinson  
Engineering Supervisor

LR/nc




ing working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 165 East Railroad Ave., Green River, Wyoming 82935; telephone, 875-6911.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
*William Garland*  
\_\_\_\_\_  
William Garland  
Administrator  
Water Quality Division  
November 2, 1983  
Date of Issuance

  
*Robert E. Sundin*  
\_\_\_\_\_  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.

\* CONDITIONS OF PERMIT \*

1. At least three percolation tests must be run at each site. Determine the average percolation rate and size the leach field according to Tables 1 and 2 in the specifications.
2. The permittee shall notify the appropriate DEQ/WQD office before any system is installed. Upon abandoning the site, the system should be salvaged and the appropriate DEQ/WQD office notified.
3. The seasonal high groundwater depth must be at least 6 feet below the ground surface. If seasonal high groundwater depth is less than 6 feet, this permit will be deemed invalid for this site and the appropriate DEQ/WQD office must be notified.

JB:mpm

cc: Robert A. Harrower  
P. O. Box 67  
Pinedale, WY 82941

12-5-83

PERMIT TO CONSTRUCT

New

Renewal

Modified

Permit No. 83-588R  
SEE SPECIAL CONDITIONS

Casper Regional Solid Waste Management Facility  
(Name of Facility)

This permit hereby authorizes the applicant (name and address):

City of Casper

Department of Public Works

255 North Beech Street

Casper, WY 82601

to construct, install, or modify a industrial subsurface wastewater disposal facility according to the procedures and conditions of the application No. 83-588R. The facility is located in Section 35, T34N, R79W in the County of Natrona, in the State of Wyoming. This permit shall be effective for a period of two (2) years (five (5) years maximum) from the date of issuance of this permit.

The issuance of this permit provides that the Department of Environmental Quality has evaluated and determined that the application meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the applicant, owner, or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming Department of Environmental Quality guarantees or insures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Environmental Quality Act have been met. The State assumes no liability for, and does not in any way guarantee the performance of, the permittee in the exercise of its activities allowed under this permit. The Permittee understands that it is solely responsible to any third parties for any liability arising from the construction or operation of the facility described herein. By the issuance of this permit, the State does not in any way waive its sovereign immunity.

The permittee shall allow authorized representatives from the Department of Environmental Quality, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002; telephone, 777-7781.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
WILLIAM L. GARLAND  
Administrator # 1479  
Water Quality Division  
STATE OF WYOMING  
November 30, 1983  
Date of Issuance

  
ROBERT E. SUNDIN  
NO. 285  
REGISTERED PROFESSIONAL ENGINEER  
STATE OF WYOMING  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.

Conditions to Permit to Construct

1. The intent of the construction authorized by this permit is to provide facilities for the interim treatment of wastewater until such time that treatment is available through a regional wastewater system. The Casper Urban Water Quality Management Plan requires that treatment be provided through a regional system. The facilities authorized by this permit will be operated until services are available through the approved regional system. At that time these facilities will be abandoned or integrated into the regional system in accordance with the requirements of the Casper Urban Water Quality Management Plan and the Final 201 Facility Plan.
2. The permittee shall notify representatives of the Natrona County Health Department of the estimated day construction will commence and the estimated day of completion of this project. Inspection of the installed system is required prior to backfilling. The authorized representative in your area can be contacted at the following address:

Nix Anderson, Natrona County Health Department, 1200 East 3rd, Casper, WY 82601-2990  
Telephone: 235-9316

cc: Ronald R. Pedde, Casper Engineers, Inc., P.O. Box 3199, Gillette, WY 82716  
Charles Porter, DEQ/SWM

Review of Plans and Specifications

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
1111 East Lincolnway  
Cheyenne, Wyoming 82002

PROJECT: Casper Regional Solid Waste Management Facility, Natrona Co.

ARCHITECT OR ENGINEER: Ronald Pedde, Cooper Engineers, Inc.  
P.O. Box 3199, Gillette, WY 82716

APPLICANT: City of Casper, Dept. of Public Works  
1255 No. Beech St., Casper, WY 82601

WATER QUALITY DIVISION REFERENCE NUMBER: 83-588

REVIEWING ENGINEER: LeRoy C. Feusner, P.E. 

DATE OF REVIEW: October 18, 1983

ACTION: NOT AUTHORIZED FOR CONSTRUCTION

COMMENTS:

1. The application for the permit to construct must be signed by the owner of the facility. Resubmit application with signature of a City of Casper management person.
2. Three sets of engineering plans must be submitted to the Water Quality Division. Please provide two additional sets of plans.
3. The plans must carry the seal or signature of the design engineer who is a professional engineer licensed in the State of Wyoming.
4. The application form must also address the engineering/construction aspects of a modification to existing water supply system (i.e., installation of fire hydrant and water distribution main to facility).
5. How many vehicles/equipment items will require wash down per day in the Baling Station? What other facility/shop wastes will be disposed into this proposed system?
6. A silt/grease trap is highly recommended in the Baling Station to pretreat the wastewater prior to entering the collection/septic tank/soil absorption system to prevent plugging of the sewer line and premature filling of the initial septic tank.
7. If the wastewater generation rates are correct the soil absorption system for the Baling Station is too small. For a wastewater generation rate of 1430 gal/day and a soil percolation rate of 5 minutes/inch, a minimum soil absorption bed of 1787 square feet (0.8 gallons/day/square foot) would be required. We would accept a 40 x 40 foot bed design, not 30 x 30 feet.



THE STATE OF WYOMING

*Patterson  
Albany*

83-589

ED HERSCHLER  
GOVERNOR

*Department of Environmental Quality  
Water Quality Division*

1111 EAST LINCOLNWAY

CHEYENNE, WYOMING 82002

TELEPHONE 307 777-7781

January 12, 1984

CERTIFIED

Mr. George Riddle  
5802 South View Road  
Laramie, Wyoming 82070

Re: Construction of Wastewater  
Facilities, Letter of Violation

Dear Mr. Riddle:

On October 5, 1983, you applied for a permit to modify your subsurface wastewater treatment and disposal system to include an additional residence. On October 12, 1983, this department sent a review letter stating the proposal to be inadequate and that construction was not authorized.

On January 11, 1984, information was received by the department stating that the modification had already taken place. The modification of a wastewater facility without a permit is a violation of the Environmental Quality Act Section 35-11-301 (a) and Chapter III of the Water Quality Rules and Regulations. Since you were aware of the permitting requirements, this is considered a willful violation of state statute and thus carries a significantly higher penalty (Section 35-11-901 (j)).

To bring your system into compliance, you must respond to the review letter of October 12, 1983. If your system is not adequate, upgrading will be required.

Failure to respond promptly is not in your best interest especially since this was a willful violation. Continual lack of progress will require this matter to be turned over to the Attorney General office for enforcement.

Sincerely,

*Thomas S. Norman*

Thomas S. Norman  
Water Quality Engineer

TSN/kb

cc: Tom Curren, Albany County Planner  
LeRoy Feusner  
William E. Grenier, Assoc. Engineers, Laramie

10-17-83

Review of Plans and Specifications

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
1111 East Lincolnway  
Cheyenne, Wyoming 82002

PROJECT: Patterson - Modified, Albany Co.

ARCHITECT OR ENGINEER: William E. Grenier, Associated Engineers  
609 So. 2nd St., Laramie, WY 82070

APPLICANT: George D. Riddle  
5802 So. View Road, Laramie, WY 82070

WATER QUALITY DIVISION REFERENCE NUMBER: 83-589

REVIEWING ENGINEER: Thomas S. Norman *T S Norman*

DATE OF REVIEW: October 12, 1983

ACTION: NOT AUTHORIZED FOR CONSTRUCTION

COMMENTS:

1. The plan sheet did not show the location and measurements of both trailers, service lines, wells, property lines, water ways, etc.
2. The initial permit showed a drain field of 3 lines of only 80 lineal feet with an 18 inch width per trench. Now the as builts show a totally different system. Documentation must be provided that either the engineer has personally documented the new lengths and widths or provide receipts of pipe and trench rock quantities.
3. What is the 20-30 feet depth to on the check sheet? Is it to the seasonal high groundwater table or is it to the impervious layer? How was this determined?

PERMIT TO CONSTRUCT

- New
- Renewal
- Modified

Permit No. 83-590  
SEE SPECIAL CONDITION

Security Storage  
(Name of Facility)

This permit hereby authorizes the applicant (name and address):

Cheyenne Board Of Public Utilities

2100 Pioneer Ave.

Cheyenne, WY 82001

to construct, install, or modify a potable water main facility according to the procedures and conditions of the application No. 83-590. The facility is located in Section 29, T14N, R66W in the County of Laramie, in the State of Wyoming. This permit shall be effective for a period of two (2) years (five (5) years maximum) from the date of issuance of this permit.

The issuance of this permit provides that the Department of Environmental Quality has evaluated and determined that the application meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the applicant, owner, or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming Department of Environmental Quality guarantees or insures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Environmental Quality Act have been met. The State assumes no liability for, and does not in any way guarantee the performance of, the permittee in the exercise of its activities allowed under this permit. The Permittee understands that it is solely responsible to any third parties for any liability arising from the construction or operation of the facility described herein. By the issuance of this permit, the State does not in any way waive its sovereign immunity.



The permittee shall allow authorized representatives from the Department of Environmental Quality, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002; telephone, 777-7781.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:



William L. Garland  
Administrator  
Water Quality Division  
October 13, 1983  
Date of Issuance

Robert E. Sturgeon  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.

Condition to Permit to Construct

The fill soil shall be placed and properly compacted on this site prior to installing the water main. Special care shall be used to prevent cave-in when excavating the trenches in the fill soil.

cc: Jon L. Anderson  
AVI  
7300 Yellowstone Rd.  
Cheyenne, WY 82009




ing working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 165 East Railroad Ave., Green River, Wyoming 82935; telephone, 875-6911.


Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.


The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
WILLIAM L. GARAND  
Administrator  
Water Quality Division  
E # 1479  
January 3, 1987  
Date of Issuance



  
ROBERT E. SUNDIN  
Director  
Dept. of Environmental Quality



This permit does not supercede the requirements for obtaining any permit from local agencies.

JB:mpm

cc: Duane Fehring  
Western Engineers-Architects, Inc.  
501 N. Sun Drive  
Casper, WY 82609




ing working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 165 East Railroad Ave., Green River, Wyoming 82935; telephone, 875-6911.


Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.


The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:



  
WILLIAM L. GARLAND  
Administrator  
Water Quality Division #1479  
November 2, 1983  
Date of Issuance



  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.

\* CONDITIONS OF PERMIT \*

The permittee shall notify representatives of the Uinta County Planning Office of the estimated day construction will commence and the estimated day of completion of this project. Inspection of the installed system is required prior to back-filling. The authorized representative in your area can be reached at the following address:

William Gates  
Uinta County Sanitarian  
P. O. Box 895  
Evanston, WY 82930  
789-9387

JB:mpm

cc: Harry J. Kessner  
Bennett-Carder & Assoc, Inc.  
507 5th Street  
Rock Springs, WY 82901

PERMIT TO CONSTRUCT

- New
- Renewal
- Modified

Permit No. 83-593  
SEE SPECIAL CONDITION

Dry Creek North  
(Name of Facility)

This permit hereby authorizes the applicant (name and address):

Cheyenne Board of Public Utilities

2100 Pioneer Ave.

Cheyenne, WY 82001

to construct, install, or modify a sanitary sewer and potable water main facility according to the procedures and conditions of the application No. 83-593. The facility is located in Section 19, T14N, R66W in the County of Laramie, in the State of Wyoming. This permit shall be effective for a period of two (2) years (five (5) years maximum) from the date of issuance of this permit.

The issuance of this permit provides that the Department of Environmental Quality has evaluated and determined that the application meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the applicant, owner, or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming Department of Environmental Quality guarantees or insures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Environmental Quality Act have been met. The State assumes no liability for, and does not in any way guarantee the performance of, the permittee in the exercise of its activities allowed under this permit. The Permittee understands that it is solely responsible to any third parties for any liability arising from the construction or operation of the facility described herein. By the issuance of this permit, the State does not in any way waive its sovereign immunity.


The permittee shall allow authorized representatives from the Department of Environmental Quality, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002; telephone, 777-7781.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:



A circular seal for a Registered Professional Engineer. The outer ring contains the text "REGISTERED PROFESSIONAL ENGINEER" at the top and "STATE OF WYOMING" at the bottom, separated by two stars. The inner circle contains the name "WILLIAM GARDNER".  
*William Gardner*  
\_\_\_\_\_  
Administrator  
Water Quality Division

*Robert E. Sunden*  
\_\_\_\_\_  
Director  
Dept. of Environmental Quality

October 12, 1983  
\_\_\_\_\_  
Date of Issuance

This permit does not supercede the requirements for obtaining any permit from local agencies.

cc: Peter J. Hutchison  
Intermountain Professional Services  
2206 Pioneer Ave.  
Cheyenne, WY 82001

Condition to Permit to Construct

An air release valve or fire hydrant should be provided at all high points of the water main.

3-20-84

PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

Permit No. 83-594R

South Fork Mobile Home Subdivision  
(Name of Facility)

This permit hereby authorizes the applicant (name and address):

William J. Edwards

504 Edwards Drive

Cheyenne, WY 82009

to construct, install, or modify a public water supply distribution and wastewater collection facility according to the procedures and conditions of the application No. 83-594R. The facility is located in NW1/4 Section 20, T13N, R60W in the County of Laramie, in the State of Wyoming. This permit shall be effective for a period of two (2) years (five (5) years maximum) from the date of issuance of this permit.

The issuance of this permit provides that the Department of Environmental Quality has evaluated and determined that the application meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the applicant, owner, or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming Department of Environmental Quality guarantees or insures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Environmental Quality Act have been met. The State assumes no liability for, and does not in any way guarantee the performance of, the permittee in the exercise of its activities allowed under this permit. The Permittee understands that it is solely responsible to any third parties for any liability arising from the construction or operation of the facility described herein. By the issuance of this permit, the State does not in any way waive its sovereign immunity.


The permittee shall allow authorized representatives from the Department of Environmental Quality, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002; telephone, 777-7781.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
*William L. Garland*  
WILLIAM L. GARLAND  
Administrator PE #1479  
Water Quality Division  
March 7, 1984  
Date of Issuance

  
*Robert E. Sunden*  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.

cc: James Voeller  
AVI Engineers  
1700 Westland Road  
Cheyenne, WY 82001

2-15-84

THE STATE OF WYOMING



ED HERSCHLER  
GOVERNOR

*Department of Environmental Quality*  
*Water Quality Division*

1111 EAST LINCOLNWAY

CHEYENNE, WYOMING 82002

TELEPHONE 307 777-7781

February 13, 1984

Mr. William J. Edwards  
504 Edwards Drive  
Cheyenne, WY 82009

Dear Mr. Edwards:

Our records indicate your application for a permit to construct has not been resubmitted to this office for review and authorization. The specific information for your proposed project are:


Facility name:	South Fork Mobile Home Park
DEQ/WQD Reference Number:	<u>83-594</u>
Engineering Consultant:	James Voeller, AVI Engineers
DEQ/WQD Reviewing Engineer:	LeRoy C. Feusner
Date of DEQ/WQD Review:	October 18, 1983

Please indicate below the status of your application and return this form to our office:

- The application will not be resubmitted as the proposed project has been cancelled.
- The application will be resubmitted within 30 days.
- The facility has been constructed, or is under construction. As built construction plans and specifications will be submitted within 30 days.
- Other remarks \_\_\_\_\_

You are reminded that the construction, installation, or modification of any sewerage system, treatment works, disposal system, or other facility capable of causing or contributing to pollution, or public water supply system without a Permit to Construct is a violation of Wyoming State Statutes. Unless the Water Quality Division reviewing engineer receives this information within 15 days of the receipt of this letter, follow-up action will be taken.

Sincerely,



LeRoy C. Feusner, P.E.  
Southeast District Supervisor  
Water Quality Division

cc: James Voeller  
AVI Engineers  
7300 Yellowstone Rd.  
Cheyenne, WY 82009

10-19-83

Review of Plans and Specifications


WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
1111 East Lincolnway  
Cheyenne, Wyoming 82002

PROJECT: South Fork MHP Subdiv., Laramie Co.

ARCHITECT OR ENGINEER: James D. Voeller, AVI Engineers  
7300 Yellowstone Rd., Cheyenne, WY 82009

APPLICANT: William J. Edwards  
504 Edwards Dr., Cheyenne, WY 82009

WATER QUALITY DIVISION REFERENCE NUMBER: 83-594

REVIEWING ENGINEER: LeRoy C. Feusner, P.E. 

DATE OF REVIEW: October 18, 1983

ACTION: NOT AUTHORIZED FOR CONSTRUCTION

COMMENTS:

1. Provide a letter from the South Cheyenne Water & Sewer District indicating that they can adequately supply potable drinking water at a minimum water pressure of 20 psi under all conditions of flow for this mobile home park subdivision.
2. Provide a letter from the South Cheyenne Water & Sewer District indicating that they have adequate sewer main capacity to transport the wastewater, and that they have adequate wastewater treatment capacity at their plant to handle the additional loading of this project.
3. Provide a detail construction drawing (riser construction, etc.) of the individual sewer/water hookups at each location. It may be a typical drawing but must include all information specified in Chapter III, Wyoming Water Quality Rules and Regulations.



*Department of Environmental Quality*  
*Water Quality Division*

HERSCHLER BUILDING

CHEYENNE, WYOMING 82002

TELEPHONE 307 777-7781

May 16, 1986

Chevron USA Inc.  
P.O. Box 599  
Denver, CO 80201

To whom it may concern:

Your statewide permit number 83-595, for small wastewater facilities, contains a condition requiring the notification of the appropriate county or state agency prior to the installation or abandonment of facilities authorized by the permit.

A review of state and county records indicates that very few of these facilities are being reported. It is important that these facilities be reported on a regular basis. County governments have agreed to the use of statewide permits on the condition that they be properly notified. If the statewide permitting system is not responsive to the needs of the counties, the state will not be able to issue statewide permits and it will be necessary to obtain permits for such facilities with the individual counties.

In order to address this problem you are requested to do the following:

1. Provide this office a list and location of all facilities constructed under your statewide permit.
2. Indicate the present status of each facility, i.e., operational or abandoned.
3. Indicate whether or not you wish to maintain the statewide permit in an active status.
4. Provide the required notification to both the appropriate county and state agency for all future facilities.

Sincerely yours,

A handwritten signature in cursive script that reads "Lawrence Robinson".

Lawrence Robinson  
Engineering Supervisor

LR/nc



ing working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 210 Lincoln, Lander, Wyoming 82520; telephone, 332-3144.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
Administrator  
Water Quality Division  
September 16, 1985  
Date of Issuance



  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.

\* CONDITION ON PERMIT \*

1. The permit is valid for temporary construction camps only. Temporary being defined as one year or less. If a proposed construction camp is to be operated for more than one year, that camp must obtain authorization from this department.
2. The permittee shall notify the appropriate county and state agency prior to the installation, removal or abandonment of any facility authorized by this permit. The appropriate agency for each county is indicated in the attached list. Notification shall be by phone with a follow-up written notice. Upon abandoning the site, the facility will be removed, disposed of, or left in place in a condition rendering the site safe for the public. Any waste from the facility shall be disposed of only in areas and in a manner approved by the appropriate agency. Upon request, the permittee shall allow authorized representatives of the local agency or the State to have access to the authorized facility for the purpose of conducting an inspection to determine compliance with the provisions of this permit.
3. A set of the approved plans shall be supplied to each county agency in which a temporary facility is to be located. This shall be done prior to commencement of construction of said facility.

AGENCIES RESPONSIBLE FOR SMALL WASTEWATER PERMITS

1. Albany County  
Albany County Planning Office  
405 Grand Avenue  
Laramie, WY 82070  
Phone: (307) 721-5188
2. Big Horn County  
Big Horn County Engineer  
P.O. Box 31  
County Courthouse  
Basin, WY 82410  
Phone: (307) 568-2358
3. Campbell County  
Campbell County Engineer  
500 South Gillette Avenue  
Gillette, WY 82716  
Phone: (307) 682-1970
4. Carbon County  
District Supervisor  
Water Quality Division  
Department of Environmental Quality  
Herschler Bldg. - 4th West  
Cheyenne, WY 82002  
Phone: (307) 777-7781
5. Converse County  
Converse County Sanitarian  
County Health Department  
530 Oak  
Douglas, WY 82633  
Phone: (307) 358-2536
6. Crook County  
District Supervisor  
Water Quality Division  
Department of Environmental Quality  
2161 Coffeen Avenue  
Sheridan, WY 82801  
Phone: (307) 672-6457
7. Fremont County  
Fremont County Planner  
Room 200, County Courthouse  
Lander, WY 82520  
Phone: (307) 332-5371
8. Goshen County  
Goshen County Sanitarian  
P.O. Box 1132  
County Courthouse  
Torrington, WY 82240  
Phone: (307) 532-5002
9. Hot Springs County  
Hot Springs County Planner  
County Courthouse  
Thermopolis, WY 82443  
Phone: (307) 864-2732
10. Johnson County  
Johnson County Sanitarian  
County Courthouse  
Buffalo, WY 82834  
Phone: (307) 684-7555
11. Laramie County  
Laramie County Environmental Health  
1700 Snyder Avenue  
Cheyenne, WY 82001  
Phone: (307) 638-8545
12. Lincoln County  
Office of Planning and Development  
P.O. Box 414  
Afton, WY 83110  
Phone: (307) 886-3825
13. Natrona County  
Environmental Health Division  
Natrona County Health Department  
1200 East 3rd  
Casper, WY 82601-2990  
Phone: (307) 235-9316
14. Niobrara County  
District Supervisor  
Water Quality Division  
Department of Environmental Quality  
2161 Coffeen Avenue  
Sheridan, WY 82801  
Phone: (307) 672-6457

15. Park County  
Park County Planning Coordinator  
P.O. Box 160  
Cody, WY 82414  
Phone: (307) 587-2208
16. Platte County  
Platte County Sanitarian  
P.O. Box 55  
Wheatland, WY 82210  
Phone: (307) 322-9571
17. Sheridan County  
Sheridan County Engineer  
P.O. Box 612  
Sheridan, WY 82801  
Phone: (307) 672-3426
18. Sublette County  
Sublette County Planner  
P.O. Box 506  
Pinedale, WY 82941  
Phone: (307) 367-4375
19. Sweetwater County  
Sweetwater County Sanitarian  
205 East Railroad Ave.  
Green River, WY 82935  
Phone: (307) 875-2611 Ext. 278
20. Teton County  
Teton County Sanitarian  
P.O. Box 1727  
Jackson, WY 83001  
Phone: (307) 733-3959
21. Uinta County  
Uinta County Engineer  
225 9th Street  
Evanston, WY 82930  
Phone: (307) 789-1780 ext. 318
22. Washakie County  
Washakie County Planner  
County Courthouse  
Worland, WY 82401  
Phone: (307) 347-2741
23. Weston County  
District Supervisor  
Water Quality Division  
Department of Environmental Quality  
2161 Coffeen Avenue  
Sheridan, WY 82801  
Phone: (307) 672-6457





during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 210 Lincoln, Lander, Wyoming 82520; telephone, 332-3144.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
WILLIAM L. GARLAND  
Administrator  
Water Quality Division  
P.E. #1479  


  
ROBERT E. SUNDIN  
Director  
Dept. of Environmental Quality  


October 14, 1983

Date of Issuance

This permit does not supercede the requirements for obtaining any permit from local agencies.

\* CONDITIONS ON PERMIT \*

This Permit is authorized with the requirement that the following conditions be followed:

1. At no time can the holding tanks be permitted to discharge. A discharge would be a violation of the Environmental Quality Act.
2. The appropriate Department of Environmental Quality, Water Quality Division, must be notified prior to the placement and operation of the holding tanks on any drill site.

JH:dcn

PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

Permit No. 83-595

\* CONDITIONS ON PERMIT \*

CHEVRON U.S.A. - STATEWIDE SEWAGE HOLDING TANKS  
(Name of Facility)

This permit hereby authorizes the applicant (name and address):

Chevron U.S.A., Inc.

P. O. Box 599

Denver, CO 80201

to construct, install, or modify a sewage holding tanks for well drilling sites

facility according to the procedures and conditions of the application No. 83-595. The facility is located in STATEWIDE

STATEWIDE

in the County of STATEWIDE, in the State of Wyoming. This permit shall be effective for a period of two (2) years (five (5) years maximum) from the date of issuance of this permit.

The issuance of this permit provides that the Department of Environmental Quality has evaluated and determined that the application meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the applicant, owner, or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming Department of Environmental Quality guarantees or insures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Environmental Quality Act have been met. The State assumes no liability for, and does not in any way guarantee the performance of, the permittee in the exercise of its activities allowed under this permit. The Permittee understands that it is solely responsible to any third parties for any liability arising from the construction or operation of the facility described herein. By the issuance of this permit, the State does not in any way waive its sovereign immunity.

The permittee shall allow authorized representatives from the Department of Environmental Quality, Water Quality Division, upon the presentation of credentials and


L.L.K. OCT 31 '83

during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit. The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 210 Lincoln, Lander, Wyoming 82520; telephone, 332-3144.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:



Director  
Dept. of Environmental Quality

October 14, 1983

Date of Issuance


\* CONDITIONS ON PERMIT \*

This Permit is authorized with the requirement that the following conditions be followed:

1. At no time can the holding tanks be permitted to discharge. A discharge would be a violation of the Environmental Quality Act.
2. The appropriate Department of Environmental Quality, Water Quality Division, must be notified prior to the placement and operation of the holding tanks on any drill site.

JH:dcn

March 19, 1984



CHEVRON U.S.A. INC. DRILLING SITE  
SEWAGE DISPOSAL NOTICE FOR THE  
DEPARTMENT OF ENVIRONMENTAL QUALITY

WYOMING DRILLING SITE LOCATION NO: Chevron-Gulf 2-19M

SECTION 19 TOWNSHIP 19N RANGE 119W  
Lincoln County, Wyoming

WASTEWATER DISPOSAL CONTRACTING FIRM: Dalbo Trucking Company

MAILING ADDRESS \_\_\_\_\_

Box 938

CITY Evanston STATE WY ZIP 82930

WASTEWATER DISPOSAL FREQUENCY PER WEEK: 2 times each week

WASTEWATER VOLUME DISPOSED PER WEEK: 2,000 to 5,000 gallons each week

FINAL WASTEWATER DISPOSAL DESTINATION: City of Evanston,  
Evanston, Wyoming

PROJECTED COMPLETION DATE: February 1985

Chevron U.S.A. Inc.  
P.O. Box 599  
Denver, CO 80201

Department of Environmental Quality  
State Wide Sewage Permit #83-595

- 3 - DEQ Green River
- 2 - Lincoln County Comm., Afton, Wyoming
- 2 - Larry Lee
- 1 - J. J. Johnson
- 1 - R. B. Northrop
- 1 - File

10-20-83

PERMIT TO CONSTRUCT

Permit No. 83-596

SEE CONDITIONS ATTACHED TO THIS PERMIT

- New
- Renewal
- Modified

Klabzuba 1-30 Federal  
(Name of Facility)

This permit hereby authorizes the applicant (name and address):

Robert Klabzuba

c/o Don E. Lawson

254 N. Center, Suite 100

Casper, WY 82601

to construct, install, or modify a drilling fluid reserve pit facility according to the procedures and conditions of the application No. 83-596. The facility is located in NE1/4 SW1/4 Section 30, T33N, R98W in the County of Fremont, in the State of Wyoming. This permit shall be effective for a period of one year (five (5) years maximum) from the date of issuance of this permit.

The issuance of this permit provides that the Department of Environmental Quality has evaluated and determined that the application meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the applicant, owner, or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming Department of Environmental Quality guarantees or insures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Environmental Quality Act have been met. The State assumes no liability for, and does not in any way guarantee the performance of, the permittee in the exercise of its activities allowed under this permit. The Permittee understands that it is solely responsible to any third parties for any liability arising from the construction or operation of the facility described herein. By the issuance of this permit, the State does not in any way waive its sovereign immunity.



The permittee shall allow authorized representatives from the Department of Environmental Quality, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.



The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002; telephone, 777-7781.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
  
WILLIAM C. GARLAND  
No. 1479  
Administrator  
Water Quality Division  
STATE OF WYOMING  
October 14, 1988  
Date of Issuance

  
  
ROBERT E. SUNDIN  
NO. 285  
Director  
Dept. of Environmental Quality  
STATE OF WYOMING

This permit does not supercede the requirements for obtaining any permit from local agencies.

This permit authorizes you to dispose of 23,400 gallons of drilling fluid wastewater on the surrounding one acre or at \_\_\_\_\_, comprising \_\_\_\_\_ acres, a total liquid application of 0.86 inches.

CONDITIONS TO PERMIT TO CONSTRUCT

1. Wastewater shall be applied at a rate which will not produce runoff or ponding. Application shall not be initiated during the spring runoff period or other periods where saturated soil conditions exist.
2. The application site slope shall not exceed 8% for vehicular application or 15% for spray irrigation or irrigation by gated pipe on the contour. Vegetated areas of the site shall not be spray-irrigated where possible plant leaf injury may result from salt residue.
3. Wastewater application shall be terminated within 300 feet of the defineable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
4. To assess the long term effects of the wastewater application on the soil and its relation to revegetation success on denuded areas, the seed mix (% of selected species), seed rate (lbs. of bulk seed/acre and % pure live seed), mulch and fertilizer preferred by the landowner-lessee or land management agency should be forwarded to E. J. Fanning, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002, within 30 days of receipt of this permit. Not applicable to this permit.
5. This permit is issued based on verbal agreement that the pit water will be spray-irrigated or surface-applied to the surrounding site at a controlled rate rather than discharged to the adjacent draw.

11-18-53

PERMIT TO CONSTRUCT

Permit No. 83-597  
SEE SPECIAL CONDITION

New  
 Renewal  
 Modified

Saratoga Water Treatment System  
(Name of Facility)

This permit hereby authorizes the applicant (name and address):

Town of Saratoga

P.O. Box 486

Saratoga, WY 82331

to construct, install, or modify a new river water intake and backwash pond facility according to the procedures and conditions of the application No. 83-597. The facility is located in Section 11, T17N, R84W in the County of Carbon, in the State of Wyoming. This permit shall be effective for a period of two (2) years (five (5) years maximum) from the date of issuance of this permit.

The issuance of this permit provides that the Department of Environmental Quality has evaluated and determined that the application meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the applicant, owner, or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming Department of Environmental Quality guarantees or insures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Environmental Quality Act have been met. The State assumes no liability for, and does not in any way guarantee the performance of, the permittee in the exercise of its activities allowed under this permit. The Permittee understands that it is solely responsible to any third parties for any liability arising from the construction or operation of the facility described herein. By the issuance of this permit, the State does not in any way waive its sovereign immunity.


The permittee shall allow authorized representatives from the Department of Environmental Quality, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002; telephone, 777-7781.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
\_\_\_\_\_  
WILLIAM L. GARLAND  
Administrator  
Water Quality Division  
  
November 4, 1983  
Date of Issuance

  
\_\_\_\_\_  
ROBERT E. SUNDIN  
Director  
Dept. of Environmental Quality  


This permit does not supercede the requirements for obtaining any permit from local agencies.

cc: Russell L. Donley  
Russell L. Donley & Assoc.  
240 S. Wolcott, Suite 202  
Casper, WY 82602

CONDITION TO PERMIT TO CONSTRUCT

The interior slopes of the backwash pond and the river bank in the area of the backwash pond shall be rip-rapped. A Corps of Engineers permit may be required for the river rip-rap.




ing working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 165 East Railroad Ave., Green River, Wyoming 82935; telephone, 875-6911.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
WILLIAM L. GARLAND  
Administrator P.E. # 1479  
Water Quality Division  
STATE OF WYOMING  
November 7, 1983  
Date of Issuance

  
ROBERT E. SUNDIR  
NO. 285  
REGISTERED PROFESSIONAL ENGINEER  
STATE OF WYOMING  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.

JB:mpm

cc: Stan deSousa  
Pacific Power & Light  
920 S.W. Sixth Avenue  
Portland, OR 97204

1-1-83

PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

Permit No. 83-599

Natrona County Junior High School  
(Name of Facility)

This permit hereby authorizes the applicant (name and address):

Casper Board of Public Utilities

200 North David St.

Casper, WY 82601

to construct, install, or modify a municipal water distribution and wastewater collection facility according to the procedures and conditions of the application No. 83-599. The facility is located in Section 13, T33N, R79W in the County of Natrona, in the State of Wyoming. This permit shall be effective for a period of two (2) years (five (5) years maximum) from the date of issuance of this permit.

The issuance of this permit provides that the Department of Environmental Quality has evaluated and determined that the application meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the applicant, owner, or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming Department of Environmental Quality guarantees or insures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement of the construction or the design of the facility described herein. This permit indicates only that standards of design and construction required by the Environmental Quality Act have been met. The State assumes no liability for, and does not in any way guarantee the performance of, the permittee in the exercise of its activities allowed under this permit. The Permittee understands that it is solely responsible to any third parties for any liability arising from the construction or operation of the facility described herein. By the issuance of this permit, the State does not in any way waive its sovereign immunity.

The permittee shall allow authorized representatives from the Department of Environmental Quality, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 1111 East Lincolnway, Cheyenne, Wyoming 82002; telephone, 777-7781.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

*William P. Garland*  
\_\_\_\_\_  
REGISTERED PROFESSIONAL ENGINEER  
WILLIAM P. GARLAND  
Administrator  
Water Quality Division  
PS # 1479  
OCTOBER 21 1983  
Date of Issuance  
STATE OF WYOMING

*Robert E. Sundin*  
\_\_\_\_\_  
REGISTERED PROFESSIONAL ENGINEER  
ROBERT E. SUNDIN  
NO. 285  
STATE OF WYOMING  
Director  
Dept. of Environmental Quality

This permit does not supercede the requirements for obtaining any permit from local agencies.

cc: John E. Donmyer  
HNTB  
P.O. Box 3478  
Casper, WY 82602




during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.



The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, Department of Environmental Quality, Water Quality Division, 2161 Coffeen Avenue, Suite 301, Sheridan, Wyoming 82801; telephone, 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of Federal, State or local laws or regulations.

AUTHORIZED BY:

  
\_\_\_\_\_  
Administrator  
Water Quality Division  
November 17, 1988  
Date of Issuance  


  
\_\_\_\_\_  
Director  
Dept. of Environmental Quality  


This permit does not supercede the requirements for obtaining any permit from local agencies.

xc: McDill Engineering  
400 W. Boxelder Road  
Gillette, WY 82716