

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 95-400
SPECIAL CONDITIONS

Dale G. Richert Septic Tank and Leach Field

This permit hereby authorizes the applicant:

Dale G. Richert
HCR 77 Box 187
Thermopolis, Wyoming 82443

to construct a residential septic tank and leach field according to the procedures and conditions of the application number 95-400. The facility is located in SE 1/4 of Sec. 11, T42N, R95W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any portion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/13/95
Date of Issuance

MDR/mad 54021.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-400

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

Not Applicable

V. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 8 September 1995.

Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 95-401
SPECIAL CONDITIONS

Richard H. Groh Septic Tank and Leachfield

This permit hereby authorizes the applicant:

Richard H. Groh
461 Hwy 20 North
Thermopolis, Wyoming 82443

to construct a septic tank and leach field according to the procedures and conditions of the application number 95-401. The facility is located in the NE 1/4 of Sec. 18, T43N, R94W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/13/95
Date of Issuance

MDR/mad 54020.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-401

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

Not Applicable

V. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 8 September 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 95-402
SPECIAL CONDITIONS

Wyoming Regional Shopping Center

This permit hereby authorizes the applicant:

Larry Small, JJLC Management Company, Inc.
P. O. Box 157
Big Horn, Wyoming 82833

to construct a PVC sewer line and a PVC water line together with appurtenances according to the procedures and conditions of the application number 95-402. The facility is located in SE1/4 of Sec. 22, T1N, R4E in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/13/95

Date of Issuance

MDR/mad 54017.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-402

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

- VI. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 8 September 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.



STATE OF WYOMING



JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

February 4, 1998

Mr. Wilford J. Flyte
P O Box 5265
Cheyenne, WY 82007

RE: Application 95-403

Dear Mr. Flyte:

Your application is considered inactive and is being returned under the assumption that the applicant does not wish to proceed with the permit to construct permitting process.

This project has not been permitted. Construction of this facility without a permit is a violation of the Environmental Quality Act and is punishable with fines not to exceed \$10,000 per day of violation. If this project has already been constructed, it is your responsibility to immediately contact this office for further information. If you wish to reconsider construction of this facility, then application procedures pursuant to Chapter III, Wyoming Water Quality Rules and Regulations must be followed.

Sincerely,

Ron L. Ewald
District Engineer

RLE/mad 80388.LTR
cc: IPS



THE STATE OF WYOMING

JIM GERINGER
GOVERNOR

RECEIVED

FEB 2 1998



WATER QUALITY DIVISION
WYOMING

Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

CERTIFIED

January 28, 1998

Mr. Wilford J. Flyte
P.O. Box 5265
Cheyenne, Wyoming 82003

RE: **Unpermitted Facility/Non Response to Review: Application # 95-403**

Dear Mr. Flyte:

Our records indicate your application for permit to construct has not been resubmitted to this office for review and authorization. The specific information for your proposed project is:

Facility Name:	Flyte Sanitation - Commercial Septic System
DEQ/WQD Reference Number:	95-403
Engineering Consultant:	Rick Johnston, Gust & Johnston
DEQ/WQD Reviewing Engineer:	Ronald L. Ewald
Date of DEQ/WQD Review:	September 15, 1995

According to Chapter III of the Water Quality Rules and Regulations, Section 7(b)(2), "If an application is denied because of incompleteness necessitating a request for additional information, the applicant shall have a maximum of six months to comply with the request. If the applicant fails to provide the requested information within that period, the entire incomplete application shall be returned."

Please indicate below the status of your application and return this form to our office:

The application will not be resubmitted as the proposed project has been canceled.

The application will be resubmitted within 30 days.

The facility has been constructed, or is under construction. As built construction plans and specifications will be submitted within 30 days.

Other/Remarks: We looked into Southside WATER + Sewer in Dec '95. address: 410 Cty Rd 128A

Mr. Flyte
January 28, 1998
Page 2

You are reminded that the construction, installation, or modification of any sewerage system, treatment works, disposal system, or other facility capable of causing or contributing to pollution, or public water supply system without a Permit to Construct is a violation of Wyoming State Statutes. Unless the Water Quality Division review engineer receives information concerning the status of this project within 15 days of the receipt of this letter, follow-up action will be undertaken.

Sincerely,

A handwritten signature in cursive script that reads "Ronald L. Ewald".

Ronald L. Ewald
Senior Analyst
SE District/Water Quality Division

RLE/bb/80297.ltr

cc: IPS



THE STATE OF WYOMING



JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

CERTIFIED

January 28, 1998

Mr. Wilford J. Flyte
P.O. Box 5265
Cheyenne, Wyoming 82003

RE: **Unpermitted Facility/Non Response to Review: Application # 95-403**

Dear Mr. Flyte:

Our records indicate your application for permit to construct has not been resubmitted to this office for review and authorization. The specific information for your proposed project is:

Facility Name:	Flyte Sanitation - Commercial Septic System
DEQ/WQD Reference Number:	95-403
Engineering Consultant:	Rick Johnston, Gust & Johnston
DEQ/WQD Reviewing Engineer:	Ronald L. Ewald
Date of DEQ/WQD Review:	September 15, 1995

According to Chapter III of the Water Quality Rules and Regulations, Section 7(b)(2), "If an application is denied because of incompleteness necessitating a request for additional information, the applicant shall have a maximum of six months to comply with the request. If the applicant fails to provide the requested information within that period, the entire incomplete application shall be returned."

Please indicate below the status of your application and return this form to our office:

The application will not be resubmitted as the proposed project has been canceled.

The application will be resubmitted within 30 days.

The facility has been constructed, or is under construction. As built construction plans and specifications will be submitted within 30 days.

Other/Remarks: _____

Mr. Flyte
January 28, 1998
Page 2

You are reminded that the construction, installation, or modification of any sewerage system, treatment works, disposal system, or other facility capable of causing or contributing to pollution, or public water supply system without a Permit to Construct is a violation of Wyoming State Statutes. Unless the Water Quality Division review engineer receives information concerning the status of this project within 15 days of the receipt of this letter, follow-up action will be undertaken.

Sincerely,

A handwritten signature in cursive script that reads "Ronald L. Ewald".

Ronald L. Ewald
Senior Analyst
SE District/Water Quality Division

RLE/bb/80297.ltr

cc: IPS

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
Herschler Bldg., 4 West
Cheyenne, Wyoming 82002

PROJECT: Flyte Sanitation - Commercial Septic System

ENGINEER: Rick Johnston
Gust & Johnston
2232 Del Range, Suite 203
Cheyenne, Wyoming 82009

APPLICANT: Wilford J. Flyte
P.O. Box 5265
Cheyenne, Wyoming 82003

WATER QUALITY REFERENCE NUMBER: 95-403

REVIEWING ENGINEER: Ronald L. Ewald *RLE*

DATE OF REVIEW: September 15, 1995

ACTION: NOT AUTHORIZED FOR CONSTRUCTION

COMMENTS, PROBLEMS, INADEQUACIES, and QUESTIONS:

1. The location for the replacement leach field area is not indicated on the plans.
2. This site is near Crow Creek. Where exactly is Crow Creek relative to this property?
3. How was the depth of 7.2 feet to groundwater determined?
4. "201" Exemption Required Before Permit can be Issued - This site is within the "201" plan area for the Cheyenne public wastewater treatment and collection system; therefore, a permit for a septic system Can Not be issued until an exemption from hooking up to the public wastewater system is obtained. To apply for a "201" Exemption contact Gary Hickman of the Laramie County Environmental Health Division at 100 Central Avenue, Cheyenne, Wyoming, or by phone at 633-4090. Please note that this site is in an area where several other recent applications for an exemption have been denied; therefore, it may not be a given that an exemption will be granted.

RLE/nc 54109.LTR

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 95-404
 SPECIAL CONDITIONS

Albin Water & Sewer Line Extensions

This permit hereby authorizes the applicant:

Town of Albin
P.O. Box 188
Albin, WY 82050

to construct an extension to the existing distribution and collection systems according to the procedures and conditions of the application number 95-404. The facility is located in NW 1/4 Section 29, T17N, R60W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/13/95

Date of Issuance

GLS/mad 54031.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-404

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

N/A

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on September 12, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-405
SPECIAL CONDITIONS

Anschutz Ranch East Gas Plant Leak Detection Wells

This permit hereby authorizes the applicant:

Amoco Production Co.
Anschutz Ranch East
P.O. Box 829
Evanston, WY 82931

to construct leak detection wells according to the procedures and conditions of the application number 95-405. The facility is located in NW¼ S35 T13N R121W in the county of Uinta, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any infringement of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 10 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 10 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 10 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 10 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
5. of 10 After the monitoring wells have fulfilled their useful purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. No monitoring well shall be abandoned without approval from the Water Quality Division.
6. of 10 The WDEQ/WQD S.W. District office, 250 Lincoln Street, Lander, WY 82520, (307) 332-3144, shall be given at least two (2) weeks notice prior to the installation of monitor wells so that they may be on site if deemed necessary.
7. of 10 Records of monitoring information shall be maintained by the permittee for a period of at least three (3) years. Monitoring information records shall include:
 - a. The date, exact place, and time of sampling or measurements;
 - b. The name(s) of individual(s) who performed the sampling or measurements;
 - c. Sampling procedures and sample preservation accomplished;
 - d. The date(s) analyses were performed, the analytical techniques or methods used, the names of individuals who performed the analyses, and the results of such analyses.

- e. Monitor wells shall be monitored for the presence of fluids and sampled for potential contaminants.

8. of 10 The WDEQ/WQD S.W. District office shall be contacted if fluids are detected in the leak detection monitoring wells. A sampling plan shall be submitted and shall be subject to approval by the WDEQ/WQD. If no fluids are detected an annual report shall be submitted to the S.W. District office with a summary of monitoring information.

9. of 10 The following information shall be documented during actual construction and installation of monitoring wells. The information shall be submitted to the Water Quality Division before or at the time of the first monitoring report.

- a. Date/time of construction
- b. Person developing information/other person(s) on site and their association with the project.
- c. Drilling method and if drilling fluid was used
- d. Well locations and depths
- e. Borehole diameter and well casing diameter
- f. Drilling and lithologic logs (including visual, olfactory, and any vapor detections used)
- g. Casing material, and screen materials and type/location (including screen slot size/length)
- h. Filter pack material/size, grain analysis, volume calculated/actually installed, filter pack placement method/location
- i. Sealant (annular space) materials, volume used, placement method/location
- j. Surface seal design/construction
- k. Type of protective well cap (top and bottom)
- l. Detailed 'as-built' construction drawing of well, including dimensions to all well features (see attached 'Monitor Well Installation Diagram').
- m. Method of downhole equipment decontamination between wells

10. of 10 The leak detection monitoring wells shall be installed in accordance with the conditions of this permit. Additional wells meeting the requirements of this permit may be installed if prior approval is received from the WDEQ/WQD S.W. District office. The well construction and operation shall include the following features:


- a. All downhole equipment shall be decontaminated between wells to minimize the potential for cross-contamination.
- b. If groundwater is encountered the monitoring well shall be developed by the use of a pump or bailer so that representative groundwater samples can be collected.
- c. Well caps shall be kept locked at all times other than for monitoring purposes. The wells shall be clearly numbered using either a stamp to permanently engrave the number into the steel top or by writing the number in the wet concrete of the base.

- d. When PVC casing is used, the casing shall be installed using threaded joints, couplings, or mechanical connectors. Solvents or glues shall not be used in the construction or installation of a well.
- e. The annular space shall be sealed to protect it against contamination by entrance of surface and/or shallow subsurface waters. Sealing materials shall consist of neat cement grout, sand-cement grout, bentonite clay or concrete.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9-14-95

Date of Issuance

RT/nc 54041.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-40~~8~~5

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not Applicable

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, S.W. District Engineering Supervisor, and completed on 12 September 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RT/nc 54041.LTR

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 95-406
SPECIAL CONDITIONS
REF/PERMIT #

Hulett Sewerage Lift Station

This permit hereby authorizes the applicant:

Town of Hulett
P.O. Box 278
Hulett, Wyoming 82720
Attention: Mayor Betty Rush

to construct, install or modify a sewage pump station according to the procedures and conditions of the application number 95-406. The facility is located in NE/4 of the NE/4 of Section 12, Township 54 North, Range 65 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


 Administrator
 Water Quality Division


 Director
 Department of Environmental Quality

10/16/95
 Date of Issuance

BDM/pr: October 10, 1995
 b/54624.ltr

cc: Jerry West, P.E., Weston Engineering Inc., P.O. Box 260, Upton, WY 82730

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 95-406
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- Not applicable
- B. Briefly state the basis for the deviation.
- Not applicable
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- Not applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on October 10, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

BDM/bb/54624.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 95-407
SPECIAL CONDITIONS

Tweed Lane Sewer Main

This permit hereby authorizes the applicant:

Tweed Lane Water and Sewer District, Steve Dutcher, President
88 Tweed Lane
Lander Wyoming 82520

to construct approximately 1620' of new eight inch PVC sewer main with appurtenances according to the procedures and conditions of the application number 95-407. The facility is located in the SW 1/4 of Sec. 7, T33N, R99W and the SE 1/4 of Sec. 12, T33N, R100W in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/18/95

Date of Issuance

MDR/bb/54090.ltr

STATEMENT OF BASIS

General information.

A. Permit Number: 95-407

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

- VI. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 14 September 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR/bb/54090.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X
New
Renewal
Modified

PERMIT NO. 95-409
SPECIAL CONDITIONS

Yellowstone Regional Airport ARFF Station Treated Water Main

This permit hereby authorizes the applicant:

Yellowstone Regional Airport, Laurie Suttmeier, Manager
3001 Duggleby Drive
Cody, Wyoming 82414

to construct 5500 feet of 8 inch ductile iron pipe in a looped configuration into the city of Cody treated water system according to the procedures and conditions of the application number 95-409. The facility is located in Tract 60, T52N and T53N, R101W in the county of Park, in the State of Wyoming. This permit shall be effective for a period of three years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/18/95

Date of Issuance

MDR/nc 54127.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-409

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

- VI. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 15 September 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR/nc 54127.LTR

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 95-410
SPECIAL CONDITIONS

Replat of South 247 feet of Block 118, West Laramie

This permit hereby authorizes the applicant:

Habitat for Humanity of Albany County
410 South 3rd Street
Laramie, WY 82070

to construct an extension of the publicly owned water distribution system and wastewater collection system according to the procedures and conditions of the application number 95-410. The facility is located in SE 1/4 Section 31, T16N, R73W in the county of Albany, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 5 The water distribution extension shall have a minimum pressure of 20 psi under all flow conditions.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-12-95
Date of Issuance

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-410

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on October 6, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LAND APPLICATION PERMIT

X New
Renewal
Modified

PERMIT NO. 95-411
SPECIAL CONDITIONS

South Big Hand Minnelusa "B" Unit Road Application

This permit hereby authorizes the applicant:

St. Mary Operating Company
1776 Lincoln Street, Suite 500
Denver, CO 80203
Attention: Mr. Jim Anderson

to land apply oil contaminated soil according to the procedures and conditions of the application number 95-411. The facility is located in the NW/4 of Section 29 of Township 47 North Range 70 West in the county of Campbell, in the State of Wyoming. This permit shall be effective until November 1, 1995.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 9 The permittee shall notify representatives from the Department of Environmental Quality, Water Quality Division (DEQ/WQD) of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: DEQ/WQD Northeast Office, 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307)672-6457, FAX (307)674-6050.
- 2 of 9 The permittee shall provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
- 3 of 9 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the Northeast district Office on the attached Certification of Completion form.
- 4 of 9 The permittee shall submit a contour map depicting only those sections of road that actually received oil contaminated soil within sixty (60) days of the project completion to the Northeast District Office.
- 5 of 9 The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
- 6 of 9 Oil contaminated soil shall be applied uniformly. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. Oil contaminated soil shall not be applied during the period from November 1 to April 10.
- 7 of 9 The application site slope shall not exceed eight percent (8%) for vehicular application.
- 8 of 9 Oil contaminated soil application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
- 9 of 9 Any oil contaminated soil application after November 1 must be re-permitted.


AUTHORIZED BY:



Administrator
Water Quality Division

9/18/95

Date of Issuance



Director
Department of Environmental Quality

DRM/pr:09/14/95

b/54091.ltr

cc: NE District Campbell County Road Application File

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-411

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are no numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the oil contaminated soil onto the roadbed. Repeated applications of oil contaminated soil on the same sections of road will be monitored by roadbed analyses.

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Donald R. McKenzie, NE District Engineering Supervisor, and completed on September 14, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

DRM/bb/54091.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

ROAD APPLICATION PERMIT

New
 Renewal
 Modified

PERMIT NO. 95-412
SPECIAL CONDITIONS

M&C Oil Co, Road Application

This permit hereby authorizes the applicant:

M&C Oil Co
100 Sunset, Lot 40
Evanston, WY 82930

to road apply oil contaminated dirt according to the procedures and conditions of application number 95-412. The application site is located in T15N R119W S27 in the county of Uinta in the State of Wyoming. This permit shall be effective until November 01, 1995.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), upon the presentation of credentials and during working hours, to have access to inspect the waste source and application site location, for the purpose of compliance with the provisions of this permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


1. of 8 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: Water Quality Division, 250 Lincoln Street, Lander, WY 82520. (307)332-3144.

2. of 8 The permittee will provide immediate oral and/or written notice to Water Quality Division, 250 Lincoln, Lander, WY 82520, (307) 332-3144, in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
3. of 8 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the Water Quality Division, 250 Lincoln, Lander, WY 82520, on the attached Certification of Completion form.
 - a. Date that the road application was completed; and
 - b. Certification the road application was done in accordance with the terms and conditions of the permit; or
 - c. Certification the road application was completed with changes or modifications. Submit the information necessary to clearly indicate the road application as actually performed. This information shall include a contour map depicting only those sections of road that actually received oil contaminated dirt.
4. of 8 The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
5. of 8 Oil contaminated dirt shall be applied uniformly and incorporated into the roadbed. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. Oil shall not be applied during the period from November 1 to April 10.
6. of 8 The application site slope shall not exceed eight percent (8%) for vehicular application.
7. of 8 The road application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
8. of 8 Only the roads designated in this permit are authorized for application of the oil contaminated dirt. Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Dept. of Environmental Quality

9-13-95

Date of Issuance

RRT/bb/54055.ltr

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 95-412
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. No
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
No
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
There are no numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.
- B. Briefly state the basis for the deviation.
Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the oil contaminated dirt onto the roadbed. Repeated applications of oil contaminated dirt on the same sections of road will require monitoring by roadbed analyses.

- B. Quality of waste is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, S.W. District Engineering Supervisor, and completed on 13 September 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RRT/bb/54055.ltr

DEPARTMENT OF ENVIRONMENTAL QUALITY
STATE OF WYOMING
GROUNDWATER POLLUTION CONTROL PERMIT
AUTHORIZATION TO DISCHARGE INTO UNDERGROUND RECEIVERS
(Permit to Inject)

() New
(X) Modified

Permit Number UIC 95-413
UIC Class 5D2

In compliance with the Wyoming Environmental Quality Act (W.S. 35-11-101 through 1104, specifically 301(a)(i) through (iv), Laws 1973, Ch. 250, Section 1) and Water Quality Rules and Regulations Chapter IX (September 4, 1980),

The City of Laramie
P.O. Box C
Laramie, WY 82070
(307) 721-5264


is authorized to operate drainage wells located on Eberhart Street and in Kiwanis Park in Laramie, located in Section 31, Township 26 North, Range 73 West, Sixth Principal Meridian according to procedures and conditions of the applications UIC 83-638 and UIC 89-111 and requirements and other conditions of this permit contained on pages 1 through 9.

This permit shall become effective on date of issuance.



Administrator
Water Quality Division
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002
Phone: (307) 777-7781

11/27/95
Date



Director
Department of Environmental Quality
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002

11/28-95
Date

A. Discharge (Injection) Zone and Area of Review

The Discharge Zone for this permit is limited to the Alluvial Aquifer along the Laramie River at a depth of less than 30 feet below ground surface.

The Area of Review for this permit is legally described as follows:

Township 26 North, Range 73 West, 6th Principal Meridian

Section 31: S $\frac{1}{2}$ N $\frac{1}{2}$ NW $\frac{1}{4}$, S $\frac{1}{2}$ NW $\frac{1}{4}$, SW $\frac{1}{4}$, SW $\frac{1}{4}$ NW $\frac{1}{4}$ NE $\frac{1}{4}$,
W $\frac{1}{2}$ SW $\frac{1}{4}$ NE $\frac{1}{4}$, NW $\frac{1}{4}$ NW $\frac{1}{4}$ SE $\frac{1}{4}$

Township 25 North, Range 73 West, 6th Principal Meridian

Section 6: N $\frac{1}{2}$ NW $\frac{1}{4}$

B. Groundwater Classification

The groundwater in the Alluvial Aquifer along the Laramie River is class I groundwater by use. There are numerous points of use inside the above area of review, most of which use the groundwater for lawn and garden watering, a domestic use. By ambient quality, the alluvial aquifer meets only class III standards, because of Sulfate, Total Dissolved Solids and Chloride content.

C. Authorized Operations

The permittee is authorized to operate stormwater drainage wells along Eberhart Street and in Kiwanis Park in Laramie, Wyoming. There is no limit placed on the volume of water to be injected under static water pressure. No monitoring of the flow volume or pressure is required. The permit covers up to six individual wells within the above area of review. If any well becomes plugged it may be replaced with another well of similar construction without prior approval from the Water Quality Division.

D. Proper Operation and Maintenance

The permittee is required to conduct the operation in accordance with statements, representations and procedures presented in the complete permit application and supporting documents, as accepted and approved by the administrator.

The permittee is required at all times to properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve permit compliance. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training and adequate laboratory and process controls, including appropriate quality assurance procedures.

The subsurface discharge (injection) authorized by permit shall be consistent with the conditions and content of the permit; any modifications which will result in a violation of permit conditions shall be reported by submission of a new or amended permit application and shall not be implemented until a new or modified permit has been issued.

E. Entry and Inspection

The permittee shall allow the administrator, or an authorized representative, upon the presentation of credentials and other documents as may be required by law to:

1. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
3. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), and practice, or operations regulated or required under this permit; and
4. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the appropriate rules and regulations of the Department, any substances or parameters at any location.

F. Environmental Monitoring Program for Groundwaters of the State

1. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
2. The permittee shall prepare records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation to be retained for a period of at least 3 years after closure of the facility.
3. Records of monitoring information shall include:
 - a. The date, exact place, and time of sampling or measurements;
 - b. The name(s) of individual(s) who performed the sampling or measurements;
 - c. The date(s) analyses were performed;
 - d. Names of individuals who performed the analyses;
 - e. The analytical techniques or methods used; and
 - f. The results of such analyses.
4. The prescribed program for this permitted activity is as follows: No monitoring of the groundwater other than at the point of injection is required under this permit. Extensive monitoring of this system between 1983 and 1995 has shown that monitoring of point of use wells is un-necessary unless the quality of the injected water deteriorates. In the case where the quality of the injected water exceeds the upper control limits found in the next section, the Water Quality Division may require additional groundwater monitoring.

G. Requirements for Monitoring the Discharge

The permittee shall monitor the quality of the injected water on an approved schedule. The following parameters shall be analyzed by the listed methods and reported annually:

SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT OR (UCL)*
Annually in December	EPA Method 160.1	Total Dissolved Solids	2,500
	EPA Method 350.3	Ammonia as N	3.0
	EPA Method 353.2	Nitrate as N	15.0
	EPA Method 418.1	Total Petroleum Hydrocarbons	10.0
	EPA Method 239.2	Total Lead	0.05
	EPA Method 218.1	Total Chromium	0.05
	EPA Method 213.2	Total Cadmium	0.01

The above Upper Control Limit (UCL) is not to be exceeded in any sample. Exceedance of this value is a violation of this permit and shall require corrective action.

and

In addition to the above Upper Control Limits, the following Lower Control Limits (LCL) shall apply. Exceedance of any Lower Control Limit is not a violation of this permit, but shall require increased monitoring on the part of the permittee. At the time when the following limits are exceeded, the permittee shall propose a groundwater monitoring program to determine if there has been an adverse affect on the groundwater quality caused by these exceedances. Monitoring of existing point of use wells or the installation of monitoring wells may be required as a part of this plan. Upon approval of this plan by the Water Quality Division, the permittee shall undertake the monitoring work required within 90 days of his receipt of the department approval. Failure to take corrective action after exceeding a LCL is a violation of this permit.

SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT OR (LCL)*
Annually in December	EPA Method 160.1	Total Dissolved Solids	2,000
	EPA Method 350.3	Ammonia as N	.50
	EPA Method 353.2	Nitrate as N	10.0
	EPA Method 418.1	Total Petroleum Hydrocarbons	10.0
	EPA Method 239.2	Total Lead	0.05
	EPA Method 218.1	Total Chromium	0.05
	EPA Method 213.2	Total Cadmium	0.01

*All chemical parameters listed in this permit are expressed in mg/l unless otherwise shown. pH is always expressed in standard units, and Conductivity is always expressed in mmhos/meter or umhos/cm.

In addition to the above laboratory measurements, the permittee shall also record the static water level and the pH for each point monitored and for each sample taken.

H. Test Procedures

Test procedures for the determination of water quality parameters and constituents shall be in accord with provisions of Water Quality Rules and Regulations Chapter VIII, Section 7.

All samples taken for compliance with this permit shall be accompanied throughout the sampling event by a trip blank of distilled water prepared by the laboratory and analyzed as a quality control measure for the same parameters as the analytical samples for that date.

At least one sample from one of the injection wells covered by this permit shall be duplicated in the field and analyzed twice by the laboratory. This duplicated sample shall be labeled so that the laboratory will not know which sample is the duplicate and it shall be submitted to the laboratory in such a way that the original sample and the duplicate would not normally be consecutive samples.

I. Records and Reports

1. The permittee shall retain copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the report or application.
2. The permittee shall give notice to the administrator as soon as possible of any planned physical alterations or additions to the permitted facility.
3. The permittee shall give advance notice to the administrator of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.
4. Monitoring results shall be reported at intervals specified in section C and/or Section G of this permit.
5. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.
6. The permittee shall report any noncompliance which may endanger health or the environment, orally within 24 hours from the time the permittee becomes aware of the circumstances. The report should include:
 - a. Any monitoring or other information which indicates that any contaminant may cause an endangerment to a usable groundwater of the state.
 - b. Any noncompliance with a permit condition or malfunction of the discharge (injection) system which may cause fluid migration into or between usable groundwaters of the state.

A written submission shall be provided within 5 days of the time the permittee becomes aware of the circumstances. This written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected; the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

7. The permittee shall report all instances of noncompliance not reported otherwise, at the time monitoring reports are submitted; such reports shall contain the information listed in 6. above.
8. When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the administrator, it shall promptly submit such facts or information.
9. The permittee shall retain all records concerning the nature and composition of injected fluids until 5 years after completion of any specified plugging and abandonment procedures. The administrator may require the owner/operator to deliver the records to the administrator at the conclusion of the retention period.
10. A subsurface discharge (injection) well may not commence subsurface discharge (injection) until, following public notice and an opportunity for hearing, a groundwater pollution control permit has been issued by the department for the proposed operation, and:
 - a. Well construction is complete and the permittee has submitted notice of completion of construction to the administrator,
 - b. The administrator has inspected or otherwise reviewed the subsurface discharge (injection) well and finds it in compliance with the conditions of the permit; or the permittee has not received notice from the administrator of intent to inspect or otherwise review the facility within 13 days of the notice of a. above, in which case prior inspection or review is waived, and
 - c. Well mechanical integrity testing has been proven or demonstrated to the satisfaction of the administrator.
11. Annual reports shall be submitted to the administrator within 30 days following the end of each calendar year following issuance of the permit. The annual report for this permit shall include all analytical parameters required under Section G of this permit.
12. A comprehensive report for an aborted or curtailed operation authorized by this permit shall be submitted to the administrator within 30 days of complete termination of the injection (discharge) or associated activity, in lieu of an annual report.

J. Permit Actions

After notice and opportunity for a hearing, a permit may be modified, suspended or revoked in whole or part during its term for cause which includes, but is not limited to, any of the following:

1. Violation of the permit;
2. Obtaining a permit by misrepresentation or failure of the discharge well or system.

Each permit is reviewed at least once every 5 years, and may be reviewed more frequently.

A permit may be modified at any time as may be required, including for conformity with changes in regulations or standards which occur after the permit is issued.

A permit may be modified in whole or part in order to apply more, or less, stringent standards; or prohibitions for a toxic or other substance present in the permittee's discharge, as may be ordered by the council.

This operation (permit) can be terminated by authority of the administrator for one or more permit violations.

Public notice of the permit review and request for public comment will be made every 10 years by the administrator.

K. Mechanical Integrity

There are no mechanical integrity requirements placed on this permit.

L. Abandonment

The permittee shall notify the administrator at least 180 days before well abandonment. Immediately following the permit cessation of subsurface discharge or related activity, or where a well has not been completed, the applicant/permittee shall notify the director and follow the procedures prescribed by the director for plugging and abandonment or the discontinuance of related activities.

If it becomes necessary to plug and abandon any well covered by this permit, the well shall be drilled out to total depth and the casing removed from the well. The well bore shall be filled with bentonite grout having a 10 minute gel strength of at least 20 pounds per 100 square feet and a filtrate volume not to exceed 13.5 cubic centimeters.

M. Duties of the Permittee

It is a duty of the permittee to:

1. Comply with all permit conditions;
2. Halt or reduce activity -- it shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permittee activity in order to maintain compliance with the permit conditions;
3. Take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with this permit; and
4. Furnish to the administrator within a reasonable time, any information which the administrator may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit; and furnish to the administrator, upon request, copies of records required to be kept by this permit.

N. Financial Responsibility

There are no financial responsibility requirements for this permit.

O. Special Measures the Director Finds Necessary

Whenever the permittee becomes aware that a spill has occurred which has entered one of the drainage wells covered by this permit, that spill shall be reported in accordance with section 16 of this permit.

Permits numbered 83-638 and 89-111 are hereby cancelled.

P. Special Permit Conditions

Pollution or waste which migrates into an aquifer containing a usable groundwater of the state is a violation of the permit.

Q. Signatories Requirement

All reports required by this permit and other requested information shall be signed as follows:

For a corporation -- by a principal executive officer of at least the level of vice-president;

For a partnership or sole proprietorship -- by a general partner or the proprietor, respectively;

For a municipality, state, federal or other public agency -- by either a principal executive officer or ranking elected official; or

By a duly authorized representative for any of the above. A person is a duly authorized representative only if:

1. The authorization is made in writing by one of the described principals;
2. The authorization specifies either an individual or position having responsibility for the overall operation of the regulated facility or activity; and
3. The written authorization is submitted to the administrator.

If an authorization is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to the administrator prior to or together with any reports or information, to be signed by an authorized representative.

Any person signing a report or other requested information shall make the following certification:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

R. Noncompliance

Any permit noncompliance constitutes a violation of the permit.

The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination; or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

S. Permit Transfer

The owner/operator of record (permittee) is always responsible for permit compliance. A permit holder cannot transfer his permit without approval of the department director.

T. Responsibilities

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable state law or regulation.

U. Property Rights

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

V. Severability

The provisions of this permit are severable, and if any provision of the permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

RL/bb/54054.ltr



THE STATE OF WYOMING



JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building ● 122 West 25th Street ● Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-7682	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

September 14, 1995

The City of Laramie
P.O. Box C
Laramie, WY 82070

RE: Eberhart Street and Kiwanis Park Drainage Wells
Draft Permit UIC 95-413
Albany County, Wyoming

Dear Sir or Madam:

The Water Quality Division was originally established to prevent the degradation of one of Wyoming's most important resources, its water. Within the division, the Underground Injection Control Program seeks to prevent contamination of Wyoming's groundwater caused by direct injection of water into aquifers. This program does this by regulating how and where injections can occur and placing limits on the quality of the water injected.

The City of Laramie has, since 1983, injected stormwater runoff into the Alluvial Aquifer along the Laramie River on Eberhart Street and in Kiwanis Park. These discharges are presently regulated under permits UIC 83-638 and UIC 89-111. These permits require monitoring of nearby wells which could be affected by these discharges. A body of scientific data has been created over the years showing what affect these discharges have on the aquifer. Every five years, regulations require that each permit be reviewed in detail. This department has just finished a comprehensive review of these permits. A copy of this review is enclosed.


As part of the review process, the department not only determines if the permit has been complied with, but also determines if the permit itself could be improved. In this case, we have determined that these permits could be consolidated and the monitoring could be improved if the point of discharge was monitored rather than the wells being monitored now. The attached draft permit, when issued, will take the place of the existing permits. It is our belief that this permit will provide more cost effective management of these injection wells while providing comprehensive data concerning the discharge itself.

City of Laramie
September 14, 1995
Page 2

Please review the attached *draft permit*. This draft is open for your comment prior to the beginning of a public comment period. Only after you have had the opportunity to comment will the public notice period begin. Until this new permit is issued, the existing permits remain in full force and effect. In order to insure that the process proceeds at a reasonable pace, the public notice period will be set to begin October 15 if we have not heard from you sooner.

We believe that this approach is reasonable, sensible, and responsible in light of the department's legislative mandate and the responsibilities that the City of Laramie is fulfilling by injecting the stormwater. It is precisely because this department cares about the costs associated with our permits that this review has been undertaken. The replacement permit should be less costly to the City of Laramie.

Sincerely,



Robert Lucht, P.E.
UIC Program Supervisor
Water Quality Division

RL/bb/54064.ltr

Attachment

P 7

PERMIT TO CONSTRUCT

New
Renewal
 Modified

PERMIT NO. 95-415
SPECIAL CONDITIONS
REF/PERMIT #94-341

Ponderosa Ridge - Sow Site

This permit hereby authorizes the applicant:

Ponderosa Ridge, LLC
P.O. Box 97
Albin, WY 82050-0097

to modify the location of the collection line to facilitate the relocation of buildings according to the procedures and conditions of the application number 95-415. The facility is located in SW&SE 1/4, Section 26, T17N, R62W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to Southeast District office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 5 This permit is being issued for the relocation of the proposed collection line to facilitate the relocation of buildings on the site. All permit conditions under Permit to Construct 94-341 still apply and are to be adhered to.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/18/95
Date of Issuance

GLS/mad 54096.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 94-341

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on September 15, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

R7

PERMIT TO CONSTRUCT

New
Renewal
 Modified

PERMIT NO. 95-416
SPECIAL CONDITIONS
REF/PERMIT #95-017

Ponderosa Ridge Nursery Site and Finish Site No. 1

This permit hereby authorizes the applicant:

Ponderosa Ridge, LLC
P.O. Box 97
Albin, WY 82050-0097

to modify the location of a force main and extend a wastewater collection line according to the procedures and conditions of the application number 95-416. The facility is located in Lots 1,2,3,4;SE, Section 35;33, T17N, R60W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to Southeast District office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 5 This permit is being issued for the relocation of the force main from the nursery site to Finish Site No. 1 and to extend the collection line at the Nursery site to the north to facilitate the relocation of 2 buildings. All permit conditions under Permit to Construct 95-017 still apply and are to be adhered to.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/18/95

Date of Issuance

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 95-416
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- N/A
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)
- N/A

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on September 15, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 95-417
SPECIAL CONDITIONS

Collier View Estates, Green River

This permit hereby authorizes the applicant:

Mildred Collier
500 Ironwood
Green River, WY 82935

to construct extensions for a water distribution system and for a wastewater collection system according to the procedures and conditions of the application number 95-417. The facility is located in SW ¼ T18N R107W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/18/95

Date of Issuance

RRT/bb/54093.ltr

STATEMENT OF BASIS

General information.

A. Permit Number: 95-417

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not Applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, S.W. District Engineering Supervisor, and completed on 14 September. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RRT/bb/54093.ltr

PERMIT TO CONSTRUCT

X. New
Renewal
Modified

PERMIT NO. 95-418
SPECIAL CONDITIONS

Lander - Riverview Drive Sewer Extension

This permit hereby authorizes the applicant:

City of Lander
240 Lincoln
Lander, WY 82520

to construct 330 feet of 8 inch diameter PVC sewer line according to the procedures and conditions of the application number 95-418. The facility is located in SE¼ Section 7, T33N, R99W in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/18/95
Date of Issuance

JH/jyi /nc 54154.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-418

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on September 18, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-419
SPECIAL CONDITIONS

Town of Moorcroft Little Horn Sewer Improvement

This permit hereby authorizes the applicant:

Town of Moorcroft
P.O. Box 70
Moorcroft, Wyoming 82721

to construct, install or modify a sanitary sewer according to the procedures and conditions of the application number 95-419. The facility is located in NE/4 of the NW/4 of Section 6, Township 49 North, Range 68 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/18/95

Date of Issuance

BDM/pr: September 15, 1995 /nc 54110.LTR

cc: Jerry Hunt, P.E., Weston Engineering, P.O. Box 260, Upton, WY 82730

STATEMENT OF BASIS

General information.

A. Permit Number: 95-419

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. yes

B. Chapter XII. no

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

no

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

no

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

not applicable

B. Briefly state the basis for the deviation.

not applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

not applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

not applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

not applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on September 15, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

BDM/pr: September 15, 1995 /nc 54110.LTR

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-420
SPECIAL CONDITIONS

DAYTON/LEMON WATER IMPROVEMENT PROJECT

This permit hereby authorizes the applicant:

Town of Dayton
P.O. Box 176
Dayton, WY 82836
Attention: Mr. Arthur Badgett

to construct, install or modify a watermain according to the procedures and conditions of the application number 95-420. The facility is located in the SE/4 and NE/4 of Section 32 of Township 57 North Range 86 West in the county of Sheridan, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division

9/18/95
Date of Issuance



Director
Department of Environmental Quality

DRM/pr:09/14/95
b/54092.ltr

cc: Jim Willey, M-W Consultants, 1030 N. Main, #2 Taylor Pl., Sheridan

STATEMENT OF BASIS

General information.

A. Permit Number: 95-420

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of Section VI. from the Statement of Basis.)

N/A

VI. N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Donald R. McKenzie, Northeast District Engineering Supervisor, and completed on September 14, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

DRM/bb/54092.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-421
SPECIAL CONDITIONS
REF/PERMIT #

Dowell Schlumberger Gillette Shop

This permit hereby authorizes the applicant:

Schlumberger Oilfield Services
PO Box 2727
Houston, TX 77252-2727

to construct, install or modify a groundwater remediation system known as a permeable reaction trench according to the procedures and conditions of the application number 95-421. The facility is located in NW 1/4 Section 26, T.50N., R.72W. in the county of Campbell, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: NE District, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 21. Construction of the permeable reaction trench shall be per the Corrective Action Plan (CAP) as submitted to DEQ and as amended in the October 3, 1995 letter from John Miller (Schlumberger Oilfield Services) to DEQ. No deviation from the CAP without authorization from DEQ/WQD is acceptable. DEQ/WQD personnel shall be given at least two (2) weeks notice prior to construction of the permeable reaction trench so that DEQ/WQD personnel may be on site if deemed necessary.
- 2 of 21. The permeable reaction trench and associated monitor wells shall be located as per the CAP and John A. Miller's (Schlumberger Oilfield Services) letter of October 3, 1995.
- 3 of 21. The permittee shall submit a health and safety plan for construction of the trench to DEQ prior to commencing construction. The plan will limit access to the immediate trench area by workers and provides for periodically monitoring organic vapors, explosive limits, and oxygen levels in the trench area during construction.
- 4 of 21. If dewatering or extraction pumping become necessary during the construction or operation of the system, the extracted water may need to be treated prior to disposal. Contact NE District, State of Wyoming, DEQ/WQD, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050, for disposal authorization.
- 5 of 21. Injection of chemicals to enhance operation of the permeable reaction trench or to return effluent water to the aquifer requires an Underground Injection Control (UIC) permit. Contact the UIC Program Principal in the Cheyenne office, (307) 777-7095, to obtain a permit.
- 6 of 21. The groundwater monitoring wells/piezometers shall be installed in accordance with the conditions of this permit and the plans and specifications submitted in Permit to Construct application number 95-421. Additional wells meeting the requirements of this permit may be installed if prior approval is received from the Water Quality Division (WQD).
- 7 of 21. Monitoring well/piezometer construction must meet the requirements of Chapter XI Wyoming Water Quality Rules and Regulations. Monitoring well/piezometer casings shall meet the conditions provided in Chapter XI, Section 67. All monitoring wells/piezometers must be constructed from materials free of material having the potential to contaminate groundwater samples.
- 8 of 21. All downhole equipment shall be decontaminated between wells (borings) to minimize the potential for cross-contamination.
- 9 of 21. Borehole cuttings must be screened and disposed of properly. Contaminated cuttings must be disposed of at a site approved by the DEQ's Solid and Hazardous Waste Management Division.
- 10 of 21. Pursuant to Wyoming Water Quality Rules and Regulations, Chapter XI, Section 63(A), a deviation is hereby granted for those wells/piezometers prevented by physical limitations to adherence to the requirements on minimum depths of seal below the ground surface as detailed in Chapter XI, Part G. However, a sufficient seal shall be installed according to normal engineering practice.

- 11 of 21. After the monitoring wells/piezometers have fulfilled their useful purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. In addition, borings in public use areas, particularly paved streets and alleys, shall be abandoned in accordance with city and/or highway department requirements. No monitoring well/piezometer shall be abandoned without prior approval from the Water Quality Division.
- 12 of 21. Well caps shall be kept locked at all times other than for monitoring purposes. Any tampering with the monitor wells/piezometers shall be reported immediately to the division. The wells shall be clearly numbered using either a stamp to permanently engrave the number into the steel top or by writing the number in the wet concrete of the base.
- 13 of 21. The applicant is responsible for obtaining any permits required by the State Engineer's Office (307-777-7354).
- 14 of 21. The issuance of this permit does not relieve the permittee from obligations to complete any additional site investigations or remedial actions that may be required by the WQD.
- 15 of 21. In addition to the well/piezometer construction information submitted with the permit application, the following items relating to well/piezometer construction shall be implemented when the wells/piezometers are constructed, installed and developed:
- a. The borehole diameter shall be at least four (4) inches larger in diameter than the casing diameter;
 - b. For water table (unconfined) aquifers, the screened interval shall extend at least two (2) feet above the highest expected groundwater level. Monitoring wells/piezometers installed in confined and semi-confined aquifers shall be constructed in accordance with Chapter XI, Section 68 of Water Quality Division Rules and Regulations. Factory screen or slotted casing is recommended for the perforated interval;
 - c. When PVC casing is used, the casing shall be installed using threaded joints, couplings, or mechanical connectors without the use of solvents or glues to hold the casing sections together;
 - d. To minimize the entrance of fine grained material into the well/piezometer, the filter pack shall be designed to be compatible with the perforation size and the geologic materials encountered within the perforated interval. The filter pack shall extend to a minimum of one (1) foot above the screened interval;
 - e. Filter pack, annular seal, and surface seal material shall be entered into the well/piezometer in a manner such that no voids or bridging occur;
 - f. A minimum two (2) foot thickness of bentonite or bentonite grout is required at the top of the filter pack to serve as an annular seal. After the bentonite has been placed in the annular space, it shall be hydrated to insure a proper seal;
 - g. The annular space above the bentonite seal to within one (1) foot of the surface will be sealed with Portland cement, sand-cement grout, or bentonite grout;
 - h. A protective casing shall be cemented into place when the upper one (1) foot of the annular space is completed with cement, forming a concrete apron sloping away from the well/piezometer;

- i. A top and bottom cap of the same material as the well/piezometer casing shall be installed to prevent sediment and surface water from entering the well/piezometer; and
 - j. The monitoring well/piezometer shall be developed by the use of a pump or bailer so that representative groundwater samples can be collected.
- 16 of 21. DEQ/WQD personnel shall be given at least two (2) weeks notice prior to the installation of monitor wells/piezometers and sample collection so that DEQ/WQD personnel may be on site if deemed necessary.
- 17 of 21. Within ninety (90) days of completion of the remediation system construction, a report of remediation system construction and completion shall be submitted to WQD. This report shall contain at a minimum:
- a. A chronology of events leading up to the remediation system construction;
 - b. A site map showing the physical features, monitoring well/piezometer/borehole locations, and mean sea level elevations of the top of casing/measuring point;
 - c. The permittee shall provide the exact latitude and longitude for each of the monitor wells/piezometers being constructed under this permit. These figures shall be accurate to the nearest one (1) second of latitude and longitude;
 - d. Final location, construction details and lithologic logs of monitor wells/piezometers/boreholes;
 - e. Geohydrologic maps and/or cross sections that clearly describe the subsurface distribution of geologic materials and groundwater occurrence;
 - f. Depth to water and product thickness measurements;
 - g. Sample collection procedures;
 - h. Sampling analytical results;
 - i. A map delineating the extent of the subsurface contamination including LNAPL (free product), soil and dissolved groundwater contamination and concentrations;
 - j. A potentiometric surface map showing the direction and gradient of groundwater flow; and
 - k. Interpretation of the data and conclusions of the investigation, including additional recommended investigation and remedial measures, and a schedule for implementation of these measures.
- 18 of 21. Proper monitoring well/piezometer evacuation shall include removal of a minimum of three (3) casing volumes prior to sampling or pumping the well/piezometer dry once, whichever occurs first. Sample collection, preservation, transportation and chemical analytical procedures shall be completed in accordance with WQD and EPA standard procedures.
- 19 of 21. All monitor wells/piezometers associated with this facility shall be sampled and the groundwater analyzed semi-annually for the following listed parameters according to the EPA Method 8240 plus xylenes:

- a. After the second monitoring event, the WQD may substitute a shorter list for the above parameters, depending on the results of the second monitoring event. WQD may substitute less expensive methods for the above listed methods depending on the results of the first monitoring.
- b. The results of these analyses shall be submitted to DEQ/WQD, 1043 Coffeen Avenue, Suite D, Sheridan, WY 82801; telephone (307) 672-6457; FAX (307) 674-6050 by the last day of the month following the end of each applicable quarter.

20 of 21. Water which is collected during monitoring well/piezometer development or sampling must be disposed of properly. The applicant must contact the city for authorization to dispose into the local storm sewer, sanitary sewer, wastewater treatment plant, or other facility.

21 of 21. The results of any analyses conducted on soil or water removed from these wells/piezometers or boreholes shall be provided to the department as soon as they are available.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10/16/95

Date of Issuance

WJC/bb/54623.ltr

cc: LeRoy Feusner, P.E., DEE, AUST Program Engineering Supervisor, Cheyenne

STATEMENT OF BASIS

GROUNDWATER REMEDIATION SYSTEM (PERMEABLE REACTION TRENCH)

This statement of basis for Permit Number 95-421 is for the purpose of constructing a groundwater remediation system, a permeable reaction trench, at UST Facility ID #1450, Dowell Schlumberger Shop, Gillette, Wyoming. The UST facility is a contaminated site. No known USTs remain at the site. Review of the application and corrective action plan indicate that no adverse impacts to groundwater will result from the planned construction or operation of the permeable reaction trench. The permeable reaction trench will de-halogenate chlorinated hydrocarbons dissolved in groundwater as the hydrocarbons pass through the trench. No hazardous residues or spent materials are generated from the operation of this system. The system will be monitored for a suitable time period (four years) following construction. After four years, the remediation system will be re-designed to treat groundwater to acceptable MCL concentrations, if necessary, or alternative groundwater remediation measures will be considered.

The review of the application indicates that the proposed facility will be in compliance with applicable regulations identified in Chapter XI, Part G (Well Construction Standards). Groundwater monitor wells require that depth to groundwater be less than twenty (20) feet below ground surface. Therefore, regulations in Chapter XI, Part G, Section 63, stipulate that deviation to adherence of the requirements on minimum depths of seal below the ground surface is granted for wells prevented by physical limitations (shallow depths) from meeting those requirements. A well completion submittal report is required within 90 days of remediation system completion.

Review of the application to determine groundwater impacts in accordance with Chapter III, Section 15, requires that the construction adhere to the standard conditions for groundwater monitor wells in the permit to construct. Furthermore, monitor wells are required to have a locked cap marked "monitor well" and "no fill" to prevent accidental contaminant discharge through the wellbore.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Wayne J. Carlisle, Senior Environmental Analyst, and completed on October 10, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

WJC/bb/54623.ltr

RF

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-422
SPECIAL CONDITIONS

Albin - 4th Ave. Sanitary Sewer Main Extension

This permit hereby authorizes the applicant:

Town of Albin
Town Hall
Albin, Wyoming 82050

to construct, install or modify a sewer main extension according to the procedures and conditions of the application number 95-422. The facility is located in Section 19, T17N, R60W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the SE District office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SE District office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/18/95

Date of Issuance

RLE/nc 54161.LTR

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 95-422
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- NOT Applicable
- B. Briefly state the basis for the deviation.
- NOT Applicable
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on September 18, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/nc. 54161.LTR

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 95-423
SPECIAL CONDITIONS

Yellowstone Regional Airport ARFF Septic Tank and Leach Field

This permit hereby authorizes the applicant:

Yellowstone Regional Airport, Roger Sedam, Board Chairman
P. O. Box 2748
Cody, Wyoming 82414

to construct a septic tank, grease trap and leach field at the ARFF facility at the Yellowstone Regional Airport according to the procedures and conditions of the application number 95-423. The facility is located in the NW/4 of Sec. 5, T52N, R101W in the county of Park, in the State of Wyoming. This permit shall be effective for a period of three years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/18/95

Date of Issuance

MDR/nc 54128.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-423

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

- VI. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 15 September 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR/nc 54128.LTR

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 95-424R
SPECIAL CONDITIONS
Reference WDEQ/WQD #91-413RRR, and
#94-423R

Burns Brothers Travel Stop, Ft. Bridger, Lagoon

This permit hereby authorizes the applicant:

Burns Bros. Travel Stops, Inc.
516 SE Morrison Suite 1200
Portland, OR 97214

to construct lagoon aeration in cell 1, effluent structure and chlorination facility in cell 2, and to construct a new lined polishing cell that will be cell 3 with discharge structure that will eventually supply a proposed constructed wetlands according to the procedures and conditions of the application number 95-424R. The facility is located in S33 T16N R116W in the county of Uinta, in the State of Wyoming. This permit shall be effective for a period of two from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 5 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
5. of 5 An operation and maintenance manual must be accepted by the DEQ/WQD prior to placing the completed project into operation.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-2-95

Date of Issuance

STATEMENT OF BASIS

General information.

A. Permit Number: 95-424R

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable. A groundwater review was performed for permit #94-423R, and the proposed additional cell will be lined with a 30 mil PVC liner to prevent discharge to groundwater.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not Applicable

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII.

Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, S.W. District Engr. Supervisor, and completed on 09/29/95. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RRT/nc 54378.LTR

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 95-425
SPECIAL CONDITIONS

White Mountain Water & Sewer District - Wastewater Metering Station

This permit hereby authorizes the applicant:

White Mountain Water & Sewer District
P.O. Box 2221
Rock Springs, WY 82902

to construct 75 feet of 10 inch collection pipe and a parshall flume in vault according to the procedures and conditions of the application number 95-425. The facility is located in SW¼ S10 T19N R105W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/18/95
Date of Issuance

RT/nc 54125.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-425

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter XI, Section 9(c)(i)(C) requires a minimum slope for 10 inch collection pipe to be 0.28 foot/100 feet. The application proposes to lay 75 feet of 10 inch line at a grade of 0.13 foot/110 feet.

B. Briefly state the basis for the deviation.

A parshall flume flow measuring vault is being installed into an existing 10 inch collection pipeline. The flume will take 0.5 foot of head to operate. To prevent backwater into the flume the District will relay 75 feet of the 10 inch pipeline down stream from the flume to the next manhole. This relatively short, flat stretch of pipeline is recognized by the District as being a source of solids accumulation, and the District will compensate by performing additional cleanout maintenance at this location.

Cleanout of this flat stretch of line can be performed from each end of the 75 foot length.

- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not Applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, S.W. District Engineering Supervisor, and completed on 15 September 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RT/nc 54125.LTR

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-427
SPECIAL CONDITIONS
81-658RR and 94-511RR

D&B Service Evaporative System

This permit hereby authorizes the applicant:

D&B Service, Inc.
P.O. Box 148
Mountain View, WY 82939

to construct spray evaporative system according to the procedures and conditions of the application number 95-427. The facility is located in E½ and NE¼ S28 T13N R115W in the county of Uinta, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-18-95
Date of Issuance

RT/ks 54725.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-427

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not Applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, S.W. Dist. Engineering Supervisor, and completed on 17 October 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 95-428
SPECIAL CONDITIONS

Town of Sundance Water Distribution and Wastewater Collection System

This permit hereby authorizes the applicant:

Town of Sundance
P.O. Box 542
Sundance, Wyoming 82729
Attn: Mayor James A. Miller

to construct, install or modify a water distribution system and wastewater collection system according to the procedures and conditions of the application number 95-248. The facility is located in Section 6, 7, and 18 in Township 51 North, Range 62 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9-27-95

Date of Issuance

BDM/pr: September 20, 1995 /nc 54217.LTR

cc: Ralph Goodson, P.E., Bearlodge Ltd. Inc., P.O. Box 130, Sundance, WY 82729

STATEMENT OF BASIS

General information.

A. Permit Number: 95-428

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. yes

B. Chapter XII. yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

no

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

no

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

not applicable

B. Briefly state the basis for the deviation.

not applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

not applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

not applicable

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

not applicable

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on September 20, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

BDM/pr: September 20, 1995 /nc 54217.LTR

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 95-429
SPECIAL CONDITIONS
REF/PERMIT #86-138R

Highland Village Subdivision - Water & Sewer Extensions

This permit hereby authorizes the applicant:

Cheyenne BOPU
2100 Pioneer Avenue
Cheyenne, Wyoming 82001

to construct, install or modify water and sewer main extensions according to the procedures and conditions of the application number 95-429. The facility is located in the SE 1/4 of Section 5, T13N, R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the SE District office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SE District office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/29/95

Date of Issuance

RLE/mad 54305.LTR

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 95-429
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- NOT Applicable
- B. Briefly state the basis for the deviation.
- NOT Applicable
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on September 26, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

95-430



THE STATE OF WYOMING

JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-7682	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

October 4, 1995

Mr. Terrell K. Johnson
Sr. Environmental Engineer
Cyprus Shoshone Coal Corporation
P.O. Box 830
Hanna, WY 82327

RE: Submittal for Modification to Permit No. 78-357R

Dear Mr. Johnson:

This letter is a follow up to our phone conversations regarding the above mentioned project. As I indicated to you the Water Quality Division does not require a modification to the above referenced permit since this activity is now permitted through the Land Quality Division of the DEQ.

I am returning you submittal with this letter since you indicated that you have already provided the Land Quality Division with an application to modify the above referenced facility.

If you have any questions regarding this letter please feel free to contact me.

Sincerely,

Gary Steele, P.E.
Southeast District Supervising Engineer
Water Quality Division

GS/mad 54492.LTR

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 95-431
SPECIAL CONDITIONS
93-475

Nordic Ranches Water System Divisions 6 & 7

This permit hereby authorizes the applicant:

Clarence Reinhart
P.O. Box 258
Alpine, WY 83128

to water distribution and storage system extensions according to the procedures and conditions of the application number 95-431. The facility is located in S25 & S26 T36N R119W in the county of Lincoln, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 7 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 7 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 7 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 7 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
5. of 7 An "Operation and Maintenance" manual for the system must be approved by the DEQ/WQD prior to placing the facilities of this permit into operation. Submit the O&M manual to the DEQ/WQD SW District office at 250 Lincoln St.; Lander, WY 82520.
6. of 7 Both well (two total) shall be operational and equipped to produce 120 gpm each no later than 01 July 1996.

PERMIT NO. 95-431

7. of 7 An extra 10,000 gallons of storage capacity shall be constructed concurrently with the pipeline extensions proposed in this permit, as proposed by the applicant (this will bring the total constructed storage to 40,000 gallons). No later than 01 September 1997 water storage capacity shall be permitted and constructed to bring the total storage capacity, serving the distribution system described within this permit application, to a minimum of 46,375 gallons. This time period is given to allow integration of additional storage with plans for future development, but the required 46,375 gallons is to be in service by this date irrespective of whether or not the planned future development is being realized.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

3/11/96

Date of Issuance

RT:ks
61132.ltr

cc: Lincoln Co. Planning

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 95-431
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. No
- B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- Not Applicable
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- Not Applicable
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- Not Applicable
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)
- Not Applicable

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not Applicable

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, S.W. District Engineering Supervisor, and completed on 08 March 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-432
SPECIAL CONDITIONS
REF/PERMIT #

Lynn Brewer Septic System

This permit hereby authorizes the applicant:

Lynn Brewer
P.O. Box 551
Belle Plain, Kansas 67013

to construct, install or modify a septic system according to the procedures and conditions of the application number 95-432. The facility is located in S/2 of the SW/4 of the SW/4 of Section 13, Township 50 North, Range 66 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-5-95
Date of Issuance

BDM/bm: October 2, 1995

b/54428.ltr

cc: Sam Haptonstall, P.O. Box 551, Upton, WY 82730

STATEMENT OF BASIS

General information.

A. Permit Number: 95-432

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. yes

B. Chapter XII. no

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

no

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

no

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

not applicable

B. Briefly state the basis for the deviation.

not applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

not applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

not applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

not applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on October 2, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

BDM/bb/54428.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 95-433
SPECIAL CONDITIONS

Calico Restaurant Sewer

This permit hereby authorizes the applicant:

Jeffrey Davies
P.O. Box 590
Teton Village, WY 83025

to construct about 270 lineal feet of 6-inch PVC sewer with manhole according to the procedures and conditions of the application number 95-433. The facility is located in NW¼ (Lot 2) Section 13, T41N, R117W in the county of Teton, in the State of Wyoming. This permit shall be effective for a period of two (2) from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 5 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
5. of 5 The septic tank baffles must be inspected and repaired as necessary. Each tank must have an adequate number of manholes accessible to the surface to provide access for cleaning all areas of the interceptor. Manhole covers shall have a minimum opening dimension of twenty (20) inches. The interceptors must be inspected regularly and the intercepted grease removed at a frequency that will prevent grease from discharging to the downstream sewer pipe.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9-27-95

Date of Issuance

STATEMENT OF BASIS

General information.

A. Permit Number: 95-433

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

V. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on September 21, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 95-434
SPECIAL CONDITIONS

Honken Veterinary Clinic - Small Wastewater System

This permit hereby authorizes the applicant:

Robert M. Honken
2527 Mountain Valley Drive
Laramie, Wyoming 82070

to construct, install or modify a small wastewater collection and containment system according to the procedures and conditions of the application number 95-434. The facility is located in the NW1/4 of Section 2, T15N, R73W in the county of Albany, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 8. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 8. The applicant will provide immediate oral and/or written notice to the SE District office in accordance with the provisions of Section 9, Chapter III; Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 8. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SE District office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 8. Final Operation and Maintenance Manual - The final O&M manual shall be submitted to the Water Quality Division for review and approval within 60 days of the system being placed into service to allow for a fine tuning period.
- 5 of 8. Variance Granted - Holding Tank Vent Pipes - A variance from requiring vent pipes on the holding tanks is granted because other means of venting the tanks is provided. The vent pipes can be excluded.
- 6 of 8. The intent of the construction authorized by this permit is to provide for the temporary treatment of wastewater until such time that treatment is available through a regional wastewater system. The Laramie Step I Wastewater Facility Plan requires that treatment be provided through a regional system. The facilities authorized by this permit (provided that they fall within the coverage of the Laramie 201 Plan) will be operated under the provisions of the 201 Plan Exemption process administered by the Albany County Planning Commission, the Albany County Board of County Commissioners, the Laramie Planning Commission, and the Laramie City Council. The operation of these facilities will be subject to any review and/or renewal requirements imposed by the 201 Plan Exemption. Finally, these facilities will only be operated until services are available through the approved regional system. These facilities will then be properly abandoned or integrated into the regional system in accordance with the requirements of the Facility Plan, unless the City of Laramie and Albany County jointly authorize an additional extension. If you have any questions contact the Albany County Planning Commission.


Permit #95-434

- 7 of 8. Before the holding tanks, or other important components are covered, the applicant shall contact the Environmental Health Director for the City of Laramie/Albany County (Stephanie Whitman) at 721-5283, to arrange for an inspection of the project. The system shall not be covered or placed into service until this inspection has been conducted and the work has been approved.
- 8 of 8. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-6-95
Date of Issuance

R/E/nc 54482.LTR

Stephanie Whitman, Laramie/Albany County Environmental Health Director
Andy Kasehagen, Albany County Planner

STATEMENT OF BASIS

- .. General information.
- A. Permit Number: 95-434
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- No
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- Yes
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- Chapter XI, Section 43(d) - Requires vent pipes on holding tanks.
- B. Briefly state the basis for the deviation.
- A variance from this requirement has been granted because the design of the facility provides for other means of venting the holding tanks.
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- Not Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 4, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/nc 54482.LTR

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 95-435
SPECIAL CONDITIONS
REF/PERMIT #

Noah Wallis Addition, Lot 1, Block 6 - Water Main Extensions

This permit hereby authorizes the applicant:

Laramie Housing, Inc.
c/o Mary Louise Hanson
703 Ivinson Avenue
Laramie, Wyoming 82070

to construct, install or modify water distribution mains according to the procedures and conditions of the application number 95-435. The facility is located in the NE 1/4 of Section 3, T15N, R73W, and the SE 1/4 of Section 34, T16N, R73W in the county of Albany, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 6. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 6. The applicant will provide immediate oral and/or written notice to the SE District office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 6. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SE District office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 6. Backflow Prevention - A backflow prevention device equal to a double check valve or equivalent approved by the Foundation for Cross-Connection Control, University of Southern California, shall be installed on the fire sprinkler system to protect the public water supply system from cross connection and backflow.

5 of 6. Low Pressure Fire Hydrant Variance Granted - The request for a special low pressure fire hydrant (less than 20 psi) located on the Northern side of Lot 1, Block 6 is hereby granted based on the engineering information submitted and information from the Laramie Fire Department about special procedures they have in place for low pressure fire hydrant operations to ensure that they do not drop below 10 psi. Additionally, this hydrant shall be specially marked as a low pressure hydrant.

6 of 6. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

11/2/95

Date of Issuance

RLE/bb/54758.ltr

STATEMENT OF BASIS

General information.

A. Permit Number: 95-435

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Chapter XI - Yes

Chapter XII - No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter XII, Section 14(b)(i) and (ii) requires a minimum water main pressure of 20 psi at all points in the system for fire protection.

B. Briefly state the basis for the deviation.

The basis of the deviation is that the Laramie Fire Department has requested a special low pressure fire hydrant in this location because of the lack of other hydrants. This line will have no other taps on it other than the low pressure hydrant, and the hydrant will be specially marked. A letter from the Fire Department describes how and why this low pressure hydrant will work. The hydrant will not be allowed to be used below 10 psi as per Laramie Fire Department special operating procedures.

- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

- VI. Deleted

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 31, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/bb/54758.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-436
SPECIAL CONDITIONS

Lot 5, Block 1, Lots 1-5, Block 2, Laramie River Business Park

This permit hereby authorizes the applicant:

Laramie Economic Development Corp.
500 South 3rd Street
Laramie, WY 82070

to construct an extension of the publicly owned distribution and collection systems according to the procedures and conditions of the application number 95-436. The facility is located in NW 1/4 Section 5, T15N, R73W in the county of Albany, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10/26/95

Date of Issuance

GLS/nc 54822.LTR

STATEMENT OF BASIS

- I. General information.
 - A. Permit Number: 95-436
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
 - A. Chapter XI. Yes
 - B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
 - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
Yes
 - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
 - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
N/A
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)
N/A

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on October 20, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

GLS/nc 54822.LTR

R7

**REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION**

Herschler Bldg., 4 West
Cheyenne, Wyoming 82002

PROJECT: Lot 5, Block 1, Lots 1-5, Block 2, Laramie River Business Park

ENGINEER: Robert J. Coffey
Coffey & Assoc., L.L.C.
903 Grand Ave.
Laramie, WY 82070

APPLICANT: Laramie Economic Development Corp.
500 South 3rd Street
Laramie, WY 82070

WATER QUALITY REFERENCE NUMBER: 95-436

APPROVING ENGINEER: Gary Steele 

DATE OF REVIEW: October 4, 1995

ACTION: NOT AUTHORIZED FOR CONSTRUCTION

COMMENTS, PROBLEMS, INADEQUACIES, and QUESTIONS:

- 1 of 3 Chapter XII Section 14(c) of the Water Quality Rules and Regulations require that isolation valves be placed a maximum of 800 feet apart. The plans as submitted have a valve spacing of approximately 1,200 feet.
- 2 of 3 At the crossing of the storm sewer over the proposed water main, additional protection is required. The additional protection can be provided by placing either the water main or the storm sewer in a separate conduit or constructing the storm sewer with water grade piping.
- 3 of 3 For your information only the manhole at station 4+00.72 has the invert out higher than the invert in. Also the distance between the existing manhole and the manhole at station 4+00.72 should be equal to or less than 379.88 feet according to the stationing.

GS/nc 54466.LTR

PERMIT TO CONSTRUCT

x New
Renewal
Modified

PERMIT NO. 95-437
SPECIAL CONDITIONS X

This permit hereby authorizes the applicant:

Sheridan County School District Number 2
P.O. Box 919
Sheridan, WY 82801

to construct, install or modify monitor wells according to the procedures and conditions of the application number 95-437. The facility is located in NE ¼, Section 27, Township 56N, Range 84 West in the county of Sheridan, in the State of Wyoming. This permit shall be effective for a period of two years, (five years maximum) from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming, 82801, phone (307) 672-6457, fax (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- I. After the monitoring well(s) have fulfilled their useful purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. In addition, borings in public use areas, particularly paved streets and alleys, shall be abandoned in accordance with City and/or Highway Department requirements. No monitoring well shall be abandoned without prior approval from the Water Quality Division.
- II. WDEQ/WQD personnel shall be given at least two (2) weeks notice prior to the installation of monitor well(s) and sample collection so that they may be on site if deemed necessary.
- III. The results of any other analyses conducted on soil or water removed from these wells shall be provided to the department as soon as they are available.

IV. ***Environmental Monitoring Program for Groundwater of the State:***

- A. The permittee shall maintain records of all monitoring information for a period of at least 3 years.
- B. Records of monitoring information shall include:
 1. The date, exact place, and time of sampling or measurements;
 2. The name(s) of individual(s) who performed the sampling or measurements;
 3. Sampling procedures and sample preservation accomplished;
 4. The date(s) analyses were performed;
 5. Names of individuals who performed the analyses;
 6. The analytical techniques or methods used; and
 7. The results of such analyses.
 8. Monitor wells shall be sampled and the groundwater analyzed as indicated on the following table:

WELL NAME OR NUMBER	SAMPLING FREQUENCY	ANALYTICAL METHOD(S)	PARAMETER(S) ANALYZED
ALL	QUARTERLY	EPA METHOD 8015 MODIFIED	TPH

All chemical concentrations in this permit are expressed in mg/l unless otherwise noted.

- V. The results of these analyses shall be submitted to the Sheridan office by the last day of the month following the end of each quarter. The first set of results are due upon receipt.

VI. Within ninety (90) days of issuance of this permit, or completion of the installation and sampling of monitoring well(s) authorized by this permit, the Applicant shall submit to WDEQ/WQD a **Report of Investigation**. At a minimum, the *Report of Investigation* shall contain the following information:

- A. A site map which illustrates:
 - 1. physical features (i.e. structures, utilities, etc.).
 - 2. monitoring well locations.
 - 3. surface waters.
- B. Geohydrologic maps and cross sections that clearly describe the subsurface distribution of geologic materials and elevations of groundwater.
- C. Depth to water and product thickness measurements.
- D. Sample collection procedures utilized and analytical results.
- E. A map delineating the extent of the subsurface contamination, including:
 - 1. Location(s) and thickness(es) of contaminated soils.
 - 2. LNAPL (free product) thickness iso-contours.
 - 3. Dissolved (in groundwater) contaminant iso-concentration maps.
- F. A potentiometric surface map showing the direction and gradient of groundwater flow.
- G. Interpretation of the data and summary conclusions of the investigation results.
- H. A recommended **Corrective Action Plan** and schedule for either:
 - 1. Development and implementation of additional **Subsurface Investigation** work.

OR

- 2. Development and implementation of **Corrective Measures** to:
 - a. Remove LNAPL (Free-product).
 - b. Control the migration of LNAPL (free-product)
 - c. Control (contain) the migration of contaminated (dissolved) groundwater.
 - d. Restore the quality of groundwater to within Wyoming groundwater quality standards.


OR

- 3. Development and submittal of **Statement of Basis** to justify **Project (Site) Closure**.


NOTE: All plans and schedules for implementation of Subsurface Investigations, Corrective Measures and Project (Site) Closure require Department of Environmental Quality, Water Quality Division (WDEQ/WQD) approval prior to their implementation.

- VII. The issuance of this permit does not relieve the permittee from obligations to complete the extent of contamination study and any further remedial work which may be required. Depending on the results of the subsurface investigation, additional site investigations or remedial actions may be required by the WQD. An adequate number of well(s) shall be installed to define the nature and extent of the contamination.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/29/95
Date of Issuance

DF/mad 54293.LTR

cc: IPS, Cheyenne

GROUNDWATER POLLUTION CONTROL PROGRAM
REVIEW COMMENTS:
PLANS/SPECIFICATIONS/PROPOSALS/REPORTS

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
1043 COFFEEN AVENUE, SUITE D
SHERIDAN, WYOMING 82801

PROJECT: SITE CHARACTERIZATION

FACILITY: Sheridan County Junior High School

APPLICANT: Sheridan County School District Number 2
P.O. Box 919
Sheridan, WY 82801
Attn: Mr. Loren J. Leichtnam

CONSULTANT: Y Environmental
P.O. Box 433
Sheridan, WY 82801
Attn: Mr. Yon A. Malkuch
Phone: 672-3937

WATER QUALITY DIVISION REFERENCE (PERMIT) NUMBER: 95-437

EXISTING NEW AS BUILT

TITLE: Subsurface Investigation, Sheridan County Junior High, Sheridan, Wyoming

PLANS SPECS PROPOSAL REPORT

DATE ON PROPOSAL/PLANS/REPORT: 9/20/95

IS THIS PROPOSAL SUBMITTED PURSUANT TO:

'CONDITIONS' TO ANY WQD PERMIT? NO YES

AN LOV, NOV OR OTHER ENFORCEMENT? NO YES

REVIEWING GEOLOGIST: Wm Donald Fischer

DATE OF THIS REVIEW: 9/25/95

ACTION: PERMIT TO CONSTRUCT NUMBER 95-437 AUTHORIZED FOR CONSTRUCTION

COMMENTS: GROUNDWATER SECTION

I. SUMMARY OF EXISTING CONTAMINATION:

On August 12, 1993, Pelesky Petroleum Company removed an underground heating oil tank from Sheridan Junior High School, 620 Adair Avenue, Sheridan, Wyoming. During the course of the removal, hydrocarbon contamination was noted in the shallow groundwater in the tank excavation by Joe Carlisle of the DEQ/WQD UST Program. After further inquiry, it was determined that the tank was not eligible for state UST program funding.

The actual amount of hydrocarbon that was released is not precisely known. The heating oil tank had passed a tightness test in 1992. Water was noticed entering the tank the following year, after which it was decided to pump the tank and remove it from service. Records do not indicate a measurable loss of hydrocarbons from the heating oil tank.

II. CONCLUSION OF ADEQUACY OF WORK COMPLETED TO DATE:

The contaminated soil was removed from the site and disposed of at the Sheridan County Landfill. There is no source for continued leaching of hydrocarbon into the subsurface.

III. REQUESTS/REQUIREMENTS/RECOMMENDATIONS:

1. Monitor well(s) shall be installed as per the locations described in the permit application.
2. In order to minimize analytical expenditures, groundwater from the monitor wells shall be initially sampled and analyzed for Total Petroleum Hydrocarbons (TPH) as an initial indicator of hydrocarbon contamination. If initial analytical results reveal levels in excess of 10 milligrams/liter, the DEQ/WQD may require further analytical analyses to determine the levels of individual chemical constituents.
3. Permit to Construct number 95-437 special conditions have been reviewed by and agreed to by Mr. Loren Leichtnam, a representative of Sheridan School District number 2.

END OF REVIEW

ROAD APPLICATION PERMIT

X New
Renewal
Modified

PERMIT NO. 95-438
SPECIAL CONDITIONS

UNOCAL South Casper Creek Field Road Application

This permit hereby authorizes the applicant:

Union Oil Company of California
P.O. Box 2620
Casper, Wyoming 82602-2620
Attention: Bruce Gomendi

to road apply sludge and waste crude oil according to the procedures and conditions of application number 95-438. The application site is located in Sections 2 and 3 in Township 33 North, Range 83 West in the county of Natrona, in the State of Wyoming. This permit shall be effective until November 1, 1995.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), upon the presentation of credentials and during working hours, to have access to inspect the waste source and application site location, for the purpose of compliance with the provisions of this permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 9 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: Northeast District Office, Department of Environmental Quality/Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801, tel. (307) 672-6457, FAX (307) 674-6050.

2 of 9 The permittee shall provide immediate oral and/or written notice to Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.

- 3 of 9 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the Northeast District office on the attached Certification of Completion form.
- a. Date that the road application was completed; and
 - b. Certification the road application was done in accordance with the terms and conditions of the permit; or
 - c. Certification the road application was completed with changes or modifications. Submit the information necessary to clearly indicate the road application as actually performed. This information shall include a contour map depicting only those sections of road that actually received sludge and crude oil.
- 4 of 9 The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
- 5 of 9 Sludge and waste crude oil shall be applied uniformly and incorporated into the road bed. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. sludge and waste crude oil shall not be applied during the period from November 1 to April 10.
- 6 of 9 The application site slope shall not exceed eight percent (8%) for vehicular application.
- 7 of 9 Sludge and waste crude oil application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
- 8 of 9 Only the roads designated in this permit are authorized for application of the sludge and waste crude oil. Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.
- 9 of 9 Any sludge and waste crude oil application after November 1, 1995 must be re-permitted.


AUTHORIZED BY:



Administrator
Water Quality Division

9-27-95

Date of Issuance



Director
Department of Environmental Quality

BDM/pr:mad 54268.LTR

cc: Don Whyde, BLM Platte River Resource Area, Box 2420, Mills, WY 82644

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 95-438
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. No
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- No
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- There are no numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.
- B. Briefly state the basis for the deviation.
- Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

Applicable

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the sludge and waste crude onto the roadbed. Repeated applications of sludge and waste crude on the same sections of road will be monitored by roadbed analyses.

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst and completed on September 25, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

53368.DOC

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 95-439R
SPECIAL CONDITIONS

Wildhorse Estates Subdivision Water and Sewer Systems

This permit hereby authorizes the applicant:

D & A Construction; Alice R. Jones, President
P. O. Box 1328
Thermopolis, Wyoming 82443

to construct a sanitary sewer collection system and a water distribution system according to the procedures and conditions of the application number 95-439R. The facility is located in the NE/4 of Sec. 1, T42N, R95W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10/16/95

Date of Issuance

MDR/mad 54676.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-439R

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

- VI. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 11 October 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 95-440
SPECIAL CONDITIONS

Lyle Neves Leach Field and Septic Tank Installation

This permit hereby authorizes the applicant:

Lyle J. Neves
P. O. Box 13
Burlington, Wyoming 82411

to construct a residential septic tank and leach field system according to the procedures and conditions of the application number 95-440. The facility is located in the NE/4 of Sec. 19, T51N, R96W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-5-95
Date of Issuance

MDR/bb/54394.ltr

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-440

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

- VI. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 29 September 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR/bb/54394.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

mf

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-441
SPECIAL CONDITIONS

Snowy Range Ski Area Sewer Improvements

This permit hereby authorizes the applicant:

Richard Colling
6416 Mountain Mist Ct.
Laramie, WY 82070

to modify the existing wastewater system by replacing the 4" collection line from the Rental Shop to the wastewater plant according to the procedures and conditions of the application number 95-441. The facility is located in NW 1/4 Section 20, T16N, R78W in the county of Albany, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-19-95

Date of Issuance

GLS/ks 54741.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-441

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on October 17, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 95-442
SPECIAL CONDITIONS

Nels H. Anderson Wastewater Facility (Residential Septic System)

This permit hereby authorizes the applicant:

Nels H. Anderson
W296 N7074 Tamron Court
Hartland, WI 53029

to install a residential septic system according to the procedures and conditions of the application number 95-442. The facility is located in SE 1/4 NW 1/4 of Section 34, T19N, R85W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

Issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-5-95

Date of Issuance

GLS/mad 54438.LTR

cc: Nina Adams, Carbon County Planning Director

STATEMENT OF BASIS

General information.

A. Permit Number: 95-442

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

N/A

B. Briefly state the basis for the deviation.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on October 3, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

PERMIT TO CONSTRUCT

x New
Renewal
Modified

PERMIT NO. 95-443
SPECIAL CONDITIONS

Honor Addition Sewer Collection and Water Distribution Systems

This permit hereby authorizes the applicant:

Don W. and Lea S. Johnson
400 Monroe Avenue, #5
Green River, Wyoming 82935

to construct sewer collection and water distribution systems according to the procedures and conditions of the application number 95-443. The facility is located in the SW/4 of Sec. 26, T18N, R107W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-2-95

Date of Issuance

MDR/nc 54379.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-443

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

- VI. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 29 September 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR/nc 54379.LTR

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 95-444
SPECIAL CONDITIONS

Hope Circle Addition Water Distribution and Sewer Collection Systems

This permit hereby authorizes the applicant:

Don W. Johnson
400 Monroe Avenue, #5
Green River, Wyoming 82935

to construct a sanitary sewer collection and domestic water distribution system according to the procedures and conditions of the application number 95-444. The facility is located in the SW/4 of Sec. 29, T18N, R107W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9/29/95

Date of Issuance

MDR/mad 54336.LTR

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 95-444
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- Not Applicable
- B. Briefly state the basis for the deviation.
- Not Applicable
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- Not Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

- VI. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 27 September 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-445
SPECIAL CONDITIONS

Lincoln and Washakie Streets, Sanitary Sewer Reconstruction and Extension

This permit hereby authorizes the applicant:

Town of Dubois; Ronald L. Paris, Mayor
712 Meckem
Dubois, Wyoming 82513

to construct a new 8" diameter sanitary sewer with appurtenance and extensions replacing an outdated 6" diameter system according to the procedures and conditions of the application number 95-445. The facility is located in the SW/4 of Sec. 6, T41N, R106W in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of three years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-5-95
Date of Issuance

MDR/mad 54435.LTR

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 95-445
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- Not Applicable
- B. Briefly state the basis for the deviation.
- Not Applicable
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- Not Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

- VI. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by , Michael D. Roberts, P. E., Northwest District Engineer, and completed on 2 October 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 95-446
SPECIAL CONDITIONS
REF/PERMITS #95-045, 95-220, 95-375

Brooks/Mills Watermain Interconnection

This permit hereby authorizes the applicant:

Town of Mills
P.O. Box 789
Mills, Wyoming 82644
Attention: Mayor Robert Goff

to construct, install or modify watermains according to the procedures and conditions of the application number 95-446. The facility is located in NW/4 of Section 11, Township 33 North, Range 80 West in the county of Natrona, in the State of Wyoming. This permit shall be effective for a period of one year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-11-95

Date of Issuance

BDM/bm: October 6, 1995
b/54531.ltr

cc: Colin Cunningham, P.E., WLC, 200 Pronghorn Street, Casper, WY 82801

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 95-446
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. no
- B. Chapter XII. yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- no
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- no
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- not applicable
- B. Briefly state the basis for the deviation.
- not applicable
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- not applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

not applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

not applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on October 6, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

BDM/bb/54531.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 95-447
SPECIAL CONDITIONS

Matteson Avenue Sewer Extension: Town of Basin, Wyoming

This permit hereby authorizes the applicant:

Town of Basin, Wyoming
P. O. Box 599
Basin, Wyoming 82410

to construct an 8" diameter sewer line extension along Matteson Avenue according to the procedures and conditions of the application number 95-447. The facility is located in the SW/4 of Sec. 21, T53N, R91W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-5-95

Date of Issuance

MDR/bb/54395.ltr

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 95-447
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
Not Applicable
- B. Briefly state the basis for the deviation.
Not Applicable
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
Not Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

- VI. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 29 September 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR/bb/54395.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 95-448
SPECIAL CONDITIONS

WYMT Feeding Company: Worland Operations Livestock Feedlot

This permit hereby authorizes the applicant:

WYMT Feeding Company, Inc.
Route 3, Box 58-C
Torrington, Wyoming 82240

To construct wastewater runoff, collection, retention, disposal and control structures which are integral components of a livestock feedlot defined as a concentrated animal feeding operations facility according to the procedures and conditions of the application number 95-448. The facility is located in the SE/4 of Sec. 35, T47N, R93W in the county of Washakie, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 6 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 6 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 6 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 6 Operation of this facility authorized under Permit to Construct No. 95-448 shall not commence until an Operations and Maintenance Manual for this facility has been reviewed and approved by the Department of Environmental Quality/Water Quality Division.
5. of 6 Groundwater monitor wells on site and permitted under As-Built Permit No. 95-488 are an integral component of this Permit to Construct. The sampling procedure is to be biannual with samples taken in February and August for a period of two years. The water quality analyses at the end of this two year period will determine if the frequency of sampling needs to be modified. The samples are to be analyzed for the following compounds and properties:
 - (1) ammonia
 - (2) nitrates
 - (3) nitrites
 - (4) chlorides
 - (5) total dissolved solids
 - (6) pH
 - (7) static water level


Sampling results are to be provided to the DEQ/WQD Lander office within 30 days of sampling. A groundwater gradient map is to be prepared with each sampling event. Any degrading of sample quality in excess of limits established for Class III groundwater may require additional sampling and corrective action.

6 of 6 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

1-5-96

Date of Issuance

MDR/bb/60014.ltr

STATEMENT OF BASIS

General information.

A. Permit Number: 95-448

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Applicable

V. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

Maintenance of drainage ditches and optimum thickness of manure pack required to route wastewater and runoff into a wastewater collection pond for periodic transfer to wastewater retention ponds will be employed. The collection pond and the retention ponds are to be sealed with

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

a soil-bentonite mixture to restrict leakage into the groundwater. Both the collection and the retention ponds will be kept moist to ensure integrity of the clay-soil bottom. Periodic application of the water stored in the retention ponds may be applied at established agronomic rates to agricultural land approximately 1/4 mile south of the ponds in order to maintain sufficient storage capacity.

- B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

Wastewater will be contaminated with animal manure wastes. It will degrade groundwater if it is allowed to penetrate into the groundwater aquifer.

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

The nature of the soils at the project site consists largely of silt and loam with minor amounts of naturally occurring bentonite. The soil will not prevent discharge to the groundwater without additional bentonite and satisfactorily blending this mixture to acceptable impermeability standards.

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

Drainage control ditches, a wastewater collection pond, water transfer equipment, wastewater retention ponds and a maintained manure pack will be employed to ensure groundwater and surface water protection.

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

The facility is designed and will be operated in such a manner so that the groundwater aquifer should not be degraded below the existing Class III standard.

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

No activity which allows for the exceeding of Class III standards for groundwater are planned for this facility.

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

Five groundwater monitoring wells have been constructed at strategic locations on the facility. These wells are to be sampled biannually in February and August for the first two years of operation of this facility. Sample results are to be provided to the DEQ/WOD office in Lander within 30 days of sampling. Failure to supply these analysis reports in a timely manner will constitute a violation. Exceeding established contaminant standards also constitutes a violation. Steps to bring the groundwater standards back to established limits will be employed. These may include increased sampling frequency until the situation is resolved.

VI. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 28 December 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR/bb/60014.ltr

PERMIT TO CONSTRUCT

New
Renewal
 Modified- CHANGE OF OWNER

PERMIT NO. 95-449
SPECIAL CONDITIONS
REF/PERMIT #92-152

High Plains Addition-Green River

This permit hereby authorizes the applicant:

City of Green River
50 East 2nd North
Green River, WY 82935

to construct a water supply and wastewater collection system according to the procedures and conditions of the application number 92-152. The facility is located in the NW1/4 of Section 35, T18N, R107W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective for a period of two(2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; telephone (307) 332-3144, FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any infringement of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

11-16-92
Date of Issuance

LR/nc 54363.LTR
cc: Robert I. Harris, FMC Corporation
Lynette J. Boomgaarden, Holland & Hart
Randy Taylor, DEQ/WQD, Lander

95-449

PERMIT TRANSFER REQUEST

Date: September 28, 1995

RECEIVED

Water Quality Division
Department of Environmental Quality
122 West 25th Street
Herschler Building
Cheyenne, WY 82002

SEP 28 1995

WATER QUALITY DIVISION
WYOMING

To Whom It May Concern:

FMC Wyoming Corporation transferred the facility associated with Permit Number 92-152R (Original Owner)

to the developer of the High Plains Addition in Green River, Wyoming. Upon completion of the water supply and wastewater collection system constructed to serve the High Plains Addition, the City of Green River assumed ownership and control of the facility. According to DEQ files, (New Owner)

FMC Wyoming Corporation remains the Permittee under Permit Number 92-152. It is understood that by law, the terms and conditions of the original permit transferred to and became the responsibility of the City of Green River at the time the City assumed ownership and control of the property. Nevertheless, in order to clarify the ownership status in DEQ's files, we request that you formally transfer the permit to the new owner's name and issue a modified permit reflecting the transfer of ownership in accordance with section 10(c) and (d) of Chapter III, Wyoming Water Quality Rules and Regulations. The new owner agrees to accept and be bound by the provisions of the permit and any amendments, agrees to operate the facility in accordance with the approved permit and agrees to accept responsibility for the facility's compliance with applicable standards and permit conditions, including the responsibility to perform any necessary corrective actions.

Norman C. Stark
City of Green River

Robert I. Harris
FMC Corporation

Name Norman C. Stark, Mayor

Robert I. Harris, Vice President

Address 50 East 2nd North

Address 1735 Market Street

Green River, WY 82935

Philadelphia, PA 19103

Telephone (307) 872-0500

Telephone (215) 299-6000

PERMIT TO CONSTRUCT

New
Renewal
 Modified- CHANGE OF OWNER

PERMIT NO. 95-450
SPECIAL CONDITIONS
REF/PERMIT #68-118

Green Acres Recreation Area

This permit hereby authorizes the applicant:

City of Green River
50 East 2nd North
Green River, WY 82935

to construct water and sewage disposal systems according to the procedures and conditions of the application number 68-118. The facility is located in the county of Sweetwater, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: District Engineer, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; telephone (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

May 6, 1969
Date of Issuance

LR/nc 54367.LTR

cc: Robert I. Harris FMC Corporation
Lynnette J. Boomgaarden, Holland & Hart
Randy Taylor, DEQ/WQD, Lander

95-450

PERMIT TRANSFER REQUEST

Date: September 28, 1995

RECEIVED

SEP 28 1995

Water Quality Division
Department of Environmental Quality
122 West 25th Street
Herschler Building
Cheyenne, WY 82002

WATER QUALITY DIVISION
WYOMING

To Whom It May Concern:

In 1987, FMC Corporation transferred ownership of the facility associated with
(Original Owner)
Permit Number 68-118 to the Green River Recreation Club. Subsequently, the Green River
Recreation Club donated the facility to the City of Green River
(New Owner)

However, according to DEQ files, Permit Number 68-118 has never been transferred to the new owner. It is understood that by law, the terms and conditions of the original permit were automatically transferred to and became the responsibility of the City of Green River at the time the City assumed ownership and control of the property. Nevertheless, in order to clarify the ownership status in DEQ's files, we request that you formally transfer the permit to the new owner's name and issue a modified permit reflecting the transfer of ownership in accordance with section 10(c) and (d) of Chapter III, Wyoming Water Quality Rules and Regulations. The new owner agrees to accept and be bound by the provisions of the permit and any amendments, agrees to operate the facility in accordance with the approved permit and agrees to accept responsibility for the facility's compliance with applicable standards and permit conditions, including the responsibility to perform any necessary corrective actions.

Norman C. Stark
City of Green River

Robert I. Harris
FMC Corporation

Name Norman C. Stark, Mayor

Name Robert I. Harris, Vice President

Address 50 East 2nd North

Address 1735 Market Street

Green River, WY 82935

Philadelphia, PA 19103

Telephone (307) 872-0500

Telephone (215) 299-6000