PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-451
SPECIAL CONDITIONS
REF/PERMIT #

Buffalo Dormitory Monitor Wells

This permit hereby authorizes the applicant:

Grand Teton National Park
P.O. Drawer 170
Moose, WY 83012

to install three (3) groundwater monitor wells according to the procedures and conditions of the application number 95-451. The facility is located in NW¼ Section 26, T45N, R114W in the county of Teton, in the State of Wyoming. This permit shall be effective for a period of two (2) from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Field Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 5 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis."

5. of 5 Permit conditions related to monitoring are included in Attachment I and Attachment II.

AUTHORIZED BY:

Administrator
Water Quality Division

12-8-95
Date of Issuance

Director
Department of Environmental Quality

JH/jyi
b/55504.ltr

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-451

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

V. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on December 1, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

ATTACHMENT I

I. After the monitoring well(s)/piezometer(s) have fulfilled their useful purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. In addition, borings in public use areas, particularly paved streets and alleys, shall be abandoned in accordance with City and/or Highway Department requirements. No monitoring well/piezometer shall be abandoned without prior approval from the Water Quality Division.

II. WDEQ/WQD personnel shall be given at least two (2) weeks notice prior to the installation of monitor well(s)/piezometer(s) and sample collection so that they may be on site if deemed necessary.

III. The applicant is responsible for obtaining any Permits required by the State Engineer's Office (777-7354).

IV. The results of any other analyses conducted on soil or water removed from these wells/piezometers or boreholes shall be provided to the department as soon as they are available.

V. ***Environmental Monitoring Program for Groundwater of the State:***

A. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.

B. The permittee shall maintain records of all monitoring information for a period of at least 3 years.

C. Records of monitoring information shall include:

1. The date, exact place, and time of sampling or measurements;
2. The name(s) of individual(s) who performed the sampling or measurements;
3. Sampling procedures and sample preservation accomplished;
4. The date(s) analyses were performed;
5. Names of individuals who performed the analyses;
6. The analytical techniques or methods used; and
7. The results of such analyses.
8. Monitor wells shall be sampled and the groundwater analyzed as indicated on the following table:

WELL NAME OR NUMBER	SAMPLING FREQUENCY	ANALYTICAL METHOD(S)	PARAMETER(S) ANALYZED	PERMIT LIMIT*
------	------	EPA 8015 Modified .8260 BETX	TPH	------

**** End of Attachment I Conditions - See Following Attachment II Conditions ****

ATTACHMENT II

VI. The results of these analyses shall be submitted to the Lander office at 250 Lincoln. The first set of results are due within 30 days of sampling.

VII. Pursuant to Wyoming Water Quality Rules and Regulations, Chapter XI, Section 63(A), a deviation is hereby granted for those well(s)/piezometer(s) prevented by physical limitations to adherence to the requirements on minimum depths of seal below the ground surface as detailed in Chapter XI, Part G. However, a sufficient seal shall be installed according to standard engineering practice.

VIII. **Field Documentation of Design, Construction and Installation of Monitoring Wells:**

A. The following information shall be documented during actual construction and installation of monitoring wells. The information shall be submitted to the Water Quality Division before or at the time of the first monitoring report.

1. Date/time of construction.
2. Person developing information/other person(s) on site and their association to the project.
3. Drilling method and if drilling fluid was used.
4. Well location (± 0.5 ft.).
5. Well depth (± 0.1 ft.).
6. Bore hole diameter and well casing diameter.
7. Drilling and lithologic logs (including visual, olfactory and vapor detection observations).
8. Casing material.
9. Screen materials and design/location.
10. Casing and screen joint type.
11. Screen slot size/length.
12. Filter pack material/size, grain analysis.
13. Filter pack volume calculated/actually installed.
14. Filter pack placement method/location.
15. Sealant (annular space) materials.
16. Sealant volume used.
17. Sealant placement method/location.
18. Surface seal design/construction.
19. Well development procedure used.
20. Type of protective well cap (top and bottom).
21. Surveyed elevation (± 0.01 ft. Mean Sea Level) of:
    a. ground surface
    b. surveyor's well reference point
    c. top of well casing
    d. top of protective structure
22. Location of well number stamp or identification marking.
23. Detailed 'as-built' construction drawing of well, including dimensions to all well features. *NOTE: The detailed drawing(s) to be submitted must indicate all well features with relation to stratigraphic sections.*
24. Method of down hole equipment decontamination between wells.

IX. All downhole equipment shall be de-contaminated between wells (borings) to minimize the potential for cross-contamination.

X. Borehole cuttings must be screened and disposed of properly. Contaminated cuttings must be disposed of at a site approved by the WDEQ's Solid and Hazardous Waste Management Division.

XI. The monitoring well/piezometer shall be developed by the use of a pump or bailer so that representative groundwater samples can be collected.

XII. Water which is collected during monitoring well/piezometer development or sampling must be disposed of properly. The Applicant must contact the City (or applicable owner) for authorization prior to disposal into a local storm sewer, sanitary sewer, wastewater treatment plant, or other facility.

XIII. Well caps shall be kept locked at all times other than for monitoring purposes. Any tampering with the monitor well(s)/piezometer(s) shall be reported immediately to the Division. The wells shall be clearly numbered using either a stamp to permanently engrave the number into the steel top or by writing the number in the wet concrete of the base.

XIV. When PVC casing is used, the casing shall be installed using threaded joints, couplings, or mechanical connectors without the use of solvents or glues to hold the casing sections together.

XV. In accordance with Section 13(a)(iv) of Chapter III of WDEQ/WQD rules and regulations, the following items relating to monitoring well/piezometer construction contained in Sections 64 - 69 of Part G of Chapter XI of WDEQ/WQD rules and regulations take precedence over permit application content and shall be implemented when the well(s)/piezometer(s) are constructed, installed and developed:

A. To minimize the entrance of fine grained material into the monitoring well/piezometer, the filter pack shall be designed to be compatible with the perforation size and the geologic materials encountered within the perforated interval. The filter pack shall extend to a minimum of one (1) foot above the screened interval.

B. Filter pack, annular seal, and surface seal material shall be entered into the monitoring well/piezometer in a manner such that no voids or bridging occur.

C. A minimum two (2) foot thickness of bentonite or bentonite grout is required at the top of the filter pack to serve as an annular seal. After the bentonite has been placed in the annular space, it shall be hydrated to insure a proper seal.

D. The annular space above the bentonite seal to within one foot (1') of the surface will be sealed with neat cement grout, sand-cement grout, bentonite, or concrete according to the specifications provided in WQD Chapter XI, Section 65(c)(i-viii).

E. A protective casing shall be cemented into place with the upper one (1) foot of the annular space completed in cement, forming a concrete apron sloping away from the monitoring well/piezometer.

F. A top and bottom cap of the same material as the monitoring well/piezometer casing shall be installed to prevent sediment and surface water from entering the monitoring well/piezometer.

XVI. Prior to sampling, monitoring well(s)/piezometer(s) shall be purged until a minimum of three (3) casing volumes have been removed, or until purged dry, whichever occurs first. Sample collection, preservation, transportation and chemical analytical procedures shall be completed in accordance with WQD and EPA standard procedures.

XVII. Within ninety (90) days of issuance of this permit, or completion of the installation and sampling of monitoring well(s)/piezometer(s) authorized by this permit, the Applicant shall submit to WDEQ/WQD a ***Report of Investigation***. At a minimum, the *Report of Investigation* shall contain the following information:

A. A chronology of events leading up to the investigation.

B. A site map which illustrates:

1. physical features (i.e. structures, utilities, etc.).
2. monitoring well/piezometer/test pit/borehole locations.
3. locations and use (i.e. domestic, irrigation, stock) of municipal drinking water and private groundwater supply wells existing within 1 mile of the site.
4. surface waters.
5. existing treatment, recovery and containment systems.

C. Geohydrologic maps and cross sections that clearly describe the subsurface distribution of geologic materials and elevations of groundwater.

D. Depth to water and product thickness measurements.

E. Sample collection procedures utilized and analytical results.

F. A map delineating the extent of the subsurface contamination, including:

1. Location(s) and thickness(es) of contaminated soils.
2. LNAPL (free product) thickness iso-contours.
3. Dissolved (in groundwater) contaminant iso-concentration maps.

G. A potentiometric surface map showing the direction and gradient of groundwater flow.

H. Interpretation of the data and summary conclusions of the investigation results.

I. A recommended ***Corrective Action Plan*** and schedule for **either:**

1. Development and implementation of additional ***Subsurface Investigation*** work.

OR

2. Development and implementation of ***Corrective Measures*** to:

a. Remove LNAPL (Free-product).
b. Control the migration of LNAPL (free-product)
c. Control (contain) the migration of contaminated (dissolved) groundwater.
d. Restore the quality of groundwater to within Wyoming groundwater quality standards.

OR

3. Development and submittal of ***Statement of Basis*** to justify ***Project (Site) Closure***.

NOTE: **All plans and schedules for implementation of Subsurface Investigations, Corrective Measures and Project (Site) Closure require Department of Environmental Quality, Water Quality Division (WDEQ/WQD) approval <u>prior</u> to their implementation.**

J. ***Sampling and Analysis Plan (SAP)*** for continued groundwater monitoring and reporting. The SAP shall include:

1. Proposed format for reporting data.
2. Proposed frequency of sampling and reporting events.
3. A site map showing physical features and the location of monitoring wells.
4. Proposed parameters for water sample analyses and lab analytical procedures. The proposed parameters for analyses must include those constituents which are characteristic of the suspected contamination.
5. Description of sampling procedures to be followed, including:

   a. A description of (or reference to) groundwater sampling equipment to be used.

   b. QA/QC plan (including decontamination procedures) to be used.

6. Mean sea level elevations of the top of the casing/measuring point and depth to water of the monitoring wells.

7. A potentiometric surface map illustrating the direction and gradient of groundwater flow.

8. Time vs. concentration graph illustrating historical change in groundwater monitoring elevations and contaminant concentrations at each monitoring well/piezometer over time for each monitoring and/or sampling event.

XVIII. The issuance of this permit does not relieve the permittee from obligations to complete the extent of contamination study and any further remedial work which may be required. Depending on the results of the subsurface investigation, additional site investigations or remedial actions may be required by the WQD. An adequate number of well(s)/piezometer(s) shall be installed to define the nature and extent of the contamination.

**** End of Attachment II Conditions ****

JH/bb/55504.ltr

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-452R
SPECIAL CONDITIONS

Lundberg Residence Septic System

This permit hereby authorizes the applicant:

Max Lundberg
P.O. Box 1947
Pinedale,WY 82941

to construct a small wastewater system according to the procedures and conditions of the application number 95-452R. The facility is located in SW¼ S35 T34N R109W in the county of Sublette, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

10-24-95
Date of Issuance

RT/nc 54823.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-452R

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not Applicable

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, S.W. District Engineering Supervisor, and completed on 20 October 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RT/nc 54823.LTR

PERMIT TO CONSTRUCT

x New
Renewal
Modified

PERMIT NO. 95-453
SPECIAL CONDITIONS

Maxfield Farms - Lingle West Feedlot - Scale House Septic System

This permit hereby authorizes the applicant:

Maxfield Farms
120 East 22nd Avenue, P.O. Box C
Torrington, Wyoming 82240

to construct, install or modify a business/domestic septic system with drain field according to the procedures and conditions of the application number 95-453. The facility is located in the NE1/4 of Section 15, T25N, R63W in the county of Goshen, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 4. The applicant will provide immediate oral and/or written notice to the SE District office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SE District office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

10-12-95
Date of Issuance

RLE/nc 54594.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-453

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 10, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/nc 54594.LTR

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-454
SPECIAL CONDITIONS
Reference Permit 83-630

1619 COMMERCIAL AVENUE NON-DOMESTIC WASTE SEPTIC SYSTEM

This permit hereby authorizes the applicant:

Sheridan Commercial Park
2986 US Highway 87
Sheridan, WY 82801
Attention: Mr. Brad Waters

to construct, install or modify a non-domestic waste septic system according to the procedures and conditions of the application numbers 95-454 and 83-630. The facility is located in the SE/4 of the SE/4 of Section 35 of T56N R84W in the county of Sheridan, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 2 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

2 of 2 Once municipal sewer service is available, the applicant shall disconnect and abandon the site septic systems and connect to the wastewater collection system.

AUTHORIZED BY:

Administrator
Water Quality Division

11/1/95
Date of Issuance

Director
Department of Environmental Quality

DRM/pr/ks
54839.ltr

xc: Elmer Kuball, AE, 1325 Sugarview Dr., Sheridan, 82801
Edith Johnson-LaMeres, City of Sheridan, POB 848, Sheridan, 82801
Mike Evans, Sheridan County, 224 N. Main St., Ste. B8E, Sheridan, 82801

Enclosure: Statement of Basis

STATEMENT OF BASIS

General information.

A. Permit Number: 95-454

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of Section VI. from the Statement of Basis.)

N/A. The existing 300 gallon per day (gpd) domestic waste septic system will still operate as a simple hydrologic system, although it will now receive 50 gpd of compatible non-domestic waste potato wash water. No adverse environmental impacts are anticipated with the change in the waste source for the facility.

Under the 201 Agreement, the City of Sheridan and Sheridan County have provided written authorization for a temporary exemption. The applicant has indicated he will connect to the municipal sewer system when it is available at the site.

The construction of a separate septic system for domestic waste is currently under review by Sheridan County.

VI. N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Donald R. McKenzie, Northeast District Engineering Supervisor, and completed on October 17, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

R7

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-455
SPECIAL CONDITIONS

Aspen Park

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities
2100 Pioneer Ave.
Cheyenne, WY 82001

to construct an extension of the publicly owned distribution and collection systems according to the procedures and conditions of the application number 95-455. The facility is located in SW 1/4 Section 12 & NW 1/4 Section 13, T14N, R67W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 4 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

10/26/95
Date of Issuance

GLS/nc 54817.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-455

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on October 20, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

GLS/nc 54817.LTR

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-456
SPECIAL CONDITIONS
REF/PERMIT # 95-277

Lucerne School Septic Tank

This permit hereby authorizes the applicant:

Hot Springs County School District No. 1
415 Spring View
Thermopolis, WY 82443

to install a 1000 gallon septic tank and 4 inch PVC piping according to the procedures and conditions of the application number 95-456. The facility is located in SW¼ Section 32, T44N, R94W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

10-5-95
Date of Issuance

JH/jyi/nc 54453.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-456

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

V. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on October 3, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JH/jyi/nc 54453.LTR

PERMIT TO CONSTRUCT

x New
Renewal
Modified

PERMIT NO. 95-457
SPECIAL CONDITIONS

Lovell Game Warden Residence Septic Tank and Leach Field

This permit hereby authorizes the applicant:

Wyoming Game and Fish Department
955 Road 18
Lovell, Wyoming 82431

to construct a septic tank and leach field system according to the procedures and conditions of the application number 95-457. The facility is located in the SW/4 of Sec. 1, T56N, R95W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any asion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

10-12-95
Date of Issuance

MDR/bb/54534.ltr

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-457

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

VI. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 6 October 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR/bb/54534.ltr

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

XX New
Renewal
Modified

PERMIT NO. 95-458
SPECIAL CONDITIONS

Kaiser Francis Oil Company, Statewide Anode

This permit hereby authorizes the applicant:

Kaiser Francis Oil Company
c/o David Rodawalt, Regional Manager
11722 East Highway 80 East
Odessa, TX 79765

to construct, install or modify deep bed anode system according to the procedures and conditions of the application number 95-458. The facility is located in statewide, in the State of Wyoming. This permit shall be effective for a period of five years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: UIC Program Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 5. An unlimited number of cathodic protection deep anode beds may be installed under this permit statewide. This authorization applies to Kaiser Francis Oil Company and all subsidiary companies operating in Wyoming. All such facilities shall be installed in accordance with the conditions of this permit and plans and specifications submitted in permit to construct application number 95-458.

2 of 5. After the deep anode beds have fulfilled their useful purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. Within 45 days after a well has been plugged and abandoned, the owner shall file a plugging record with WQD.

3 of 5. In addition to the anode bed construction information submitted with the permit application, the following items relating to construction shall be implemented when the anode beds are installed: All aquifers encountered while drilling shall be isolated from one another using a bentonite seal of at least 2 feet in vertical dimension. Each separate aquifer penetrated shall require a separate breather pipe. Each aquifer shall remain in hydrologic isolation from each other if they were isolated prior to installation.

4 of 5. Within 45 days after the anodes are installed, as-built construction plans shall be submitted to the DEQ/WQD, detailing how groundwater was protected during installation.

5 of 5. If it becomes necessary to wet any anode installed under this permit, only water from an approved public water supply shall be used unless DEQ/WQD is first supplied with an analyses of the water for approval. Waters that originate in sources other than an approved public water supply shall not be used unless first approved.

AUTHORIZED BY:

Administrator
Water Quality Division

10-12-95
Date of Issuance

Director
Department of Environmental Quality

RFL/nc 54485.LTR

cc: David H. Scriven, P.E.
Western States Mining Consultants
770 West Collins, Suite 200
Casper, WY 82601

STATEMENT OF BASIS

I. Permit Number: 95-458

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. This permit covers deep groundbed anodes statewide. It has been reviewed for general conformance with regulations found in Chapter XI, Part G covering construction of wells. There are no specific regulations covering deep groundbed anodes.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Robert Lucht, P.E., UIC Program Supervisor and completed on October 4, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RFL/nc 54485.LTR

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-459R
SPECIAL CONDITIONS

Rock Springs Pipeline - Phase XII Wind River Tank & Stagecoach Transmission Pipeline

This permit hereby authorizes the applicant:

Green River-Rock Springs-Sweetwater County Joint Powers Water Board
P.O. Box 1299
Green River, WY 82935

to construct 2MG concrete water storage tank and transmission pipelines according to the procedures and conditions of the application number 95-459R. The facility is located in S½ S22, N½ S28, N½ S29; T19N R105W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective for a period of three years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

10-24-95
Date of Issuance

RRT/bb/54782.ltr

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-459R

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not Applicable

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, S.W. District Engineering Supervisor, and completed on 18 October 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RRT/bb/54782.ltr

PERMIT TO CONSTRUCT

x New
Renewal
Modified

PERMIT NO. 95-460
SPECIAL CONDITIONS
REF/PERMIT #95-121

Frontier Feedlot - Preliminary Monitoring Wells

This permit hereby authorizes the applicant:

Shawn Madden
Route 3, Box A-1
Torrington, Wyoming 82240

to construct, install or modify groundwater monitoring wells and soil borings according to the procedures and conditions of the application number 95-460. The facility is located in the NW1/4 of Section 7, T24N, R61W in the county of Goshen, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 20. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 20. The applicant will provide immediate oral and/or written notice to the SE District office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 20. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SE District office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 20. A 4th soil boring shall be accomplished generally in the area directly east of the east end of retention pond A as discussed with the engineer.

5 of 20. Sufficient water level elevations of the abandoned man-made irrigation channel shall be taken to determine if the water in this channel is connected to the groundwater system and whether or not it has an effect on the local groundwater gradients.

6 of 20. The groundwater depths at the 4 soil boring locations and the existing wells (as possible) will be determined before the monitoring wells are installed. If the above information indicates a dramatically different groundwater flow direction than that assumed such that the proposed locations of the monitoring wells will need to be drastically changed; then the WQD should be contacted and consulted before installation of the monitoring wells at significantly different locations proceeds.

7 of 20. A report on the findings of this investigation shall be provided to the WQD as soon as possible after completion and shall include all information as identified in the remaining permit conditions.

Conditions for the Construction of Groundwater Monitoring Wells & Piezometers:

8 of 20. After the monitoring well(s)/piezometer(s) have fulfilled their useful purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. In addition, borings in public use areas, particularly paved streets and alleys, shall be abandoned in accordance with City and/or Highway Department requirements.

No monitoring well/piezometer shall be abandoned without prior approval from the Water Quality Division.

9 of 20. WDEQ/WQD personnel shall be given at least two (2) days notice prior to the installation of monitor well(s)/piezometer(s) and sample collection so that they may be on site if deemed necessary.

10 of 20 The applicant is responsible for obtaining any Permits required by the State Engineer's Office (777-7354).

11 of 20. The results of any analyses conducted on soil or water removed from these wells/piezometers or boreholes shall be provided to the department as soon as they are available.

12 of 20 ***Environmental Monitoring Program for Groundwater of the State:***

A. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.

B. The permittee shall maintain records of all monitoring information for a period of at least 3 years.

C. Records of monitoring information shall include:

1. The date, exact place, and time of sampling or measurements;
2. The name(s) of individual(s) who performed the sampling or measurements;
3. Sampling procedures and sample preservation accomplished;
4. The date(s) analyses were performed;
5. Names of individuals who performed the analyses;
6. The analytical techniques or methods used; and
7. The results of such analyses.

13 of 20 Pursuant to Wyoming Water Quality Rules and Regulations, Chapter XI, Section 63(A), a deviation is hereby granted for those well(s)/piezometer(s) prevented by physical limitations to adherence to the requirements on minimum depths of seal below the ground surface as detailed in Chapter XI, Part G. However, a sufficient seal shall be installed according to standard engineering practice.

14 of 20 **Field Documentation of Design, Construction and Installation of Monitoring Wells:**

A. The following information shall be documented during actual construction and installation of monitoring wells. The information shall be submitted to the Water Quality Division before or at the time of the first monitoring report.

1. Date/time of construction.
2. Person developing information/other person(s) on site and their association to the project.
3. Drilling method and if drilling fluid was used.
4. Well location (± 0.5 ft.).
5. Well depth (± 0.1 ft.).
6. Bore hole diameter and well casing diameter.

7. Drilling and lithologic logs (including visual, olfactory and vapor detection observations). *(See attached '<u>Borehole Installation Diagram</u>').*
8. Casing material.
9. Screen materials and design/location.
10. Casing and screen joint type.
11. Screen slot size/length.
12. Filter pack material/size, grain analysis.
13. Filter pack volume calculated/actually installed.
14. Filter pack placement method/location.
15. Sealant (annular space) materials.
16. Sealant volume used.
17. Sealant placement method/location.
18. Surface seal design/construction.
19. Well development procedure used.
20. Type of protective well cap (top and bottom).
21. Surveyed elevation (± 0.01 ft. Mean Sea Level) of:
    a. ground surface
    b. surveyor's well reference point
    c. top of well casing
    d. top of protective structure
22. Location of well number stamp or identification marking.
23. Detailed 'as-built' construction drawing of well, including dimensions to all well features. *(See attached '<u>Monitor Well Installation Diagram</u>')*
    NOTE: The detailed drawing(s) to be submitted must indicate all well features with relation to stratigraphic sections.
24. Method of down hole equipment decontamination between wells.

15 of 20 The monitoring well/piezometer shall be developed by the use of a pump or bailer so that representative groundwater samples can be collected.

16 of 20 Well caps shall be kept locked at all times other than for monitoring purposes. Any tampering with the monitor well(s)/piezometer(s) shall be reported immediately to the Division. The wells shall be clearly numbered using either a stamp to permanently engrave the number into the steel top or by writing the number in the wet concrete of the base.

17 of 20 When PVC casing is used, the casing shall be installed using threaded joints, couplings, or mechanical connectors without the use of solvents or glues to hold the casing sections together.

18 of 20 In accordance with Section 13(a)(iv) of Chapter III of WDEQ/WQD rules and regulations, the following items relating to monitoring well/piezometer construction contained in Sections 64 - 69 of Part G of Chapter XI of WDEQ/WQD rules and regulations take precedence over permit application content and shall be implemented when the well(s)/piezometer(s) are constructed, installed and developed:

A. The borehole diameter shall be at least four (4) inches larger in diameter than the casing diameter.

B. For water table (unconfined) aquifers, the screened interval shall extend at least two (2) feet above the highest expected groundwater level and five (5) feet below the lowest expected water table. Monitoring well(s)/piezometer(s) installed in confined and semi-confined aquifers shall be constructed in accordance with Chapter XI, Section 68 of Water Quality Division Rules and Regulations. Factory screen or slotted casing is recommended for the perforated interval.

C. To minimize the entrance of fine grained material into the monitoring well/piezometer, the filter pack shall be designed to be compatible with the perforation size and the geologic materials encountered within the perforated interval. The filter pack shall extend to a minimum of one (1) foot above the screened interval.

D. Filter pack, annular seal, and surface seal material shall be entered into the monitoring well/piezometer in a manner such that no voids or bridging occur.

E. A minimum two (2) foot thickness of bentonite or bentonite grout is required at the top of the filter pack to serve as an annular seal. After the bentonite has been placed in the annular space, it shall be hydrated to insure a proper seal.

F. The annular space above the bentonite seal to within one foot (1') of the surface will be sealed with neat cement grout, sand-cement grout, bentonite, or concrete according to the specifications provided in WQD Chapter XI, Section 65(c)(i-viii).

G. A protective casing shall be cemented into place with the upper one (1) foot of the annular space completed in cement, forming a concrete apron sloping away from the monitoring well/piezometer.

H. A top and bottom cap of the same material as the monitoring well/piezometer casing shall be installed to prevent sediment and surface water from entering the monitoring well/piezometer.

19 of 20 Prior to sampling, monitoring well(s)/piezometer(s) shall be purged until a minimum of three (3) casing volumes have been removed, or until purged dry, whichever occurs first. Sample collection, preservation, transportation and chemical analytical procedures shall be completed in accordance with WQD and EPA standard procedures.

STATEMENT OF BASIS:

20 of 20 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

10-18-95
Date of Issuance

RLE/mad 54683.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-460

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

Yes

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter XI, PART G, Section 65 - "Sealing the Annular Space"

This section contains specific requirements for how to seal the annular space including minimum depths of seal, sealing conditions, sealing materials, thickness of seal, and placement of seal.

B. Briefly state the basis for the deviation.

The basis for the deviation is that when groundwater is very shallow, as in this case, it is physically impossible to meet all of the specific requirements in Section 65.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

The deviation is based on SPO policy number 2.1.11, "Conditions for the Construction of Groundwater Monitoring Wells" which in part allows for this deviation provided that a sufficient seal shall be installed according to standard engineering practice.

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 13, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-461
SPECIAL CONDITIONS

Erikson Septic System (Residential Septic System)

This permit hereby authorizes the applicant:

Rob Erikson
28 Meadow Lane
Wheatland, WY 82201

to install a residential septic system according to the procedures and conditions of the application number 95-461. The facility is located in NE 1/4 Section 26, T24N, R68W in the county of Platte, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 4 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

10-12-95
Date of Issuance

GLS/nc 54566.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-461

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on October 9, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

GLS/nc 54566.LTR

PERMIT TO CONSTRUCT

x New
Renewal
Modified

PERMIT NO. 95-462
SPECIAL CONDITIONS

Holm View Addition No.1 Water and Sewer Systems

This permit hereby authorizes the applicant:

Holm View Addition, L. C.,Paul Sandbak,Jr.,Mgr
P. O. Box 1501
Cody, Wyoming 82414

to construct a residential water distribution system and a sanitary sewer collection system with appurtenances according to the procedures and conditions of the application number 95-462. The facility is located in the NW/4 of Sec. 34, T53N, R101W in the county of Park, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

10-18-95
Date of Issuance

MDR/ks 54718.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-462

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

VI. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 16 October 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

x New
Renewal
Modified

PERMIT NO. 95-463
SPECIAL CONDITIONS

Todd Rice septic tank and leach field

This permit hereby authorizes the applicant:

Todd Rice
P. O. Box 281
Thermopolis, Wyoming 82443

to construct a residential septic tank and leach field according to the procedures and conditions of the application number 95-463. The facility is located in the NE/4 of Sec. &, T44N, R94W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

10/16/95
Date of Issuance

MDR/mad 54677.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-463

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

VI. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 10 October 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-464
SPECIAL CONDITIONS

Family Camping Grounds

This permit hereby authorizes the applicant:

90 CES/CE United States Air Force
300 Vesle Drive, Ste 600
F.E. Warren AFB WY 82005-2788

to construct an expansion to the collection and distribution system to facility an expansion in the above referenced facility according to the procedures and conditions of the application number 95-464. The facility is located in NE 1/4 Section 27, T14N, R67W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 4 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

12-19-95
Date of Issuance

GLS:ks
55625.ltr

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-464

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on December 12, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

PERMIT TO CONSTRUCT

Y New
Renewal
Modified

PERMIT NO. 95-465
SPECIAL CONDITIONS

Ponderosa Ridge, LLC - Nursery Site #2 (Septic System)

This permit hereby authorizes the applicant:

Ponderosa Ridge, LLC
P.O. Box 97
Albin, WY 82050

to install a septic system for domestic waste from the office of the above referenced facility according to the procedures and conditions of the application number 95-465. The facility is located in Lot 4 Section 35, T17N, R60W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction stan ırds and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational quirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 5 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

5 of 5 The permittee shall notify the Laramie County Environmental Health Division at least (2) days prior to installation of this system to arrange for required inspections. Inspection of the installed system is required prior to backfilling. Laramie County Environmental Health charges a fee for these inspection services. Their offices are located at 100 Central Ave, Cheyenne, Wyoming 82007; or they can be reached by phone at (307) 633-4090

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11/1/95
Date of Issuance

GLS:ks 54840.ltr

cc: Laramie County Environmental Health

STATEMENT OF BASIS

General information.

A. Permit Number: 95-465

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on October 23, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

THE STATE OF WYOMING

JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building ● 122 West 25th Street ● Cheyenne, Wyoming 82002

ADMINISTRATION	ABANDONED MINES	AIR QUALITY	INDUSTRIAL SITING	LAND QUALITY	SOLID & HAZARDOUS WASTE	WATER QUALITY
(307) 777-7758	(307) 777-6145	(307) 777-7391	(307) 777-7368	(307) 777-7756	(307) 777-7752	(307) 777-7781
FAX 777-7682	FAX 634-0799	FAX 777-5616	FAX 777-6937	FAX 634-0799	FAX 777-5973	FAX 777-5973

July 24, 1996

Mr. Gary Cole
Cowboy Village Resort LLC
P. O. Box 1747
Jackson, WY 83001

RE: As-Built Permit To Construct, WQD Reference Number 95-466RRR

Dear Mr. Cole:

The Department of Environmental Quality/Water Quality Division (DEQ/WQD) has reviewed the referenced As-Built Application submitted by your engineer, Gerald Edwards of Nelson Engineering. Our review of the information and as-built constructed plans submitted to this office indicates that the application meets DEQ/WQD regulations with the deviations noted in the Statement of Basis so the enclosed As-Built Permit To Construct is hereby issued. The enclosed permit covers constructed water storage tanks, booster pump facility, distribution system, a sewage collection system, and to install staff gauges in the percolation ponds which have already been constructed.

Please be advised that the system must be constructed, installed and operated in accordance with the statements, representations and procedures presented in the application and all supporting documentation as well as the terms and conditions of the permit. You are urged to be familiar with all aspects of the permit application, permit and permit conditions. Any person objecting to a permit issued by the DEQ and desiring affirmative relief may request a hearing before the Environmental Quality Council in accordance with the Rules of Practice and Procedure for the Department of Environmental Quality and the Wyoming Administrative Procedures Act.

Sincerely,

Dennis Hemmer
Director
Department of Environmental Quality

DH/JH/jm/ks 63013.ltr

Enclosure

cc: Melissa Hearst, U. S. Forest Service, Buffalo Ranger District

AS-BUILT
PERMIT TO CONSTRUCT

X New
- Renewal
- Modified

PERMIT NO. 95-466
SPECIAL CONDITIONS
REF/PERMIT # 87-317

Cowboy Village at Togwotee

This permit hereby authorizes the applicant:

Cowboy Village Resort LLC
P. O. Box 1747
Jackson, WY 83001

to have constructed water storage tanks, a booster pump facility, a distribution system, a sewage collection system, and to install staff gauges in the percolation ponds according to the procedures and conditions of the application number 95-466. The facility is located in SW1/4 Sec.32, T45N, R111W in the county of Teton, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it appears to meet the minimum applicable construction and design standards with minor deviations noted in the Statement of Basis. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, meets applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee has constructed and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1) All water usage and wastewater levels in the percolation ponds must be monitored and recorded at least monthly. Usage and levels must be correlated to occupancy numbers, total meals served, and staff numbers.

2) The infiltrative surface of each percolation pond must be maintained on alternating years. The maintenance must be in accordance with the operating and maintenance procedure prepared by your engineer.

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

7-30-96
Date of Issuance

JH:ks
63014.ltr

cc: Melissa Hearst, U.S. Forest Service - Buffalo Ranger District

STATEMENT OF BASIS

I. General information.

A. As-Built Permit Number: 95-466

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter XII, Section 12 (q)(i) Pumping facility valves; check valves required on discharge side pumps and (ii) gauges; shall be each suction and discharge line.

B. Briefly state the basis for the deviation.

The deviations stated don't cause a health threat to the users of the system , but are required to allow for more efficient operation and maintenance.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NA

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NA

VI. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Engineer,, and completed on 7/23/96. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RF

DEPARTMENT OF ENVIRONMENTAL QUALITY
STATE OF WYOMING
GROUNDWATER POLLUTION CONTROL PERMIT
AUTHORIZATION TO DISCHARGE INTO UNDERGROUND RECEIVERS
(Permit to Inject)

(X) New
( ) Modified

Permit Number: 95-408
Subclass Number: 5D2

In compliance with the Wyoming Environmental Quality Act (W.S. 35-11-101 through 1104, specifically 301(a)(i) through (iv), Laws 1973, Ch. 250, Section 1) and Water Quality Rules and Regulations, Chapter III (March 28, 1988), and Chapter IX (September 4, 1980),

Applicant: Jackson State Bank
112 Center Street
Jackson, Wyoming 83001
(307) 733-3737

is authorized to operate The Jackson State Bank West Branch Dry Wells in the SW¼NE¼ and NW¼SE¼, Section 32, Township 41 North, Range 116 West, of the 6th Principal Meridian; according to the procedures and conditions of application #95-408 and requirements and other conditions of this permit as contained on pages 1 through 6.

This permit shall become effective on date of issuance.

Administrator
Water Quality Division
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002
Phone: (307) 777-7781

Date 9/15/95

Director
Department of Environmental Quality
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002

Date 9-15-95

A. DISCHARGE ZONE AND AREA OF REVIEW

Discharge Zone

These injection wells are authorized to inject into the Alluvial Aquifer along Flat Creek which is found at this location from 0 to 75 feet below the ground surface.

Area of Review

The facility authorized by this permit is located in:

Township 41 North, Range 116 West, 6th Principal Meridian
Section 32: SW¼NE¼, NW¼SE¼

The Area of Review around this facility is legally described as:

Township 41 North, Range 116 West, 6th Principal Meridian
Section 32: N½

B. GROUNDWATER CLASSIFICATION

The groundwater in the Alluvial Aquifer along Flat Creek is classified as class I under Chapter VIII of Wyoming Water Quality Rules and Regulations (April 9, 1980). This classification was made because:

1. The groundwater in this formation meets all of the quality standards set forth in Chapter VIII for class I water; and

2. The groundwater in this formation is presently being used as a source of water which meets the definition of class I.

Groundwater of class I shall not be degraded so as to make it unusable as a source of water for this purpose. Any parameters which do not meet the class of use standard shall not be degraded whatsoever.

C. AUTHORIZED OPERATIONS

The permittee is authorized to inject 13,714 barrels per day (576,000 gallons per day) of groundwater as described: Natural groundwater pumped from the foundation drains of a bank building. No waste of any description is authorized to be disposed of into this system.

The permittee is authorized to inject at a pressure of no more than atmospheric as measured at the wellhead.

Hazardous Waste

This permit does not allow for the injection of any hazardous waste as defined by 40 CFR 261. Injection of any substance defined as hazardous waste, whether hazardous by listing or by characteristic is a violation of this permit.

F. ENVIRONMENTAL MONITORING PROGRAM FOR GROUNDWATERS OF THE STATE

1. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.

2. The permittee shall prepare records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation to be retained for a period of at least 3 years after closure of the facility.

3. Records of monitoring information shall include:

   a. The date, exact place, and time of sampling or measurements;

   b. The name(s) of individual(s) who performed the sampling or measurements;

   c. The date(s) analyses were performed;

   d. Names of individuals who performed the analyses;

   e. The analytical techniques or methods used; and

   f. The results of such analyses.

4. Because of the type of water to be injected no groundwater monitoring plan is required.

G. REQUIREMENTS FOR MONITORING THE DISCHARGE

Because of the type of water being injected and the engineering of the pumping and injection facilities, no injectate monitoring plan is required.

I. RECORDS AND REPORTS

1. The permittee shall retain copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the report or application.

2. The permittee shall give notice to the administrator as soon as possible of any planned physical alterations or additions to the permitted facility.

3. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 30 days following each schedule date.

4. The permittee shall report any noncompliance which may endanger health or the environment, orally within 24 hours from the time the permittee becomes aware of the circumstances. The report should include:

   a. Any monitoring or other information which indicates that any contaminant may cause an endangerment to a usable groundwater of the state.

   b. Any noncompliance with a permit condition or malfunction of the discharge (injection) system which may cause fluid migration into or between usable groundwaters of the state.

   A written submission shall be provided within 5 days of the time the permittee becomes aware of the circumstances. This written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected; the anticipated time it is expected to

continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

5. The permittee shall report all instances of noncompliance not reported otherwise, at the time monitoring reports are submitted; such reports shall contain the information listed in 4. above.

6. When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the administrator, it shall promptly submit such facts or information.

7. The permittee shall retain all records concerning the nature and composition of injected fluids until 5 years after completion of any specified plugging and abandonment procedures. The administrator may require the owner/operator to deliver the records to the administrator at the conclusion of the retention period.

8. A subsurface discharge (injection) well may not commence subsurface discharge (injection) until, following public notice and an opportunity for hearing, a groundwater pollution control permit has been issued by the department for the proposed operation, and:

   a. Well construction is complete and the permittee has submitted notice of completion of construction to the administrator, and

   b. The administrator has inspected or otherwise reviewed the subsurface discharge (injection) well and finds it in compliance with the conditions of the permit; or the permittee has not received notice from the administrator of intent to inspect or otherwise review the facility within 13 days of the notice of a. above, in which case prior inspection or review is waived.

9. No quarterly report of operations for these wells shall be required.

10. In the event that the permittee becomes aware that anything other than uncontaminated groundwater has been injected into this system, this fact shall be reported within 5 days of the permittee becoming aware of this fact. Such a report shall be in writing and shall include an estimate of the type of contamination present. Monitoring of this facility may be required based on the amount and type of contamination which may be present.

J. GENERAL PERMIT CONDITIONS

After notice and opportunity for a hearing, a permit may be modified, suspended or revoked in whole or part during its term for cause which includes, but is not limited to, any of the following:

1. Violation of the permit;

2. Obtaining a permit by misrepresentation or failure of the discharge well or system.

Each permit is reviewed at least once every 5 years, and may be reviewed more frequently.

A permit may be modified at any time as may be required, including for conformity with changes in regulations or standards which occur after the permit is issued. A permit may be modified in whole or part in order to apply more, or less, stringent standards; or prohibitions for a toxic or other substance present in the permittee's discharge, as may be ordered by the council. This permit can be terminated by authority of the administrator for one or more permit violations.

Public notice of the permit review and request for public comment has not been made by the administrator. This is based on the fact that no waste is authorized to be disposed of in this facility, and no adverse groundwater impacts are anticipated.

Any permit noncompliance constitutes a violation of the permit.

The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

The owner/operator of record (permittee) is always responsible for permit compliance. A permit holder cannot transfer his permit without approval of the department director.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable state law or regulation.

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The provisions of this permit are severable, and if any provision of the permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

Pollution or waste which migrates into an aquifer containing a usable groundwater of the state is a violation of the permit.

K. ABANDONMENT

The permittee shall notify the administrator at least 180 days before well abandonment. Immediately following the permit cessation of subsurface discharge or related activity, or where a well has not been completed, the applicant/permittee shall notify the director and follow the procedures prescribed by the director for plugging and abandonment or the discontinuance of related activities.

The three injection wells shall be abandoned in accordance with requirements found in Chapter XI, Part G, Wyoming Water Quality Rules and Regulations, at the time when they are no longer needed.

M. DUTIES OF THE PERMITTEE

It is a duty of the permittee to:

1. Comply with all permit conditions;

2. Halt or reduce activity -- it shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permittee activity in order to maintain compliance with the permit conditions;

3. Take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with this permit; and

4. Furnish to the administrator within a reasonable time, any information which the administrator may request to determine whether cause exists for modifying, revoking and reissuing, or

terminating this permit, or to determine compliance with this permit; and furnish to the administrator, upon request, copies of records required to be kept by this permit.

P. SIGNATORIES REQUIREMENT

All reports required by this permit and other requested information shall be signed as follows:

For a corporation -- by a principal executive officer of at least the level of vice-president;

For a partnership or sole proprietorship -- by a general partner or the proprietor, respectively;

For a municipality, state, federal or other public agency -- by either a principal executive officer or ranking elected official; or

By a duly authorized representative for any of the above. A person is a duly authorized representative only if:

1. The authorization is made in writing by one of the described principals;

2. The authorization specifies either an individual or position having responsibility for the overall operation of the regulated facility or activity; and

3. The written authorization is submitted to the administrator.

If an authorization is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to the administrator prior to or together with any reports or information, to be signed by an authorized representative.

Any person signing a report or other requested information shall make the following certification:

> "I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

RL/nc 54047.LTR

DEPARTMENT OF ENVIRONMENTAL QUALITY
STATE OF WYOMING
GROUNDWATER POLLUTION CONTROL PERMIT
AUTHORIZATION TO DISCHARGE INTO UNDERGROUND RECEIVERS
(Permit to Inject)

( ) New
(X) Modified

Permit Number UIC 95-414
UIC Class 5D2

In compliance with the Wyoming Environmental Quality Act (W.S. 35-11-101 through 1104, specifically 301(a)(i) through (iv), Laws 1973, Ch. 250, Section 1) and Water Quality Rules and Regulations Chapter IX (September 4, 1980),

Albany County School District No. 1
1948 Grand Avenue
Laramie, WY 82070

is authorized to operate a drainage well located at Linford School in Laramie, located in Section 31, Township 26 North, Range 73 West, Sixth Principal Meridian according to procedures and conditions of the application UIC 85-616 and requirements and other conditions of this permit contained on pages 1 through 9.

This permit shall become effective on date of issuance.

Administrator
Water Quality Division
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002
Phone: (307) 777-7781

11/27/95
Date

Director
Department of Environmental Quality
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002

11/28/95
Date

A. Discharge (Injection) Zone and Area of Review

The Discharge Zone for this permit is limited to the Alluvial Aquifer along the Laramie River at a depth of less than 30 feet below ground surface.

The Area of Review for this permit is legally described as follows:

Township 26 North, Range 73 West, 6th Principal Meridian

Section 31: SE¼NW¼, W½SW¼SE¼, SE¼SW¼NE¼, NE¼SW¼, NW¼SE¼, N½SE¼SW¼, NW¼SW¼SE¼

B. Groundwater Classification

The groundwater in the Alluvial Aquifer along the Laramie River is class I groundwater by use. There are numerous points of use inside the above area of review, most of which use the groundwater for lawn and garden watering, a domestic use. By ambient quality, the alluvial aquifer meets only class III standards, because of Sulfate, Total Dissolved Solids and Chloride content.

C. Authorized Operations

The permittee is authorized to operate stormwater drainage wells at the Linford School in Laramie, Wyoming. There is no limit placed on the volume of water to be injected under static water pressure. No monitoring of the flow volume or pressure is required. The permit covers up to six individual wells within the above area of review. If any well becomes plugged it may be replaced with another well of similar construction without prior approval from the Water Quality Division.

D. Proper Operation and Maintenance

The permittee is required to conduct the operation in accordance with statements, representations and procedures presented in the complete permit application and supporting documents, as accepted and approved by the administrator.

The permittee is required at all times to properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve permit compliance. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training and adequate laboratory and process controls, including appropriate quality assurance procedures.

The subsurface discharge (injection) authorized by permit shall be consistent with the conditions and content of the permit; any modifications which will result in a violation of permit conditions shall be reported by submission of a new or amended permit application and shall not be implemented until a new or modified permit has been issued.

E. Entry and Inspection

The permittee shall allow the administrator, or an authorized representative, upon the presentation of credentials and other documents as may be required by law to:

1. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;

2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;

3. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), and practice, or operations regulated or required under this permit; and

4. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the appropriate rules and regulations of the Department, any substances or parameters at any location.

F. Environmental Monitoring Program for Groundwaters of the State

1. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.

2. The permittee shall prepare records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation to be retained for a period of at least 3 years after closure of the facility.

3. Records of monitoring information shall include:

   a. The date, exact place, and time of sampling or measurements;

   b. The name(s) of individual(s) who performed the sampling or measurements;

   c. The date(s) analyses were performed;

   d. Names of individuals who performed the analyses;

   e. The analytical techniques or methods used; and

   f. The results of such analyses.

4. The prescribed program for this permitted activity is as follows: No monitoring of the groundwater other than at the point of injection is required under this permit. Extensive monitoring of this system between 1983 and 1995 has shown that monitoring of point of use wells is un-necessary unless the quality of the injected water deteriorates. In the case where the quality of the injected water exceeds the upper control limits found in the next section, the Water Quality Division may require additional groundwater monitoring.

G. Requirements for Monitoring the Discharge

The permittee shall monitor the quality of the injected water on an approved schedule. The following parameters shall be analyzed by the listed methods and reported annually:

SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT OR (UCL)*
Annually in December	EPA Method 160.1	Total Dissolved Solids	2,500
	EPA Method 350.3	Ammonia as N	3.0
	EPA Method 353.2	Nitrate as N	15.0
	EPA Method 418.1	Total Petroleum Hydrocarbons	10.0
	EPA Method 239.2	Total Lead	0.05
	EPA Method 218.1	Total Chromium	0.05
	EPA Method 213.2	Total Cadmium	0.01

The above Upper Control Limit (UCL) is not to be exceeded in any sample. Exceedance of this value is a violation of this permit and shall require corrective action.

and

In addition to the above Upper Control Limits, the following Lower Control Limits (LCL) shall apply. Exceedance of any Lower Control Limit is not a violation of this permit, but shall require increased monitoring on the part of the permittee. At the time when the following limits are exceeded, the permittee shall propose a groundwater monitoring program to determine if there has been an adverse affect on the groundwater quality caused by these exceedances. Monitoring of existing point of use wells or the installation of monitoring wells may be required as a part of this plan. Upon approval of this plan by the Water Quality Division, the permittee shall undertake the monitoring work required within 90 days of his receipt of the department approval. Failure to take corrective action afte exceeding a LCL is a violation of this permit.

SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT OR (LCL)*
Annually in December	EPA Method 160.1	Total Dissolved Solids	2,000
	EPA Method 350.3	Ammonia as N	.50
	EPA Method 353.2	Nitrate as N	10.0
	EPA Method 418.1	Total Petroleum Hydrocarbons	10.0
	EPA Method 239.2	Total Lead	0.05
	EPA Method 218.1	Total Chromium	0.05
	EPA Method 213.2	Total Cadmium	0.01

*All chemical parameters listed in this permit are expressed in mg/l unless otherwise shown. pH is always expressed in standard units, and Conductivity is always expressed in mmhos/meter or umhos/cm.

In addition to the above laboratory measurements, the permittee shall also record the static water level and the pH for each point monitored and for each sample taken.

H. Test Procedures

Test procedures for the determination of water quality parameters and constituents shall be in accord with provisions of Water Quality Rules and Regulations Chapter VIII, Section 7.

All samples taken for compliance with this permit shall be accompanied throughout the sampling event by a trip blank of distilled water prepared by the laboratory and analyzed as a quality control measure for the same parameters as the analytical samples for that date.

At least one sample from one of the injection wells covered by this permit shall be duplicated in the field and analyzed twice by the laboratory. This duplicated sample shall be labeled so that the laboratory will not know which sample is the duplicate and it shall be submitted to the laboratory in such a way that the original sample and the duplicate would not normally be consecutive samples.

I. Records and Reports

1. The permittee shall retain copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the report or application.

2. The permittee shall give notice to the administrator as soon as possible of any planned physical alterations or additions to the permitted facility.

3. The permittee shall give advance notice to the administrator of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

4. Monitoring results shall be reported at intervals specified in section C and/or Section G of this permit.

5. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.

6. The permittee shall report any noncompliance which may endanger health or the environment, orally within 24 hours from the time the permittee becomes aware of the circumstances. The report should include:

   a. Any monitoring or other information which indicates that any contaminant may cause an endangerment to a usable groundwater of the state.

   b. Any noncompliance with a permit condition or malfunction of the discharge (injection) system which may cause fluid migration into or between usable groundwaters of the state.

   A written submission shall be provided within 5 days of the time the permittee becomes aware of the circumstances. This written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected; the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

7. The permittee shall report all instances of noncompliance not reported otherwise, at the time monitoring reports are submitted; such reports shall contain the information listed in 6. above.

8. When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the administrator, it shall promptly submit such facts or information.

9. The permittee shall retain all records concerning the nature and composition of injected fluids until 5 years after completion of any specified plugging and abandonment procedures. The administrator may require the owner/operator to deliver the records to the administrator at the conclusion of the retention period.

10. A subsurface discharge (injection) well may not commence subsurface discharge (injection) until, following public notice and an opportunity for hearing, a groundwater pollution control permit has been issued by the department for the proposed operation, and:

    a. Well construction is complete and the permittee has submitted notice of completion of construction to the administrator,

    b. The administrator has inspected or otherwise reviewed the subsurface discharge (injection) well and finds it in compliance with the conditions of the permit; or the permittee has not received notice from the administrator of intent to inspect or otherwise review the facility within 13 days of the notice of a. above, in which case prior inspection or review is waived, and

    c. Well mechanical integrity testing has been proven or demonstrated to the satisfaction of the administrator.

11. Annual reports shall be submitted to the administrator within 30 days following the end of each calendar year following issuance of the permit. The annual report for this permit shall include all analytical parameters required under Section G of this permit.

12. A comprehensive report for an aborted or curtailed operation authorized by this permit shall be submitted to the administrator within 30 days of complete termination of the injection (discharge) or associated activity, in lieu of an annual report.

J. Permit Actions

After notice and opportunity for a hearing, a permit may be modified, suspended or revoked in whole or part during its term for cause which includes, but is not limited to, any of the following:

1. Violation of the permit;

2. Obtaining a permit by misrepresentation or failure of the discharge well or system.

Each permit is reviewed at least once every 5 years, and may be reviewed more frequently.

A permit may be modified at any time as may be required, including for conformity with changes in regulations or standards which occur after the permit is issued.

A permit may be modified in whole or part in order to apply more, or less, stringent standards; or prohibitions for a toxic or other substance present in the permittee's discharge, as may be ordered by the council.

This operation (permit) can be terminated by authority of the administrator for one or more permit violations.

Public notice of the permit review and request for public comment will be made every 10 years by the administrator.

K. Mechanical Integrity

There are no mechanical integrity requirements placed on this permit.

L. Abandonment

The permittee shall notify the administrator at least 180 days before well abandonment. Immediately following the permit cessation of subsurface discharge or related activity, or where a well has not been completed, the applicant/permittee shall notify the director and follow the procedures prescribed by the director for plugging and abandonment or the discontinuance of related activities.

If it becomes necessary to plug and abandon any well covered by this permit, the well shall be drilled out to total depth and the casing removed from the well. The well bore shall be filled with bentonite grout having a 10 minute gel strength of at least 20 pounds per 100 square feet and a filtrate volume not to exceed 13.5 cubic centimeters.

M. Duties of the Permittee

It is a duty of the permittee to:

1. Comply with all permit conditions;

2. Halt or reduce activity -- it shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permittee activity in order to maintain compliance with the permit conditions;

3. Take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with this permit; and

4. Furnish to the administrator within a reasonable time, any information which the administrator may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit; and furnish to the administrator, upon request, copies of records required to be kept by this permit.

N. Financial Responsibility

There are no financial responsibility requirements for this permit.

O. Special Measures the Director Finds Necessary

Whenever the permittee becomes aware that a spill has occurred which has entered one of the drainage wells covered by this permit, that spill shall be reported in accordance with section I6 of this permit.

Permits numbered 83-638 and 89-111 are hereby cancelled.

P. Special Permit Conditions

Pollution or waste which migrates into an aquifer containing a usable groundwater of the state is a violation of the permit.

Q. Signatories Requirement

All reports required by this permit and other requested information shall be signed as follows:

For a corporation -- by a principal executive officer of at least the level of vice-president;

For a partnership or sole proprietorship -- by a general partner or the proprietor, respectively;

For a municipality, state, federal or other public agency -- by either a principal executive officer or ranking elected official; or

By a duly authorized representative for any of the above. A person is a duly authorized representative only if:

1. The authorization is made in writing by one of the described principals;

2. The authorization specifies either an individual or position having responsibility for the overall operation of the regulated facility or activity; and

3. The written authorization is submitted to the administrator.

If an authorization is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to the administrator prior to or together with any reports or information, to be signed by an authorized representative.

Any person signing a report or other requested information shall make the following certification:

> "I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

R. Noncompliance

Any permit noncompliance constitutes a violation of the permit.

The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

S. Permit Transfer

The owner/operator of record (permittee) is always responsible for permit compliance. A permit holder cannot transfer his permit without approval of the department director.

T. Responsibilities

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable state law or regulation.

U. Property Rights

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

V. Severability

The provisions of this permit are severable, and if any provision of the permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

RL/bb/54056.ltr

IE STATE OF WYOMING

JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building ● 122 West 25th Street ● Cheyenne, Wyoming 82002

ADMINISTRATION	ABANDONED MINES	AIR QUALITY	INDUSTRIAL SITING	LAND QUALITY	SOLID & HAZARDOUS WASTE	WATER QUALITY
(307) 777-7758	(307) 777-6145	(307) 777-7391	(307) 777-7368	(307) 777-7756	(307) 777-7752	(307) 777-7781
FAX 777-7682	FAX 634-0799	FAX 777-7682	FAX 777-6937	FAX 634-0799	FAX 777-5973	FAX 777-5973

September 14, 1995

Albany County School District No. 1
1948 Grand Avenue
Laramie, WY 82070

RE: Linford School Drainage Well
Draft Permit UIC 95-414
Albany County, Wyoming

Dear Sir or Madam:

The Water Quality Division was originally established to prevent the degradation of one of Wyoming's most important resources, its water. Within the division, the Underground Injection Control Program seeks to prevent contamination of Wyoming's groundwater caused by direct injection of water into aquifers. This program does this by regulating how and where injections can occur and placing limits on the quality of the water injected.

The Albany County School District No. 1 has, since 1985, injected stormwater runoff into the Alluvial Aquifer along the Laramie River at the Linford School in Laramie. This discharge is presently regulated under permit UIC 85-616. This permit requires monitoring of nearby wells which could be affected by the discharge. A body of scientific data has been created over the years showing what affect this discharge has on the aquifer. Every five years, regulations require that each permit be reviewed in detail. This department has just finished a comprehensive review of this permit. A copy of this review is enclosed.

As part of the review process, the department not only determines if the permit has been complied with, but also determines if the permit itself could be improved. In this case, we have determined that the monitoring could be improved if the point of discharge was monitored rather than the wells being monitored now. The attached draft permit, when issued, will take the place of the existing permit. It is our belief that this permit will provide more cost effective management of this injection well while providing comprehensive data concerning the discharge itself.

Please review the attached *draft permit*. This draft is open for your comment prior to the beginning of a public comment period. Only after you have had the opportunity to comment will the public notice period begin. Until this new permit is issued, the existing permits remain in full force and effect. In order to insure that the process proceeds at a reasonable pace, the public notice period will be set to begin October 15 if we have not heard from you sooner.

We believe that this approach is reasonable, sensible, and responsible in light of the department's legislative mandate and the responsibilities that the school district is fulfilling by injecting the stormwater. It is precisely because this department cares about the costs associated with our permits that this review has been undertaken. The replacement permit should be less costly to Albany County School District No. 1.

Sincerely,

Robert Lucht, P.E.
UIC Program Supervisor
Water Quality Division

RL/bb/54065.ltr

Attachments

THE STATE OF WYOMING

JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building ● 122 West 25th Street ● Cheyenne, Wyoming 82002

ADMINISTRATION	ABANDONED MINES	AIR QUALITY	INDUSTRIAL SITING	LAND QUALITY	SOLID & HAZARDOUS WASTE	WATER QUALITY
(307) 777-7758	(307) 777-6145	(307) 777-7391	(307) 777-7368	(307) 777-7756	(307) 777-7752	(307) 777-7781
FAX 777-7682	FAX 634-0799	FAX 777-7682	FAX 777-6937	FAX 634-0799	FAX 777-5973	FAX 777-5973

September 29, 1995

Graden Betz, P.E.
Platte Pipe Line Company
P.O. Box 3128
Houston, TX 77253-3128

RE: Aquifer Remediation: Industrial Drywell Area
Permit Number: 95-426
Natrona County, Wyoming

Dear Mr. Betz:

Enclosed please find your approved permit to construct a vapor recovery system at your Casper station. All of the permit conditions should be complied with entirely. Your comments on the draft permit have been considered fully, and you will find that almost all of the changes you suggested have been incorporated into this permit.

I am pleased that your company has taken this very positive step in eliminating any adverse environmental affects caused by the operation of the industrial drywell on this location. All of us in both the Water Quality Division and the Solid and Hazardous Waste Management Division fully expect that your efforts will remove most, if not all, of the Tetrachloroethene present in the groundwater. While we expect success, it would be wrong to imply that the installation of this system will eliminate any of Platte's responsibility for this site in the event that remediation cannot be achieved. Platte still has to fully define the extent of contamination on the north side of Highway 20/26 as you were told in my last letter.

This permit allows Platte to construct the system according to the plan submitted to the Water Quality Division on September 14, 1995. Platte cannot operate this system until it receives either the Air Quality Division permit that you applied for or a waiver

of the permit from the Air Quality Division. If you do not receive either of these possible approvals within two weeks please let me know.

This division, and especially those of us who have worked on this case with Platte, very much appreciate your cooperative attitude and willingness to remediate this area. Thank you for your cooperation.

Sincerely,

Robert Lucht, P.E.
UIC Program Supervisor
Water Quality Division

RL/nc 54392.LTR

Enclosure: Permit to Construct 95-426

xc: Mike Jennings, Natrona County Health Department, 1200 East 3rd Street, Casper, WY 82601
Don McKenzie, Sheridan Office WQ
Carl Anderson, SHWM Division
EPA Region VIII, RCRA Branch, 999 18th Street, Suite 500, Denver, CO 80202
Dan Jackson, UIC Branch, EPA Region VIII, 999 18th Street, Suite 500, Denver, CO 80202

PERMIT TO CONSTRUCT

XX New
Renewal
Modified

PERMIT NO. 95-426
SPECIAL CONDITIONS

Platte Pipe Line Casper Station Soil Vapor Extraction System

This permit hereby authorizes the applicant:

Platte Pipe Line Company
P.O. Box 3128
Houston, TX 77253-3128
Attn: Graden Betz, P.E. (713) 629-6600

to construct, install or modify an active aquifer remediation system including air sparger wells and a vapor recovery system according to the procedures and conditions of the application number 95-426. The facility is located in Section 35, SW¼, Township 34 North, Range 80 West, 6th Principal Meridian in the county of Natrona, in the State of Wyoming. This permit shall be effective for a period of five (5) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: UIC Program Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 6. Quarterly monitoring reports are required for the first year, followed by semi-annual reports thereafter, showing the analytical data and water levels for all samples taken during the period. Reports are due within 30 days of the end of each calendar quarter or calendar half year and shall include all analytical reports available on the date on which it was prepared. Analytical reports for samples which have been taken, but for which the reports are not yet available on the date of the report shall be included with the next report. Monitor wells MW-1, MW-5, MW-7 and MW-8 shall be monitored for the following parameters from the EPA Method 624 list found in 40 CFR 136 Appendix A:

Chloroethane
1,1-Dichloroethane
1,2-Dichloroethane
1,1-Dichloroethene
trans-1,2-Dichloroethene
1,1,2,2-Tetrachloroethane
1,1,1-Trichloroethane
1,1,2-Trichloroethane
Vinyl Chloride
Trichloroethene
Tetrachloroethene

2 of 6. DEQ/WQD approval shall be required prior to shutdown of the system and the start of the stability monitoring period. A stability monitoring period is required after the system is shutdown to determine that the remediation is complete. During this period, all monitor wells named in condition 1 (above), shall be monitored semiannually for the parameters named in 1 (above). The system shall not be abandoned until the Water Quality Division has split samples once during the stability period and given its approval for the abandonment.

3 of 6. DEQ/WQD shall be notified in writing within 30 days of any system failure which is not corrected within 48 hours.

4 of 6. An operational log of the system shall be maintained on site showing all maintenance performed and a log of system downtime. Maintenance manuals for all mechanical equipment which is part of this system shall be maintained on site.

5 of 6. Changes to the system may be made by Platte without modification of this permit as long as those changes do not adversely impact the operation of the system. If any major component is added to the system, Platte will submit its specifications to the department. Maintenance manuals for any new components or replacement components different from the originally installed equipment shall be kept on site as part of the system operation and maintenance manual.

6 of 6. If remediation and final shutdown has not occurred within 24 months of the date when this system is installed, the department will review this permit and both parties will reach a mutual agreement to determine if future action is necessary.

AUTHORIZED BY:

Administrator
Water Quality Division

10-12-95
Date of Issuance

Director
Department of Environmental Quality

RFL/nc 54389.LTR

cc: Craig Hofmeister
Handex of Colorado, Inc.
400 Corporate Circle, Suite I
Golden, CO 80401

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-426

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III. Note that sediment ponds, public water supplies, sewerage systems, and small wastewater systems are exempt from the requirements of Section 15. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Applicable - A groundwater contamination plume is known to exist at this location. Tetrachloroethene (PCE) has been detected at levels as high as 760 $\mu g/\ell$. This system is designed to remediate groundwater only on the south side of State Highway 20/26. Recent information shows that the plume extends to the north side of State Highway 20/26. The extent of contamination north of the highway has not yet been determined, and Platte may be required to perform active remediation north of the highway as well. No public or private water supply wells exist which are close enough to be affected by this system in any way. Monitoring has been required as part of this permit.

V. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

Applicable - Groundwater is to be monitored at wells MW-1, MW-5, MW-7 and MW-8 for volatile hydrocarbons by EPA Method 624.

VI. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

VII. Applicant Participation

A. The applicant has been provided with a copy of all permit conditions prior to the permit being issued.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Robert Lucht, P.E., UIC Program Supervisor, and completed on September 29, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RFL/nc 54389.LTR

THE STATE OF WYOMING

JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building ● 122 West 25th Street ● Cheyenne, Wyoming 82002

ADMINISTRATION	ABANDONED MINES	AIR QUALITY	INDUSTRIAL SITING	LAND QUALITY	SOLID & HAZARDOUS WASTE	WATER QUALITY
(307) 777-7758	(307) 777-6145	(307) 777-7391	(307) 777-7368	(307) 777-7756	(307) 777-7752	(307) 777-7781
FAX 777-7682	FAX 634-0799	FAX 777-5616	FAX 777-6937	FAX 634-0799	FAX 777-5973	FAX 777-5973

December 4, 1995

Chuck Davidson
Schleedlewitz L.L.C.
P.O. Box 831
Saratoga, WY 82331

RE: Schleedlewitz Septic System
Permit Number 95-467R
Carbon County, Wyoming

Dear Mr. Davidson:

Enclosed please find the original approved permit to construct covering a small wastewater system for your commercial development. There are several permit conditions attached to this permit which are meant to address the rather unique situation of having a sanitary septic system which is already within a few hundred feet of a sanitary sewer collection system. Please see conditions 1 through 6 of the attached permit, with special reference to conditions 5 and 6.

Sincerely,

Robert Lucht, P.E.
UIC Program Supervisor
Water Quality Division

RFL:ks
55453.ltr

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-467
SPECIAL CONDITIONS

Schleedlewitz L.L.C., Septic System

This permit hereby authorizes the applicant:

Schleedlewitz L.L.C.
P.O. Box 831
Saratoga, WY 82331

to construct, install or modify small wastewater system according to the procedures and conditions of the application number 95-467. The facility is located in Section 23, NE¼, T17N, R84W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: UIC Program Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 6 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 6 The applicant will provide immediate oral and/or written notice to the SE District Office in Cheyenne in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 6 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SE District Office in Cheyenne on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 6 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

5 of 6 This permit covers a facility which is within one quarter mile of the Town of Saratoga sanitary sewer lines. When and if the Town of Saratoga extends its sanitary sewer to provide service to this property, the permittee shall connect to that sewer within one year of it becoming available.

 This permit covers a facility with a design capacity of 1,974 gallons per day based on the following commercial sizing: 132 seats in a bar, 62 seats in a restaurant, and 3 employees in a retail area. The permittee is specifically notified that to increase any of these capacities requires that a modified permit be issued. Such a modified permit will include the requirement to conduct an on-site groundwater investigation including the installation of monitor wells, the determination of baseline water quality in the first useable aquifer, and the submission of quarterly monitoring results.

AUTHORIZED BY:

Administrator
Water Quality Division

12/7/95
Date of Issuance

Director
Department of Environmental Quality

RFL/ks
55453.ltr

cc: Nia Adams
Carbon County Planning Dept
P.O. Box 487
Rawlins, WY 82301

Gary Steele, SE District Engineer

51865.doc

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-467R

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

V. Application was reviewed to determine groundwater impacts in accordance with Section 15, Chapter III. Permittee has revised the application to show that the total design capacity will be 1,972 gallons per day. This is only 28 gallons per day less that the 2,000 gallons per day which requires the groundwater study. Permit Condition 6 of 6 was placed in the permit to notify the permittee that <u>any</u> modification which results in an increase in the required design capacity to more than 2,000 gallons per day will require that a modification permit be applied for. This includes items as small as increasing the number of employees in the retail establishment, adding just two chairs to the restaurant seating capacity, or adding just 10 persons to the bar seating capacity.

VI. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

VII. Applicant Participation

A. The applicant has been provided with a copy of all permit conditions prior to the permit being issued.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Robert F. Lucht, P.E. and P.G., UIC Program Supervisor, and completed on <u>date</u>. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

x New
Renewal
Modified

PERMIT NO. 95-468
SPECIAL CONDITIONS

Mammoth Hot Springs Duplex Housing Site Utility Line Relocations

This permit hereby authorizes the applicant:

TW Recreational Services, Inc., Barry Cantor, Director of Engineering
P. O. Box 595
Mammoth Hot Springs, Wyoming 82190-0165

to construct a relocated water supply line and a relocated sanitary sewer line with appurtenances according to the procedures and conditions of the application number 95-468. The facility is located in Yellowstone National Park, Mammoth Hot Springs Housing Site, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any ...asion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION. OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

10-18-95
Date of Issuance

MDR/ks 54719.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-468

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

VI. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 16 October 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-469
SPECIAL CONDITIONS

Sorenson Tank Piping Modification and Roof Repair

This permit hereby authorizes the applicant:

Kemmerer/Diamondville Joint Powers Water and Wastewater Board
700 Cedar Avenue
Kemmerer, Wyoming 83101

to construct bypass water lines around the Sorenson water storage tank, repair the roof on this tank and disinfect the tank according to the procedures and conditions of the application number 95-469. The facility is located in NE/4 of Sec. 23, T21N, R116W in the county of Lincoln, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

10-24-95
Date of Issuance

MDR/nc 54813.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-469

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

VI. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E. , Northwest District Engineer, and completed on 19 October 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR/nc 54813.LTR

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

x New
Renewal
Modified

PERMIT NO. 95-470
SPECIAL CONDITIONS

T. Daniel & Nicole D. Vigil Septic Tank and Leach Field

This permit hereby authorizes the applicant:

T. Daniel & Nicole D. Vigil
4564 Orchard Bench Road
Basin, Wyoming 82410

to construct a residential septic tank and leach field according to the procedures and conditions of the application number 95-470. The facility is located in the SE/4 of Sec. 28, T51N, R93W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any i sion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

10-18-95
Date of Issuance

MDR/ks 54726.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-470

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. NO

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

VI. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 17 October 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-471
SPECIAL CONDITIONS

Aryn Tippetts Septic Tank and Leach Field

This permit hereby authorizes the applicant:

Aryn L. Tippetts
507 Nevada Avenue
Lovell, Wyoming 82431

to construct a residential septic tank and leach field according to the procedures and conditions of the application number 95-471. The facility is located in Lot 4, Sec. 10 resurvey, T56N, R95W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any infringement of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

10-18-95
Date of Issuance

MDR/ks 54745.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-471

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

VI. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 17 October 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-472
SPECIAL CONDITIONS

Carol Davidson Powers Leach Field

This permit hereby authorizes the applicant:

Carol Davidson Powers
Shell Route
Greybull, Wyoming 82426

to construct a septic tank leach field according to the procedures and conditions of the application number 95-472. The facility is located in the SE/4 of Sec.10, T52N, R93W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any i sion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

10-18-95
Date of Issuance

MDR/ks 54746.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-472

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

VI. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 17 October 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

THE STATE OF WYOMING

JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building ● 122 West 25th Street ● Cheyenne, Wyoming 82002

ADMINISTRATION	ABANDONED MINES	AIR QUALITY	INDUSTRIAL SITING	LAND QUALITY	SOLID & HAZARDOUS WASTE	WATER QUALITY
(307) 777-7758	(307) 777-6145	(307) 777-7391	(307) 777-7368	(307) 777-7756	(307) 777-7752	(307) 777-7781
FAX 777-7682	FAX 634-0799	FAX 777-5616	FAX 777-6937	FAX 634-0799	FAX 777-5973	FAX 777-5973

October 18, 1995

Steve W. Siegel
5204 Kaycee Place
Cheyenne, Wyoming 82007

RE: Application #95-473, Music room addition to residence - Modified septic system permit - **NOT REQUIRED**

Dear Mr. Siegel:

The Wyoming Department of Environmental Quality (DEQ) / Water Quality Division (WQD) has received and reviewed your application for a revised septic system permit for the purpose of adding a detached music room with a half bath to your residence. The WQD has determined that since this addition will not change the design load on your system, that this configuration will still be considered to be a single family residence. Also, since the current system is adequate for a 3 bedroom house and was properly permitted as such; this change does not require a permit from the DEQ/WQD. Therefore, as far as the DEQ/WQD is concerned, you may proceed - a permit is not required.

Because a permit is not required, we are returning your application with this letter. If you should have any further questions, please call me at (307) 777-6183.

Sincerely,

Gary Beach
Administrator
Water Quality Division

GB/RLE/ks
54697.ltr

Enclosure: Application Package

cc: Gary Steele, SE District Engineer

MEMO

To: Gary Beach

From: Ron Ewald

Date: October 18, 1995

Subject: Permit application return letter for your signature

I have reviewed this application and determined that it does not require a permit from the WQD. Gary Steele and Larry Robinson both agree. Therefore, in accordance with Chapter III, Section 7 (f), I have prepared such a letter for your signature.

CHAPTER III
APPLICATION FOR PERMIT TO CONSTRUCT, INSTALL, OR MODIFY WATER SUPPLIES, WASTEWATER FACILITIES, OR GROUNDWATER POLLUTION CONTROL SYSTEMS IN WYOMING

FOR USE BY DEQ/WQD ONLY
APPLICATION NO. 95-473
DATE RECEIVED 10-11-95
PROGRAM ASSIGNED SE

APPLICATION FORM

Application must contain three copies of the application form, plans, specifications, and pertinent design information. Submit to appropriate field office.

DEQ/Water Quality Division, 122 West 26th Street, Herschler Building, 4W, Cheyenne, WY 82002 (307) 777-7781
DEQ/Water Quality Division, 250 Lincoln Street, Lander, WY 82520 (307) 332-3144
DEQ/Water Quality Division, 2161 Coffeen Avenue, Sheridan, WY 82801 (307) 672-6457

Name of facility Private Residence of Steve Siegel

Location of facility: County: Laramie
Township: 14 Range: 65
Section: 24 ¼ Section: ____
Lot 22 Blk 5 Durham Estates

Type of application: 22
____ New permit*
X Revised permit*
____ As built approval
____ Standard specification permit
____ Renewal of permit*

*Previous DEQ/WQD construction permit no(s). if applicable (modification, revision or renewal) ____

Type of Project (Mark all that apply)

____	201 Construction Grant Wastewater Treatment Plant (WWTP)	
____	State Revolving Fund (SRF) WWTP	
____	Public Water Supply (20 or more service connections)	including ground or surface water source, transmission line, treatment plant, chlorination or pumping system, storage facility, backflow prevention device, or laboratory
X	Wastewater Facility	including small wastewater facility (single unit, domestic sewage, less than 2,000 gallons), domestic sewage pond, disinfection, collection or pumping system, evaporative/containment pond, sedimentation pond, mechanical treatment plant, oil/water separator (external to a structure), sludge facility or laboratory
____	Monitoring wells	(groundwater contamination not determined) (P.E. not required)
____	Land Application System	including road application, land farming or one-time land application
____	Underground Storage Tank/Leaking Underground Storage Tank (UST/LUST)	
____	Site assessment/site characterization	including monitoring wells, borings, etc. (P.E. not required)
____	Groundwater remediation/treatment systems (owner lead)	including pump and treat, bioremediation, air sparging, soil vapor extraction, oil/water separator, recovery well, etc.
____	Leak detection	groundwater or vapor
____	Groundwater Pollution Control (GPC) Program	
____	Site assessment/site characterization	including monitoring wells, borings, etc. (groundwater contamination has been determined) (P.E. not required)
____	Groundwater and contamination containment systems	including physical, hydraulic, etc.
____	Groundwater remediation/treatment systems	including pump and treat, etc.
____	Deep anode beds	

Briefly describe facilities proposed to be constructed: I have added a small building off of the main house to serve as a music room. I would like to tie in to existing septic system. In summary I am adding a new bathroom. The room / building is 28' X 28'

Have all required State Engineer permits been obtained? Yes ____ No ____ N/A X

If yes, provide permit number(s) ____

If not, the State Engineer (telephone number 777-7354) should be contacted to determine if any permit(s) is required for this project; it is illegal to appropriate water without a permit.

Will the proposed water supply/wastewater treatment facility discharge to the surface? Yes ____ No X

If yes, NPDES permit application no. ____

Name of receiving waters ____

Owner	Engineer
Name: Steve W Siegel	Name:
Address: 5204 Kayce Pl.	Wyoming P.E.#:
Cheyenne WYO 82009	Engineering Firm:
(City, State, Zip)	Address:
Phone: 307-632-7597	(City, State, Zip)
	Phone:

This form must be signed by the owner, or in the case of the owner being a corporation or other business organization, by an individual with the legal authority to bind the corporation or business organization.

I certify that the above described facility has been submitted in accordance with local, county and state statutes, as required, and that said facility shall be constructed as authorized under the provisions specified in Wyoming Water Quality Rules and Regulations, Chapter III.

Steve W Siegel
Owner (please print or type)

Owner
Title

Owner's Signature

Oct 2-97
Date

3/94

24696.DOC

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-474R
SPECIAL CONDITIONS

Buffalo Junction Commercial Development Water and Sewer Systems

This permit hereby authorizes the applicant:

Albert and Sondra Ellis
Star Route 11-23, 8800 S. Meander Way
Jackson, Wyoming 83001

to construct a commercial water distribution and sewer collection system extension according to the procedures and conditions of the application number 95-474R. The facility is located in the SE/4 of Sec. 32, T41N, R116W in the county of Teton, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11/1/95
Date of Issuance

MDR/nc 54921.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-474R

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

VI. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 29 October 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR/nc 54921.LTR

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

x New
Renewal
Modified

PERMIT NO. 95-475
SPECIAL CONDITIONS

Yellowstone Park; Lamar Station Water and Sewer System Improvements

This permit hereby authorizes the applicant:

Yellowstone Association; Donald M. Nelson, Director
P. O. Box 117
Yellowstone Park, Wyoming 82190

to construct waterline relocations, septic tank improvements, effluent discharge pump, dosing chamber and leach field construction according to the procedures and conditions of the application number 95-475. The facility is located in Yellowstone National Park at a north latitude of 44 deg 55 min and a west longitude of 110 deg 20 min in the county of Park, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11/15/95
Date of Issuance

MDR/mad 55190.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-475

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

V. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 13 November 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

R7

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 95-476
SPECIAL CONDITIONS

Westgate Park II Wastewater Collection System

This permit hereby authorizes the applicant:

U.S. Fuel and Food Corporation dba Ghost Town Truck Stop
6841 Algonquin
Loveland, CO 80537
Attention: Jerry Whitaker

to construct, install or modify a sewage collection system according to the procedures and conditions of the application number 95-476. The facility is located in Sections 27 and 34, Township 34 North, Range 80 West in the county of Natrona, in the State of Wyoming. This permit shall be effective for a period of one year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11/1/95
Date of Issuance

BDM/pr:mad

cc: Barry Venn, P.E., CEPI, 355 N. Lincoln, Casper, WY 82601
David Hill, P.E., City of Casper, 200 N. David, Casper, WY 82601
Ken Hoff, Natrona County Health, 1200 E. 3rd, Casper, WY 82601-2990
Tom Keller, Natrona County Planning, 1200 W. 1st, Casper, WY 82601-2463

STATEMENT OF BASIS

General information.

A. Permit Number: 95-476

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. yes

B. Chapter XII. no

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

no

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

no

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

not applicable

B. Briefly state the basis for the deviation.

not applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

not applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

not applicable

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

not applicable

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on October 24, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-477
SPECIAL CONDITIONS

Water Supply System for the Salt Creek Joint Powers Board

This permit hereby authorizes the applicant:

Salt Creek Joint Powers Board
P.O. Box 146
Midwest, Wyoming 82634
Attention: John VanderVoort

to construct, install or modify a water pump station, storage tank, surge tank and water transmission line according to the procedures and conditions of the application number 95-477. The facility is located in Sections 4, 9, 16, 17, 20, 29, 32, T34N, R79W, Sections 3, 4, 9, 16, 21, 28, 33, T35N, R79W, Sections [illegible] 15, 22, 27, 34, T36N, R79W, Sections 11, 12, 14, 23, 26, 35, T37N, R79W, Sections 6, 7, 12, 13 [illegible] 23, 26, 35, T38N, R79W, Sections 6, 7, 18, 19, 30, 31, T39N, R78W, and Sections 30, 31, T40N, [illegible] in the county of Natrona, in the State of Wyoming. This permit shall be effective for a period of one year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding [illegible] enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and
b. Date that the facility was placed in operation; and
c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

12/12/95
Date of Issuance

BDM/ks 55590.ltr

cc: Colin Cunningham, P.E., WLC, 200 Pronghorn, Casper, WY 82601
Mike Jennings, Natrona Co. Health, 1200 E. 3rd, Casper, WY 82601-2990
Tom Keller, Natrona Co. Planning, 120 W. 1st #200, Casper, WY 82601-2463
Mike Besson, P.E., WWDC, 4th Floor Herschler Building, Cheyenne, WY 82002

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-477

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. no

B. Chapter XII. yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

no

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

no

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

no

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter XII Section 13.(a)(iv) requires security fencing for above ground water storage facilities to prevent trespassing, vandalism and sabotage.

B. Briefly state the basis for the deviation.

The applicant requests a deviation because no vandalism has occurred at the existing 1,500,000 gallon tank currently on site. A new 250,000 gallon tank is proposed. The existing tank has no fencing.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

not applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

not applicable

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

not applicable

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on December 7, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
Renewal
X Modified

PERMIT NO. 95-478
SPECIAL CONDITIONS
REF/PERMIT #89-21

University of Wyoming - Animal Science Livestock Teaching Arena

This permit hereby authorizes the applicant:

University of Wyoming
Merica Hall, Suite 211
Laramie, WY 82071-0211

to construct an extension of the water distribution and wastewater collection system to facilitate hookup of the above referenced facility according to the procedures and conditions of the application number 95-478. The facility is located in E1/2 Section 11, T15N, R74W in the county of Albany, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 5 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

PERMIT NO. 95-478

The addition of the Livestock Teaching Arena will increase the hydraulic loading on the lagoon such that it will no longer be a non discharging system. The permittee will implement one of the additional methods of disposal as outlined in the permit application package and listed below prior to November 1, 1996.

1. Increase the size of the lagoon system to store the additional hydraulic loading.

2. Obtain an NPDES permit for discharge of wastewater or a land application permit for the disposal of the wastewater.

3. Reduce the inflow into the lagoon by using lagoon water from the polishing pond for the swine building flush tanks.

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

1-29-96
Date of Issuance

GLS:ks
60489.ltr

STATEMENT OF BASIS

General information.

A. Permit Number: 95-478

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on January 25, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

PERMIT TO CONSTRUCT

New
Renewal
X Modified

PERMIT NO. 95-479
SPECIAL CONDITIONS
REF/PERMIT #87-063

Broadmoor East Boarding & Grooming

This permit hereby authorizes the applicant:

Dr. Mike Driscoll
4218 E. Pershing
Cheyenne, WY 82001

to modify an existing failed septic system to include replacement area leach field according to the procedures and conditions of the application number 95-479. The facility is located in SE 1/4 Section 27, T14N, R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 8 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 8 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 8 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 8 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

5 of 8 The permittee shall notify the Laramie County Environmental Health Division at least (2) days prior to installation of this system to arrange for required inspections. Inspection of the installed system is required prior to backfilling. Laramie County Environmental Health charges a fee for these inspection services. Their offices are located at 100 Central Ave, Cheyenne, Wyoming 82007; or they can be reached by phone at (307) 633-4090

6 of 8 The intent of the construction authorized by this permit is to provide facilities for the interim treatment of wastewater until such time that treatment is available through a regional wastewater system. The 201 Facilities Plan Final Report: City of Cheyenne, South Cheyenne Water and Sewer District and Laramie County requires that treatment be provided through a regional system. The facilities authorized by this permit will be operated until services are available through the approved regional system. At that time these facilities will be abandoned or integrated into the regional system in accordance with the requirements of the Facility Plan.

7 of 8 The 201 Exception was granted for this facility on the condition that within one year of issuance of the Construct Permit this facility will either be hooked to the regional wastewater collection system or have all permits and agreements with an approved schedule for the hookup.

The hair trap shown on the plans shall be maintained and operation procedures shall be developed to verify that hair is being efficiently removed from the system.

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11-9-95
Date of Issuance

GLS/mad 55152.LTR

cc: Laramie County Environmental Health

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-479

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

N/A

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

N/A

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on October 30, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

R7

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-480
SPECIAL CONDITIONS

UMETCO Minerals Septic System

This permit hereby authorizes the applicant:

UMETCO Minerals Corporation
P.O. Box 151
Riverton, Wyoming 82501
Attention: Bert Hankins

to construct, install or modify an onsite wastewater system according to the procedures and conditions of the application number 95-480. The facility is located in SW/4 of Section 10, Township 33 North, Range 89 West in the county of Natrona, in the State of Wyoming. This permit shall be effective for a period of one year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11/1/95
Date of Issuance

BDM/pr/ks
54930.ltr

cc: Terry Zenk, P.E., Apex Surveying, P.O. Box 1751, Riverton, WY 82501
Mike Jennings, Natrona County Health, 1200 East 3rd, Casper, WY 82601-2990
Tom Keller, Natrona County Planning, 120 West 1st, Casper, WY 82601-2463

STATEMENT OF BASIS

General information.

A. Permit Number: 95-480

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. yes

B. Chapter XII. no

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

no

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

no

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

not applicable

B. Briefly state the basis for the deviation.

not applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

not applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

not applicable

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

not applicable

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on October 27, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

x New
Renewal
Modified

PERMIT NO. 95-481R
SPECIAL CONDITIONS

Wempen Mobile Home Park Pumped Sewage Disposal System

This permit hereby authorizes the applicant:

Freeman Wempen
309 West Washington
Riverton, Wyoming 82501

to construct a pumped sewage disposal system discharging into an existing sewer main owned by the City of Riverton according to the procedures and conditions of the application number 95-481R. The facility is located in the SW/4 of Sec. 36, T1N, R4E in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11/15/95
Date of Issuance

MDR/bb/55162.ltr

STATEMENT OF BASIS

General information.

A. Permit Number: 95-481R

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

V. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 9 November 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR/bb/55162.ltr

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-482
SPECIAL CONDITIONS
REF/PERMIT #79-224

Winchester Hills 4th Filing

This permit hereby authorizes the applicant:

TFS Limited Liability Company
1124 Dunn Avenue
Cheyenne, WY 82001

to construct an extension to the existing distribution system according to the procedures and conditions of the application number 95-482. The facility is located in E 1/2 Sections 30/31, T13N, R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 5 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

5 of 5 The distribution system as expanded by this permit is approaching the capacity of the well, pumping and storage requirements as required by Water Quality Rules and Regulations. Additional expansions of the Distribution system will need to include evaluations of these facilities and a demonstration that the requirements of Chapter XII are being met.

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11-13-95
Date of Issuance

GLS/nc 54985.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-482

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on November 1, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

GLS/nc 54985.LTR

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 95-483
SPECIAL CONDITIONS

POWDER HORN RANCH PHASE I WATER DISTRIBUTION SYSTEM

This permit hereby authorizes the applicant:

Sheridan Area Water Supply Joint Powers Board
224 South Main Street
Sheridan, WY 82801
Attention: Mr. David Engels

to construct, install or modify water distribution system according to the procedures and conditions of the application number 95-483. The facility is located in the Sections 3 and 4 of Township 54 North, Range 84 West and Sections 33 and 34 of Township 55 North, Range 84 West in the county of Sheridan, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 4 The applicant will provide immediate oral and/or written notice to Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and
b. Date that the facility was placed in operation; and
c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

11-22-95
Date of Issuance

Director
Department of Environmental Quality

DRM/dm
bb/55297.ltr
cc: Jim Willey, M-W, 1030 N. Main, Ste 2, Sheridan, 82801
Edith Johnson-LaMeres, City of Sheridan, POB 848, Sheridan
Mike Evans, Sheridan County, 224 S. Main, Ste B8E, Sheridan
Northeast District File

Enclosures: Notification Post Card
Certificate of Completion
Statement of Basis

STATEMENT OF BASIS

General information.

A. Permit Number: 95-483

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes, except for one deviation request and recommendation.

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

WWQRR Chapter XII Section 14 (h) (ii) (B) requires the installation of a manhole to house the stream crossing valve nearest the water supply source.

B. Briefly state the basis for the deviation.

The installation of a manhole will not increase the probability of gaining access to the valve during a flood event.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

There is no general or statewide deviation policy for this request, but deviations have been given in the past on a case-by-case basis.

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of Section VI from the Statement of Basis.)

Not Applicable (N/A)

VI. N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Donald R. McKenzie, Northeast District Engineering Supervisor, and completed on November 21, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

DRM/bb/55297.ltr

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
Renewal
x Modified

PERMIT NO. 95-484
SPECIAL CONDITIONS
REF/PERMIT #95-434

Honken Veterinary Clinic - Wastewater Modifications

This permit hereby authorizes the applicant:

Robert M. Honken
2527 Mountain Valley Drive
Laramie, Wyoming 82070

to construct, install or modify a small wastewater system according to the procedures and conditions of the application number 95-484. The facility is located in the NW1/4 of Section 2, T15N, R73W in the county of Albany, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 6. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 6. The applicant will provide immediate oral and/or written notice to the SE District office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 6. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SE District office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 6. Elimination of bag filter pretreatment system from the original plans for Permit # 95-434 is **APPROVED** - Because the City of Laramie Industrial Pretreatment Program has determined that these pretreatment facilities are not required, all of the materials, equipment, and appurtenances associated with this filter system can be eliminated from the previously approved plans as follows:

a. The building wastewater plumbing can be modified to flow directly into the wastewater holding tanks,

b. All materials and equipment associated with the bag filter pretreatment process, including the duplex pump station, emergency overflow pit, filter housing, bag filter, filter alarm, sewage basin, and high water level alarm; can be eliminated from the construction of this facility.

All conditions of Permit # 95-434 remain in full force.

6. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11-13-95
Date of Issuance

RLE/mad 55046.LTR

cc: Stephanie Whitman, Laramie/Albany County Environmental Health Director
Andy Kasehagen, Albany County Planner

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-484

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on November 2, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 95-485R
SPECIAL CONDITIONS

Water and Sewer Improvements for Country Club Villages Fifth Subdivision

This permit hereby authorizes the applicant:

Bishop Cable Communications, Inc.
716 College View Drive
Riverton, Wyoming 82501

to construct extensions to water distribution and sewer collection systems along with appurtenances and connect these extensions to the systems owned by the City of Riverton according to the procedures and conditions of the application number 95-485R. The facility is located in the NE/4 of Sec. 31, T1N, R4E in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

he issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11/15/95
Date of Issuance

MDR/bb/55163.ltr

STATEMENT OF BASIS

General information.

A. Permit Number: 95-485R

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

V. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 9 November 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR/bb/55163.ltr

CHAPTER III
APPLICATION FOR PERMIT TO CONSTRUCT, INSTALL, OR MODIFY PUBLIC WATER SUPPLIES, WASTEWATER FACILITIES, DISPOSAL SYSTEMS, OR GROUNDWATER MONITORING WELLS IN WYOMING

FOR USE BY DEQ/WQD ONLY

APPLICATION NO. 95-486

DATE RECEIVED _____

Application must contain three copies of the application form, plans, specifications, and pertinent design information.

1. Name of Facility City of Sheridan Phase I Street Paving and Utility Replacement Project

2. Owner, company, or corporation name City of Sheridan

3. Location of facility: County Sheridan

Section 26 ¼ Section NW Township 56N Range 84W

FEB 1997
RECEIVED
WATER QUALITY
DIVISION
SHERIDAN

4. Type of application:
- X New permit
- ___ Revised permit*
- ___ As built approval
- ___ Renewal of permit*

*Previous DEQ/WQD construction permit no(s). _____

5. Facility description: ___ New Facility X Modified facility

MARK ALL THAT APPLY (AT LEAST ONE IN EACH COLUMN)

Public water supply
- X Publicly-owned
- ___ Privately-owned

Type of facility
- ___ Source development
  - ___ Groundwater
  - ___ Surfacewater
- ___ Treatment plant
- X Distribution system

MARK ALL THAT APPLY (AT LEAST ONE IN EACH COLUMN)

Wastewater facility
- X Publicly-owned
- ___ Commercial
- ___ Industrial (including mines)
- ___ Coal mine
- ___ Small (single unit, domestic waste, less than 2000 gpd)

Type of facility
- ___ Septic system
- ___ Domestic sewage pond
- ___ Sedimentation facility
- ___ Evaporative/containment pond
- ___ Mechanical treatment plant/system
- X Collection system
- ___ Land application facility
- ___ Other _____

Groundwater pollution control systems
- ___ Groundwater pollution control or containment system
- ___ Groundwater restoration system
- ___ Monitoring well(s) (P.E. not required)
- ___ Test hole(s) for subsurface contamination assessment (P.E. not required)
- ___ Injection or recovery well
- ___ Cathodic Protection Anode

6. Have all State Engineer permits been obtained? _____ Yes _____ No N/A

If yes, provide permit number(s) _____

If not, the State Engineer (telephone number 777-7354) should be contacted to determine if any permit(s) is required for th project; it is illegal to appropriate water without a permit.

7. Briefly describe facilities proposed to be constructed: Replace deteriorated water and sewer mains in part of Sheridan. Approximately 8,600' of replacement water line and 2,300' of sanitary sewer are involved.

8. Will the proposed water supply/wastewater treatment facility discharge to the surface? _____ Yes __X__ No
If yes, NPDES permit application No. _____

Name of receiving waters _____

Applicant

Name: City of Sheridan

Address: P.O. Box 848

Sheridan, WY 82801
(City,State,Zip)

Phone _____

Engineer

Name: Dayton Alsaker, P.E.

Wyoming P.E. #: 6148

Engineering Firm: MSE-HKM, Inc.

Address: P.O. Box 7010

Sheridan, WY 82801
(City,State,Zip)

Phone 307-672-9006

I certify that the above described facility has been submitted in accordance with local, county and state statutes, as required, and that said facility shall be constructed as authorized under the provisions specified in Wyoming Water Quality Rules and Regulations, Chapter III.

Signature of Applicant

2/5/97
Date

F:\crooks&u\deqappli.pmt

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 95-486
SPECIAL CONDITIONS
REF/PERMIT #

City of Sheridan Phase I Utility Improvement Projects

This permit hereby authorizes the applicant:

City of Sheridan
P.O. Box 848
Sheridan, WY 82801

to construct, install or modify a sewage collection system and a water distribution system according to the procedures and conditions of the application number 95-486. The facility is located in Sections 23 and 26, Township 56 North, Range 84 West in the county of Sheridan, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

4-11-97
Date of Issuance

BDM/pr: April 8, 1997
bb/71223.ltr
cc: Dayton Alsaker, P.E., MSE-HKM, Inc., P.O. Box 7010, Sheridan, WY 82801

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-486

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter XII Section 14.(c) requires valves be located no greater than 800 feet apart in residential districts.

B. Briefly state the basis for the deviation.

Four (4) sections of waterline have valve spacings greater than 800 feet; the longest is approximately 850 feet. Requiring intermediate valves will not significantly reduce inconvenience or minimize sanitary hazards associated with repairs. This deviation has been granted on previous permits.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable (N/A)

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, Senior Environmental Analyst, and completed on April 7, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

BDM/bb/71223.ltr

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

THE STATE OF WYOMING

JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building ● 122 West 25th Street ● Cheyenne, Wyoming 82002

ADMINISTRATION	ABANDONED MINES	AIR QUALITY	INDUSTRIAL SITING	LAND QUALITY	SOLID & HAZARDOUS WASTE	WATER QUALITY
(307) 777-7758	(307) 777-6145	(307) 777-7391	(307) 777-7368	(307) 777-7756	(307) 777-7752	(307) 777-7781
FAX 777-7682	FAX 634-0799	FAX 777-7682	FAX 777-6937	FAX 634-0799	FAX 777-5973	FAX 777-5973

January 4, 1996

Mr. and Mrs. Troy Dysart
P.O. Box 333
Wright, WY 82732

RE: As-Built Permit To Construct, WQD Reference Number 95-487

Dear Mr. and Mrs. Dysart:

The Department of Environmental Quality/Water Quality Division (DEQ/WQD) has reviewed your As-Built Application. Our review of the information and as-constructed plans submitted to this office indicates that the application appears to meet the intent of the DEQ/WQD regulations and the enclosed As-Built Permit To Construct is hereby issued. The enclosed permit covers a domestic septic system which has already been constructed.

Please be advised that the system must be constructed, installed and operated in accordance with the statements, representations and procedures presented in the application and all supporting documentation as well as the terms and conditions of the permit.

You are urged to be familiar with all aspects of the permit application, permit and permit conditions. Any person objecting to a permit issued by the DEQ and desiring affirmative relief may request a hearing before the Environmental Quality Council in accordance with the Rules of Practice and Procedure for the Department of Environmental Quality and the Wyoming Administrative Procedures Act.

Sincerely,

Dennis Hemmer
Director
Department of Environmental Quality

DH/DRM/ks 60060.ltr

Enclosure

xc: Don McKenzie, DEQ/WQD, Sheridan

AS-BUILT
PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-487

TROY DYSART DOMESTIC SEPTIC SYSTEM

This permit hereby authorizes the applicant:

Troy Dysart
P.O. Box 333
Wright, WY 82732

to have constructed, installed or modified a domestic septic system according to the procedures and conditions of the application number 95-487. The facility is located in the SE/4 of Section 34 T45N R65W in the county of Weston, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, meets applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee has constructed and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

1-8-96
Date of Issuance

DRM/ks
60025.ltr

xc: NE District Weston County SWW File

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-487

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes, except for one deviation request

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Wyoming Water Quality Rules and Regulations Chapter XI Section 39 (a) (iii) (A). A septic tank length to width ratio shall be 2:1.

B. Briefly state the basis for the deviation.

The septic tank installed is 8' long by 6' wide (1.3:1 length to width ratio). Adequate solids removal and mixing are anticipated in spite of the non-compliance dimensions.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

No

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable (N/A)

VI. N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Don McKenzie, District Engineer, and completed on January 3, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

THE STATE OF WYOMING

JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building ● 122 West 25th Street ● Cheyenne, Wyoming 82002

ADMINISTRATION	ABANDONED MINES	AIR QUALITY	INDUSTRIAL SITING	LAND QUALITY	SOLID & HAZARDOUS WASTE	WATER QUALITY
(307) 777-7758	(307) 777-6145	(307) 777-7391	(307) 777-7368	(307) 777-7756	(307) 777-7752	(307) 777-7781
FAX 777-7682	FAX 634-0799	FAX 777-7682	FAX 777-6937	FAX 634-0799	FAX 777-5973	FAX 777-5973

December 11, 1995

Wyoming-Montana Feeding Company
P. O. Box 1094
Worland, Wyoming 82401

RE: As-Built Permit To Construct, WQD Reference Number 95-488

Gentlemen:

The Department of Environmental Quality/Water Quality Division (DEQ/WQD) has reviewed the referenced As-Built Application submitted by your company. Our review of the information and as-constructed plans submitted to this office indicates that the application meets DEQ/WQD regulations and the enclosed As-Built Permit To Construct is hereby issued. The enclosed permit covers the construction of five groundwater monitoring wells and the operational procedures for those wells which have already been constructed.

Please be advised that the system must be constructed, installed and operated in accordance with the statements, representations and procedures presented in the application and all supporting documentation as well as the terms and conditions of the permit. You are urged to be familiar with all aspects of the permit application, permit and permit conditions. Any person objecting to a permit issued by the DEQ and desiring affirmative relief may request a hearing before the Environmental Quality Council in accordance with the Rules of Practice and Procedure for the Department of Environmental Quality and the Wyoming Administrative Procedures Act.

Sincerely,

Dennis Hemmer
Director
Department of Environmental Quality

DH/MDR/ks
55622.ltr

Enclosure

AS-BUILT
PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-488
SPECIAL CONDITIONS

WYMT Feeding Company, Worland Facility Monitor Wells

This permit hereby authorizes the applicant:

Wyoming-Montana Feeding Company
P. O. Box 1094
Worland, Wyoming 82401

to have constructed five groundwater monitoring wells following the approved design standards according to the procedures and conditions of the application number 95-488. The facility is located in the SE/4 of Sec. 35, T47N, R93W in the county of Washakie, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, meets applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee has constructed and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 13. After the monitoring well(s)/piezometer(s) have fulfilled their useful purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. No monitoring well/piezometer shall be abandoned without prior approval from the Water Quality Division.

2 of 13. WDEQ/WQD personnel shall be given at least two (2) weeks notice prior to the installation of additional monitor well(s)/piezometer(s) and sample collection so that they may be on site if deemed necessary.

3 of 13. The applicant is responsible for obtaining any Permits required by the State Engineer's Office (777-7354).

4 of 13. The results of any other analyses conducted on soil or water removed from these wells/piezometers or boreholes shall be provided to the department as soon as they are available.

5 of 13. ***Environmental Monitoring Program for Groundwater of the State:***

a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. Groundwater samples are to be analyzed for those contaminants as listed in Department of Environmental Quality, Water Quality Division Rules and Regulations, Chapter VIII, Section 5, page 9.

b. The permittee shall maintain records of all monitoring information for a period of at least 3 years.

c. Records of monitoring information shall include:

1. The date, exact place, and time of sampling or measurements;
2. The name(s) of individual(s) who performed the sampling or measurements;
3. Sampling procedures and sample preservation accomplished;
4. The date(s) analyses were performed;
5. Names of individuals who performed the analyses;
6. The analytical techniques or methods used; and
7. The results of such analyses.

After the second monitoring event, the WQD may substitute a shorter list for the above parameters, depending on the results of the second monitoring event. WQD may substitute less expensive methods for the above listed methods depending upon the analytical results of the monitoring.

6 of 13. **Field Documentation of Design, Construction and Installation of Monitoring Wells:**

a. The following information shall be documented during actual construction and installation of monitoring wells. The information shall be submitted to the Water Quality Division before or at the time of the first monitoring report.

1. Date/time of construction.
2. Person developing information/other person(s) on site and their association to the project.
3. Drilling method and if drilling fluid was used.
4. Well location (± 0.5 ft.).
5. Well depth (± 0.1 ft.).
6. Bore hole diameter and well casing diameter.
7. Drilling and lithologic logs (including visual, olfactory and vapor detection observations). *(See attached 'Borehole Installation Diagram').*
8. Casing material.
9. Screen materials and design/location.
10. Casing and screen joint type.
11. Screen slot size/length.
12. Filter pack material/size, grain analysis.
13. Filter pack volume calculated/actually installed.
14. Filter pack placement method/location.
15. Sealant (annular space) materials.
16. Sealant volume used.
17. Sealant placement method/location.
18. Surface seal design/construction.
19. Well development procedure used.
20. Type of protective well cap (top and bottom).
21. Surveyed elevation (± 0.01 ft. Mean Sea Level) of:
    a.ground surface
    b.surveyor's well reference point
    c.top of well casing
    d.top of protective structure
22. Location of well number stamp or identification marking.
23. Detailed 'as-built' construction drawing of well, including dimensions to all well features. *(See attached 'Monitor Well Installation Diagram')*
    NOTE: The detailed drawing(s) to be submitted must indicate all well features with relation to stratigraphic sections.
24. Method of down hole equipment decontamination between wells.

7 of 13. The monitoring well/piezometer shall be developed by the use of a pump or bailer so that representative groundwater samples can be collected.

8 of 13. Well caps shall be kept locked at all times other than for monitoring purposes. Any tampering with the monitor well(s)/piezometer(s) shall be reported immediately to the Division. The wells shall be clearly numbered using either a stamp to permanently engrave the number into the steel top or by writing the number in the wet concrete of the base.

9 of 13. When PVC casing is used, the casing shall be installed using threaded joints, couplings, or mechanical connectors without the use of solvents or glues to hold the casing sections together.

10 of 13. In accordance with Section 13(a)(iv) of Chapter III of WDEQ/WQD rules and regulations, the following items relating to monitoring well/piezometer construction contained in Sections 64 - 69 of Part G of Chapter XI of WDEQ/WQD rules and regulations take precedence over permit application content and shall be implemented when the well(s)/piezometer(s) are constructed, installed and developed:

a. The borehole diameter shall be at least four (4) inches larger in diameter than the casing diameter.

b. For water table (unconfined) aquifers, the screened interval shall extend at least two (2) feet above the highest expected groundwater level and five (5) feet below the lowest expected water table. Monitoring well(s)/piezometer(s) installed in confined and semi-confined aquifers shall be constructed in accordance with Chapter XI, Section 68 of Water Quality Division Rules and Regulations. Factory screen or slotted casing is recommended for the perforated interval.

c. To minimize the entrance of fine grained material into the monitoring well/piezometer, the filter pack shall be designed to be compatible with the perforation size and the geologic materials encountered within the perforated interval. The filter pack shall extend to a minimum of one (1) foot above the screened interval.

d. Filter pack, annular seal, and surface seal material shall be entered into the monitoring well/piezometer in a manner such that no voids or bridging occur.

e. A minimum two (2) foot thickness of bentonite or bentonite grout is required at the top of the filter pack to serve as an annular seal. After the bentonite has been placed in the annular space, it shall be hydrated to insure a proper seal.

f. The annular space above the bentonite seal to within one foot (1') of the surface will be sealed with neat cement grout, sand-cement grout, bentonite, or concrete according to the specifications provided in WQD Chapter XI, Section 65(c)(i-viii).

g. A protective casing shall be cemented into place with the upper one (1) foot of the annular space completed in cement, forming a concrete apron sloping away from the monitoring well/piezometer.

h. A top and bottom cap of the same material as the monitoring well/piezometer casing shall be installed to prevent sediment and surface water from entering the monitoring well/piezometer.

11 of 13. Prior to sampling, monitoring well(s)/piezometer(s) shall be purged until a minimum of three (3) casing volumes have been removed, or until purged dry, whichever occurs first. Sample collection, preservation, transportation and chemical analytical procedures shall be completed in accordance with WQD and EPA standard procedures.

Within ninety (90) days of issuance of this permit, or completion of the installation and sampling of monitoring well(s)/piezometer(s) authorized by this permit, the Applicant shall submit to WDEQ/WQD a ***Report of Investigation***. At a minimum, the *Report of Investigation* shall contain the following information:

a. A site map which illustrates:

1. physical features (i.e. structures, utilities, etc.).
2. monitoring well/piezometer/test pit/borehole locations.
3. locations and use (i.e. domestic, irrigation, stock) of municipal drinking water and private groundwater supply wells existing within 1 mile of the site.
4. surface waters.

b. Geohydrologic maps and cross sections that clearly describe the subsurface distribution of geologic materials and elevations of groundwater.

c. Depth to water

d. Sample collection procedures utilized and analytical results.

e. A potentiometric surface map showing the direction and gradient of groundwater flow.

f. Interpretation of the data and summary conclusions of the investigation results.

g. ***Sampling and Analysis Plan (SAP)*** for continued groundwater monitoring and reporting. The SAP shall include:

1. Proposed format for reporting data.
2. Proposed frequency of sampling and reporting events.
3. A site map showing physical features and the location of monitoring wells.
4. Proposed parameters for water sample analyses and lab analytical procedures. The proposed parameters for analyses must include those constituents which are characteristic of livestock operations.
5. Description of sampling procedures to be followed, including:

   a. A description of (or reference to) groundwater sampling equipment to be used.
   b. QA/QC plan (including decontamination procedures) to be used.

6. Mean sea level elevations of the top of the casing/measuring point and depth to water of the monitoring wells.

7. A potentiometric surface map illustrating the direction and gradient of groundwater flow.

8. Time vs. concentration graph illustrating historical change in groundwater monitoring elevations and contaminant concentrations at each monitoring well/piezometer over time for each monitoring and/or sampling event.

13 of 13. An adequate number of well(s)/piezometer(s) shall be installed to define the background water quality and to adequately track potential contaminants generated by the confined livestock feeding operations.

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

12-19-95
Date of Issuance

MDR:ks
55623.ltr

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-488

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 8 December 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR:ks
55623.ltr

THE STATE OF WYOMING

JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building ● 122 West 25th Street ● Cheyenne, Wyoming 82002

ADMINISTRATION	ABANDONED MINES	AIR QUALITY	INDUSTRIAL SITING	LAND QUALITY	SOLID & HAZARDOUS WASTE	WATER QUALITY
(307) 777-7758	(307) 777-6145	(307) 777-7391	(307) 777-7368	(307) 777-7756	(307) 777-7752	(307) 777-7781
FAX 777-7682	FAX 634-0799	FAX 777-5616	FAX 777-6937	FAX 634-0799	FAX 777-5973	FAX 777-5973

November 2, 1995

Mr. Christy Smith
19 North Summit Avenue
Newcastle, WY 82701

RE: As-Built Permit To Construct, WQD Reference Number 95-489

Dear Mr. Smith:

The Department of Environmental Quality/Water Quality Division (DEQ/WQD) has reviewed the referenced as-built application submittal. Our review of the information and as-constructed plans submitted to this office indicates that the application appears to meet DEQ/WQD regulations and the enclosed As-Built Permit To Construct is hereby issued. The enclosed permit covers a septic tank and leachfield which have already been constructed.

Please be advised that the system must be constructed, installed and operated in accordance with the statements, representations and procedures presented in the application and all supporting documentation as well as the terms and conditions of the permit.

You are urged to be familiar with all aspects of the permit application, permit and permit conditions. Any person objecting to a permit issued by the DEQ and desiring affirmative relief may request a hearing before the Environmental Quality Council in accordance with the Rules of Practice and Procedure for the Department of Environmental Quality and the Wyoming Administrative Procedures Act.

Sincerely,

Dennis Hemmer
Director
Department of Environmental Quality

DH/DRM/ks
55022.ltr

Enclosure

cc: Don McKenzie, DEQ/WQD, Sheridan

AS-BUILT
PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-489

REF/PERMIT # 90-265

BUCKHORN BAR & GRILL SEPTIC SYSTEM II

This permit hereby authorizes the applicant:

Christy K. Smith
19 North Summit Avenue
Newcastle, WY 82701

to have constructed, installed or modified septic system according to the procedures and conditions of the application number 95-489. The facility is located in the SE/4 of Section 8 of T48N R60W in the county of Weston, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, meets applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee has constructed and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11/14/95
Date of Issuance

DRM/pr/ks
55021.ltr

xc: NE DEQ/WQD District Weston County SWW File

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-489

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Donald R. McKenzie, NE District Engineering Supervisor, and completed on October 31, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

DRM/pr/ks
55021.ltr

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
Renewal
X Modified

PERMIT NO. 95-490
SPECIAL CONDITIONS
REF/PERMIT #95-422 & 95-404

Revised Water Main Ext. - 6th Ave. & Sanitary Sewer - 4th & 6th Ave.

This permit hereby authorizes the applicant:

Town of Albin
P.O. Box 188
Albin, WY 82050

to modify the alignment of the 4th Ave. and extend proposed water and sewer mains in 6th ave. according to the procedures and conditions of the application number 95-490. The facility is located in NW 1/4 Section 19, T17N, R60W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 5 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

5 of 5 This permit is being issued for realignment of the sewer main on 4th Ave. and the extension of the water and sewer mains on 6th Ave. only. All permit conditions under Permit to Construct 95-422 & 95-404 are to be adhered to.

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11-13-95
Date of Issuance

GLS/mad 55068.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-490

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on November 6, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-491
SPECIAL CONDITIONS

Northwest Community Baptist Church

This permit hereby authorizes the applicant:

Northwest Community Baptist Church
9204 Yellowstone Rd.
Cheyenne, WY 82009

to install a commercial septic system for domestic waste only according to the procedures and conditions of the application number 95-491. The facility is located in NE 1/4 Section 12, T14N, R67W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineer, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 5 The applicant will provide immediate oral and/or written notice to Southeast District Engineer in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Engineer on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

5 of 5 The permittee shall notify the Laramie County Environmental Health Division at least (2) days prior to installation of this system to arrange for required inspections. Inspection of the installed system is required prior to backfilling. Laramie County Environmental Health charges a fee for these inspection services. Their offices are located at 100 Central Ave, Cheyenne, Wyoming 82007; or they can be reached by phone at (307) 633-4090

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11-13-95
Date of Issuance

GLS/mad 55072.LTR
cc: Laramie County Environmental Health

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-491

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

N/A

B. Briefly state the basis for the deviation.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on November 6, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

STATE OF WYOMING

JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building ● 122 West 25th Street ● Cheyenne, Wyoming 82002

ADMINISTRATION	ABANDONED MINES	AIR QUALITY	INDUSTRIAL SITING	LAND QUALITY	SOLID & HAZARDOUS WASTE	WATER QUALITY
(307) 777-7758	(307) 777-6145	(307) 777-7391	(307) 777-7368	(307) 777-7756	(307) 777-7752	(307) 777-7781
FAX 777-7682	FAX 634-0799	FAX 777-5616	FAX 777-6937	FAX 634-0799	FAX 777-5973	FAX 777-5973

October 27, 1997

Darwin Dunn
Box 3
Savery, Wyoming 82332

RE: **Permit Reporting Requirements** for Permit Number - **95-492**

Dear Mr. Dunn:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Notify the WQD of any changes (Condition 1)
2. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 2)

Please read the permit conditions carefully and follow through as required. Finally, bear in mind that the submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit.

If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald

Ronald L. Ewald
Senior Analyst
SE District, Water Quality Division

RLE/mad 73303.LTR

: Brent Mosier, Town of Baggs - Director of Public Works
nclosure: Permit Referenced Above

AS-BUILT
PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 95-492
SPECIAL CONDITIONS

Dunn Trucking Shop - Holding Tank

This permit hereby authorizes the applicant:

Darwin and Carol Lee Dunn
Box 3
Savery, Wyoming 82332

to have constructed and installed a domestic wastewater holding tank according to the procedures and conditions of the application number 95-492. The facility is located in the SE 1/4 of Section 05, T12N, R91W in the county of Carbon, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards, except as noted in the permit conditions and "Statement of Basis". The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, meets applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee has constructed and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. All **modifications or deviations** from the authorized plans **must be highlighted**.

3 of 4. Ten(10) Year Tank Removal Requirement - Because this is a steel tank without cathodic protection, the tank shall be removed on or before January 1, 2008. On or before January 1, 2008, the trucking shop sewer should be connected to the Town of Baggs wastewater collection system. If this is still not possible, then the facility owner shall apply for another "Permit To Construct" to install a replacement holding tank made of more suitable material.

4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Gary Beach
Administrator
Water Quality Division

Dennis Hemmer
Director
Department of Environmental Quality

10-30-97
Date of Issuance

RLE/mad 73304.LTR

cc: Carbon County Planner/Sanitarian
Brent Mosier, Town of Baggs - Director of Public Works

STATEMENT OF BASIS

General information.

A. Permit Number: 95-492

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Applicable - Chapter XI, Section 39(a)(i) - Septic Tank Materials: Septic tanks shall be constructed of durable materials not subject to excessive corrosion or decay.

B. Briefly state the basis for the deviation.

Basis Is - The holding tank is 3/8 inch thick steel which is to be replaced within ten(10) years with a tank constructed of more suitable materials, or the shop sewer will be connected to the Town of Baggs wastewater collection system before 10 years passes.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 27, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

Herschler Bldg., 4 West
Cheyenne, Wyoming 82002

PROJECT: Dunn Trucking Shop - Holding Tank

ENGINEER: None

APPLICANT: Darwin & Carol Lee Dunn
Box 3
Savery, Wyoming 82332

WATER QUALITY DIVISION REFERENCE NUMBER: 95-492

REVIEWING ENGINEER: Ronald L. Ewald RLE

DATE OF REVIEW: July 14, 1997

ACTION: **NOT AUTHORIZED FOR CONSTRUCTION**. In accordance with Section 12 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. Please indicate what section, township, and range this facility is located in.

2. Tank Materials - Your submittal says the tank is heavy guage metal designed for underground. What kind of metal is the tank, and what does designed for underground mean? Is this an old used underground fuel tank, or what? Does this metal tank have cathodic protection?

3. Separation Distances - How far is it from the holding tank to:

   a. The nearest well,
   b. Property lines,
   c. Potable water lines, and
   d. A stream, or any other body of water?

4. Groundwater Depth - What is the depth of the seasonally high groundwater in the area of the holding tank? Does the tank extend into the groundwater table?

5. Vent Pipe Details - Please provide more detailed drawings of the vent pipe. Does it have a return elbow and screen? How far is it from any doors or windows?

6. Level Indicator/Alarm - Please provide more details and drawings of the visual level indicator system. Explain in detail how it is set-up and how it works.

7. Letter of Waste Acceptance - A letter of acceptance from the ultimate waste receiver must be submitted. A letter from the waste hauler alone is not sufficient.

8. Professional Engineer Required - Because this application is for a commercial facility the plans must be prepared by and stamped by a Wyoming registered Professional Engineer.

RLE:ks
72302.ltr

cc: Town of Baggs

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-493
SPECIAL CONDITIONS

LEWIS WILSON RESIDENCE SEPTIC SYSTEM

This permit hereby authorizes the applicant:

Lewis Wilson
P. O. Box 903
Upton, WY 82730

to construct, install or modify a septic system according to the procedures and conditions of the application numbers 95-493. The facility is located in the SE/4 of Section 20 of T48N R63W in the county of Weston, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 4 The applicant will provide immediate oral and/or written notice to Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

11/15/95
Date of Issuance

Director
Department of Environmental Quality

DRM/pr/mad 55191.LTR
Enclosures: Notification Post Card
Certificate of Completion
Statement of Basis

STATEMENT OF BASIS

General information.

A. Permit Number: 95-493

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of Section VI. from the Statement of Basis.)

N/A

VI. N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Donald R. McKenzie, Northeast District Engineering Supervisor, and completed on November 13, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-494
SPECIAL CONDITIONS

Smart Start Academy Water and Sewer Extension

This permit hereby authorizes the applicant:

City of Riverton, Harry C. LaBonde, Jr., Public Works Director
P. O. Box 1700
Riverton, Wyoming 82501

to construct 315' of 10" PVC water main extension and 315' of 8" sewer main extension, both of which will serve the Smart Start Academy, according to the procedures and conditions of the application number 95-494. The facility is located in the NE/4 of Sec. 28, T1N, R4E in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11/15/95
Date of Issuance

MDR/mad 55192.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-494

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

V. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 13 November 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LAND APPLICATION PERMIT

X New
Renewal
Modified

PERMIT NO. 95-495
SPECIAL CONDITIONS
REF/PERMIT #

Fuel America Sewage Lagoon (Sludge Application)

This permit hereby authorizes the applicant:

Wyoming Truck "N" Travel
P.O. Box 699
Spanish Fork, Utah 84660

to land apply domestic sewage sludge on a one time basis which meets the requirements of CFR 503 for class B sludge according to the procedures and conditions of the application number 95-495. The application site is located in NE 1/4 Section 14, T13N, R67W in the county of Laramie, in the State of Wyoming. This permit shall be effective until January 1, 1996.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the land application described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the land application. By issuing this permit, the state does not waive its sovereign immunity.

he permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 7 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: Southeast District Office 122 W. 25 Street, Herschler 4 West, Cheyenne, WY 82002.

` of 7 The permittee shall provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.

3 of 7 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the Southeast District Office on the attached Certification of Completion form.

a. Date that the land application was completed; and

b. Certification the land application was done in accordance with the terms and conditions of the permit; or

c. Certification the land application was completed with changes or modifications. Submit the information necessary to clearly indicate the land application as actually performed. This information shall include a contour map depicting only those sections that actually received .

4 of 7 The review and approval of this permit is based upon the items identified in the attached Statement of Basis.

5 of 7 Application shall be terminated within 100 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs or existing wells in the area.

6 of 7 A report shall be prepared and submitted within 60 days of completion of the sludge application. The report shall include sampling results of the sludge fly ash mixture, and calculations showing how the 60 pounds per acre of total N was obtained. The report shall also include the total area where sludge was applied, the total amount of sludge applied to the site, and the total amount of sludge hauled to the landfill.

7 of 7 This permit is for the application of the domestic sewage sludge only and does not relieve the Permittee of any on going enforcement activities or requirements to remediate existing contamination on the site.

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11/15/95
Date of Issuance

GLS/bb/55174.ltr

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-495

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Applicable portions of Chapter XI Part E

B. Briefly state the basis for the deviation.

CFR Part 503 was passed after Part E of Chapter XI was adopted. The 503 sludge regulations are applicable whether a permit is issued or not. This sludge application is being approved Under Section 5 of Chapter XI of the Water Quality Rules and Regulations. The Water Quality Division has reviewed the land application information to verify that it is in accordance with the 503 regulations.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Applicable

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

The sludge is to be applied at an agronomic rate of 60 lbs of total N per acre. The application of the sludge at an agronomic rate will not create a groundwater violation.

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

Monitoring will include sampling of the sludge fly ash mixture to determine the application rate of the mixture.

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer and completed on November 13, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

GLS/bb/55174.ltr

PERMIT TO CONSTRUCT

New
Renewal
X Modified

PERMIT NO. 95-496
SPECIAL CONDITIONS
REF/PERMIT #95-429

Highland Village Subdivision

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities
2100 Pioneer Avenue
Cheyenne, WY 82001

to modify a proposed extension to the publicly owned distribution system to include the extension of one main to include an additional fire hydrant according to the procedures and conditions of the application number 95-496. The facility is located in SE 1/4 Section 5, T13N, R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 5 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

5 of 5 This permit is for the extension of a distribution main and to add an additional fire hydrant for fire protection. All Permit Conditions issued under Permit to Construct 95-429 shall be adhered to.

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11/15/95
Date of Issuance

GLS/bb/55164.ltr

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-496

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on November 9, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

GLS/bb/55164.ltr

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-497
SPECIAL CONDITIONS
REF/PERMIT #

Moorcroft Water System Improvements

This permit hereby authorizes the applicant:

Town of Moorcroft
P.O. Box 70
Moorcroft, Wyoming 82721
Attention: Mayor Fred Welch

to construct, install or modify a water transmission line and water storage tank according to the procedures and conditions of the application number 95-497. The facility is located in S36 T50N R68W, S31 T50N R67W, S5 T49N R67W in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

1-11-96
Date of Issuance

BDM/ks 60143.ltr

cc: Jerry Hunt, P.E., Weston Engineering, P.O. Box 260, Upton, WY 82730

STATEMENT OF BASIS

General information.

A. Permit Number: 95-497

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. no

B. Chapter XII. yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

no

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

no

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

not applicable

B. Briefly state the basis for the deviation.

not applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

not applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

not applicable

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

not applicable

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on January 9, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-498
SPECIAL CONDITIONS

F.E. Warren AFB (Alter Dormitory 224)

This permit hereby authorizes the applicant:

John L. Wright
300 Vesle Drive, Suite 600
F.E. Warren AFB, WY 82005

to install a fire line and cross connection control device to the above titled facility according to the procedures and conditions of the application number 95-498. The facility is located in Section 23, T14N, R67W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 4 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11-24-95
Date of Issuance

GLS/mad 55240.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-498

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

---

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on November 17, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-499
SPECIAL CONDITIONS
Reference 95-045

MISCELLANEOUS WATERMAIN REPLACEMENT PROJECT II

This permit hereby authorizes the applicant:

City of Casper
200 North David
Casper, WY 82601
Attention: Mr. Hal Hutchinson

to construct, install or modify water mains according to the procedures and conditions of the application number 95-045 and 95-499. The facility is located in the NE/4 Section 15 T33N R79W in the county of Natrona, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2 of 4 The applicant will provide immediate oral and/or written notice to Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11/15/95
Date of Issuance

DRM/pr/mad 55193.LTR

Enclosures: Notification Post Card
Certificate of Completion
Statement of Basis

STATEMENT OF BASIS

I. General information.

A. Permit Number: 95-499

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of Section VI. from the Statement of Basis.)

N/A

VI. N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Donald R. McKenzie, Northeast District Engineering Supervisor, and completed on November 13, 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 95-500
SPECIAL CONDITIONS

Rick and Colleen Tippetts septic tank and leach field

This permit hereby authorizes the applicant:

Rick and Colleen Tippetts
425 Penn Avenue #3
Lovell, Wyoming 82431

to construct a residential septic tank and leach field system according to the procedures and conditions of the application number 95-500. The facility is located in the SE/4 of Sec.7, T56N, R95W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.

2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:

   a. Date that construction of the facility was completed; and

   b. Date that the facility was placed in operation; and

   c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

   d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Administrator
Water Quality Division

Director
Department of Environmental Quality

11/15/95
Date of Issuance

MDR/mad 55194.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 95-500

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

V. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P. E., Northwest District Engineer, and completed on 13 November 1995. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."