

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 96-401
SPECIAL CONDITIONS
REF/PERMIT # 96-202

Casper Wolf Creek Water Main Loop Improvements

This permit hereby authorizes the applicant:

City of Casper
200 N. David
Casper, Wyoming 82601
Attention: Hal Hutchinson

to construct, install or modify a water main according to the procedures and conditions of the application number 96-202 and 96-401. The facility is located in the NW/4 of Section 19, Township 33 North, Range 79 West in the county of Natrona, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9-24-96

Date of Issuance

BDM/pr: mad 63581.LTR

cc: Michael Bell, P.E., 259 Center St., Suite 306, Casper, WY 82601
Mike Jennings, Natrona County Health, 1200 E. 3rd, Casper WY 82601
Tom Curren, Natrona County Planning, 120 W. 1st, #200, Casper, WY 82601

STATEMENT OF BASIS

General information.

A. Permit Number: 96-401

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not applicable

B. Briefly state the basis for the deviation.

Not applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on September 20, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

2
New
Renewal
Modified

PERMIT NO. 96-402
SPECIAL CONDITIONS
REF/PERMIT #

Gillette Madison Well Field Pipeline Improvements

This permit hereby authorizes the applicant:

City of Gillette
P.O. Box 3003
Gillette, WY 82716
Attention: Bill Carson

to construct, install or modify a well field water transmission line according to the procedures and conditions of the application number 96-402. The facility is located in Section 6, Township 51 North, Range 66 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

9-26-96

Date of Issuance

BDM/pr/ks 63609.ltr

cc: Ed Nowak, P.E., Wester-Wetstein & Assoc., Inc., 605 Plaza Court, Laramie, WY 82070

STATEMENT OF BASIS

General information.

A. Permit Number: 96-402

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not applicable

B. Briefly state the basis for the deviation.

Not applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not applicable

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not applicable

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on September 23, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

THE STATE



OF WYOMING



JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building ● 122 West 25th Street ● Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

October 21, 1996

Alan H. Hall
P.O. Box 65
Elk Mountain, Wyoming 82324

RE: Permit Reporting Requirements for Permit Number - 96-403

Dear Mr. Hall:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Estimated Construction Schedule Post Card (Condition 1)
2. Notify the WQD of any changes (Condition 2)
3. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 3)

Please read the permit conditions carefully and follow through as required. Finally, bear in mind that the submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit.

If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Senior Analyst
SE District, Water Quality Division

RLE/bb/63956.1tr

Enclosure: Permit Referenced Above

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 96-403
SPECIAL CONDITIONS
REF/PERMIT #

Hall Residential Septic System

This permit hereby authorizes the applicant:

Alan H. Hall
P.O. Box 65
Elk Mountain, Wyoming 82324

to construct, install or modify a residential septic system with "Infiltrator" leach field according to the procedures and conditions of the application number 96-403. The facility is located in the NE 1/4 of Section 11, T19N, R81W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 6. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 6. The applicant will provide immediate oral and/or written notice to the SE District office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 6. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SE District office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 6. Norwesco Septic Tank Requirements - To ensure structural integrity the manufacturers **instructions** regarding filling the tank with water during burial and immediately after pumping **must be followed** during installation.
- 5 of 6. Infiltrator Trenches - A **minimum of 15 sections of infiltrator leaching chambers** shall be installed in accordance with the manufacturers instructions.
- 6 of 6. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-28-96
Date of Issuance

RLE/bb/63961.ltr
cc: Carbon County Planner/Sanitarian

STATEMENT OF BASIS

- I. General information.
 - A. Permit Number: 96-403
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
 - A. Chapter XI. Yes
 - B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
 - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
Yes
 - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
 - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
 - A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
NOT Applicable
 - B. Briefly state the basis for the deviation.
NOT Applicable
 - C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 18, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/bb/63961.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

ROAD APPLICATION PERMIT

X New
Renewal
Modified

PERMIT NO. 96-404
SPECIAL CONDITIONS
REF/PERMIT #

ALTEX East Tisdale Oil Field Road Application Number 1

This permit hereby authorizes the applicant:

ALTEX Oil Company
P.O. Box 1057
Breckenridge, CO 80424
Attention: Steve Cardin

to road apply oil contaminated soil according to the procedures and conditions of application number 96-404. The application site is located in Sections 9, 16, 21, 22, 27, Township 41 North, Range 81 West in the county of Johnson, in the State of Wyoming. This permit shall be effective until November 1, 1996.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), upon the presentation of credentials and during working hours, to have access to inspect the waste source and application site location, for the purpose of compliance with the provisions of this permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 9 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: Northeast District Office, Department of Environmental Quality/Water Quality Division, 1043 Coffeen Ave., Suite D, Sheridan, WY 82801; Tel. (307) 672-6457, FAX (307) 674-6050.

- 2 of 9 The permittee shall provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.

- 3 of 9 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the Northeast District Office on the attached Certification of Completion form.
- a. Date that the road application was completed; and
 - b. Certification the road application was done in accordance with the terms and conditions of the permit; or
 - c. Certification the road application was completed with changes or modifications. Submit the information necessary to clearly indicate the road application as actually performed. This information shall include a contour map depicting only those sections of road that actually received oil contaminated soil.
- 4 of 9 The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
- 5 of 9 Oil contaminated soil shall be applied uniformly and incorporated into the road bed. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. oil contaminated soil shall not be applied during the period from November 1 to April 10.
- 6 of 9 The application site slope shall not exceed eight percent (8%) for vehicular application.
- 7 of 9 Oil contaminated soil application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
- 8 of 9 Only the roads designated in this permit are authorized for application of the oil contaminated soil. Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.
- 9 of 9 Any oil contaminated soil road application after November 1, 1996 must be re-permitted.


AUTHORIZED BY:



Administrator
Water Quality Division

9-30-96

Date of Issuance



Director
Department of Environmental Quality

BDM/pr:mad 63554.LTR

cc: Bret Wolz, P.E. CERI, 400 S. Miller, Gillette, WY 82716

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 96-404
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. No
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
No
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
There are no numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.
- B. Briefly state the basis for the deviation.
Road application is permitted when DFO authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)
Applicable

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the oil contaminated soil onto the roadbed. Repeated applications of oil contaminated soil on the same sections of road will be monitored by roadbed analyses.

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian Mark, Senior Environmental Analyst, and completed on September 19, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

53368.DOC

ROAD APPLICATION PERMIT

X New
Renewal
Modified

PERMIT NO. 96-405
SPECIAL CONDITIONS
REF/PERMIT #

ALTEX East Tisdale Oil Field Road Application Number 2

This permit hereby authorizes the applicant:

ALTEX Oil Company
P.O. Box 1057
Breckenridge, CO 80424
Attention: Steve Cardin

to road apply oil contaminated soil according to the procedures and conditions of application number 96-405. The application site is located in Section 16, Township 41 North, Range 81 West in the county of Johnson, in the State of Wyoming. This permit shall be effective until November 1, 1996.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), upon the presentation of credentials and during working hours, to have access to inspect the waste source and application site location, for the purpose of compliance with the provisions of this permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 9 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: Northeast District Office, Department of Environmental Quality/Water Quality Division, 1043 Coffeen Ave., Suite D, Sheridan, WY 82801; Tel. (307) 672-6457, FAX (307) 674-6050.

2 of 9 The permittee shall provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.

- 3 of 9 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the Northeast District Office on the attached Certification of Completion form.
- a. Date that the road application was completed; and
 - b. Certification the road application was done in accordance with the terms and conditions of the permit; or
 - c. Certification the road application was completed with changes or modifications. Submit the information necessary to clearly indicate the road application as actually performed. This information shall include a contour map depicting only those sections of road that actually received oil contaminated soil.
- 4 of 9 The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
- 5 of 9 Oil contaminated soil shall be applied uniformly and incorporated into the road bed. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. oil contaminated soil shall not be applied during the period from November 1 to April 10.
- 6 of 9 The application site slope shall not exceed eight percent (8%) for vehicular application.
- 7 of 9 Oil contaminated soil application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
- 8 of 9 Only the roads designated in this permit are authorized for application of the oil contaminated soil. Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.
- 9 of 9 Any oil contaminated soil road application after November 1, 1996 must be re-permitted.


AUTHORIZED BY:



Administrator
Water Quality Division

9-20-96

Date of Issuance



Director
Department of Environmental Quality

BDM/pr: mad 63555.LTR

cc: Bret Wolz, P.E. CERI, 400 S. Miller, Gillette, WY 82716

STATEMENT OF BASIS

I. General information.

A. Permit Number: 96-405

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are no numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DFO authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Applicable

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the oil contaminated soil onto the roadbed. Repeated applications of oil contaminated soil on the same sections of road will be monitored by roadbed analyses.

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian Mark, Senior Environmental Analyst, and completed on September 19, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

☒ New
Renewal
Modified

PERMIT NO. 96-406
SPECIAL CONDITIONS
REF/PERMIT #93-421

Mills, Black Hills Bentonite, Water Line and Sewer Line Extensions

This permit hereby authorizes the applicant:

Town of Mills
704 4th Street
Mills, WY 82644
Attention: Bob Goff

to construct, install or modify a water line and sewer line according to the procedures and conditions of the application number 96-406. The facility is located in SW/4 of the NW/4, Section 6, Township 33 North, Range 79 West in the county of Natrona, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-10-96
Date of Issuance

BDM/pr/mad 63848.LTR

cc: Brad Shaffer, P.E., Worthington, Lenhart and Carpenter, Inc., 200 Pronghorn, Casper, WY 82601

STATEMENT OF BASIS

I. General information.

A. Permit Number: 96-406

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not applicable

B. Briefly state the basis for the deviation.

Not applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on October 7, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

ROAD APPLICATION PERMIT

X New
Renewal
Modified

PERMIT NO. 96-407
SPECIAL CONDITIONS
REF/PERMIT #95-293

Exxon Hartzog Draw Unit Road Application 1996

This permit hereby authorizes the applicant:

Exxon Corporation
P.O. Box 1719
Gillette, WY 82717
Attention: Mr. R.S. Large

to road apply oil contaminated soils and waste oil sludges according to the procedures and conditions of application number 96-407. The application site is located in Sections 8, 9, 17, Township 44 North, Range 75 West in the county of Campbell, in the State of Wyoming. This permit shall be effective until November 1, 1996.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), upon the presentation of credentials and during working hours, to have access to inspect the waste source and application site location, for the purpose of compliance with the provisions of this permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 9 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: Northeast District Office, Department of Environmental Quality/Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, WY 82801; Tel (307) 672-6457, FAX (307) 674-6050.
- 2 of 9 The permittee shall provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.

- 3 of 9 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the Northeast District Office on the attached Certification of Completion form.
- a. Date that the road application was completed; and
 - b. Certification the road application was done in accordance with the terms and conditions of the permit; or
 - c. Certification the road application was completed with changes or modifications. Submit the information necessary to clearly indicate the road application as actually performed. This information shall include a contour map depicting only those sections of road that actually received oil contaminated soils and waste oil sludges.
- 4 of 9 The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
- 5 of 9 Oil contaminated soils and waste oil sludges shall be applied uniformly and incorporated into the road bed. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. oil contaminated soils and waste oil sludges shall not be applied during the period from November 1 to April 10.
- 6 of 9 The application site slope shall not exceed eight percent (8%) for vehicular application.
- 7 of 9 Oil contaminated soils and waste oil sludges application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
- 8 of 9 Only the roads designated in this permit are authorized for application of the oil contaminated soils and waste oil sludges. Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.
- 9 of 9 Any oil contaminated soils and waste oil sludges application after November 1, 1996 must be re-permitted.

AUTHORIZED BY:



Administrator
Water Quality Division

9-20-96
Date of Issuance



Director
Department of Environmental Quality

BDM/pr:mad 63568.LTR

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 96-407
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. No
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
No
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
There are no numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.
- B. Briefly state the basis for the deviation.
Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)
Applicable

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the oil contaminated soils and waste oil sludges onto the roadbed. Repeated applications of oil contaminated soils and waste oil sludges on the same sections of road will be monitored by roadbed analyses.

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian Mark, Senior Environmental Analyst and completed on September 19, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 96-408
SPECIAL CONDITIONS
REF/PERMIT #

Goshen Care Center - Water and Sewer Improvements

This permit hereby authorizes the applicant:

Town of Torrington
336 W. Railway
Torrington, WY 82240

to construct an extension to the publicly owned distribution and collection systems according to the procedures and conditions of the application number 96-408. The facility is located in NE 1/4 Section 4, T24N, R61W in the county of Goshen, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-2-96

Date of Issuance

GLS/bb/63732.ltr

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 96-408
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- N/A
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)
- N/A
- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)
- N/A

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on September 30, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

GLS/bb/63732.ltr

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 96-409
SPECIAL CONDITIONS
REF/PERMIT #

Sun Valley Addition, 14th Filing - Phase 4

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities
2100 Snyder Ave.
Cheyenne, WY 82001

to construct an extension to the publicly owned distribution and collection systems according to the procedures and conditions of the application number 96-409. The facility is located in SE SW 1/4 Section 35, T14N, R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-16-96

Date of Issuance

GLS/mad 63931.LTR

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 96-409
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- N/A
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)
- N/A
- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)
- N/A

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on October 14, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

Herschler Bldg., 4 West
Cheyenne, Wyoming 82002

PROJECT: Sun Valley Addition, 14th Filing - Phase 4

ENGINEER: Joseph E. Kub, P.E.
Kub Engineers
6118 Yellowstone Road
Cheyenne, WY 82009

APPLICANT: Cheyenne Board of Public Utilities
2100 Snyder Avenue
Cheyenne, WY 82001

WATER QUALITY DIVISION REFERENCE NUMBER: 96-409

REVIEWING ENGINEER: Gary Steele



DATE OF REVIEW: September 30, 1996

ACTION: NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 12 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS:

1 of 2 Water Quality Rules and Regulations require that an Engineering Design Report be submitted which describes the proposed project and provides flow and pressure information for design of the water and wastewater systems. If this information has been provided in other projects, those projects should be referenced.

2 of 2 Water Quality Rules and Regulations require that a plan and profile be provided for all proposed water and sewer mains. The plans do not provide plan and profile sheets for the proposed lines on Gettysburg Drive or Pennsylvania Ave. Please provide plan and profile sheets for these lines.

GLS/bb/63721.ltr

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
Herschler Bldg., 4 West
Cheyenne, Wyoming 82002

PROJECT: Sybille Wildlife Research Unit: Resident/Office Septic System

ENGINEER: Tee J. Burr
Coffey & Associates, LLC
903 Grand Avenue
Laramie, Wyoming 82070
(307) 742-7425

APPLICANT: US Fish & Wildlife Service
410 E Grand Avenue, Ste. 315
Laramie, Wyoming 82070

WATER QUALITY DIVISION REFERENCE NUMBER: 96-410

REVIEWING ENGINEER: Ronald L. Ewald *RLE*

DATE OF REVIEW: September 30, 1996

ACTION: **NOT AUTHORIZED FOR USE.** In accordance with Section 12 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. Septic Tank Specifications - Please indicate the brand name or manufacturer of the septic tank so we can check if it is on our pre-approved list. If not, please provide dimensions and other specifications of the septic tank. Is this a one or two compartment tank? Also, were any clean-outs or manways brought to the surface?
2. Equal Flow Distribution Questionable - The use of a simple pipe T with one leg aligned in line with the approach flow will not provide equal flow to the two separate "Infiltrator" trenches. This needs to be re-worked to provide relatively equal flow distribution to the two legs. Please propose a different flow splitting method.

RLE/bb/63729.ltr



THE STATE OF WYOMING



JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-7682	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

October 11, 1996

US Fish & Wildlife Service
Attn. J. Michael Lockhart
410 E Grand Avenue, Ste. 315
Laramie, Wyoming 82070

RE: Permit Reporting Requirements for Permit Number - 96-410

Dear Mr. Lockhart:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Estimated Construction Schedule Post Card (Condition 1)
2. Notify the WQD of any changes (Condition 2)
3. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 3)

Please read the permit conditions carefully and follow through as required. Finally, bear in mind that the submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit.

If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Senior Analyst
SE District, Water Quality Division

RLE/bb/63919.1tr

Enclosure: Permit Referenced Above

cc: Tee J. Burr, Coffey & Associates, LLC
903 Grand Avenue
Laramie, Wyoming 82070

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 96-410
SPECIAL CONDITIONS
REF/PERMIT #

Sybilie Wildlife Research Unit: Resident/Office Septic System

This permit hereby authorizes the applicant:

US Fish & Wildlife Service
410 E Grand Avenue, Ste. 315
Laramie, Wyoming 82070

to construct, install or modify a commercial domestic character septic system with "Infiltrator" leach field according to the procedures and conditions of the application number 96-410. The facility is located in the SE 1/4 of Section 29, T21N, R71W in the county of Albany, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 6. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 6. The applicant will provide immediate oral and/or written notice to the SE District office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 6. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SE District office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 6. Flow Divider Approved - The Zabel Z200 Flow Divider is approved to be used instead of a D-Box.
- 5 of 6. Before the septic tank, leach field pipe, or other important components are covered, the applicant shall contact the Environmental Health Director for the City of Laramie/Albany County (Stephanie Whitman) at 721-5283, to arrange for an inspection of the project. The system shall not be covered or placed into service until this inspection has been conducted and the work has been approved.
- 6 of 6. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".


AUTHORIZED BY:



Administrator
Water Quality Division

10-16-96

Date of Issuance



Director
Department of Environmental Quality

RLE/bb/63920.ltr

cc: Stephanie Whitman, Laramie/Albany County Environmental Health Director

STATEMENT OF BASIS

General information.

A. Permit Number: 96-410

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 11, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/bb/63920.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
Renewal
X Modified

PERMIT NO. 96-411
SPECIAL CONDITIONS
REF/PERMIT #96-033

Carpenter School Addition - Septic System Modification

This permit hereby authorizes the applicant:

Laramie County School District No. 2
P.O. Box 368
Pine Bluffs, Wyoming 82082

to construct, install or modify and add to the septic system for the school addition according to the procedures and conditions of the application number 96-411. The facility is located in Section 31, T13N, R62W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period ending on March 29, 1998.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 7. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 7. The applicant will provide immediate oral and/or written notice to the SF District office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 7. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SF District office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 7. The connection of the residential trailer house to the school septic system is allowed with the following restriction:


As long as the trailer house is connected to the school septic system the school population, which means students, teachers, and any other staff, shall not exceed 102 people.
- 5 of 7. Before such time as the school population does exceed 102 people, the School District shall notify the Water Quality Division in writing of this impending occurrence and shall accomplish one of the following two options:
 - a. Disconnect the trailer house permanently from the school septic system. This disconnection shall be inspected and approved by the WQD.

OR


 - b. Expand the septic system to allow for the additional loading. This expansion would require that the School District apply for and receive a "Permit To Construct" authorizing the modifications and additions from the WQD.
- 6 of 7. The modifications authorized by this permit must be inspected and approved by personnel from the WQD before they are covered. To arrange for this inspection, contact Ronald L. Ewald at (307) 777-6183.

7 of 7. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-10-96
Date of Issuance

RLE/mad 63834.LTR

STATEMENT OF BASIS

- I. General information.
 - A. Permit Number: 96-411

- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
 - A. Chapter XI. Yes
 - B. Chapter XII. No

- III. Basis for issuing permit. (Indicate yes or no for each section.)
 - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
Yes
 - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
 - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No

- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
 - A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
NOT Applicable
 - B. Briefly state the basis for the deviation.
NOT Applicable
 - C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

- VI. Deleted

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 7, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 96-412
SPECIAL CONDITIONS

Tim Kershner Septic Tank and Leach Field

This permit hereby authorizes the applicant:

Tim Kershner
3451 Rimrock Road
Greybull, Wyoming 82426

to construct a single family residential septic tank and leach field system according to the procedures and conditions of the application number 96-412. The facility is located in the SW corner of the Knode Ranch Tract, Sec. 9, T52N, R93W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-1-96
Date of Issuance

MDR/mad 63684.LTR

STATEMENT OF BASIS

- I. General information.
 - A. Permit Number: 96-412
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
 - A. Chapter XI. Yes
 - B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
 - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes
 - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No
 - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No
- IV. Documentation of Statement of Basis.
 - A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 26 September 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

ROAD APPLICATION PERMIT

x New
Renewal
Modified

PERMIT NO. 96-413
SPECIAL CONDITIONS

Eagle Bronze Petroleum Stained Soil Road Application

This permit hereby authorizes the applicant:

Eagle Bronze
P.O. Box 1100
Lander, Wyoming 82520

to road apply eight cu yds of oil stained sandy soil according to the procedures and conditions of application number 96-413. The application site is located in the SE/4 of Sec. 20, T33N, R99W in the county of Fremont in the State of Wyoming. This permit shall be effective until 1 November 1996.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), upon the presentation of credentials and during working hours, to have access to inspect the waste source and application site location, for the purpose of compliance with the provisions of this permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


1. of 8 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: Water Quality Division, 250 Lincoln Street, Lander, WY 82520. (307)332-3144.

2. of 8 The permittee will provide immediate oral and/or written notice to Water Quality Division, 250 Lincoln, Lander, WY 82520, (307) 332-3144, in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
3. of 8 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the Water Quality Division, 250 Lincoln, Lander, WY 82520, on the attached Certification of Completion form.
 - a. Date that the road application was completed; and
 - b. Certification the road application was done in accordance with the terms and conditions of the permit; or
 - c. Certification the road application was completed with changes or modifications. Submit the information necessary to clearly indicate the road application as actually performed. This information shall include a contour map depicting only those sections of road that actually received eight cu yds of oil stained sandy soil.
4. of 8 The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
5. of 8 eight cu yds shall be applied uniformly and incorporated into the roadbed. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. Eight cu yds shall not be applied during the period from November 1 to April 10.
6. of 8 The application site slope shall not exceed eight percent (8%) for vehicular application.
7. of 8 eight cu yds of oil application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
8. of 8 Only the roads designated in this permit are authorized for application of the eight cu yds of oil stained sandy soil. Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Dept. of Environmental Quality

10-1-96
Date of Issuance

MDR
CC:

STATEMENT OF BASIS

- I. General information.
 - A. Permit Number: 96-413
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
 - A. Chapter XI. Yes
 - B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
 - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No
 - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

Yes
 - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

Yes
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
 - A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are no numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified or operated.
 - B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.
 - C. Permit based on general or statewide deviation contained in approved policy statement (indicate

the policy number and briefly summarize the nature of the deviation).

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the eight cu yds of oil stained sandy soil onto the roadbed. Repeated applications of eight cu yds of oil stained sandy soil on the same sections of road will be monitored by roadbed analyses.

- B. Quality of waste is such that it will not cause a violation of groundwater standards. Briefly describe:

Contaminant levels are far below the regulatory limits when applying the 20 fold dilution factor.

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

Material will be applied to an existing roadbed.

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

There are no areas within the application zone that exceed three percent slope; The application area is underlain by low permeability soil.

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

No exceedances allowed.

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

No exceedances allowed.

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

Periodic inspection of runoff and standing water for oil sheen.

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 26 September 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

x New
Renewal
Modified

PERMIT NO. 96-414
SPECIAL CONDITIONS

Capitol Hill and Maverick Trailer Park Sanitary Sewer Reconstruction

This permit hereby authorizes the applicant:

City of Lander
240 Lincoln Street
Lander, Wyoming 82520

to reconstruct outdated and damaged vitrified clay sewer lines with PVC 8" and 12" replacement lines according to the procedures and conditions of the application number 96-414. The facility is located in the NE/4 of Sec 19 and the SW/4 of Sec, 8, T33N, R99W in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10/10/96
Date of Issuance

MDR/bb/63802.ltr

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 96-414
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- Yes
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- Yes
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- Chapter XI, Part B, Section 9, (c), (I), page 12
- B. Briefly state the basis for the deviation.
- The proposed reconstruction requires a variance from the minimum slope regulations in order to tie into the existing Lander sewer network. Calculations of flow characteristics with the new PVC pipe indicate sufficient flow velocities to operate satisfactorily at the reduced line slope.
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- Not Applicable

V. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 3 October 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR/bb/63802.ltr

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 96-415
SPECIAL CONDITIONS
REF/PERMIT #

Town of Rolling Hills Waterline Loop - 1996

This permit hereby authorizes the applicant:

Town of Rolling Hills
38 South Badger
Rolling Hills, WY 82637

to install well pump in well permitted under Permit to Construct 95-123 (WWDC Statewide permit) and construct transmission piping to existing storage facilities according to the procedures and conditions of the application number 96-415. The facility is located in Sections 15, 22 & 27 of T34N, R75W in the county of Converse, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-16-96
Date of Issuance

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 96-415
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. No
- B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- N/A
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)
- N/A
- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)
- N/A

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on October 11, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

GLS/bb/63918.ltr

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 96-416
SPECIAL CONDITIONS
REF/PERMIT #

Janice Smith Septic System

This permit hereby authorizes the applicant:

Janice C. Smith
1417 Wolfensberger Rd.
Castle Rock, CO 80104

to construct, install or modify a septic system according to the procedures and conditions of the application number 96-416. The facility is located in NE/4 of the SE/4, Section 3, Township 54 North, Range 66 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-7-96

Date of Issuance

BDM/pr/ks
63776.ltr

cc: Crook County Small Wastewater File

STATEMENT OF BASIS

- I. General information.
 - A. Permit Number: 96-416
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
 - A. Chapter XI. Yes
 - B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
 - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
Yes
 - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
 - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
 - A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
Not applicable
 - B. Briefly state the basis for the deviation.
Not applicable
 - C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
Not applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on October 1, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 96-417
SPECIAL CONDITIONS
REF/PERMIT #

High Country Ranch Septic System

This permit hereby authorizes the applicant:

John Steinbrecher
P.O. Box 1287
Sundance, WY 82729

to construct, install or modify a septic system according to the procedures and conditions of the application number 96-417. The facility is located in SE/4 of the SE/4, Section 8, Township 53 North, Range 61 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-7-96

Date of Issuance

BDM/pr/ks 63777.ltr

cc: Crook County Small Wastewater File

STATEMENT OF BASIS

I. General information.

A. Permit Number: 96-417

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not applicable

B. Briefly state the basis for the deviation.

Not applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on October 2, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
- Renewal
- Modified

PERMIT NO. 96-418RR
SPECIAL CONDITIONS

Green River Water Treatment Plant

This permit hereby authorizes the applicant:

Green River-Rock Springs-Sweetwater County Joint Powers Water Board
165 Railroad Ave., Suite C
Green River, WY 82937

to construct a water treatment plant according to the procedures and conditions of the application number 96-418RR. The facility is located in S21 & 22 T18N R107W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective for a period of four years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any violation of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and per

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

12-12-96
Date of Issuance

RRT/bb/64606.ltr

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 96-418RR
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. No
- B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- No
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- Yes
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- Section 10(h) of Chapter XII limits the flow rate for steeply inclined tube clarifiers to no more than 2.0 gpm/sq ft. The clarifiers used are a variation of settling tube clarifiers, and are not specifically addressed by our regulations. The proposed clarifiers utilize pulsating flows and are called "superpulsator clarifiers"; they are a proprietary product manufactured by Infilco Degremont.
- B. Briefly state the basis for the deviation.
- Approval is granted based upon pilot studies with Green River water and upon successful operation of other plants at the design loading rate of 3.0 gpm/sq ft.

- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not Applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, S.W. District Engineering Supervisor, and completed on 09 December 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RRT/bb/64606.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 96-419
SPECIAL CONDITIONS
REF/PERMIT #

Central Wyoming Regional Water System Wellfield Bid Package No. 4

This permit hereby authorizes the applicant:

Central Wyoming Regional Water System
201 N. David Street, 5th Floor
Casper, Wyoming 82601
Attention: Dean Dickey

to construct, install or modify a wellfield according to the procedures and conditions of the application number 96-419. The facility is located in the SW/4 and NW/4 of Section 18, T 33 N, R 79 W, the SW/4 of Section 7, T 33 N, R 79 W, and the SE/4 of Section 12, T 33 N, R 80 W in the county of Natrona, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-9-96

Date of Issuance

BDM/pr/mad 63867.LTR

cc: Phil Tscheschke, P.E., CH2M HILL, 100 Inverness Terrace East, Englewood, CO 80112
Karen Speer, P.E., CH2M HILL, 100 Inverness Terrace East, Englewood, CO 80112

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 96-419
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. No
- B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- Not applicable
- B. Briefly state the basis for the deviation.
- Not applicable
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- Not applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on October 9, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 96-420
SPECIAL CONDITIONS

Afton Water Star Pipeline

This permit hereby authorizes the applicant:

Town of Afton
P.O. Box 310
Afton, WY 83110

to construct water distribution mainline according to the procedures and conditions of the application number 96-420. The facility is located in NW¼ S31 T32N R118W in the county of Lincoln, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-1-96
Date of Issuance

RRT:ks
63701.ltr

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 96-420
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. No
- B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- Not Applicable
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)
- Not Applicable
- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)
- Not Applicable

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, S.W. District Engineering Supervisor, and completed on 27 September 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

☐ New
☐ Renewal
☐ Modified

PERMIT NO. 96-421
SPECIAL CONDITIONS

Teton Village/Millward Trailer Park Sewer Line Extension

This permit hereby authorizes the applicant:

Art Shierry and Roger Millward
P.O. Box 38
Teton Village, Wyoming 83025

to construct approximately 1620 LF of 8" sewer line with manhole structures connected to the Aspens Water and Sewer District system according to the procedures and conditions of the application number 96-421. The facility is located in the NE/4 of Sec. 13, T41N, R117W in the county of Teton, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-28-96
Date of Issuance

MDR/bb/63966.ltr

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 96-421
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Documentation of Statement of Basis.
- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 18 October 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

X New
- Renewal
- Modified

PERMIT NO. 96-422
SPECIAL CONDITIONS

Hake Residence and Shop

This permit hereby authorizes the applicant:

Ken Hake
P.O. Box 987
Pinedale, WY 82941

to construct a residence wastewater system with pumping to Pinedale mainline according to the procedures and conditions of the application number 96-422. The facility is located in SE ¼ S32 T34N R109W in the county of Sublette, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 5 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
5. of 5 The validity of this permit is conditioned based upon acceptance of wastewater flows by the Town of Pinedale.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

11-18-96

Date of Issuance

RRT/bb/64258.ltr

cc: Sublette Planning & Zoning Office; P.O. Box 506; Pinedale, WY 82941

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 96-422
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- Not Applicable
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)
- Not Applicable

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not Applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, S.W. District Engineering Supervisor, and completed on 30 September 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RRT/bb/64258.ltr

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 96-423
SPECIAL CONDITIONS

Bob Stevens Septic Tank and Leach Field

This permit hereby authorizes the applicant:

Hal Price
1815 Hwy 310
Lovell, Wyoming 82431

to install a single family residential septic tank and leach field according to the procedures and conditions of the application number 96-423. The facility is located in the NW/4 of Sec 10, T56N, R96W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-10-96
Date of Issuance

MDR/mad 63869.LTR

STATEMENT OF BASIS

- I. General information.
 - A. Permit Number: 96-423
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
 - A. Chapter XI. Yes
 - B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
 - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
Yes
 - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
 - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Documentation of Statement of Basis.
 - A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 8 October 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building • 122 West 28th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7768 FAX 777-7682	ABANDONED MINES (307) 777-6148 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-6818	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7786 FAX 634-0789	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7751 FAX 777-5973
--	---	---	---	--	---	---

FAX TRANSMITTAL

DATE: 10-1-96
 TO: Brian Mark FAX# 307 674 6050
 & Pat & Don
 FROM: Barb DeQ/WQD # OF PAGES 6
 REMARKS: Here's your permit - original in
mail.

96-425

TRANSMISSION REPORT

USER NAME : WQD

**THIS DOCUMENT WAS CONFIRMED
(REDUCED SAMPLE ABOVE - SEE DETAILS BELOW)**

**** COUNT ****

TOTAL PAGES SCANNED : 6
 TOTAL PAGES CONFIRMED : 6

*** SEND ***

No.	REMOTE STATION	START TIME	DURATION	#PAGES	MODE	RESULTS
1	SHERIDAN AQ&WQ	10- 1-96 9:48	3' 15"	6/ 6	EC	COMPLETED 9600

TOTAL 0:03'15" 6

NOTE:

No. : OPERATION NUMBER 48 : 4800BPS SELECTED EC : ERROR CORRECT G2 : G2 COMMUNICATION
 PD : POLLED BY REMOTE SF : STORE & FORWARD RI : RELAY INITIATE RS : RELAY STATION
 MB : SEND TO MAILBOX PG : POLLING A REMOTE MP : MULTI-POLLING RM : RECEIVE TO MEMORY

PERMIT TO CONSTRUCT

X New
- Renewal
- Modified

PERMIT NO. 96-424
SPECIAL CONDITIONS

Hay Residence Septic System, Pinedale

This permit hereby authorizes the applicant:

Keith N. Hay
2108 Hillcrest Dr.
Rock Springs, WY 82901

to construct a residence wastewater system with pumping to Pinedale mainline according to the procedures and conditions of the application number 96-424. The facility is located in SW¼ S33 T34N R109W in the county of Sublette, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 5 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
5. of 5 The validity of this permit is conditioned based upon acceptance of wastewater flows by the Town of Pinedale.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

11-18-96

Date of Issuance

RRT/bb/64259.ltr

cc: Sublette Planning & Zoning Office; P.O. Box 506; Pinedale, WY 82941

STATEMENT OF BASIS

- I. General information.
 - A. Permit Number: 96-424
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
 - A. Chapter XI. Yes
 - B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
 - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
Yes
 - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
 - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
Not Applicable
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)
Not Applicable

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not Applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, S.W. District Engineering Supervisor, and completed on 30 September 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RRT/bb/64259.ltr

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 96-425
SPECIAL CONDITIONS

AXELS AVENUE & HIGHWAY 51 PIEZOMETER WELLS

This permit hereby authorizes the applicant:

Exxon Company USA
800 Bell
Houston, TX 77002
Attention: K.M. Civiello

to construct, install or modify piezometer wells according to the procedures and conditions of the application numbers 96-425. The facility is located in the NE/4 of Section 25 of T50N R72W in the county of Campbell, in the State of Wyoming. This permit shall be effective for a period of one (1) month from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (DEQ/WQD), upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ/WQD the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, DEQ/WQD, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-1-96

Date of Issuance

DRM/dm:09/30/96

b\63742.ltr

Enclosures: Notification Post Card
Certificate of Completion
Statement of Basis

cc: Jim Sullivan, SECOR, 2905 Montana Avenue, Billings, MT, 59101

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 96-425
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- Not Applicable (N/A)
- B. Briefly state the basis for the deviation.
- N/A
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of Section VI. from the Statement of Basis.)

Applicable

- VI. If Section 15 of Chapter III of the Wyoming Water Quality Rules and Regulations (WWQRR) is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

There will be no discharge to groundwater associated with the construction and operation of the project piezometer wells.

- B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

Not Applicable (N/A)

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

During this site investigation, the applicant shall conduct at least one sampling event of the soils and groundwater encountered by the piezometer wells for the constituents listed below and using the indicated test methods. The purpose of this project is to conduct a limited extent of petroleum hydrocarbon contamination, identify the type of petroleum hydrocarbon(s) present, and determine the local groundwater gradient and direction of flow.

CONSTITUENTS TO BE SAMPLED	EPA TEST METHODS
TPH (groundwater & soil)	8015 Modified for GRO & DRO
BTEX (groundwater)	524.4 or Equivalent
BTEX (soil)	8020
MTBE (groundwater & soil)	No DEQ/WQD Reference

The applicant has agreed to provide the DEQ/WQD with a follow-up report on the work conducted and the test results. Appendix A of Chapter XVII of the Wyoming Water Quality Rules and Regulations shall be used to determine compliance with the LUST Program cleanup levels for soils and groundwater. In the event further site assessment and/or remediation is necessary, additional enforcement action by the DEQ/WQD may be appropriate. To date, Exxon is the only party willing to proceed as requested in the Letter Of Violation dated April 6, 1995.

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Donald R. McKenzie, DEQ/WQD-SPO NE District Program Principal, and completed on September 30, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

x New
Renewal
Modified

PERMIT NO. 96-426
SPECIAL CONDITIONS

American Colloid Reverse Osmosis Leach Field

This permit hereby authorizes the applicant:

American Colloid Company
HCR 69, Box 135
Belle Fourche, South Dakota 57717

to construct a leach field to accept the discharge from a potable water treatment facility according to the procedures and conditions of the application number 96-426. The facility is located in Lots 85 and 86, T56N, R95W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-14-96

Date of Issuance

MDR:ks 63893.ltr

STATEMENT OF BASIS

General information.

A. Permit Number: 96-426

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 10 October 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 96-427
SPECIAL CONDITIONS

Terry Wood Residential Septic Tank and Leach Field

This permit hereby authorizes the applicant:

Terry K. Wood
P.O. Box 627
Greybull, Wyoming 82426

to construct a single family residential septic tank and leach field according to the procedures and conditions of the application number 96-427. The facility is located in the SE/4 Of Sec. 35, T53N, R92W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-10-96
Date of Issuance

MDR/mad 63870.LTR

STATEMENT OF BASIS

- I. General information.
 - A. Permit Number: 96-427
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
 - A. Chapter XI. Yes
 - B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
 - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
Yes
 - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
 - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Documentation of Statement of Basis.
 - A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 8 October 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 96-428
SPECIAL CONDITIONS
REF/PERMIT #

Douglas Gas Plant

This permit hereby authorizes the applicant:

KN Gas Gathering, Inc.
252 Highway 59
Douglas, WY 82633-0069

to construct, install or modify monitor wells according to the procedures and conditions of the application number 96-428. The facility is located in NE ¼ Sec 34, Township 33N, Range 71W in the county of Converse, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the permittee, owner, and/or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: State of Wyoming, Department of Environmental Quality, Water Quality Division, Groundwater Program, 1043 Coffeen Avenue, Sheridan, Wyoming 82801, telephone (307) 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- I. After the monitoring wells have fulfilled their useful purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. No monitoring well shall be abandoned without prior approval from the Water Quality Division.
- II. WDEQ/WQD personnel shall be given at least two (2) weeks notice prior to the installation of monitor wells and sample collection so that they may be on site if deemed necessary.
- III. Monitor wells shall be sampled and the groundwater analyzed as indicated on the following table:


WELL NAME OR NUMBER	SAMPLING FREQUENCY	ANALYTICAL METHOD	PARAMETER(S) ANALYZED
ALL	QUARTERLY	EPA METHOD 8020	Benzene, Ethylbenzene, Toluene, Xylenes

- IV. After review of future analytical results, the WQD may change the sampling frequency or the parameters to be analyzed, depending on the analytical results of the sampling.
- V. The results of these analyses shall be submitted to the Sheridan office at the following address, 1043 Coffeen Avenue, Sheridan, WY 82801 by the last day of the month following the end of each quarter. The first set of results are due upon receipt.
- VI. Pursuant to Wyoming Water Quality Rules and Regulations, Chapter XI, Section 63(A), a deviation is hereby granted for those wells prevented by physical limitations to adherence to the requirements on minimum depths of seal below the ground surface as detailed in Chapter XI, Part G. However, a sufficient seal shall be installed according to standard engineering practice.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-23-96

Date of Issuance

DF/bb/63946.ltr
cc: IPS

GROUNDWATER POLLUTION CONTROL PROGRAM
REVIEW COMMENTS:
PLANS/SPECIFICATIONS/PROPOSALS/REPORTS

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
1043 COFFEEN AVENUE, SUITE D
SHERIDAN, WYOMING 82801

PROJECT: SITE CHARACTERIZATION

FACILITY: KN Douglas Gas Plant

APPLICANT: KN Gas Gathering, Inc.
252 Highway 59
Douglas, WY 82633-0069

CONSULTANT: Maxxim Environmental, Inc
780 Simms Street, Suite 103
Golden, CO 80401
Attn: Mr. Timothy J. Kelly, CPG

WATER QUALITY DIVISION REFERENCE (PERMIT) NUMBER: 96-428

EXISTING NEW AS BUILT

TITLE: Site Investigation, KN Gas Gathering Plant, Douglas, WY

PLANS SPECS PROPOSAL REPORT

DATE ON PROPOSAL/PLANS/REPORT: October 10, 1996

IS THIS PROPOSAL SUBMITTED PURSUANT TO:

'CONDITIONS' TO ANY WQD PERMIT? NO YES

AN LOV, NOV OR OTHER ENFORCEMENT? NO YES

REVIEWING GEOLOGIST: _____

DATE OF THIS REVIEW: October 14, 1996

ACTION: Permit to Construct #96-428 authorized for installation of monitor wells

COMMENTS: GROUNDWATER SECTION

The KN Gas Gathering Plant is located in the NE quarter of Section 34 and the NW quarter of Section 35, Township 33 North, Range 71 West, in Converse County, Wyoming.

I. SUMMARY OF EXISTING CONTAMINATION:

The soil and groundwater contamination associated with this facility is a result of a sump that had overflowed on several occasions. The sump had been a "pass through" sump that was used since the early 1970's to collect

hydrocarbon based liquids associated with the processing of natural gas. KN removed the sump in the fall of 1995 and replaced it with a new steel sump located in a concrete vault.

Three boreholes were completed to initially investigate the soil contamination. Three temporary monitor wells were installed in the boreholes to sample the groundwater. The analytical results of the groundwater testing are displayed in the following table:

ANALYTICAL RESULTS OF GROUNDWATER SAMPLING						
DATE	WELL	BENZENE	TOLUENE	ETHYL-BENZENE	XYLENES	TVH-GASOLINE
5/96	TMW-1	0.250	0.045	0.006	0.068	1.2
5/96	TMW-2	0.19	ND	ND	0.003	0.2
5/96	TMW-3	3.60	4.00	0.290	2.40	9.1
MCL	-	0.005	1.0	0.700	10.0	-

NOTE: all results in milligrams/liter
MCL = maximum contaminant level
Shaded areas denote exceedances of MCLs.
BETX analysis by EPA method 8260
Total Volatile Hydrocarbon (TVH) by Method 8015 Modified

II. CONCLUSION OF ADEQUACY OF WORK COMPLETED TO DATE:

The excavation of the sump and the associated impacted soils appear to have removed the source of the hydrocarbons. The location and results of the downgradient soil samples indicate that the horizontal extent of the impacted soils was probably confined to the immediate area adjacent to the sump. The soil samples from the 20-22 and 30-32 foot intervals submitted for analysis from BH-3 (downgradient borehole) did not detect BTEX or TVH compounds above the laboratory detection limit.

Depth to groundwater was determined to be 33 feet below ground surface in all three boreholes based on drillers observations. Static fluid levels in the converted temporary monitor wells of May 31, 1996 ranged from 30.45 to 30.81 feet below ground surface.

The extent of groundwater contamination has not been determined at this site. Benzene levels of 3.6 milligrams/liter were identified in monitor well MW#3. Free-phase hydrocarbons were not identified during the initial groundwater investigation.

Based upon static water levels measured in the "temporary" monitor wells, the groundwater gradient is towards the southeast. One residence exists in this direction, at distance of approximately 3/4 mile. The domestic use well at this property is completed at a depth of approximately 400 feet.

III. REQUESTS/REQUIREMENTS/RECOMMENDATIONS:

1. The monitor wells shall be installed in accordance with the statements, terms, and conditions included in the permit application and Wyoming Water Quality Rules and Regulations Chapter III Permit to Construct number 96-428.
2. The conditions listed in Permit number 96-428 have been reviewed and accepted by Mr. Timothy Kelly, CPG, of Maxxim Environmental, Inc., the consultant for KN Gas Gathering, Inc. on October 15, 1996.

END OF REVIEW

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 96-428
SPECIAL CONDITIONS
REF/PERMIT #

Douglas Gas Plant

This permit hereby authorizes the applicant:

KN Gas Gathering, Inc.
252 Highway 59
Douglas, WY 82633-0069

to construct, install or modify monitor wells according to the procedures and conditions of the application number 96-428. The facility is located in NE ¼ Sec 34, Township 33N, Range 71W in the county of Converse, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the applicant's engineer's design are the responsibility of the permittee, owner, and/or operator.

The authority to construct granted by this permit does not mean or imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: State of Wyoming, Department of Environmental Quality, Water Quality Division, Groundwater Program, 1043 Coffeen Avenue, Sheridan, Wyoming 82801, telephone (307) 672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- I. After the monitoring wells have fulfilled their useful purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. No monitoring well shall be abandoned without prior approval from the Water Quality Division.
- II. WDEQ/WQD personnel shall be given at least two (2) weeks notice prior to the installation of monitor wells and sample collection so that they may be on site if deemed necessary.
- III. Monitor wells shall be sampled and the groundwater analyzed as indicated on the following table:


WELL NAME OR NUMBER	SAMPLING FREQUENCY	ANALYTICAL METHOD	PARAMETER(S) ANALYZED
ALL	QUARTERLY	EPA METHOD 8020	Benzene, Ethylbenzene, Toluene, Xylenes

- IV. After review of future analytical results, the WQD may change the sampling frequency or the parameters to be analyzed, depending on the analytical results of the sampling.
- V. The results of these analyses shall be submitted to the Sheridan office at the following address, 1043 Coffeen Avenue, Sheridan, WY 82801 by the last day of the month following the end of each quarter. The first set of results are due upon receipt.
- VI. Pursuant to Wyoming Water Quality Rules and Regulations, Chapter XI, Section 63(A), a deviation is hereby granted for those wells prevented by physical limitations to adherence to the requirements on minimum depths of seal below the ground surface as detailed in Chapter XI, Part G. However, a sufficient seal shall be installed according to standard engineering practice.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-23-96
Date of Issuance

DF/bb/63946.ltr
cc: IPS

GROUNDWATER POLLUTION CONTROL PROGRAM
REVIEW COMMENTS:
PLANS/SPECIFICATIONS/PROPOSALS/REPORTS

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
1043 COFFEEN AVENUE, SUITE D
SHERIDAN, WYOMING 82801

PROJECT: SITE CHARACTERIZATION

FACILITY: KN Douglas Gas Plant

APPLICANT: KN Gas Gathering, Inc.
252 Highway 59
Douglas, WY 82633-0069

CONSULTANT: Maxxim Environmental, Inc
780 Simms Street, Suite 103
Golden, CO 80401
Attn: Mr. Timothy J. Kelly, CPG

WATER QUALITY DIVISION REFERENCE (PERMIT) NUMBER: 96-428

EXISTING NEW AS BUILT

TITLE: Site Investigation, KN Gas Gathering Plant, Douglas, WY

PLANS SPECS PROPOSAL REPORT

DATE ON PROPOSAL/PLANS/REPORT: October 10, 1996

IS THIS PROPOSAL SUBMITTED PURSUANT TO:

'CONDITIONS' TO ANY WQD PERMIT? NO YES

AN LOV, NOV OR OTHER ENFORCEMENT? NO YES

REVIEWING GEOLOGIST: *Wm Donald Fischer*

DATE OF THIS REVIEW: October 14, 1996

ACTION: Permit to Construct #96-428 authorized for installation of monitor wells

COMMENTS: GROUNDWATER SECTION

The KN Gas Gathering Plant is located in the NE quarter of Section 34 and the NW quarter of Section 35, Township 33 North, Range 71 West, in Converse County, Wyoming.

I. SUMMARY OF EXISTING CONTAMINATION:

The soil and groundwater contamination associated with this facility is a result of a sump that had overflowed on several occasions. The sump had been a "pass through" sump that was used since the early 1970's to collect

hydrocarbon based liquids associated with the processing of natural gas. KN removed the sump in the fall of 1995 and replaced it with a new steel sump located in a concrete vault.

Three boreholes were completed to initially investigate the soil contamination. Three temporary monitor wells were installed in the boreholes to sample the groundwater. The analytical results of the groundwater testing are displayed in the following table:

ANALYTICAL RESULTS OF GROUNDWATER SAMPLING						
DATE	WELL	BENZENE	TOLUENE	ETHYL-BENZENE	XYLENES	TVH-GASOLINE
5/96	TMW-1	0.250	0.045	0.006	0.068	1.2
5/96	TMW-2	0.19	ND	ND	0.003	0.2
5/96	TMW-3	3.60	4.00	0.290	2.40	9.1
MCL	-	0.005	1.0	0.700	10.0	-

NOTE: all results in milligrams/liter
MCL = maximum contaminant level
Shaded areas denote exceedances of MCLs.
BETX analysis by EPA method 8260
Total Volatile Hydrocarbon (TVH) by Method 8015 Modified

II. CONCLUSION OF ADEQUACY OF WORK COMPLETED TO DATE:

The excavation of the sump and the associated impacted soils appear to have removed the source of the hydrocarbons. The location and results of the downgradient soil samples indicate that the horizontal extent of the impacted soils was probably confined to the immediate area adjacent to the sump. The soil samples from the 20-22 and 30-32 foot intervals submitted for analysis from BH-3 (downgradient borehole) did not detect BTEX or TVH compounds above the laboratory detection limit.

Depth to groundwater was determined to be 33 feet below ground surface in all three boreholes based on drillers observations. Static fluid levels in the converted temporary monitor wells of May 31, 1996 ranged from 30.45 to 30.81 feet below ground surface.

The extent of groundwater contamination has not been determined at this site. Benzene levels of 3.6 milligrams/liter were identified in monitor well MW#3. Free-phase hydrocarbons were not identified during the initial groundwater investigation.

Based upon static water levels measured in the "temporary" monitor wells, the groundwater gradient is towards the southeast. One residence exists in this direction, at distance of approximately 3/4 mile. The domestic use well at this property is completed at a depth of approximately 400 feet.

III. REQUESTS/REQUIREMENTS/RECOMMENDATIONS:

1. The monitor wells shall be installed in accordance with the statements, terms, and conditions included in the permit application and Wyoming Water Quality Rules and Regulations Chapter III Permit to Construct number 96-428.
2. The conditions listed in Permit number 96-428 have been reviewed and accepted by Mr. Timothy Kelly, CPG, of Maxxim Environmental, Inc., the consultant for KN Gas Gathering, Inc. on October 15, 1996.

END OF REVIEW

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 96-429
SPECIAL CONDITIONS
REF/PERMIT #

Samedan Oil Company Statewide Anode

This permit hereby authorizes the applicant:

Samedan Oil Company
1050 17th Street, Suite 1100
Denver, Colorado 80265

to construct, install or modify deep bed anode system according to the procedures and conditions of the application number 96-429. The facility is located in statewide, in the State of Wyoming. This permit shall be effective for a period of five years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: UIC Program Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5. After the deep anode beds have fulfilled their useful purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. Within 45 days after a well has been plugged and abandoned, the owner shall file a plugging record with WQD.
- 2 of 5. In addition to the anode bed construction information submitted with the permit application, the following items relating to construction shall be implemented when the anode beds are installed: Each separate aquifer penetrated shall require a separate breather pipe. Each aquifer shall remain in hydrologic isolation from each other if they were isolated prior to installation.
- 3 of 5. Within 45 days after the anodes are installed, as-built construction plans shall be submitted to the DEQ/WQD, detailing how groundwater was protected during installation.
- 4 of 5. If it becomes necessary to wet any anode installed under this permit, only water from an approved public water supply shall be used unless DEQ/WQD is first supplied with an analyses of the water for approval. Waters that originate in sources other than an approved public water supply shall not be used unless first approved.
- 5 of 5. An unlimited number of similar anodes may be installed under this permit. This authorization applies to Samedan Oil Company and all subsidiary companies operating in Wyoming.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-14-96

Date of Issuance

RFL:ks 63901.ltr

cc: Northland Corrosion Services, 1033 7th Avenue, Laurel, Montana

STATEMENT OF BASIS

- I. Permit Number: 96-429
- ii. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. This permit covers deep groundbed anodes statewide. It has been reviewed for general conformance with regulations found in Chapter XI, Part G covering construction of wells. There are no specific regulations covering deep groundbed anodes.
- V. Applicant Participation. The applicant has been provided with a draft permit for review prior to this permit being issued.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Robert F. Lucht, P.E. and P.G., UIC Program Supervisor and completed on October 10, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 96-430R
SPECIAL CONDITIONS

Bay Multi Family Complex 1996 Water and Sewer Improvements

This permit hereby authorizes the applicant:

Bryce Bay
2917 Colima Drive
Rock Springs, Wyoming 82901

to construct water and sewer extensions tying into the utility systems of the city of Riverton according to the procedures and conditions of the application number 96-430R. The facility is located in the SW/4 of Sec. 27, T1N, R4E in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-28-96

Date of Issuance

MDR/bb/63963.ltr

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 96-430R
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Documentation of Statement of Basis.
- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 17 October 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

4 New
Renewal
Modified

PERMIT NO. 96-431
SPECIAL CONDITIONS

Serjit Singh Cox Residential Septic Tank and Leach Field

This permit hereby authorizes the applicant:

Serjit Singh Cox
655 West Sunnyside
Thermopolis, Wyoming 82443

to construct a single family residential septic tank and leach field according to the procedures and conditions of the application number 96-431. The facility is located in the NE/4 of Sec. 12, T43N, R95W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-10-96
Date of Issuance

MDR/mad 63871.LTR

cc:

STATEMENT OF BASIS

I. General information.

A. Permit Number: 96-431

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 8 October 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



STATE OF WYOMING

JIM GERINGER
GOVERNOR



Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

February 9, 1998

Mr. Mark C. Eatinger
Rio Verde Engineering
P.O. Box 642
Pinedale, WY 82941

Dear Mark:

Permit application #96-432, McAmis Septic System is being returned to you because this project has been resubmitted with a new design and is currently in the application process as application #98-023.

Randall Taylor
Water Quality Division
SW Dist. Supervisor

Enclosure

xc: John McAmis
3125 South Cave Lane
Chico, CA 95928

DEQ, IPS Section
Cheyenne, WY

file: Chrono

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 96-433R
SPECIAL CONDITIONS

Water Subdivision Waterline

This permit hereby authorizes the applicant:

Jim Cross
P.O. Box 391
Powell, WY 82435

to construct a 3 inch water line connected to the O'Donnell Service Area water system according to the procedures and conditions of the application number 96-433R. The facility is located in Lot 49 Farm Unit E, T55N, R99W, resurvey in the county of Park, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

11-8-96

Date of Issuance

JH/jyi
b/64114.ltr

STATEMENT OF BASIS

.. General information.

A. Permit Number: 96-433R

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, P.E., Northwest District Supervisor, and completed on October 29, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JH/bb/64114.ltr

PERMIT TO CONSTRUCT

x New
Renewal
Modified

PERMIT NO. 96-434
SPECIAL CONDITIONS

Higbie Building Water Main Extension

This permit hereby authorizes the applicant:

Edwin Higbie
213 North 44th Street
Cody, Wyoming 82414

to construct a 4" DIP water line extension from the City of Cody water system for a fire suppression system within the Higbie commercial building according to the procedures and conditions of the application number 96-434. The facility is located in the SE/4 of the SW/4 of Sec. 28 (old survey), T53N, R101W in the county of Park, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-28-96

Date of Issuance

MDR/bb/63964.ltr

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 96-434
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. No
- B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Documentation of Statement of Basis.
- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 18 October 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR/bb/63964.ltr

PERMIT TO CONSTRUCT

New
Renewal
 Modified CHANGE OF OWNERSHIP

PERMIT NO. 96-435
SPECIAL CONDITIONS
REF/PERMIT # 93-132

Antelope Run Campground

This permit hereby authorizes the applicant:

Walter Cundy
1101 Prairie Lane
Bar Nunn, Wyoming 82602

to construct, install or modify a sewer according to the procedures and conditions of the application number 93-132. The facility is located in NE/4 of the SE/4, Section 17, Township 34 North, Range 79 West in the county of Natrona, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-10-96

Date of Issuance

BDM/pr/mad 63849.LTR

cc: C. Dean Frederick, 1101 Prairie Lane, Bar Nunn, WY 82601

STATEMENT OF BASIS

f. General information.

A. Permit Number: 96-367

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter XII Section 58.(a)(ii) requires a minimum six (6) inch sanitary sewer.

B. Briefly state the basis for the deviation.

The permit is for a campground with flows that can be handled by a four (4) inch sanitary sewer.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on October 8, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.



THE STATE OF WYOMING



JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

October 21, 1996

United States Postal Service
Shari Farrar, Postmaster
Third Street and Coates Avenue
Hillsdale, Wyoming 82060

RE: Permit Reporting Requirements for Permit Number - 96-436

Dear Ms. Farrar:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Estimated Construction Schedule Post Card (Condition 1)
2. Notify the WQD of any changes (Condition 2)
3. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 3)

Please read the permit conditions carefully and follow through as required. Finally, bear in mind that the submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit.

If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Senior Analyst
SE District, Water Quality Division

RLE/bb/63957.ltr

Enclosure: Permit Referenced Above

cc: James K. Murphy, AVI p.c., 2035 Westland Road, Cheyenne, Wyoming 82001

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 96-436
SPECIAL CONDITIONS
REF/PERMIT #

Hillsdale Main Post Office - Commercial Septic System

This permit hereby authorizes the applicant:

United States Postal Service
Shari Farrar, Postmaster
Third Street and Coates Avenue
Hillsdale, Wyoming 82060

to construct, install or modify a commercial/domestic septic system according to the procedures and conditions of the application number 96-436. The facility is located in the NW 1/4 of Section 6, T14N, R64W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 6. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 6. The applicant will provide immediate oral and/or written notice to the SE District office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 6. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SE District office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 6. Vaughn Septic Tanks - when Vaughn Concrete Products septic tanks are installed, the manways on **each compartment** must extend to the ground surface when clean-out risers are not provided.
- 5 of 6. The permittee shall notify the Laramie County Environmental Health Division at least two (2) days prior to installation of this system to arrange for required inspections. Inspection of the installed system is required prior to backfilling. Laramie County Environmental Health charges a fee for these inspection services. Their offices are located at 100 Central Avenue, Cheyenne, Wyoming 82007; or they can be reached by phone at (307) 633-4090.

6 of 6. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-28-96
Date of Issuance

RLE/bb/63962.ltr

cc: Laramie County Environmental Health Division

STATEMENT OF BASIS

- I. General information.
 - A. Permit Number: 96-436
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
 - A. Chapter XI. Yes
 - B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
 - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
Yes
 - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
 - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
 - A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
NOT Applicable
 - B. Briefly state the basis for the deviation.
NOT Applicable
 - C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 18, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/bb/63962.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 96-437
SPECIAL CONDITIONS
REF/PERMIT #

Wyoming Premium Farms, LLC - Swine Confinement Facility/ Finisher Unit #2

This permit hereby authorizes the applicant:

Wyoming Premium Farms, LLC - Doug DeRouchey (Manager)
P.O. Box 457
Wheatland, WY 82201-0457

to construct, install or modify the wastewater facilities for a confined hog feeding operation which include the collection system, 2 cell anaerobic ponds, and the land application of waste for disposal according to the procedures and conditions of the application number 96-437. The facility is located in SE 1/4 Section 35, T25N, R67W in the county of Platte, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable permit conditions or other operational requirements. Compliance with standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 20 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 20 The applicant will provide immediate oral and/or written notice to Southeast District Engineer in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 20 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Engineer on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 20 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 20 A liner report shall be prepared documenting the construction of the soil bentonite layer below the leak detection system. The report will include density testing results and information showing that the permeability of the liner is in conformance with the design information such as in place permeability tests etc. This report shall be submitted and approved prior to placing the facility in operation. The report shall also be prepared and stamped by a registered professional engineer.
- 6 of 20 The synthetic liner and geotextile material shall be installed by a certified installer for this type of installation. All seams shall be inspected and tested in an approved manner to ensure proper construction. The log for these test results shall be included in the liner report for the soil bentonite liner.
- 7 of 20 If the hog feeding operation shuts down for 30 days or more the wastewater lagoon or lagoons shall either be emptied and all sludges removed and properly disposed of, or a minimum of 2 feet of water shall be maintained over the permanent pool and the leak detection system shall be monitored until the lagoons are emptied.

- 3 of 20 The wastewater lagoons have been sized for waste from a maximum of 2,800,000 pounds of animals. Logs of the total animal weight on site at any given time throughout the year shall be submitted with the annual report required by this permit. If it is anticipated that the total weight of animals on site is to be increased then a modification to this permit must be obtained prior to the anticipated change.
- 9 of 20 The wastewater lagoons are for the storage and digestion of animal waste only. All domestic waste from human activities must be disposed of by a separate system. All dead animals, animal parts, afterbirth, syringes and any other debris are to be separated from the animal waste stream and not to be placed in the lagoons.
- 10 of 20 All animal parts, afterbirth, and any other debris is to be disposed of in an approved manner separate from the animal waste. A report shall be submitted and approved identifying how the solid waste material will be disposed of including dead animals and animal parts prior to placing the facility in operation. All permits required for the proposed disposal activity will be included in the report. The report when approved will be incorporated into the O&M Manual. If it is anticipated that such material is to be stored or disposed of on site then the solid waste division is to be notified and permits obtained if they are required. If the material is to be disposed of off site it shall be at a facility licensed to handle such waste. All appropriate permits shall be obtained before pigs are delivered to the facility.
- 11 of 20 A Reduced Pressure Backflow Preventor (RPBP) shall be installed between any irrigation well and the connection for wastewater line for land application as represented in the application package. The applicant shall submit the certification information showing the RPBP has been approved by the University of Southern California Cross Connection Control Foundation with the Operation and Maintenance Manual for approval.
- 12 of 20 The lagoon leak detection system shall be monitored weekly to verify the lagoons are not leaking. If wastewater is found in the gravel layer between the synthetic liner and the clay liner then the Southeast District Engineer for the Water Quality Division shall be notified verbally as soon as possible and no later than the next business day. The phone notification is to be followed up with a written report. The operator shall take immediate steps as outlined in the O&M Manual to identify where the leak is and fix the leak. The operator shall also start pumping the water from the leak detection system back into the lagoons immediately. The report to be completed as soon as possible shall outline the measures to be taken to fix the leak. The report shall include lagoon levels, amount of wastewater to be transferred to the non leaking lagoon, the amount of wastewater to be land applied or hauled off site, the amount and rate the water is returned from the leak detection system to the lagoons, and the time in which it will take to fix the leak. The report will also include any testing results from the wastewater as soon as they are available.
- 13 of 20 Cell II of the lagoons shall be monitored on a quarterly basis to determine nutrient and salt loading within the lagoon cell. The nutrient and salt levels within Cell II shall be kept below the levels required to meet agronomic application of the wastewater in Cell II. The nutrient and salt levels within the lagoon shall not exceed the following limits, total N - 134,400 lbs, NH₄-N 63,200lbs, P - 69,000 lbs, K- 225,000 lbs, and total salt which includes Na, Ca, N, K, & Mg shall not exceed the recommended levels for the soils it will be applied to. The samples to determine these levels shall include 2 samples from the working pool and 2 samples from the permanent pool. Each sample shall be from different depths within the lagoon. The levels identified above shall be maintained unless the applicant can identify an effective and efficient means to transport the effluent to the other application sites or additional land is identified for use. All test required by this permit shall be conducted by an independent laboratory licensed to perform such tests and the results submitted to DEQ.

- 14 of 20 The Operation and Maintenance manual shall be submitted and approved prior to placing the facility in operation. The manual needs to be approved prior to receiving any pigs at the facility.
- 15 of 20 Land application shall be restricted to maintaining a 100 foot buffer around the 100 year flood plains of the Laramie River, Chugwater Creek, and Eagles Nest Draw.
- 16 of 20 Land application of any waste from the lagoons of this facility shall be in accordance with this permit. The wastewater to be land applied shall be tested for total nitrogen, total ammonia, total phosphorous, total potassium, sodium, calcium, magnesium, zinc, copper and fecal coliform. The land application area shall also be sampled and analyzed for these nutrients in accordance with the sampling grid described below. Utilizing the test results of the waste material and the application site, the operator will determine the amount of waste material that can be applied to satisfy the nutrient deficit. Under no circumstances or situation can application of the animal waste exceed best agronomic rates. Total fecal coliform shall not exceed 1000 col/100ml or the wastewater shall be disinfected prior to application. If disinfection is required the wastewater will be sampled on a monthly basis at the application point to verify that the fecal coliform levels are being met. Chlorine residual shall be checked on a weekly basis if disinfection is required. If the total fecal coliform level is less than 1000 col/100ml then the wastewater shall be monitored on a monthly basis for verification that the 1000 col limit is being maintained. The applicant shall submit a report each year which includes the test results for the waste material, amount of waste material applied, soil test results, crop or plants grown, and a map depicting the location where waste material was applied. The map showing the location of the land application shall be divided up into a 10 acre grid and a soil sample shall be taken from each 10 acre parcel. At least 50% of the soil samples taken shall be extended and samples taken at a 5 foot depth and the results submitted. The map shall identify the location and description of each sample. After several sampling events the number of tests taken for each event may be adjusted after approval by the DEQ. Application at any location other than those areas approved by this permit will require a modification of this permit. All wastewater and soil testing shall be conducted by an independent laboratory licensed to perform such testing.
- 17 of 20 Any waste material shall be applied in such a manner which will not hydraulically overload the soil. The waste material shall not be applied in such a manner that ponding or puddling occur. The application of the wastewater shall not exceed the total hydraulic capacity of the soil for the season. Water and wastewater or the combination shall be applied at such a rate that the plant roots have an opportunity to utilize the nutrients applied. Waste material shall not be applied to saturated, frozen, or snow covered areas. Waste material shall not be applied just before, during or directly after a storm event. The waste material shall be applied in such a manner that all waste remains on the property identified in this permit and does not run off or is not carried off the property by the wind.
- 18 of 20 The applicant shall include in the report required by 16 above sodium information for the soils of the land application area. The sodium information shall include the sodium absorption ration and information showing that the salt loading to the land application area is not detrimental to the soils of the application area.
- 19 of 20 The pits of the building shall be inspected in detail for cracks at least once a quarter. The inspection shall be done when the pit is empty and clean. Documentation of this inspection is to be included in annual report. Any cracks or defects that are found will be sealed to prevent leakage from the pits.

PERMIT NO. 96-437

20 of 20 Upon completion of the project a set of as-constructed drawings shall be submitted to the Southeast District Engineer. The as-constructed drawings shall be prepared and stamped by a Wyoming Registered Professional Engineer and submitted within 60 days after completion of the project. These drawing shall be submitted along with the certificate of completion required in condition No. 2.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

4-22-97

Date of Issuance

LRR:ks
71332.ltr

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 96-270
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- N/A
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)
- Applicable

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

The two cell anaerobic lagoon is to be constructed with a 30 mil synthetic liner with a leak detection system. This system meets the requirements of Chapter III Section 15(a) for groundwater protection.

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

The land application area will have effluent applied to it at agronomic rates. The effluent is to be applied such that the soils will not be hydraulically overloaded and the plants or crops grown will utilize all of the nutrients applied.

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

The leak detection system will be monitored on a weekly basis. Soil samples will be taken annually to verify that the nutrients are applied at agronomic rates. Wastewater sample results, information on the amount of wastewater applied and maps showing the application areas are also to be submitted on a yearly basis.

PERMIT NO. 96-437

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Lawrence R. Robinson, Engineering Supervisor, and completed on April 17, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC



The State
of Wyoming

Permit No.
96-437



Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
---	--	--	--	---	---	--

September 9, 2002

Mr. Doug DeRouchey, General Manager
Wyoming Premium Farms
P.O. Box 457
Wheatland, WY 82201

Subject: Trip Reports for Site Visits August 22, 2002, and September 5, 2002.

Dear Mr. DeRouchey:

Thank you for accompanying me to each of the sites. The trip reports from the August 22 and September 5 site reports are attached.

The Finisher No. 2, Site 60 swine population of less than 15,330 satisfies the Notice of Violation and Order 3376-02. The necessary paper work to close the docket will be completed immediately.

Sincerely,

Louis B. Harmon PE
SE District Engineering Supervisor
Water Quality Division

LBH/bv/2-2869.ltr

enclosures: Site Visit Reports for August 22, 2002 and September 5, 2002

Memorandum from Lou Harmon

Southeast District Engineer, Wyoming Department of Environmental Quality/Water Quality Division
Phone (307) 777-7088, Fax (307) 777-5973, email: lharmon@state.wy.us

TO: WPF Site 60, Finisher No. 2, Permit 96-437

SUBJECT: Inspection Report

1. On August 22, 2002 I conducted an external site inspection. I was accompanied by Doug DeRouchey, general manager of Wyoming Premium Farms.
2. The lagoon levels are low enough to allow normal winter operations without any discharge. A copy of the WPF lagoon level report is attached.
3. The ammonia levels exceed the permit requirements.
4. The pilot plant to strip ammonia was not operating. A commercial stripping tower had been delivered to the site, but was not fully operational.
5. Population reduction was underway to meet the requirements of the NOV.
6. A biological additive called Agri-safe is being tested. Attached are scentometer results that indicates the product may be effective in reducing the odors leaving the site.

Memorandum from Lou Harmon

Southeast District Engineer, Wyoming Department of Environmental Quality/Water Quality Division
Phone (307) 777-7088, Fax (307) 777-5973, email: lharmo@state.wy.us

TO: WPF Site 60, Finisher No. 2, Permit 96-437

SUBJECT: Population Count Verification

1. On September 5, 2000 I conducted an unannounced count of the swine population at the Finisher No. 2 site of Wyoming Premium Farms. I was accompanied by Doug DeRouchey, general manager of Wyoming Premium Farms. The purpose of the population count was to verify compliance with the Notice of Violation, Docket No. 3376-02. NOV 3376-02 required that the swine population be reduced to a maximum of 15,330 before September 1.
2. On September 4, 2002, Wyoming Premium Farms submitted written verification that as of September 1, 2002 the Finisher No. 2, Site 60 swine population was 14,479.
3. The swine count as of 14:00 hours, September 5, 2002 was 13,572.
4. Market hogs and breeding stock is actively being shipped from the site. Feeder pigs from the nursery site are being introduced to the site to replace the hogs being shipped. Consequently, as can be seen from the attached tally sheets, the September 5 count was consistent with the September 1 count.

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

Herschler Bldg., 4 West
Cheyenne, Wyoming 82002

PROJECT: Wyoming Premium Farms, LLC - Swine Confinement Facility/Finisher Unit No. 2

ENGINEER: Larry D. McCaslin
M.C. Schaff & Associates, Inc.
Route 2, Box 118, S. Beltline Hwy. E
Scottsbluff, NE 69361

APPLICANT: Wyoming Premium Farms, LLC
Doug DeRouchey (Manager)
P.O. Box 457
Wheatland, WY 82201-0457

WATER QUALITY DIVISION REFERENCE NUMBER: 96-437

REVIEWING ENGINEER: Gary Steele 

DATE OF REVIEW: February 5, 1997

ACTION: NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 12 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS:

- 1 of 1 The proposed uptake rates identified for the pasture area is considerably higher than the anticipated removal rate. Recent research shows that the production rate from pasture areas is about 1/2 to 1 ton per acre. Based on these removal rates the land identified is not sufficient at the elevated rates for the agitated lagoons. It is recognized that application under condition number 3 may be done without agitation but verification should be done at the uptake rates identified. If recent local information is available, that information should be utilized for the calculations.

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

Herschler Bldg., 4 West
Cheyenne, Wyoming 82002

PROJECT: Wyoming Premium Farms, LLC - Swine Confinement Facility/Finisher Unit No. 2

ENGINEER: Larry D. McCaslin
M.C. Schaff & Associates, Inc.
Route 2, Box 118, S. Beltline Hwy. E
Scottsbluff, NE 69361

APPLICANT: Wyoming Premium Farms, LLC
Doug DeRouchey (Manager)
P.O. Box 457
Wheatland, WY 82201-0457

WATER QUALITY DIVISION REFERENCE NUMBER: 96-437

REVIEWING ENGINEER: Gary Steele 

DATE OF REVIEW: November 6, 1996

ACTION: NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 12 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS:

- 1 of 6 Page 3 of the EDR indicates that 96-98 percent of BOD and 80 percent of nitrogen will be removed in the 2 celled lagoon system. These numbers seem high for the loading rates proposed for this facility. Are these typical numbers and how do they relate to influent loading?
- 2 of 6 Page 4 of the EDR describes the 64 acres of land application north of the facility as rough and the irrigation system will need to be manually moved but that this portion would be considered for land application. Is this section accurate? If this section is accurate then special considerations will need to be included in the O&M manual for the manual application of the effluent.
- 3 of 6 Page 6 of the EDR indicates that dead animals will either be taken to a rendering plant or to the Farrowing unit for incineration. If the dead animals are taken to the Farrowing unit for incineration then a solid waste permit is required for the incinerator at the Farrowing unit and that permit must be obtained prior to placing this facility in operation.

- 4 of 6 Page 7 & 8 of the EDR indicates that special consideration was given to sizing the lagoons to control odor, sludge buildup, and salts. The description also indicates that several references were utilized to establish the design. The proposed design has a minimum treatment volume of 2,777,778 cf and a sludge storage volume of 469,116 cf. The application package indicates that the total permanent pool volume for this facility is 3,910,818 cf which includes the minimum design volume and sludge storage.

The SCS or NRCS design manual recommends that the minimum treatment volume be based upon a VS production rate of 5.4 lbs/AU/day and a VS loading rate of 4. The loading rate is based upon a geographic region. Calculating a minimum treatment volume based upon these numbers gives a volume of 3,375,000 cf. The design manual indicates that the minimum treatment volume is the volume needed to maintain sustainable biological activity. The manual also indicates that to control odors 25 to 50 percent of the maximum loading rate should be used. If a loading rate for VS of 3 lbs/AU/day or 2 lbs/AU/day are used the minimum treatment volumes would be 4,500,000 cf & 6,750,000 respectively. Utilizing the design manual's information for sludge accumulation the volume required to store 2 years of sludge would be 561,169 cf. Based upon these numbers the minimum volume for the permanent pool excluding odor control factors would be 3,936,169.

The Midwest Plan Service design guidelines for an anaerobic lagoon for this type of facility and geographic location would require a primary cell volume of 5,600,000 cf and a secondary cell with a volume of 1,500,000 cf. The proposed design for this facility has a primary lagoon size of 3,828,968 cf and a secondary cell of 2,290,090 cf.

Please provide copies of the reference information used to size the lagoons and provide information showing that the proposed design will perform as represented in the application package. Also please show how the proposed design has considered odor control as represented in the design. It appears, based upon the reference material I have, the proposed lagoons do not have sufficient volume to meet minimum treatment requirements nor do they have the additional capacity for odor control.

- 5 of 6 The land application areas identified in the application package included areas around Chugwater Creek, Eagle Nest Canyon, and on the edge of the flood plain of the Laramie River. If it is proposed to utilize these areas for land application, the applicant needs to provide a management plan that demonstrates both groundwater and surface water will be protected.
- 6 of 6 Please provide information that shows that the irrigated area has sufficient water to meet the peak crop production rate identified for this area. This information is needed to determine if the nutrient uptake in this area can meet the proposed levels identified in the application package.

PERMIT TO CONSTRUCT

1 New
Renewal
Modified

PERMIT NO. 96-438
SPECIAL CONDITIONS
REF/PERMIT #

Wyoming Premium Farms, Swine Confinement - Nursery Unit #1: Office Septic System

This permit hereby authorizes the applicant:

Wyoming Premium Farms, LLC
Doug DeRouchey - Manager
P.O. Box 457
Wheatland, Wyoming 82201-0457

to construct, install or modify a commercial/domestic septic system with leach field according to the procedures and conditions of the application number 96-438. The facility is located in the NE 1/4 of Section 16, T23N, R66W in the county of Platte, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the SE District office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SE District office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-29-96
Date of Issuance

RLE/mad 64004.LTR

STATEMENT OF BASIS

General information.

A. Permit Number: 96-438

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 22, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.



JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building ● 122 West 25th Street ● Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

October 22, 1996

Wyoming Premium Farm, LLC
Doug DeRouchey
P.O. Box 457
Wheatland, Wyoming 82201-0457

RE: Permit Reporting Requirements for Permit Number - 96-438

Dear Mr. DeRouchey:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Estimated Construction Schedule Post Card (Condition 1)
2. Notify the WQD of any changes (Condition 2)
3. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 3)

Please read the permit conditions carefully and follow through as required. Finally, bear in mind that the submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit.

October 22, 1996

Page 2

If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,



Ronald L. Ewald
Senior Analyst
SE District, Water Quality Division

RL/mad 64003.LTR
Enclosure: Permit Referenced Above

cc: Larry D. McCaslin
M.C. Schaff & Associates, Inc.
818 S. Beltline Highway East
Scottsbluff, Nebraska 69361

PERMIT TO CONSTRUCT

(XX) New
Renewal
Modified

PERMIT NO. 96-439
SPECIAL CONDITIONS
REF/PERMIT #

Mid America Pipeline Company Statewide Anode

This permit hereby authorizes the applicant:

Mid America Pipeline Company
1717 South Boulder Avenue
Tulsa, Oklahoma 74119-4886

to construct, install or modify deep bed anode system according to the procedures and conditions of the application number 96-439. The facility is located in statewide, in the State of Wyoming. This permit shall be effective for a period of five years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: UIC Program Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5. After the deep anode beds have fulfilled their useful purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. Within 45 days after a well has been plugged and abandoned, the owner shall file a plugging record with WQD.
- 2 of 5. In addition to the anode bed construction information submitted with the permit application, the following items relating to construction shall be implemented when the anode beds are installed: Each separate aquifer penetrated shall require a separate breather pipe. Each aquifer shall remain in hydrologic isolation from each other if they were isolated prior to installation.
- 3 of 5. Within 45 days after the anodes are installed, as-built construction plans shall be submitted to the DEQ/WQD, detailing how groundwater was protected during installation.
- 4 of 5. If it becomes necessary to wet any anode installed under this permit, only water from an approved public water supply shall be used unless DEQ/WQD is first supplied with an analyses of the water for approval. Waters that originate in sources other than an approved public water supply shall not be used unless first approved.
- 5 of 5. An unlimited number of similar anodes may be installed under this permit. This authorization applies to Mid America Pipeline Company and all subsidiary companies operating in Wyoming.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-14-96

Date of Issuance

RFL:ks 63903.ltr

cc: George L. Hoffman, Hydro-Engineering, 4685 South Magnolia, Casper, WY 82604

51865.doc

STATEMENT OF BASIS

- I. Permit Number: 96-439
- ii. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
 - A. Chapter XI. Yes
 - B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
 - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
Yes
 - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
 - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
 - A. This permit covers deep groundbed anodes statewide. It has been reviewed for general conformance with regulations found in Chapter XI, Part G covering construction of wells. There are no specific regulations covering deep groundbed anodes.
- V. Applicant Participation. The applicant has been provided with a draft permit for review prior to this permit being issued.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Robert F. Lucht, P.E. and P.G., UIC Program Supervisor and completed on October 10, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

☒ New
Renewal
Modified

PERMIT NO. 96-440
SPECIAL CONDITIONS

Lewis Brothers Subdivision Waterline

This permit hereby authorizes the applicant:

Nick Lewis
1023 Lane 12
Lovell, WY 82431

to construct a 3 inch PVC water main connected to the N.W.R.W.D. Lovell Service Area according to the procedures and conditions of the application number 96-440. The facility is located in Lot 77A and Lot 79, T56N, R96W, resurvey in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 5 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
5. of 5 The water main must be installed within a recorded easement of sufficient width to provide access for operation and maintenance.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

11 - 8 - 96
Date of Issuance

STATEMENT OF BASIS

I. General information.

A. Permit Number: 96-440

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, P.E., Northwest District Supervisor, and completed on October 29, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JH/bb/64115.ltr

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 96-441
SPECIAL CONDITIONS
REF/PERMIT #

Central Wyoming Regional Water System Bid Package No. 2

This permit hereby authorizes the applicant:

Central Wyoming Regional Water System
Attention: Dean Dickey
201 N. David, Fifth Floor
Casper, WY 82601

to construct, install or modify a water storage tank, potable water booster pump station and potable water transmission line according to the procedures and conditions of the application number 96-441. The facility is located in Sections 8 and 11, Township 34 North, Range 80 West, and Sections 21 and 28, Township 33 North, Range 80 West in the county of Natrona, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

1-22-97
Date of Issuance

BDM/pr: January 17, 1997

b/70267.ltr

cc: Karen Speer, CH2M HILL, 100 Inverness Terrace East, Englewood, CO 80112-5304
Tom Brauer, CEPI, 355 N. Lincoln, Casper, WY 82601
Mike Jennings, Natrona County Health, 1200 E. 3rd, Casper WY 82601
Tom Curren, Natrona County Planning, 120 W. 1st, #200, Casper, WY 82601

STATEMENT OF BASIS

I. General information.

A. Permit Number: 96-441

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, Senior Environmental Analyst, and completed on January 17, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

BDM/bb/70267.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

New
Renewal
X Modified

PERMIT NO. 96-442
SPECIAL CONDITIONS
REF/PERMIT #94-272

Silo Field Processing Facility

This permit hereby authorizes the applicant:

Consolidated Industrial Services, Inc.
211 West 14th Street
P.O. Box 884
Chanute, KS 66720

to construct, install or modify allow the Silo Processing Facility to accept NON-HAZARDOUS wastewater according to the procedures and conditions of the application number 96-442. The facility is located in NE 1/4 Section 12, T15N, R65W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 3 of 3 Permit to Construct 94-272 was issued for the construction of the Silo Processing Facility. The Permit (94-272) allowed the facility to accept and treat produced water from oil exploration and production activities. This permit is being issued to allow the above referenced facility to expand what it can accept and treat to NON-HAZARDOUS wastewater only. All other aspects and requirements of Permit to Construct 94-272 are still valid and need to be adhered to.


AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

 10-31-96

Date of Issuance

GLS:ks
64083.ltr

STATEMENT OF BASIS

General information.

A. Permit Number: 96-442

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

None

The purpose of this modification is to allow the referenced facility to accept and treat NON-HAZARDOUS wastewater for treatment. This permit is being issued on the basis of an evaluation of the facility procedures for evaluating and tracking of wastewater from customers. The evaluation was done by both the Solid Waste Division and the Water Quality Division of DEQ. This modification is being issued on the basis that this facility will not accept store or treat either a LISTED or CHARACTERISTIC HAZARDOUS waste.

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Applicable under Permit to Construct 94-272

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

Permit to Construct 94-272 was permitted with a synthetic liner and leak detection system and was accepted on the basis that it would not have a discharge to groundwater.

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT NO. 96-442

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Gary Steele, Southeast District Engineer, and completed on October 25, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

PERMIT TO CONSTRUCT

X New
- Renewal
- Modified

PERMIT NO. 96-443
SPECIAL CONDITIONS

LaMori Light Industrial Subdivision

This permit hereby authorizes the applicant:

Joseph M. LaMori
P.O. Box 216
Rock Springs, WY 82902

to construct water and sewer pipeline extensions according to the procedures and conditions of the application number 96-443. The facility is located in NE ¼ S12 T18N R106W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-28-96
Date of Issuance

RRT/bb/63968.ltr

STATEMENT OF BASIS

I. General information.

A. Permit Number: 96-443

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected: (Fill out only the applicable sections and indicate sections that are not applicable.)

Not Applicable

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, S.W. District Engineering Supervisor, and completed on 21 October 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RRT/bb/63968.ltr



JIM GERINGER
GOVERNOR

Department of Environmental Quality

Herschler Building ● 122 West 25th Street ● Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-7682	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

October 23, 1996

Centennial Water & Sewer District
Jane Houston, Chairperson
P.O. Box 436
Centennial, Wyoming 82055

RE: **Permit Reporting Requirements** for Permit Number - 96-444

Dear Ms. Houston:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Estimated Construction Schedule Post Card (Condition 1)
2. Notify the WQD of any changes (Condition 2)
3. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 3)

Please read the permit conditions carefully and follow through as required. Finally, bear in mind that the submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit.

If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Senior Analyst
SE District, Water Quality Division

RLE:ks 64042.ltr

Enclosure: Permit Referenced Above

cc: Robert J. Coffey, Coffey & Associates, 903 Grand Avenue, Laramie, Wyoming 82070

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 96-444
SPECIAL CONDITIONS
REF/PERMIT #

Centennial W&S District: Walnut Avenue Sewer Extension - 1996

This permit hereby authorizes the applicant:

Centennial Water & Sewer District
P.O. Box 436
Centennial, Wyoming 82055

to construct, install or modify a sewer main extension according to the procedures and conditions of the application number 96-444. The facility is located in the NE 1/4 of Section 3, T15N, R78W in the county of Albany, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the SE District office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SE District office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-28-96

Date of Issuance

RLE:ks 64043.ltr

STATEMENT OF BASIS

.. General information.

A. Permit Number: 96-444

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 22, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT TO CONSTRUCT

☐ New
☐ Renewal
☐ Modified

PERMIT NO. 96-445
SPECIAL CONDITIONS

Teton Pines Lot 3 Water and Sewer Improvements

This permit hereby authorizes the applicant:

Teton Pines LLC
3450 North Clubhouse Drive
Jackson, Wyoming 83001

to construct a wastewater collection system and a potable water distribution system and tying these into the existing Aspen Water and Sewer District network according to the procedures and conditions of the application number 96-445. The facility is located in the SE/4 of Sec. 11, T41N, R117W in the county of Teton, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

11 - 8 - 96
Date of Issuance

MDR/bb/64103.ltr

STATEMENT OF BASIS

- I. General information.
 - A. Permit Number: 96-445
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
 - A. Chapter XI. Yes
 - B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
 - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
Yes
 - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
 - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Documentation of Statement of Basis.
 - A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 28 October 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDR/bb/64103.ltr

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 96-446
SPECIAL CONDITIONS

Carol Bivens Septic Tank and Leach Field

This permit hereby authorizes the applicant:

Carol Bivens
621 Richards
Thermopolis, Wyoming 82443

to construct a single family residential septic tank and leach field according to the procedures and conditions of the application number 96-446. The facility is located in the Sunnyside Acres Subdivision on Lot 3 of Block 4 in Section 12, T43N, R95W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-23-96
Date of Issuance

MDR/mad 63950.LTR

STATEMENT OF BASIS

I. General information.

A. Permit Number: 96-446

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 17 October 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 96-447
SPECIAL CONDITIONS

Carl Leyba Elevated Mound System

This permit hereby authorizes the applicant:

Carl Leyba
844 Arapahoe
Thermopolis, Wyoming 82443

to construct an elevated mound domestic waste water disposal system according to the procedures and conditions of the application number 96-447. The facility is located in the SE/4 of the NW/4 of Sec. 30, T43N, R94W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-28-96
Date of Issuance

MDR:ks 64049.ltr

STATEMENT OF BASIS

General information.

A. Permit Number: 96-447

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 22 October 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

x New
 Renewal
 Modified

PERMIT NO. 96-448
SPECIAL CONDITIONS

Roland Luehne Elevated Mound System

This permit hereby authorizes the applicant:

Roland Luehne
266 East River Road
Thermopolis, Wyoming 82443

to construct an elevated mound domestic waste water disposal system according to the procedures and conditions of the application number 96-448. The facility is located in the SE/4 of the NW/4 of Sec. 30, T43N, R94W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Lander Office, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-7726.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
2. of 4 The applicant will provide immediate oral and/or written notice to Lander Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
3. of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Lander office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
4. of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-28-96
Date of Issuance

MDR:ks 64050.ltr

STATEMENT OF BASIS

- I. General information.
 - A. Permit Number: 96-448
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
 - A. Chapter XI. Yes
 - B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
 - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
Yes
 - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
 - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Documentation of Statement of Basis.
 - A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 22 October 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PERMIT TO CONSTRUCT

☒ New
Renewal
Modified

PERMIT NO. 96-449
SPECIAL CONDITIONS
REF/PERMIT #

Tribe Ranch Septic System

This permit hereby authorizes the applicant:

Steve Tribe
HCR 69 Box 92
Belle Fourche, SD 57717

to construct, install or modify a septic system according to the procedures and conditions of the application number 96-449. The facility is located in NE/4 of the NE/4 of Section 27, Township 57 North, Range 61 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Department of Environmental Quality

10-28-96
Date of Issuance

BDM/pr: October 18, 1996

b/63967.ltr

cc: Crook County Small Wastewater File

STATEMENT OF BASIS

- I. General information.
 - A. Permit Number: 96-449
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
 - A. Chapter XI. Yes
 - B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
 - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes
 - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No
 - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
 - A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not applicable (N/A)
 - B. Briefly state the basis for the deviation.

N/A
 - C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹: (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, P.E., Senior Environmental Analyst, and completed on October 18, 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

BDM/bb/63967.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

ROAD APPLICATION PERMIT

x New
Renewal
Modified

PERMIT NO. 96-450
SPECIAL CONDITIONS

Wyo-Ben Stucco Milling Facility Road Application

This permit hereby authorizes the applicant:

Wyo-Ben, Inc.
P.O. Box 1072
Greybull, Wyoming 82426

to road apply 40 cu yds of diesel contaminated soil according to the procedures and conditions of application number 96-450. The application site is located in the NW/4 of Sec. 12, T53N, R94W in the county of Big Horn in the State of Wyoming. This permit shall be effective until November 30, 1996.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), upon the presentation of credentials and during working hours, to have access to inspect the waste source and application site location, for the purpose of compliance with the provisions of this permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- i. of 9 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: Water Quality Division, 250 Lincoln Street, Lander, WY 82520. (307)332-3144.

2. of 9 The permittee will provide immediate oral and/or written notice to Water Quality Division, 250 Lincoln, Lander, WY 82520, (307) 332-3144, in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
3. of 9 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the Water Quality Division, 250 Lincoln, Lander, WY 82520, on the attached Certification of Completion form.
 - a. Date that the road application was completed; and
 - b. Certification the road application was done in accordance with the terms and conditions of the permit; or
 - c. Certification the road application was completed with changes or modifications. Submit the information necessary to clearly indicate the road application as actually performed. This information shall include a contour map depicting only those sections of road that actually received 40 cu yds of diesel contaminated soil.
4. of 9 The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
5. of 9 The material shall be applied uniformly and incorporated into the roadbed. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. No application is to be done after November 30, 1996.
6. of 9 The application site slope shall not exceed eight percent (8%) for vehicular application.
7. of 9 Material application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
8. of 9 Only the areas designated in this permit are authorized for application of the 40 cu yds of diesel contaminated soil. Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.
9. of 9 The 40 cu yds of diesel contaminated soil shall not be applied to frozen ground.

AUTHORIZED BY:



Administrator
Water Quality Division



Director
Dept. of Environmental Quality

10-29-96
Date of Issuance

MDR:ks
64063.ltr

STATEMENT OF BASIS

I. General information.

A. Permit Number: 96-450

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

Yes

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are no numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the 40 cu yds of diesel contaminated soil onto the roadbed. Repeated applications of 40 cu yds of diesel contaminated soil on the same sections of road will be monitored by roadbed analyses.

- B. Quality of waste is such that it will not cause a violation of groundwater standards. Briefly describe:

The diesel contaminated soil has been land farmed for two years. The volatile fractions have dispersed, decomposed and evaporated to a large degree.

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

Material will be applied as a three inch overlay to an existing roadbed.

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

Application area has slope less than two percent and is greater than 300 feet from high water limits.

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT NO. 96-450

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

No exceedances allowed.

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

No exceedances allowed.

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

Periodic inspection of runoff and standing water for visible sheen.

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Michael D. Roberts, P.E., Northwest District Engineer, and completed on 24 October 1996. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

