

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-351  
SPECIAL CONDITIONS

### City of Casper 1997 Fairdale-Fairview-Amherst Sanitary Sewer Improvements Project 97-38

This permit hereby authorizes the applicant:

City of Casper  
ATTN: Hal Hutchinson  
200 N. David  
Casper, WY 82601

to construct, install or modify a sanitary sewer according to the procedures and conditions of the application number 97-351. The facility is located in NE/4 of Section 15, Township 33 North, Range 79 West in the county of Natrona, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

9-26-97  
Date of Issuance

BDM/pr: 72947.LTR

cc: Michael Bell, P.E., 259 S. Center, Suite 306, Casper, WY 82601  
Mike Jennings, Natrona County Health, 1200 E. 3rd, Casper WY 82601  
Tom Curren, Natrona County Planning, 120 W. 1st, #200, Casper, WY 82601

## STATEMENT OF BASIS

### General information.

A. Permit Number: 97-351

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter XI Section 9.(b)(v) requires leakage tests on all pipe materials.

B. Briefly state the basis for the deviation.

This project will replace deteriorated 8 inch clay pipe. As the sewer is replaced, services will be reconnected to the new line as construction progresses. This will allow a minimum of inconvenience to users, and help expedite construction. The applicant has agreed to test all joints for proper gasket seating. Leakage often occurs as a result of a rolled, or improperly seated, gasket. This office recommends a deviation be granted. This approach has been called out in the approved flow fill policy.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Policy 13.9.11 and 14.14.14 calls out an inspection method to ensure proper gasket seating.

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable (N/A)

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, Senior Environmental Analyst, and completed on September 23, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

THE STATE



OF WYOMING



JIM GERINGER  
GOVERNOR

## Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

October 9, 1997

Mr. Dennis DaDante  
P.O. Box 164  
Elk Mountain, Wyoming 82324-0164

RE: Permit Reporting Requirements for Permit Number - 97-352

Dear Mr. DaDante:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Estimated Construction Schedule Post Card (Condition 1)
2. Notify the WQD of any changes (Condition 2)
3. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 3)

Please read the permit conditions carefully and follow through as required. Finally, bear in mind that the submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit.

If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald  
Senior Analyst  
SE District, Water Quality Division

RLE/bb/73059.1tr  
Enclosure: Permit Referenced Above

## PERMIT TO CONSTRUCT

New  
Renewal  
 Modified

PERMIT NO. 97-352  
SPECIAL CONDITIONS  
REF/PERMIT NO. 95-295

### DaDante Residential Septic System (Converted from Composting System)

This permit hereby authorizes the applicant:

Dennis and Patricia DaDante  
P.O. Box 164  
Elk Mountain, Wyoming 82324-0164

to construct, install, and modify a residential septic system with "Infiltrator" leach field converted from a composting wastewater system according to the procedures and conditions of the application number 97-352. The facility is located in the SE 1/4 NW 1/4 of Section 10, T19N, R81W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-15-97  
\_\_\_\_\_  
Date of Issuance

RLE/bb/73061.ltr

cc: Carbon County Planner/Sanitarian

## STATEMENT OF BASIS

### I. General information.

A. Permit Number: 97-352      Reference 95-295

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI.      Yes

B. Chapter XII.      No

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 9, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/bb/73061.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.



JIM GERINGER  
GOVERNOR

## Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

October 9, 1997

Mr. Fred Cariaso  
P.O. Box 35  
Elk Mountain, Wyoming 82324

RE: Permit Reporting Requirements for Permit Number - 97-353

Dear Mr. Cariaso:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Estimated Construction Schedule Post Card (Condition 1)
2. Notify the WQD of any changes (Condition 2)
3. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 3)

Please read the permit conditions carefully and follow through as required. Finally, bear in mind that the submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit.

If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald  
Senior Analyst  
SE District, Water Quality Division

RLE/bb/73060.ltr

Enclosure: Permit Referenced Above

# PERMIT TO CONSTRUCT

New  
Renewal  
 Modified

PERMIT NO. 97-353  
SPECIAL CONDITIONS  
REF/PERMIT NO. 92-231

## Cariaso/Lace Septic System (Converted from Holding Tank)

This permit hereby authorizes the applicant:

Fred Cariaso/Bonnie Lace  
P.O. Box 35  
Elk Mountain, Wyoming 82324

to construct, install, and modify a residential septic system with "Infiltrator" leach field converted from a holding tank only system according to the procedures and conditions of the application number 97-353. The facility is located in the SE 1/4 NW 1/4 of Section 10, T19N, R81W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-15-97  
Date of Issuance

RLE/bb/73058.ltr

cc: Carbon County Planner/Sanitarian

## STATEMENT OF BASIS

### I. General information.

A. Permit Number: 97-353      Reference 92-231

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI.      Yes

B. Chapter XII.      No

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 9, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/bb/73058.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are



THE STATE OF WYOMING



JIM GERINGER  
GOVERNOR

## Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

September 29, 1997

James J. Hill, III  
P.O. Box 1588  
Monterey, California 93942

RE: Permit Reporting Requirements for Permit Number - 97-354

Dear Mr. Hill:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Estimated Construction Schedule Post Card (Condition 1)
2. Notify the WQD of any changes (Condition 2)
3. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 3)

Please read the permit conditions carefully and follow through as required. Finally, bear in mind that the submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit.

If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald  
Senior Analyst  
SE District, Water Quality Division

RLE:ks 72976.ltr

Enclosure: Permit Referenced Above

cc: Douglas S. Chandler, Allied Engineering Services, Inc., 101 E. Main, Suite A, Bozeman, Montana 59715

# PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 97-354  
SPECIAL CONDITIONS

## Homestead Ranch Bunkhouse Wastewater Treatment System

This permit hereby authorizes the applicant:

James J. Hill, III  
P.O. Box 1588  
Monterey, California 93942

to construct and install a business septic system with leach field for domestic waste according to the procedures and conditions of the application number 97-354. The facility is located in the SE 1/4 of Section 20, T13N, R86W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and


PERMIT NO. 97-354

- c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
- d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate.

4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-7-97  
\_\_\_\_\_  
Date of Issuance

RLE:ks  
72978.ltr

cc: Carbon County Planner/Sanitarian

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 97-354

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on September 29, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.



THE STATE OF WYOMING



JIM GERINGER  
GOVERNOR

## Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

September 29, 1997

M. W. Gano  
183 Deadhead Creek Road  
Wheatland, Wyoming 82201

RE: Permit Reporting Requirements for Permit Number - 97-355

Dear Mr. Gano:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Estimated Construction Schedule Post Card (Condition 1)
2. Notify the WQD of any changes (Condition 2)
3. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 3)

Please read the permit conditions carefully and follow through as required. Finally, bear in mind that the submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit.

If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald  
Senior Analyst  
SE District, Water Quality Division

RLE:ks 72977.ltr

Enclosure: Permit Referenced Above

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 97-355  
SPECIAL CONDITIONS

## Gano Residential Septic System

This permit hereby authorizes the applicant:

M. W. Gano  
183 Deadhead Creek Road  
Wheatland, Wyoming 82201

to construct and install a residential septic system with "Infiltrator" leach field according to the procedures and conditions of the application number 97-355. The facility is located in the NE 1/4 of Section 09, T22N, R69W in the county of Platte, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate.

PERMIT NO. 97-355

4 of 5. Septic Tank Riser Requirement - On Vaughn Concrete Products septic tanks, the manway must be extended to the ground surface **when clean-out risers are not provided.**

5 of 5. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-7-97  
\_\_\_\_\_  
Date of Issuance

RLE:ks  
72979.ltr

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 97-355

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on September 29, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 97-356  
SPECIAL CONDITIONS

### Sand Creek Country Club Septic System 352 Sand Creek Road

This permit hereby authorizes the applicant:

Sand Creek Country Club  
ATTN: Robert Winkler  
P.O. Box 309  
Beulah, WY 82712

to construct, install or modify a septic system according to the procedures and conditions of the application number 97-356. The facility is located in NE/4 of Section 18, Township 52 North, Range 60 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-7-97  
Date of Issuance

BDM/pr:mad 72969.LTR

cc: Crook County Small Wastewater File

## STATEMENT OF BASIS

### I. General information.

A. Permit Number: 97-356

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, Senior Environmental Analyst, and completed on September 26, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 97-357RR  
SPECIAL CONDITIONS

### 1997 Greybull Water Transmission Line Improvements

This permit hereby authorizes the applicant:

Town of Greybull  
P.O. Box 127  
Greybull, WY 82426

to construct or install a new valve and metering building, pressure reducing valves and air relief valves according to the procedures and conditions of application number 97-357RR. The facility is located in SW 1/4 Sec.10, T52N, R93W, NE 1/4 Sec. 36, T53N, R93W, NW 1/4 Sec.26, T53N, R91W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

11-6-97  
Date of Issuance

JH/bal  
b/73363.ltr

## STATEMENT OF BASIS

I. General information.

Permit Number: 97-357

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on October 29, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JCH/bb/73363.ltr

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. **97-361**  
SPECIAL CONDITIONS

### Munger Septic Tank/Leach Field

This permit hereby authorizes the applicant:

Gary Munger  
325 Buffalo Creek Road  
Thermopolis, WY 82443

to construct a septic tank/leach field to serve a three bedroom residence according to the procedures and conditions of application number 97-361. The facility is located in Lot 10 of Mountain View Subdivision in Section 24, T 42 N, R 95 W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermanksy, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

9-15-97  
\_\_\_\_\_  
Date of Issuance

JH/bal  
b/72818.ltr

## STATEMENT OF BASIS

### I. General information.

Permit Number: #97-361

### II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on September 10, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JCH/bb/72818.ltr

## LAND APPLICATION PERMIT

New  
 Renewal  
 Modified

PERMIT NO. 97-362  
SPECIAL CONDITIONS

### ROBINSON ROAD APPLICATION

This permit hereby authorizes the applicant:

Integrity Oil & Gas Company  
3440 Youngfield Street  
Wheat Ridge, CO 80033  
Attention: Bob Willingham

to land apply waste oil and oil contaminated soil according to the procedures and conditions of the application number 97-362. The location of the application is in the NW/4 of Section 9 of Township 49 North Range 67 West in the county of Campbell, in the State of Wyoming. This permit shall be effective until November 1, 1997.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (DEQ/WQD) upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 9. The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: DEQ/WQD NE District Office, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming, 82801, Telephone (307) 672-6457, FAX (307) 674-6050.
- 2 of 9. The permittee shall provide immediate oral and/or written notice to the NE District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
- 3 of 9. The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the NE District Office on the attached Certification of Completion form.
- 4 of 9. The permittee shall submit a contour map depicting only those sections of road that actually received waste oil and oil contaminated soil within sixty (60) days of the project completion to the NE District Office.
- 5 of 9. The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
- 6 of 9. The waste oil and oil contaminated soil shall be applied uniformly. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. Produced water shall not be applied during the period from November 1 to April 10.
- 7 of 9. The application site slope shall not exceed eight percent (8%) for vehicular application.
- 8 of 9. Waste oil and oil contaminated soil application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
- 9 of 9. Any waste oil and oil contaminated soil application after November 1, 1997 must be re-permitted.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach, Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer, Director  
Department of Environmental Quality

9-16-97

Date of Issuance

DRM/pr/ks 72869.ltr

xc: Richard Cool & Janie Nelson, WOGCC, Casper  
Ron Lillich, EPA Region 8, Denver

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 97-362

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are no numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the waste oil and oil contaminated soil onto the roadbed. Repeated applications of waste oil and oil contaminated soil on the same sections of road will be monitored by roadbed analyses.

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Don McKenzie, SPO NE District Program Principal and completed on September 15, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

42901.DOC

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements

## ROAD APPLICATION PERMIT

X New  
Renewal  
Modified

PERMIT NO. 97-363  
SPECIAL CONDITIONS

### Hallador Federal 1-12

This permit hereby authorizes the applicant:

Hallador Petroleum Company  
1660 Lincoln St., Suite 2700  
Denver, CO 80264

to road apply crude oil sludge according to the procedures and conditions of application number 97-363. The application site is located in SW 1/4 SE 1/4 Sec. 12, T 46 N, R 100 W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective until November 1, 1998.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 8 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following

address: Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307) 332-3183.

- 2 of 8 The permittee will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
- 3 of 8 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the attached Certification of Completion form, the following information:
- A. Date that the road application was completed; and
  - B. Certification the road application was done in accordance with the terms and conditions of the permit; or
  - C. Certification the road application was completed with changes or modifications. Submit the information necessary to clearly indicate the road application as actually performed. This information shall include a contour map depicting only those sections of road that actually received the crude oil sludge.
- 4 of 8 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 8 The crude oil sludge shall be applied uniformly and incorporated into the roadbed. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. The crude oil sludge shall not be applied during the period from November 1 to April 10.
- 6 of 8 The application site slope shall not exceed eight percent (8%) for vehicular application.
- 7 of 8 The crude oil sludge application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
- 8 of 8 Only the roads designated in this permit are authorized for application of the crude oil sludge. Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-7-97  
\_\_\_\_\_  
Date of Issuance

JCH/bal/ks  
72874.ltr

## STATEMENT OF BASIS

### I. General information.

Permit Number: 93-363

### II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are not numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed modified or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement.

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria

for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the crude oil sludge onto the roadbed. Repeated applications of crude oil sludge on the same sections of road will be monitored by roadbed analyses that is required for future applications.

- B. Quality of waste is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

PERMIT NO. 97-363

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on September 26, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-364R  
SPECIAL CONDITIONS

## Sessions Septic Tank and Leach Field

This permit hereby authorizes the applicant:

Allen R. and Penny Sessions  
1265 Road 8 ½  
Lovell, WY 82431

to construct a septic tank and leach field for a three (3) bedroom residence according to the procedures and conditions of application number 97-364. The facility is located in Lot 1A within Lot 1 in the NE¼ of Section 20, T56N, R96W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

9-26-97  
Date of Issuance

RJC/rjc  
b/72925.ltr

## STATEMENT OF BASIS

General information.

Permit Number: 97-364R

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not applicable

B. Briefly state the basis for the deviation.

Not applicable

C. Permit based on general or statewide deviation contained in approved policy statement

Not applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not applicable

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected.

Not applicable

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Robin J. Coffey, Senior Environmental Analyst, and completed on September 19, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RJC/bb/72925.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-365  
SPECIAL CONDITIONS

### John Reid Septic System

This permit hereby authorizes the applicant:

John Reid  
1377 New Haven Road  
Hulett, WY 82720

to construct, install or modify a septic system according to the procedures and conditions of the application number 97-365. The facility is located in the SW/4, NE/4 of Section 30, Township 55 North, Range 66 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

12-3-97  
Date of Issuance

BDM/pr:mad 73617.LTR

cc: Crook County Small Wastewater File

## STATEMENT OF BASIS

### General information.

A. Permit Number: 97-365

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian Mark, Senior Analyst, and completed on December 1, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-366  
SPECIAL CONDITIONS

### James Reid Septic System

This permit hereby authorizes the applicant:

James Reid  
1375 New Haven Road  
Hulett, WY 82720

to construct, install or modify a septic system according to the procedures and conditions of the application number 97-366. The facility is located in the SW/4, NE/4 of Section 30, Township 55 North, Range 66 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

12-3-97  
Date of Issuance

BDM/pr:mad 73618.LTR

cc: Crook County Small Wastewater File

## STATEMENT OF BASIS

General information.

A. Permit Number: 97-366

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian Mark, Senior Analyst, and completed on December 1, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.



THE STATE OF WYOMING



JIM GERINGER  
GOVERNOR

## Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

October 9, 1997

Mr. Perry Irving  
819 South 7th Street  
Laramie, Wyoming 82070

RE: Permit Reporting Requirements for Permit Number - 97-367

Dear Mr. Irving:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Estimated Construction Schedule Post Card (Condition 1)
2. Notify the WQD of any changes (Condition 2)
3. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 3)

In addition to the requirements listed above, this permit includes **reporting requirements** which are **specific to this project**:

4. Have the construction inspected by Albany County before it is covered (Condition 5).

Please read the permit conditions carefully and follow through as required. Finally, bear in mind that the submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit. If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald  
Senior Analyst  
SE District, Water Quality Division

RLE/bb/73064.ltr

Enclosure: Permit Referenced Above

cc: Tee J. Burr, Coffey & Associates, LLC, 903 Grand Avenue, Laramie, Wyoming 82070

# PERMIT TO CONSTRUCT

☐ New  
☐ Renewal  
☐ Modified

PERMIT NO. 97-367  
SPECIAL CONDITIONS

## Irving Furniture Shop - Septic System for Employee Bathroom

This permit hereby authorizes the applicant:

Perry Irving  
819 S 7th Street  
Laramie, Wyoming 82070

to construct and install a business septic system with "Infiltrator" leach field for domestic waste according to the procedures and conditions of the application number 97-367. The facility is located in the NE 1/4 of Section 08, T15N, R73W in the county of Albany, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 6. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 6. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 6. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 6. The intent of the construction authorized by this permit is to provide for the temporary treatment of wastewater until such time that treatment is available through a regional wastewater system. The Laramie Step I Wastewater Facility Plan requires that treatment be provided through a regional system. The facilities authorized by this permit (provided that they fall within the coverage of the Laramie 201 Plan) will be operated under the provisions of the 201 Plan Exemption process administered by the Albany County Planning Commission, the Albany County Board of County Commissioners, the Laramie Planning Commission, and the Laramie City Council. The operation of these facilities will be subject to any review and/or renewal requirements imposed by the 201 Plan Exemption. Finally, these facilities will only be operated until services are available through the approved regional system. These facilities will then be properly abandoned or integrated into the regional system in accordance with the requirements of the Facility Plan, unless the City of Laramie and Albany County jointly authorize an additional extension. If you have any questions contact the Albany County Planning Commission.

- of 6. Before the septic tank, leach field pipe, or other important components are covered, the applicant shall contact the Environmental Health Director for the City of Laramie/Albany County (Stephanie Whitman) at 721-5283, to arrange for an inspection of the project. The system shall not be covered or placed into service until this inspection has been conducted and the work has been approved.
- 6 of 6. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-15-97  
\_\_\_\_\_  
Date of Issuance

RLE/bb/73065.ltr

cc: Stephanie Whitman, Laramie/Albany County Environmental Health Director

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 97-367

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 9, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/bb/73065.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-368  
SPECIAL CONDITIONS

## Teton Village Sewer System Improvements

This permit hereby authorizes the applicant:

Teton Village Water and Sewer District  
P.O. Box 586  
Teton Village, WY 83025

to construct 1800LF 18-inch PVC sewer, extend 8-inch PVC sewer, 600 LF 6-inch HDPE forced main and a new lift station according to the procedures and conditions of application number 97-368. The facility is located in SE1/4 Sec.24, T42N, R117W in the county of Teton, in the State of Wyoming. This permit shall be effective for a period of (2) two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-15-97  
Date of Issuance

JH/bal/ks  
73084.ltr

## STATEMENT OF BASIS

I. General information.

Permit Number: 97-368

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on September 30, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-368  
SPECIAL CONDITIONS

## Teton Village Sewer System Improvements

This permit hereby authorizes the applicant:

Teton Village Water and Sewer District  
P.O. Box 586  
Teton Village, WY 83025

to construct 1800LF 18-inch PVC sewer, extend 8-inch PVC sewer, 600 LF 6-inch HDPE forced main and a new lift station according to the procedures and conditions of application number 97-368. The facility is located in SE1/4 Sec.24, T42N, R117W in the county of Teton, in the State of Wyoming. This permit shall be effective for a period of (2) two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION); the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-7-97  
\_\_\_\_\_  
Date of Issuance

JH/mad 72996.LTRI

STATEMENT OF BASIS

General information.

Permit Number: 97-368

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on September 30, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-369  
SPECIAL CONDITIONS

### TERRY P. & CINDY A. NICHOLSON RESIDENTIAL SEPTIC SYSTEM #2

This permit hereby authorizes the applicant:

Terry P. & Cindy A. Nicholson  
No. 4 Pine View Drive  
Moorcroft, WY 82721

to construct, install or modify a septic system according to the procedures and conditions of the application numbers 97-369. The facility is located in the NE/4 of the NW/4 of Section 14 of T50N R66W in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (DEQ/WQD), upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ/WQD the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, DEQ/WQD, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach, Administrator  
Water Quality Division

9-26-97  
\_\_\_\_\_  
Date of Issuance

  
\_\_\_\_\_  
Dennis Hemmer, Director  
Department of Environmental Quality

DRM/pr:mad 72894.LTR

Enclosures: Notification Post Card  
Certificate of Completion  
Statement of Basis

## STATEMENT OF BASIS

### General information.

A. Permit Number: 97-369

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of Section VI. from the Statement of Basis.)

N/A

- VI. N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Donald R. McKenzie, Northeast District DEQ/WQD-SPO Program Principal, and completed on September 18, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 97-370  
SPECIAL CONDITIONS  
REF/PERMIT NO.

North View Estates, Cheyenne

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities  
2100 Pioneer Avenue  
Cheyenne, WY, 82001

to construct, install or modify a water and sewer line extension according to the procedures and conditions of the application number 97-370. The facility is located in SW 1/4 Section 18 T14N R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

9-26-97  
Date of Issuance

LBH:ks  
72907.ltr

STATEMENT OF BASIS

General information.

A. Permit Number: 97-370

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. YES

B. Chapter XII. YES

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

YES

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

NO

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

N/A

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NO

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on September 19, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

REVIEW OF PLANS AND SPECIFICATIONS  
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION

Herschler Bldg., 4 West  
Cheyenne, Wyoming 82002

PROJECT: Proposed Medicine Bow Eastside Sanitary Sewer Replacement Project


ENGINEER: Colin Cunningham: Worthington, Lenhart and Carpenter

APPLICANT: Town of Medicine Bow

WATER QUALITY DIVISION REFERENCE NUMBER: 97-371

REVIEWING ENGINEER: Lou Harmon

DATE OF REVIEW: November 18, 1997



**ACTION:** NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 12 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. The project is proposing to replace the existing sewer mains in the same locations, slopes, and elevations. To do so, will require significant deviation from the WQD Chapter 11 requirement that the minimum slope of an 8" diameter sewer is 0.4 ft/100 ft.
2. Such a request is a reasonable request to prevent additional lift stations. However, such variances will be recommended for approval only to the minimum extent necessary. The only practical restriction on replacing the existing lines is that the new lines should at all points be below the original lines. The replacement lines will be required to be layed to a constant grade, rather than a varying grade as proposed.
3. A cursory examination of the collection system layout suggests that by re-laying the line from Manhole #13 to Manhole #14, a uniform grade of 0.3ft/100 ft. throughout the system is possible.
4. The existing sewer layout is illogical. The routing can be simplified and probably result in a less expensive solution while increasing the average slope.

LBH/bb/73505.ltr

cc: Ms. Karlene Sjoden, USDA-Rural Development, P.O. Box 20, Casper, WY 82602

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-371  
SPECIAL CONDITIONS

## Medicine Bow East-Side Sanitary Sewer Replacement Project

This permit hereby authorizes the applicant:

Town of Medicine Bow  
P.O. Box 156  
Medicine Bow, WY, 82329-0156

to construct, install or modify a replacement of the east side sewer mains according to the procedures and conditions of the application number 97-371. The facility is located in Section 8 T22N R78 in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of three years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

1-23-98  
\_\_\_\_\_  
Date of Issuance

LBH:ks 80127.ltr

cc: Ms. Karlene Sjoden, USDA-Rural Development, P.O. Box 20, Casper, WY, 82602

## STATEMENT OF BASIS

General information.

A. Permit Number: 97-371

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. YES

B. Chapter XII. NO

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

NO

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

NO

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

NO

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter XI Section 9(c)(C) specifies a minimum slope of 0.004 ft/ft for 8" diameter sewer mains.

B. Briefly state the basis for the deviation.

The line replacements have been carefully re-engineered to maintain the maximum grades possible without the need to add lift stations. One section of existing 12" trunk line will be lowered to achieve an additional two feet of elevation to be used to maintain near standard grades on the replacement lines.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

With the exception of the sewer main between a couple of manholes, this permit application is consistent with the proposed flat grade sewer main policy.

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NO

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)
- A. Facility will not allow a discharge to groundwater. Briefly describe:
- B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:
- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:
- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:
- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:
- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on January 13, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-372  
SPECIAL CONDITIONS

### Simonton & Simonton Office Building Fire Sprinkler Water Line

This permit hereby authorizes the applicant:

Stephen L. Simonton  
1092 Sheridan Ave.  
Cody, WY 82414

to construct a 4-inch AWWA C900, DR14 PVC water line according to the procedures and conditions of application number 97-372. The facility is located in SE 1/4 Section 31, T 53 N, R 101 W in the county of Park, in the State of Wyoming. This permit shall be effective for a period of 2 (two) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-7-97  
\_\_\_\_\_  
Date of Issuance

JH/mad 72971.LTR

## STATEMENT OF BASIS

### I. General information.

Permit Number: 97-372R

### II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on September 25, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

THE STATE



OF WYOMING



JIM GERINGER  
GOVERNOR

## Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

October 21, 1997

Cheyenne Board of Public Utilities  
Attn. Herman Noe  
Box 1469  
Cheyenne, Wyoming 82001

RE: Permit Reporting Requirements for Permit Number - 97-373

Dear Mr. Noe:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Estimated Construction Schedule Post Card (Condition 1)
2. Notify the WQD of any changes (Condition 2)
3. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 3)

Please read the permit conditions carefully and follow through as required. Finally, bear in mind that the submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit.

If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald  
Senior Analyst  
SE District, Water Quality Division

P:\E\bb73209.1tr

Enclosure: Permit Referenced Above

cc: Donald Kramer, 2811 Central Avenue, Cheyenne, Wyoming 82001

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 97-373  
SPECIAL CONDITIONS

### Ed's Place - Middle Creek Subdivision: Water and Sewer Extensions

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities  
Box 1469  
Cheyenne, Wyoming 82001

to construct, install, and modify public water distribution and public wastewater collection utilities according to the procedures and conditions of the application number 97-373. The facility is located in the SE 1/4 of the NW 1/4 of Section 27, T14N, R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; X (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**
- 4 of 5. **Backflow Prevention** - Backflow prevention is not specifically discussed. Therefore, all the residential or domestic nature service taps connected to **new water mains** shall be protected by at least a **check valve** in accordance with the DEQ/WQD Rules and Regulations Chapter XII Section 14(i)(A). Those taps providing other than residential or "domestic nature only" commercial service must have backflow prevention as recommended by AWWA Standard M14.

5 of 5. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-27-97  
\_\_\_\_\_  
Date of Issuance

RLE/bb/73210.ltr

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 97-373

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup> (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

- VI. Deleted

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 21, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/bb/73210.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-374  
SPECIAL CONDITIONS

### Manuel Septic Tank/Leach Field

This permit hereby authorizes the applicant:

Cliff Manuel  
1804 Highway 14  
Shell, WY 82441

to construct a septic tank/leach field for a two bedroom home according to the procedures and conditions of application number 97-374. The facility is located in SW 1/4 Sec. 19, T 53 N, R 90 W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-7-97  
Date of Issuance

JH/bal/ks  
72985.ltr

## STATEMENT OF BASIS

- I. General information.
- Permit Number: 97-374
- II. Application reviewed for compliance with the following regulations.
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit.
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. N/A
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.
- N/A
- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on September 29, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 97-375  
SPECIAL CONDITIONS

### Baird & Sons, Inc. (Upper Ackerman site) Septic Tank/Leach Field

This permit hereby authorizes the applicant:

Ray Baird  
4011 Gooseberry Road  
Worland, WY 82401

to construct a septic tank/leach field to serve a 3 bedroom trailer house according to the procedures and conditions of application number 97-375. The facility is located in SW 1/4 SW 1/4 Sec. 15, T 45 N, R 96 W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of 2 (two) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-7-97  
\_\_\_\_\_  
Date of Issuance

## STATEMENT OF BASIS

I. General information.

Permit Number: 97-375

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on September 25, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-376  
SPECIAL CONDITIONS

### Day Street Watermain Replacement

This permit hereby authorizes the applicant:

City of Powell  
270 N. Clark St.  
Powell, WY 82435

to construct a 6-inch DIP watermain to replace a 4-inch according to the procedures and conditions of application number 97-376. The facility is located in NE and SE1/4 Sec. 10, T55N, R99W in the county of Park, in the State of Wyoming. This permit shall be effective for a period of (2) two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-7-97  
\_\_\_\_\_  
Date of Issuance

JH/mad 72997.LTR

## STATEMENT OF BASIS

- I. General information.
- Permit Number: 97-376
- II. Application reviewed for compliance with the following regulations.
- A. Chapter XI. No
- B. Chapter XII. Yes
- III. Basis for issuing permit.
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. N/A
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.
- N/A
- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on September 30, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



THE STATE OF WYOMING



JIM GERINGER  
GOVERNOR

## Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

November 5, 1997

Town of Rolling Hills  
Attn. Larry Zimbelman, Mayor  
38 South Badger  
Rolling Hills, Wyoming 82637

RE: Permit Reporting Requirements for Permit Number - 97-377

Dear Mayor Zimbelman:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Estimated Construction Schedule Post Card (Condition 1)
2. Notify the WQD of any changes (Condition 2)
3. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 3)

Please read the permit conditions carefully and follow through as required. Finally, bear in mind that the submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit.

If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald  
Senior Analyst  
SE District, Water Quality Division

RLE:ks 73406.ltr

Enclosure: Permit Referenced Above

cc: Robert C. Hartley, R.C.H. & Associates, P.O. Box 1659, Glenrock, Wyoming 82637

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 97-377  
SPECIAL CONDITIONS

## Town of Rolling Hills - Fire Hall Waterline Extension

This permit hereby authorizes the applicant:

Town of Rolling Hills  
38 South Badger  
Rolling Hills, Wyoming 82637

to construct, install, or modify a water main extension with fire hydrant according to the procedures and conditions of the application number 97-377. The facility is located in parts of Sections 15, 22, and 27, T34N, R75W in the county of Converse, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to

comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 4. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**

PERMIT NO. 97-377

4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

11-6-97  
\_\_\_\_\_  
Date of Issuance

RLE:ks  
3407.ltr

STATEMENT OF BASIS

I. General information.

A. Permit Number: 97-377

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

- VI. Deleted

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on November 5, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-378  
SPECIAL CONDITIONS

### Sand Creek Country Club Septic System 296 Sand Creek Road

This permit hereby authorizes the applicant:

Sand Creek Country Club  
ATTN: John Smiley  
P.O. Box 217  
Beulah, WY 82712

to construct, install or modify a septic system according to the procedures and conditions of the application number 97-378. The facility is located in SW/4 of the NE/4 of Section 18, Township 52 North, Range 60 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-7-97  
\_\_\_\_\_  
Date of Issuance

BDM/pr:mad 72970.LTR

cc: Crook County Small Wastewater File

## STATEMENT OF BASIS

General information.

A. Permit Number: 97-378

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, Senior Environmental Analyst, and completed on September 26, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 97-379  
SPECIAL CONDITIONS

### Mountain Vista Retirement Residence

This permit hereby authorizes the applicant:

City of Lander  
240 Lincoln  
Lander, WY 82520

to construct about 673LF 8-inch PVC water main with fittings, valves and 2 fire hydrants according to the procedures and conditions of application number 97-379. The facility is located in SW1/4 Sec.17, T33N, R99W in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-20-97  
\_\_\_\_\_  
Date of Issuance

## STATEMENT OF BASIS

I. General information.

Permit Number: 97-379

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on October 16, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-380  
SPECIAL CONDITIONS  
REF/PERMIT NO.

### Mall on Stillwater Water and Wastewater Connections

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities  
P.O. Box 1469  
Cheyenne, WY, 82003

to construct, install or modify a water service and fire hydrants for a strip mall according to the procedures and conditions of the application number 97-380. The facility is located in Section 29 T14N R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 A double check valve backflow prevention device shall be installed as part of the 2" water service in accordance with DEQ/WQD Rules and Regulations Chapter XI, Table 1.
- 4 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications: Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 5 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-27-97  
\_\_\_\_\_  
Date of Issuance

LBH/bb/73203.LTR

## STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 97-380
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. YES
- B. Chapter XII. YES
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- YES
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- NO
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- N/A
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- N/A
- B. Briefly state the basis for the deviation.
- N/A
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NO

- VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on October 21, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LBH/bb/73203.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

REVIEW OF PLANS AND SPECIFICATIONS  
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION

Herschler Bldg., 4 West  
Cheyenne, Wyoming 82002

PROJECT: 97-380


ENGINEER: Gertsch/Baker & Associates

APPLICANT: Cheyenne Board of Public Utilities

WATER QUALITY DIVISION REFERENCE NUMBER: 97-380

REVIEWING ENGINEER: Lou Harmon

DATE OF REVIEW: October 9, 1997



**ACTION:** NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 12 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. An analysis of the residual pressures in the 8" main with both new fire hydrants flowing at 1500 g.p.m. needs to be provided. Chapter XII of the WQD Rules and Regulations requires that the normal minimum working pressures be at least 35 psi and the minimum pressure at fire flows be at least 20 psi.
2. The water service to the building requires at least a double check valve for backflow prevention.
3. Inadequate detail is provided in the plans to determine if the minimum separation requirements for water and sewer lines have been met.

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-381  
SPECIAL CONDITIONS

### Worland Comfort Inn Water and Sewer

This permit hereby authorizes the applicant:

Muhammad Farid Khan  
500 North 10th Street  
Worland, WY 82401

to construct water main and sewer lines to serve a 50 room motel according to the procedures and conditions of application number 97-381. The facility is located in NW1/4 NW1/4 Sec.29, T47N, R92W in the county of Washakie, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

1-5-98  
\_\_\_\_\_  
Date of Issuance

JH/bal/ks  
73804.ltr

## STATEMENT OF BASIS

General information.

Permit Number: 97-381

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation. Chapter XI, Part B, Section 9 (c) - An eight inch sewer shall have a minimum slope of 0.40 feet/100feet.

B. Briefly state the basis for the deviation. Data for PVC pipe collected in Worland and elsewhere around the country, shows that you can expect good performance with slopes less than 0.40 ft/ 100ft.

C. Permit based on general or statewide deviation contained in approved policy statement

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on December 29, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-382R  
SPECIAL CONDITIONS

### Wilson Meadows Subdivision Water & Sewer

This permit hereby authorizes the applicant:

The Lazy JA, Limited Liability Company  
P.O. Box 55  
Wilson, WY 83014

to construct a wastewater collection system and water distribution system according to the procedures and conditions of application number 97-382. The facility is located in NE1/4 SE1/4 Sec.22, T41N, R117W in the county of Teton in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

11-6-97  
Date of Issuance

JH/mad 73399.LTR

## STATEMENT OF BASIS

General information.

Permit Number: 97-382R

- II. Application reviewed for compliance with the following regulations.
- A. Chapter XI. Yes
  - B. Chapter XII. Yes
- III. Basis for issuing permit.
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.  
Yes
  - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.  
No
  - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.  
No
- IV. Facilities not specifically covered by regulations. N/A
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.  
N/A
- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on November 3, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

△ New  
Renewal  
Modified

PERMIT NO. 97-383  
SPECIAL CONDITIONS

### Hynds Water Transmission Line Cleaning

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities  
2406 Snyder Ave  
Cheyenne, WY, 82001

to construct, install or modify a cleaning of the water transmission line from King Reservoir to Missile Drive according to the procedures and conditions of the application number 97-383. The facility is located in Sections 1,2,3,4,5,6 T14N R68W and S31 T13N R67W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 **The line must be disinfected after being returned to operating condition. The specifications shall be changed to include a reference to WPWSS Section 02675 DISINFECTION.**
- 4 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed;
  - b. **DATE AND RESULTS OF BATERIOLOGICAL TESTING AFTER DISINFECTION** and;
  - c. Date that the facility was placed in operation;
  - d. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - e. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 5 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-15-97  
\_\_\_\_\_  
Date of Issuance

LBH:ks  
73083.ltr

## STATEMENT OF BASIS

- I. General information.
  - A. Permit Number: 97-383
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
  - A. Chapter XI. NO
  - B. Chapter XII. YES
- III. Basis for issuing permit. (Indicate yes or no for each section.)
  - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.  
YES
  - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.  
NO
  - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.  
N/A
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
  - A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.  
N/A
  - B. Briefly state the basis for the deviation.  
N/A
  - C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).  
N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NO

- VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on October 10, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

THE STATE



OF WYOMING



**JIM GERINGER**  
GOVERNOR

## Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

October 14, 1997

Don and Martha Frederick  
Box 127  
Guernsey, Wyoming 82214

RE: Permit Reporting Requirements for Permit Number - 97-384

Dear Mr. and Mrs. Frederick:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Estimated Construction Schedule Post Card (Condition 1)
2. Notify the WQD of any changes (Condition 2)
3. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 3)

Please read the permit conditions carefully and follow through as required. Finally, bear in mind that the submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit.

If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald  
Senior Analyst  
SE District, Water Quality Division

RLE:ks 73146.ltr

Enclosure: Permit Referenced Above

cc: Weber Building and Development, 21 Cozad Road, Wheatland, Wyoming 82201

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-384  
SPECIAL CONDITIONS

## Frederick Residential Septic System

This permit hereby authorizes the applicant:

Don and Martha Frederick  
Box 127  
Guernsey, Wyoming 82214

to construct and install a residential septic system with leach field according to the procedures and conditions of the application number 97-384. The facility is located in the SE 1/4 of Section 06, T26N, R65W in the county of Platte, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 5. Septic Tank Riser Requirement - The manway on Vaughn Concrete Products septic tanks must be extended to the ground surface when clean-out risers are not provided.

5 of 5. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10/21/97  
\_\_\_\_\_  
Date of Issuance

RLE:ks  
47.ltr

cc: Weber Building and Development, 21 Cozad Road, Wheatland, Wyoming 82201

## STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 97-384
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.  
Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.  
No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.  
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.  
NOT Applicable
- B. Briefly state the basis for the deviation.  
NOT Applicable
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).  
NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 14, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 97-387R  
SPECIAL CONDITIONS

### Majhanovich Chapel of Serenity

This permit hereby authorizes the applicant:

Dale Majhnovich  
421 B Street  
Rock Springs, WY 82901

to construct water line and fire hydrant according to the procedures and conditions of application number 97-387R. The facility is located in S34 T19N R105W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.


This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

11-28-97  
Date of Issuance

RRT/mad 73542.LTR

cc: Green River-Rock Springs-Sweetwater Co. Joint Powers Water Board; P.O. Box 1299; Green River, WY 82935

Stephen Horton; City of Rock Springs; 212 D Street; Rock Springs, WY 82901

STATEMENT OF BASIS

I. General information.

Permit Number: 97-387R

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, SW District Engineering Supervisor, and completed on 21 November 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

☒ New  
Renewal  
Modified

PERMIT NO. 97-388  
SPECIAL CONDITIONS

## City of Rawlins Wastewater Plant Cell No. 1 Biosolids Disposal

This permit hereby authorizes the applicant:

City of Rawlins  
P.O. Box 953  
Rawlins, WY, 82301

to construct, install or modify a disposal of dried biosolids removed from Cell No. 1 according to the procedures and conditions of the application number 97-388. The facility is located in Section 23 T21N R87W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 2 Within sixty days of completion of disposal of the biosolids, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that disposal of the biosolids was completed; and
  - c. Certification the disposal of the biosolids in accordance with the terms and conditions of the permit.
- 2 of 2 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

6-25-98  
\_\_\_\_\_  
Date of Issuance

LBH:ks  
81846.ltr

## STATEMENT OF BASIS

- I. General information.
  - A. Permit Number: 97-388
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
  - A. Chapter XI. Yes
  - B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
  - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.  
Yes
  - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.  
No
  - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.  
N/A
- IV. This land application was approved subject to the provisions of Chapter 15, Standards for the Use or Surface Disposal of Biosolids.
  - A. It is EPA policy that small, one time applications of biosolids does not require EPA approval if the application is handled in accordance with State Rules and Regulations.
  - B. The tests submitted with the application establish that the biosolids meet the requirements of a Class B sludge for reduction of pathogens.
  - C. Soil tests and biosolids analysis verify that the application rates proposed will not exceed the agronomic rate for the application of nitrates and ammonia.

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

No

- VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on June 22, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

REVIEW OF PLANS AND SPECIFICATIONS  
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION

Herschler Bldg., 4 West  
Cheyenne, Wyoming 82002

PROJECT: Rawlins WWTF Aeration Cell #1 Sludge Land Application


ENGINEER:

APPLICANT: City of Rawlins

WATER QUALITY DIVISION REFERENCE NUMBER: 97-388

REVIEWING ENGINEER: Lou Harmon

DATE OF REVIEW: October 30, 1997



**ACTION:** NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 12 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. The sludge removed from Aeration Cell #1 meets the definition of Class B sludge, under the provisions of Alternative 3 of 40 CFR § 503.32(b)(2.) The combination of the extended aeration of Cell #1 and the several years holding time with no new loading is easily equivalent to the requirements of a process to significantly reduce pathogens (PSRP.)
2. The sludge removed from Cell #1 to the containment area should immediately be stabilized by mixing with soil. Without the addition of soil, the sludge will dry to an ash like consistency and be scattered by wind.
3. Tables 1 through 4 of 40 CFR § 503.13 are attached. Please take one representative sample of the sludge and have it tested for the metals listed in Table 1 and nitrates.
4. Please have the soil in the proposed land application area (the area designated for containment) tested for available nitrogen.
5. If the sludge meets the ceiling concentrations specified in Table 1, it can be used for land application. The sludge can be spread over the containment area if the cumulative pollutant loading rates of Table 2 are not exceeded and the application does not exceed the agronomic needs of the rangeland for available nitrogen. Additional areas within the limits of the WWTF may be used for land application as needed.

## PERMIT TO CONSTRUCT

☞ New  
Renewal  
Modified

PERMIT NO. 97-390  
SPECIAL CONDITIONS

### Good Septic Tank/Leach Field

This permit hereby authorizes the applicant:

Robert G. Good  
850 Garfield Ave.  
Lovell, WY 82431

to construct a septic tank/leach field to serve a three bedroom residence according to the procedures and conditions of application number 97-390. The facility is located in Section 8, T56N, R95W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.

2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.


3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:

- a. Date that construction of the facility was completed; and
- b. Date that the facility was placed in operation; and
- c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
- d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10/21/97  
\_\_\_\_\_  
Date of Issuance

JH/bal/ks  
73165.ltr

## STATEMENT OF BASIS

### I. General information.

Permit Number: 97-390

### II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. N/A

### V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

### VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on October 15, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



THE STATE OF WYOMING



JIM GERINGER  
GOVERNOR

## Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

October 31, 1997

Mr. David Koch, P.E.  
City of Lander  
240 Lincoln  
Lander, WY 82520


RE: As-Built Permit To Construct, WQD Reference Number 97-391

Dear Mr. Koch:

The Department of Environmental Quality/Water Quality Division (DEQ/WQD) has reviewed the above referenced As-Built Application that you submitted. Our review of the information and as-constructed plans submitted to this office indicates that the application meets DEQ/WQD regulations and the enclosed As-Built Permit To Construct is hereby issued. The enclosed permit covers the 12-inch magnetic flow meter which has already been installed.

Please be advised that the system must be constructed, installed and operated in accordance with the statements, representations and procedures presented in the application and all supporting documentation as well as the terms and conditions of the permit. You are urged to be familiar with all aspects of the permit application, permit and permit conditions. Any person objecting to a permit issued by the DEQ and desiring affirmative relief may request a hearing before the Environmental Quality Council in accordance with the Rules of Practice and Procedure for the Department of Environmental Quality and the Wyoming Administrative Procedures Act.

Sincerely,

  
Dennis Hemmer  
Director  
Department of Environmental Quality

DH/jh/mad 73356.LTR  
Enclosure

**AS-BUILT**  
**PERMIT TO CONSTRUCT**

New  
Renewal  
Modified

PERMIT NO. 97-391  
SPECIAL CONDITIONS

**Lander Wastewater Treatment Facility Effluent Flow Meter**

This permit hereby authorizes the applicant:

City of Lander  
240 Lincoln  
Lander, WY 82520

to have installed a 12-inch magnetic flow meter according to the procedures and conditions of application number 97-391. The facility is located in NE1/4 Sec. 8, T33N, R99W in the county of Fremont, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, meets applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee has constructed and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 1 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

11-4-97  
\_\_\_\_\_  
Date of Issuance

JH/mad 73356.LTR

## STATEMENT OF BASIS

### General information.

Permit Number: 97-391

### II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility is in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on October 29, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-392  
SPECIAL CONDITIONS

## Ascension Luthern Church Water and Sewer Extensions

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities  
2406 Snyder Avenue  
Cheyenne, WY, 82001

to construct, install or modify an extension of a water main and a sewer line according to the procedures and conditions of the application number 97-392. The facility is located in NE 1/4 Section 18 T14N R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-15-97  
Date of Issuance

LBH:ks  
73082.ltr

## STATEMENT OF BASIS

General information.

A. Permit Number: 97-392

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. YES

B. Chapter XII. YES

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

YES

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

NO

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

N/A

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NO

- VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on October 10, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

# PERMIT TO CONSTRUCT

X New  
— Renewal  
— Modified

PERMIT NO. 97-393RR  
SPECIAL CONDITIONS

## Expansion of Green River Oak Tree Inn

This permit hereby authorizes the applicant:

Lodging Enterprises, Inc.  
8110 E. 32nd St. N, Suite 100  
Wichita, KS 67226

to construct a waterline extension according to the procedures and conditions of application number 97-393RR. The facility is located in SW1/4 S15 T18N R107W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.


This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 5 Compliance is required with the items given in the Green River-Rock Springs-Sweetwater County Joint Powers Water Board letter of 10 December 1997.

AUTHORIZED BY:

  
for \_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_   
Dennis Hemmer  
Director  
Department of Environmental Quality

12-19-97  
Date of Issuance

RRT/mad 73735.LTR

cc: Green River-Rock Springs-Sweetwater Co.; P.O. Box 1299; Green River, WY 82935

## STATEMENT OF BASIS

General information.

Permit Number: 97-393RR

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, SW District Supervisor, and completed on 12/17/97. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## ROAD APPLICATION PERMIT

New  
Renewal  
Modified

PERMIT NO. 97-394  
SPECIAL CONDITIONS

### Amoco Exploration & Production - Elk Basin Road Application

This permit hereby authorizes the applicant:

D.D. Millage  
Amoco Exploration & Production Co.  
P.O. Box 569  
Powell, WY 82435

to road apply crude oil sludge according to the procedures and conditions of application number 97-394. The application site is located in SW 1/4 Sec.25 and E 1/2 Sec. 26, T58N, R100W in the county of Park, in the State of Wyoming. This permit shall be effective until October 31, 1998.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 8 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307) 332-3183.
- 2 of 8 The permittee will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
- 3 of 8 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the attached Certification of Completion form, the following information:
- A. Date that the road application was completed; and
  - B. Certification the road application was done in accordance with the terms and conditions of the permit; or
  - C. Certification the road application was completed with changes or modifications. Submit the information necessary to clearly indicate the road application as actually performed. This information shall include a contour map depicting only those sections of road that actually received the crude oil sludge.
- 4 of 8 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 8 The crude oil sludge shall be applied uniformly and incorporated into the roadbed. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. The crude oil sludge shall not be applied during the period from November 1 to April 10.
- 6 of 8 The application site slope shall not exceed eight percent (8%) for vehicular application.
- 7 of 8 The crude oil sludge application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
- 8 of 8 Only the roads designated in this permit are authorized for application of the crude oil sludge. Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

11-3-97  
\_\_\_\_\_  
Date of Issuance

JH/bal  
b/73324.ltr

## STATEMENT OF BASIS

General information.

Permit Number: 97-394

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are no numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement.

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Applicable

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the crude oil sludge onto the roadbed. Repeated applications of crude oil sludge on the same sections of road will be monitored by roadbed analyses.

B. Quality of waste is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on October 27, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JCH/bb/73324.ltr

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-395  
SPECIAL CONDITIONS

### Fort Laramie Pipeline Station

This permit hereby authorizes the applicant:

Amoco Pipe Line Company  
P.O. Box 168  
Fort Laramie, WY 82212

to have constructed, installed or modified monitoring wells according to the procedures and conditions of the application number 97-395. The facility is located in T26N, R64W, Section 23, SW 1/4 in the county of Goshen, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Groundwater Pollution Control Program, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

12-17-97  
Date of Issuance

1. of 10 No monitoring well/piezometer shall be abandoned without prior approval from the Water Quality Division. After the monitoring well(s)/piezometer(s) have fulfilled their purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. In addition, borings in public use areas, particularly paved streets and alleys, shall be abandoned in accordance with City and/or Highway Department requirements.
2. of 10 The applicant is responsible for obtaining any Permits required by the State Engineer's Office (777-7354).
3. of 10 The results of any other analyses conducted on soil or water removed from these wells/piezometers or boreholes shall be provided to the department as soon as they are available.
4. of 10 ***Environmental Monitoring Program for Groundwater of the State:***
  - a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity and performed in accordance with WDEQ or EPA approved Standard Procedures or Quality Assurance/Quality Control (QA/QC) Plan.
  - b. The permittee shall maintain records of all monitoring information for a period of at least 3 years.
  - c. Records of monitoring information shall include:
    - (1) The date, exact place, and time of sampling or measurements;
    - (2) The name(s) of individual(s) who performed the sampling or measurements;
    - (3) The Mean Sea Level elevation of the water table to the closest .01 ft., and the depth to water (to the closest .01 ft.) from a marked measuring point at the top of casing.
    - (4) Sampling procedures and sample preservation accomplished;

(Continued)

- (5) The date(s) analyses were performed;
  - (6) Names of individuals who performed the analyses;
  - (7) The analytical techniques or methods used; and
  - (8) The results of such analyses.
- d. WQD is requesting that Amoco monitor and sample the groundwater wells for the hydrocarbon constituents identified below. If Amoco proposes to pursue a 'natural attenuation approach' for the flange leak site, WQD recommends that the monitoring wells shall also be sampled for the biodegradation parameters provided in the table below:

WELL NAME OR NUMBER	SAMPLING FREQUENCY	ANALYTICAL METHOD(S)	PARAMETER(S) ANALYZED	PERMIT LIMIT*
Upgradient well, two new monitoring wells & W-10	Semi-annual  (corresponding to high and low water level conditions)	EPA-8015 Modified  EPA-610  EPA-8020	TPH(diesel range organics)  PAH's  BTEX	
Two Background wells  &  two new monitoring wells	Semi-annual	EPA-353.2  Field Measurement (O <sub>2</sub> probe)  EPA-300.0  Field Measurement  RSKSOP-175M  Field Measurement  EPA-200.7  EPA-310.1	<u>Biodegradation Parameters:</u> <i>(Highly Recommended)</i> Nitrates, NO <sub>3</sub> as N  Dissolved Oxygen, DO  Sulfates  Ferrous Iron  Methane  <i>(Recommended)</i> Oxidation-Reduction Potential  Manganese  Alkalinity (bicarbonate)	
All Site Wells	Semi-annual		Static Water Levels	

\* Permit Limits (i.e. Groundwater Protection Standards) are only required for compliance monitoring wells. All chemical concentrations in this permit are expressed in mg/l unless otherwise noted.

Amoco may request to utilize other EPA analytical methods. After the second monitoring event, Amoco may propose a shorter list for the sampling parameters, depending on the results of the second monitoring event.

- 5 of 10 The monitoring well/piezometer shall be developed by the use of a pump or bailer so that representative groundwater samples can be collected.
- 6.of 10 Water which is collected during monitoring well/piezometer development or sampling must be disposed of properly. The Applicant must contact the City (or applicable owner) for authorization prior to disposal into a local storm sewer, sanitary sewer, wastewater treatment plant, or other facility.
- 7.of 10 Well caps shall be kept locked at all times other than for monitoring purposes. Any tampering with the monitor well(s)/piezometer(s) shall be reported immediately to the Division. The wells shall be clearly numbered using either a stamp to permanently engrave the number into the steel top or by writing the number in the wet concrete of the base.
- 8.of 10 Prior to sampling, monitoring well(s)/piezometer(s) shall be purged until a minimum of three (3) casing volumes have been removed, or until purged dry, whichever occurs first.
- 9.of 10 Sample collection, preservation, transportation and laboratory analytical procedures shall be completed in accordance with WDEQ or EPA approved Standard Procedures or Quality Assurance/Quality Control (QA/QC) Plan.
10. of 10 Within 90 days following the 2nd semi-annual sampling event, Amoco shall submit a summary report. The report shall include site maps illustrating: potentiometric surfaces, iso-concentrations of TPH, dissolved contaminants, biodegradation parameters, etc.. The report can include a summary of the groundwater fate and transport modeling processes. The modeling results should be analyzed to evaluate whether a passive natural attenuation approach is applicable.

PBS:ks  
73712.ltr

cc: Craig Hoffmeister, Handex of Colorado

M:\DIVISION\WQD\IPS\MAIN\73712.LTR

## ROAD APPLICATION PERMIT

New  
Renewal  
Modified

PERMIT NO. 97-396  
SPECIAL CONDITIONS

### Hamilton Dome Unit

This permit hereby authorizes the applicant:

Merit Energy Company  
P.O. Box 73  
Hamilton Dome, WY 82427

to road apply crude oil sludge according to the procedures and conditions of application number 97-396. The application site is located in Sec. 18 and 19, T44N, R97W and Sec. 13 and 24, T44N, R98W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective until November 1998.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 8 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307) 332-3183.
- 2 of 8 The permittee will provide immediate oral and/or written notice to the Department of Environmental Quality/Water Quality Division, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
- 3 of 8 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the DEQ/WQD, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the attached Certification of Completion form, the following information:
  - A. Date that the road application was completed; and
  - B. Certification the road application was done in accordance with the terms and conditions of the permit; or
  - C. Certification the road application was completed with changes or modifications. Submit the information necessary to clearly indicate the road application as actually performed. This information shall include a contour map depicting only those sections of road that actually received the crude oil sludge.
- 4 of 8 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 8 The crude oil sludge shall be applied uniformly and incorporated into the roadbed. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. The crude oil sludge shall not be applied during the period from November 1 to April 10.
- 6 of 8 The application site slope shall not exceed eight percent (8%) for vehicular application.
- 7 of 8 The crude oil sludge application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.

PERMIT NO. 97-396

8 of 8 Only the roads designated in this permit are authorized for application of the crude oil sludge. Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3-20-98  
\_\_\_\_\_  
Date of Issuance

JCH/bl/ks  
^0997.ltr

## STATEMENT OF BASIS

### I. General information.

Permit Number: 97-396

### II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. No

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are not numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed modified or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement.

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Applicable

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the crude oil sludge onto the roadbed. Repeated applications of crude oil sludge on the same sections of road will be monitored by roadbed analyses that is required for future applications.

B. Quality of waste is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on March 18, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 97-397R  
SPECIAL CONDITIONS

### Cody Wastewater Treatment Facility Aeration System Modifications

This permit hereby authorizes the applicant:

City of Cody  
P.O. Drawer 2200  
Cody, WY 82414

to install six (6) - 30 horsepower aspirating floating aerators according to the procedures and conditions of application number 97-397. The facility is located in Tract 39 - Resurvey, T55N, R101W in the county of Park, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 5 The plant operation and maintenance manual must be modified to reflect the addition of the floating aerators. The draft must be submitted at the start of construction with approval received from the Water Quality Division before startup of the new aerators.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

11-25-97  
Date of Issuance

## STATEMENT OF BASIS

General information.

Permit Number: 97-397

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on November 17, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JCH/bb/73494.ltr

## PERMIT TO CONSTRUCT

△ New  
Renewal  
Modified

PERMIT NO. 97-398  
SPECIAL CONDITIONS

### John and Christina Stewart Septic System

This permit hereby authorizes the applicant:

John and Christina Stewart  
P.O. Box 1284  
Sundance, WY 82729

to construct, install or modify septic system according to the procedures and conditions of the application number 97-398. The facility is located in S/2 of the SE/4 of the NE/4, Section 23, Township 51 North, Range 62 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
Gary Beach  
Administrator  
Water Quality Division

  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-15-97  
Date of Issuance

BDM/pr/ks 73081.ltr

cc: Crook County Small Wastewater File

## STATEMENT OF BASIS

General information.

A. Permit Number: 97-398

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian Mark, Senior Analyst, and completed on October 9, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 97-399  
SPECIAL CONDITIONS

### City of Newcastle-Honor Camp Water Storage Tank

This permit hereby authorizes the applicant:

City of Newcastle  
10 West Warwick  
Newcastle, WY 82701

to construct, install or modify water storage tank, water main and pressure relief station according to the procedures and conditions of the application number 97-399. The facility is located in NW/4 of the NE/4, Section 16, Township 45 North, Range 61 West in the county of Weston, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-15-97  
Date of Issuance

BDM/pr/ks  
73114.ltr

cc: Lawrence Price, P.E., City of Newcastle

## STATEMENT OF BASIS

General information.

A. Permit Number: 97-399

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian Mark, Senior Analyst, and completed on October 10, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.



JIM GERINGER  
GOVERNOR

## Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

October 27, 1997

Western Winds, LLC  
c/o Jayo Construction, Inc.  
Attn. Richard Timm, Project Superintendent  
1309 S. Five Mile Road  
Boise, Idaho 83709

RE: Permit Reporting Requirements for Permit Number - 97-400

Dear Mr. Timm:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Estimated Construction Schedule Post Card (Condition 1)
2. Notify the WQD of any changes (Condition 2)
3. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 3)

Please read the permit conditions carefully and follow through as required. Finally, bear in mind that the submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit.

If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald  
Senior Analyst  
District, Water Quality Division

RLE/mad 73298.LTR

Enclosure: Permit Referenced Above  
cc: Peter J. Hutchison, Intermountain Professional Services, Inc., 5801

# PERMIT TO CONSTRUCT

New  
Renewal  
 Modified

PERMIT NO. 97-400  
SPECIAL CONDITIONS  
REF/PERMIT NO. 97-212

## Aspen Wind Assisted Living Center Modification

This permit hereby authorizes the applicant:

Western Winds, LLC  
c/o Jayo Construction, Inc.  
1309 S. Five Mile Road  
Boise, Idaho 83709

to construct, install, and modify water distribution utilities by increasing service line from 3 inch to 4 inch and by adding a fire hydrant according to the procedures and conditions of the application numbers 97-212 and 97-400. The facility is located in the NW 1/4 of Section 27, T14N, R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective until August 4, 1999.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781;  (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce

any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 4. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**

Permit Number 97-400

4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-30-97  
Date of Issuance

RLE/mad 73297.LTR

## STATEMENT OF BASIS

General information.

A. Permit Number: 97-400 Reference 97-212

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

- VI. Deleted

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 27, 1997. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.