



THE STATE OF WYOMING



**JIM GERINGER**  
GOVERNOR

## Department of Environmental Quality

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

February 26, 1998

W.F. Kearney  
Environmental Superintendent  
Power Resources, Inc.  
P.O. Box 1210  
Glenrock, WY 82637

RE: Power Resources Morton 1-20 Injection Well  
Permit Number: UIC 98-001  
Converse County, Wyoming


Dear Mr. Kearney:

Enclosed please find the final signed copy of the above referenced permit. The Public Notice period on this permit ended on February 23, 1998 with no adverse comments received. You are free to begin construction on the Volman 33-27 and the Vollman-1 wells at any time.

Also, enclosed please find one copy each of the reporting forms for these wells. There is one form for each well. Please use these new forms for all reports filed under this permit starting with the next quarterly report. It is not necessary to close out the reporting under the old permit, simply carry forward the volumes from the previous permit.

This department has received a copy of the certified return receipts for the mailing that Power Resources for owners of record listed in Appendix B of the Application to Modify. Those receipts will be sent to State Archives along with a copy of the application.

Sincerely,

  
Robert Lucht, P.E.  
UIC Program Supervisor  
Water Quality Division

RFL:ks 80699.ltr

encl: Signed Permit and Reporting Forms

DEPARTMENT OF ENVIRONMENTAL QUALITY  
STATE OF WYOMING  
UNDERGROUND INJECTION CONTROL PERMIT  
ISSUED UNDER CHAPTER 13  
WYOMING WATER QUALITY RULES AND REGULATIONS  
CLASS I INJECTION WELL

( ) New  
(XX) Modified

Permit Number UIC 98-001  
Reference old permits: 89-030, 88-017, and 86-128

In compliance with the Wyoming Environmental Quality Act (W.S. 35-11-101 through 1104, specifically 301(a)(i) through 301 (a) (iv), Laws 1973, Ch. 250, Section 1) and Water Quality Rules and Regulations Chapter 13 (1993),


Applicant: Power Resources, Inc.  
800 Werner Court, Suite 352  
Casper, WY 82601  
(307) 472-2035

is authorized to operate the Highland Uranium Project Underground Disposal Facility consisting of three injection wells as follows: The Morton 1-20 well located in the NW $\frac{1}{4}$ NW $\frac{1}{4}$ , Section 20, Township 36 North, Range 72 West; The Vollman 33-27 well located in NW $\frac{1}{4}$ SE $\frac{1}{4}$  Section 27, Township 36 North, Range 73 West; and the Vollman No. 1 well located in NW $\frac{1}{4}$ SW $\frac{1}{4}$  Section 22, Township 36 North, Range 73 West; all of the 6th Principal Meridian, Converse County; according to the procedures and conditions of application 98-001 and requirements and other conditions of this permit as found on pages 1 through 12.

This permit shall become effective on date of issuance.

  
\_\_\_\_\_  
Administrator  
Water Quality Division  
Herschler Building, 122 West 25th Street  
Cheyenne, WY 82002  
Phone: (307) 777-7781

Date 2/24/98

  
\_\_\_\_\_  
Director  
Department of Environmental Quality  
Herschler Building, 122 West 25th Street  
Cheyenne, WY 82002

Date 2-25-98

A. Discharge Zone

The Morton 1-20 injection well is authorized to inject into the Teapot and Parkman Formations which are found in the well bore of the Morton 1-20 from 8,629 to 9,000 and 9,015 to 9,141 feet below the ground surface respectively. The receiver in the Morton 1-20 is therefore the entire interval from 8,629 to 9,141 feet below ground surface. The Vollman 33-27 injection well is authorized to inject into the Teapot and Parkman Formations which are found in the well bore of the Vollman 33-27 from 8,778 to 9,200 and 9,200 to 9,758 feet below the ground surface respectively. The receiver in the Vollman 33-27 is therefore the entire interval from 8,778 to 9,758 feet below ground surface. The Vollman No. 1 injection well is authorized to inject into the Teapot and Parkman Formations which are found in the well bore of the Vollman No. 1 from 8,690 to 9,030 and 9,030 to 9,670 feet below the ground surface respectively. The receiver in the Vollman No. 1 is therefore the entire interval from 8,690 to 9,670 feet below ground surface. Additional perforations may be installed within the above named intervals with the prior approval of the Water Quality Division.

The packer set on the bottom of the tubing shall be set within 500 feet of the top of the authorized discharge zone but in no case shall the packer be set above the top of the cemented interval.

B. Area of Review

The wells authorized by this permit are located in:

- Township 36 North, Range 72 West, 6th Principal Meridian
  - Section 20: NW ¼ NW ¼
  - Latitude 43.08500° North, Longitude 105.53010° West
- Township 36 North, Range 73 West, 6th Principal Meridian
  - Section 27: NW ¼ SE ¼
  - Latitude 43.06120° North, Longitude 105.60200° West
- Township 36 North, Range 73 West, 6th Principal Meridian
  - Section 22: NW ¼ SW ¼
  - Latitude 43.07590° North, Longitude 105.61150° West

The Area of Review around these wells is legally described as:

- Township 36 North, Range 72 West, 6th Principal Meridian
  - Section 6: S ½ SW ¼
  - Section 7: W ½, SE ¼, W ½ NE ¼, SE ¼ NE ¼
  - Section 8: W ½ SW ¼, SE ¼ SW ¼
  - Section 17: W ½, W ½ SE ¼
  - Section 18: ALL
  - Section 19: ALL
  - Section 20: W ½, W ½ E ½
  - Section 29: W ½, W ½ NE ¼
  - Section 30: ALL
  - Section 31: N ½, SW ¼
  - Section 32: NW ¼ NW ¼
- Township 36 North, Range 73 West, 6th Principal Meridian
  - Section 1: S ½
  - Section 2: S ½
  - Section 3: S ½ SE ¼
  - Section 9: E ½ SE ¼
  - Section 10: E ½, SW ¼, E ½ NW ¼

Township 36 North, Range 73 West, 6th Principal Meridian (Con't)

- Section 11: ALL
- Section 12: ALL
- Section 13: ALL
- Section 14: ALL
- Section 15: ALL
- Section 16: E ½
- Section 21: E ½
- Section 22: ALL
- Section 23: ALL
- Section 24: ALL
- Section 25: ALL
- Section 26: ALL
- Section 27: ALL
- Section 28: NE ¼, E ½ SE ¼
- Section 34: N ½, N ½ SE ¼
- Section 35: ALL
- Section 36: ALL

C. Groundwater Classification

The groundwater in the Teapot and Parkman Formations is classified as Class VI under Chapter 8 of Wyoming Water Quality Rules and Regulations (April 9, 1980.) This classification was made because:

- a. The groundwater in the Teapot Formation contains between 16,322 and 19,954 mg/l of Total Dissolved Solids, and the groundwater in the Parkman Formation contains between 12,230 and 17,830 mg/l; and
- b. The groundwater in this formation is situated as such a depth that recovery of this water and treatment for drinking water purposes is not practical;

D. Authorized Operations

The permittee is authorized to inject 13,327 barrels per day, (559,735 gallons per day) of industrial processing wastes from the Highland Uranium Project as described:

DESCRIPTION OF PROCESSING WASTE:
Process area wash down water
Eluate solution as decanted from the uranium precipitation circuit
Wash waters decanted from yellowcake settling (thickening)
Sand filter backwash waters
Ion Exchange screening wash waters
Laboratory wastes from a laboratory located on the Highland Uranium Project.
Reverse Osmosis or Electrodialysis Brine Concentrate, Fluids from Groundwater Sweep, or Wellfield Production Bleed

No more than 5,000 barrels per day (210,000 gallons per day) shall be injected into any one well.

The permittee is authorized to inject at a pressure of no more than 2,000 psig as measured at the wellhead of any of the three wells. The pressure of injection shall be continuously monitored and recorded.

Power Resources conducted a step injection test to determine the actual fracture pressure of the formation. The permittee may conduct additional step injection tests at a later time to determine changes in the fracture pressure as the injection continues. After acceptance by the Administrator of these tests, the permittee shall limit the injection pressure to 90% of the new fracture pressure as measured on the surface.

The permittee shall monitor continuously the pressure on the casing/tubing annulus and shall maintain a positive pressure on that annulus. The pressure maintained shall be not less than 30 psig nor more than 600 psig as measured at the wellhead.

The wastes injected are from operations described by the following SIC codes: 03 and 109. The permittee is authorized to accept and dispose of fluids from other similar *in situ* leaching operations with prior WQD approval.

Produced water from oil and gas operations may be accepted for disposal with prior WQD approval. Fluids from other industrial operations may be accepted for disposal with prior WQD approval. Analyses will be required prior to injection of any waste not produced on the project covered by LQD Permit to Mine 603-A2. The exact parameters to be analyzed will be determined prior to accepting any such waste. The permittee shall contact WQD for guidance prior to ordering analyses. For any waste which is not exempt from RCRA regulation at the time of injection, the permittee shall provide at a minimum, tests for EP corrosivity, EP Toxicity using the Toxicity Characteristic Leaching Procedure (TCLP), EP Ignitability, and EP Reactivity. The Water Quality Division may waive in writing the requirement for individual tests based on the source and nature of the waste to be disposed of. Injection shall not commence until such time as an approval has been issued in writing by the Water Quality Division for that particular waste. The Water Quality Division may issue approvals under this permit for injection of industrial waste from a single source for up to three years from the date of the original analyses. Such approvals may require additional analyses during their term.

The composite injection stream may also contain a small amount of corrosion inhibitor such as an aqueous solution of alkaline amine phosphate ester and ethylene glycol. The composite injection stream may also contain a small amount of deposit control additives, scale inhibitors, and Biocides added to control scale and bacterial growth in the injection system.

#### E. Hazardous Waste

This permit does not allow for the injection of any hazardous waste as defined by 40 CFR 261. Injection of any substance defined as hazardous waste, whether hazardous by listing or by characteristic is a violation of this permit. The wastes to be injected from the Highland Uranium Project are exempt from RCRA regulation under the Beville Amendment to RCRA.

#### F. Proper Operation and Maintenance

The permittee shall take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with this permit.

The permittee shall operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of the permit. Proper operation and maintenance includes mechanical integrity of the well, effective performance, adequate funding and operator staffing and training, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of this permit.

The injection well covered by this permit shall meet all construction requirements outlined in Chapter 13, Section 11 of the Wyoming Water Quality Rules and Regulations.

The permittee is required to conduct the operation in accordance with statements, representations, and procedures presented in the complete permit application and supporting documents, as accepted and approved by the Administrator.

Any modifications which will result in a violation of permit conditions shall be reported by submission of a new or amended permit application and shall not be implemented until a new or modified permit has been issued.

Injection into a well may not commence until construction is complete.

#### G. Entry and Inspection

The permittee shall allow the Administrator, or an authorized representative for the Administrator, upon presentation of credentials and during normal working hours, to enter the premises where a regulated facility is located, or where records are kept under the conditions of this permit, and inspect the discharge and related facilities, review and copy reports and records required by this permit, collect fluid samples for analysis, measure and record water levels, and perform any other function authorized by law or regulation.

#### H. Environmental Monitoring Program for Groundwaters of the State

A monitoring program is required to establish baseline water quality of the receiving formation and to insure knowledge of migration and behavior of the discharge. The permittee is required to provide detailed information concerning the quality of the groundwater in the receiver of this injection well. At a minimum, the groundwater in the receiving formation in each well shall be sampled prior to the injection of any fluid under this permit. This sample shall be analyzed for the following parameters at a minimum:

PARAMETERS		
Calcium	Magnesium	Sodium
Sulfate	Chloride	Potassium
Carbonate and Bicarbonate	Total Dissolved Solids	pH
Conductivity	Specific Gravity	Viscosity

Because of the depth of injection and the amount of groundwater sampling already required in the general vicinity of this facility, no groundwater monitoring for the near surface groundwaters (USDW's) is required.

## I. Requirements for Monitoring the Discharge

The permittee shall monitor the injection pressure continuously and record those readings on a strip chart recorder, a circular chart recorder, or digitally by computer interface with the pressure transducer on the well or in the injection plant. A high pressure kill switch shall also be installed on the injection tubing. This device shall be set to preclude violations of the maximum injection pressure.

The permittee shall monitor the injection volume continuously and record those readings on a strip chart recorder, a circular chart recorder, or digitally by computer interface with the pressure transducer on the well or in the injection plant.

The permittee shall monitor continuously the pressure on the casing/tubing annulus and shall maintain a positive pressure on that annulus. The pressure maintained shall be not less than 30 psig nor more than 600 psig. The permittee shall record the annulus pressure continuously on a strip chart recorder, a circular chart recorder, or digitally by computer interface with the pressure transducer on the wellhead. A High/Low pressure kill switch shall also be installed on the casing/tubing annulus. This device shall be set to preclude violations of the permit for annulus pressure.

The permittee shall shut one of the wells covered by this permit in annually for a period of time long enough to observe a valid pressure falloff curve. Each year the well tested shall be a different well so that information is available for any one well every three years. This test shall be considered complete when the pressure curve becomes asymptotic to a straight line. This test shall be analyzed by the permittee using the either the Miller Dyes Hutchinson (MDH) method, the Horner Method, or an acceptable type curve matching method. In either case, graphs of this test shall be submitted to include either the MDH or Horner Plot and a Log-Log Plot after injection. From these plots, the Transmissivity in md-ft/cp, the permeability in md, and the dimensionless skin factor shall be calculated and submitted to WQD with the next quarterly report after the test is done.

The permittee shall monitor the quality of the injected water on an approved schedule. The following parameters shall be analyzed by the listed methods and reported quarterly:

SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT OR (UCL)*
Quarterly	EPA Method 160.1	Total Dissolved Solids	No Limit
	EPA Method 310.1	Total Alkalinity	No Limit
	EPA Method 350.3	Ammonia as N	No Limit
	EPA Method 908.1	Natural Uranium	65.0
	EPA Method 903.1	Radium 226	No Limit
	EPA Method 150.1	pH	> 2.0, < 11.0

\*All chemical parameters listed in this permit are expressed in mg/l unless otherwise shown. pH is always expressed in standard units, and Conductivity is always expressed in mmhos/meter or umhos/cm. The permittee shall use the above listed methods unless an alternate method is first approved by the WQD. The above analyses shall be done on samples which are composited from at least four samples taken over a period of at least two weeks.

The above Upper Control Limit (UCL) is not to be exceeded in any sample. Exceedance of this value is a violation of this permit and shall require notification under section K of this permit. Failure to perform and report analyses in accordance with the prescribed schedule and method is also a violation of this permit.

#### J. Test Procedures

All samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. All samples taken shall include a duplicate sample at least once per year.

All required analyses shall be conducted in compliance with Chapter 8 Section 7, Wyoming Water Quality Rules and Regulations.

#### K. Records and Reports

The permittee shall furnish to the Administrator, within a specified time, any information which the Administrator may request relating to the operation of the facility, including copies of records required to be kept by this permit.

The permittee shall retain copies of all records and reports required by this permit, for a period of three (3) years following permanent well abandonment. After that time, those same records shall be delivered to the Administrator for disposal or archive at his sole discretion.

Reports of compliance or noncompliance with, and any progress reports on, interim and final requirements contained in any compliance schedule shall be submitted no later than thirty (30) days following each schedule date.

Confirmed noncompliance resulting in the migration of injected fluid into any zone outside the permitted receiver shall be reported to the Administrator orally within twenty-four (24) hours, and a written submission shall be provided within five (5) days of the time the permittee becomes aware of the excursion. The written submission shall contain: a description of the noncompliance; the period of noncompliance, including exact dates and times, and if the noncompliance has not been controlled, the anticipated time it is expected to continue; and a list of the steps taken or planned to reduce, eliminate, and prevent the recurrence of the noncompliance.

Confirmed noncompliance not already reported under this section shall be reported at the time monitoring reports are submitted. The reports shall contain the same information as required by the paragraph above.

The permittee shall notify the administrator thirty (30) days in advance of any planned alteration, conversion, or abandonment of the well covered by this permit.

The quarterly report of operations for this well shall include the following information:

- a. The minimum, average, and maximum daily injection rate for each month of the quarter. The page showing the maximum injection rate shall also show the maximum permitted injection rate for comparison.
- b. The minimum, average, and maximum daily injection pressure for each month of the quarter. The page showing the maximum injection pressure shall also show the maximum permitted injection pressure for comparison.

- c. The total injection volume in gallons for each month of the quarter, the total for the quarter, the total cumulative injected to date.
- d. The maximum and minimum annulus pressure for each month of the quarter.
- e. Any permit exceedances within the quarter.
- f. Any tests run during the quarter. This includes, but is not limited to, the results on any Mechanical Integrity Tests, Pressure Falloff Tests, Step Injection Tests, or any well workovers.
- g. The analytical results for sampling for the injected water and any groundwater sampling results required under Section H.
- h. Quarterly reports are due in the Cheyenne office of the Water Quality Division no later than 30 days after the end of each calendar quarter.

The annual report of operations on these wells shall be filed at the time when the fourth quarterly report is due and shall include the fourth quarterly report and the following additional information:

- a. A graphical representation of the injection pressure and volume over time for the previous five year's operation. This graph shall have the dates of the year on the abscissa and the pressure and volume as the ordinate.
- b. Graphical representations of the quality of the injected water over time. These graphs shall show the injected quality for the previous five year's operation and shall be prepared on appropriate scales to show the variation.
- c. Monitoring results shall be reported in the annual reports unless otherwise specified.

#### L. Permit Actions

This permit is issued for a period of ten (10) years. If the permittee wishes to continue injection after the expiration date of this permit, he shall apply to the Administrator and obtain a new permit prior to the expiration date of this permit.

It shall not be a defense for a permittee in an enforcement action that it would be necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit.

The filing of a request by the permittee, or at the instigation of the Administrator, for permit modification, revocation, termination, or notification of planned changes, or anticipated noncompliance shall not stay any condition of this permit.

After notice and opportunity for a hearing, a permit may be modified, suspended, or revoked in whole or part during its term for cause which includes, but is not limited to, any of the following:

- 1. Violation of this permit;
- 2. Obtaining a permit by misrepresentation of facts in the application; or
- 3. Failure of the casing, cement or the confining layer.

This permit will be reviewed at least once every five (5) years, and may be reviewed more frequently. A permit may be modified at any time as may be required, including conformity with changes in regulations or standards which occur after the permit is issued. A permit may be modified in whole or part in order to apply more or less stringent standards, or prohibitions for toxic or other substance present in the permittee's discharge, as may be ordered by the council.

#### M. Mechanical Integrity

Mechanical Integrity shall be maintained continuously and reviewed at least once every five (5) years. The test used to determine mechanical integrity shall be a two part test approved by the Administrator. The last Mechanical Integrity Test for the Morton 1-20 was done on March 16, 1997. The next Mechanical Integrity Test on that well is due on or before March 16, 2002. The Vollman 33-27 and the Vollman No. 1 wells shall be tested for Mechanical Integrity prior to injection.

Part I of the Mechanical Integrity Test shall demonstrate the absence of leaks through the packer, tubing, casing, and wellhead. Prior to injection and at least once every five years, and more frequently if required by the Administrator, the casing tubing annulus of each of these wells shall be pressure tested to 2,000 psig. A successful test shall show that there has been negligible pressure loss after 15 minutes at 2,000 psig.

Part II of the Mechanical Integrity Test shall demonstrate the absence of fluid movement behind the casing. Prior to injection and at least once every five years, and more frequently if required by the Administrator, each of these wells shall be logged using a radioactive tracer log and both an injecting temperature log and a 24 hour shut in temperature log and the results and their interpretation shall be reported to the Water Quality Division along with the next quarterly report.

Other types of logs may be substituted for Part II of the Mechanical Integrity Test with the prior written approval of the Water Quality Division.

Prior to injection, and after all cementing operations are complete on each new well, a cement bond log shall be run. This log shall include a micro-seismogram section. This log shall be submitted to the Water Quality Division along with the first quarterly report on the injection. The cement bond log must show good quality bond to a point no deeper than 200 feet below the top of the Lewis Shale and extending downward to at least the bottom of the Lewis Shale.

Should any of the above tests show a lack of mechanical integrity, the Water Quality Division shall be notified by telephone within 24 hours and with a written report within 7 days. In the case of a failed Mechanical Integrity Test, the well shall be immediately shut-in. Injection shall not resume until the well has been repaired and a complete mechanical integrity test has been passed and the Water Quality Division has approved these tests.

If at any time injection occurs in any zone not within the permitted receiver, a permit violation has occurred. The operator shall prepare an estimate of the volume and quality of all wastewaters which were injected outside of the permitted receiver. In the case where any aquifer meeting the standards for class I through IV under Chapter 8 has been contaminated due to out of zone injection, the operator shall prepare and implement a plan to recover these solutions and inject them into the proper receiver.

## N. Abandonment

The permittee shall notify the administrator at such times as the permit requires before conversion or abandonment of the well.

Within thirty (30) days after plugging and abandonment of the well covered by this permit, the permittee shall submit a plugging and abandonment report, detailing the compliance abandonment procedures outlined in the original permit application, and describing any deviation from the original plan. The abandonment plan shall include reclamation of the well location.

At the time of permanent abandonment, the following procedure shall be followed: A minimum of 200 sacks of cement shall be squeezed through the perforations using a cement retainer set at the approximate depth of the production packer. The casing above the retainer shall then be filled with cement to a level 200 feet below the top of the Lewis Shale. A 50 sack plug shall be placed at the top of each of the following formations: Fox Hills, Lance, and Fort Union Formations. The entire surface casing shall then be filled with cement with a standard dry hole marker welded to a blind flange to be bolted to the exposed casing flange. Regardless of the above procedure, the abandonment procedure used shall not be less stringent than the procedure required by the Oil and Gas Conservation Commission for abandoned oil wells at the time of abandonment.

These wells shall be properly abandoned within six months of the end of the *in situ* leaching operation and final decommissioning of the uranium processing facilities. This well shall be considered temporarily abandoned any time there has been no injection for six full months. If this well is temporarily abandoned at any time, the operator may retain it in this status so long as all monitoring equipment is maintained in working order and all pumps are also maintained. During the period of temporary abandonment, all reports shall be filed as for an active well, but monitoring of the injected fluid is waived. Should the operator remove any of the required equipment from service, other than for maintenance, then the wells shall be permanently abandoned within six months of that time.

## O. Duties of the Permittee

The permittee shall give advance notice to the Administrator as soon as possible of any planned physical alteration or additions, other than authorized operation and maintenance, to the permitted facility and receive authorization prior to implementing the proposed alternation or addition.

The permittee shall furnish to the Administrator within a reasonable time, any information which the Administrator may request to determine whether cause exists for modifying, revoking, reissuing, or terminating this permit, or to determine compliance with this permit; and to furnish to the Administrator upon request, copies of records required to be kept by this permit.

Any modification which may result in a violation of a permit condition shall be reported to the Administrator, and any modification that will result in a violation of any permit conditions shall be reported to the administrator through the submission of a new or amended permit application.

The permittee shall report all instances where he becomes aware that he failed to submit any relevant facts in the permit application, or where he submitted incorrect information in a permit application or in any report to the Administrator, and shall promptly submit such facts or information.

Monitoring results shall be reported at the intervals specified elsewhere in this permit.

P. Financial Responsibility

The permittee has demonstrated financial responsibility as required by Chapter 13 of Wyoming Rules and Regulations in the form of an Irrevocable Letter of Credit Number 1269/S15728 drawn on the Royal Bank of Canada covering facilities included in Land Quality Division Permit to Mine 603-A2. 1269/S15728 includes funding to cover the cost of plugging, abandonment, and post closure care for these wells. The amount of this coverage is updated annually through the Land Quality Division in advance of the installation of any new system. The permittee shall maintain the above instrument or a replacement instrument for the duration of this permit and until all post-closure care requirements have been satisfied.

Q. Special Conditions

In addition to the conditions required of all permits, the Administrator has established conditions as required for monitoring, schedules of compliance, and such additional conditions as are necessary to prevent the migration of fluids into underground sources of drinking water. These conditions are established in conformance with Chapter 13, Section 9(e).

The permittee shall modify the procedure found in Appendix I of the permit amendment application prior to the installation of the well to obtain a good quality cement job from no deeper than 200 feet below the top of the Lewis Shale down to the base of the Lewis Shale.

R. Signatories Requirement

All reports filed in conjunction with this permit shall contain the following certification:

"I certify, under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

All reports required by this permit and other requested information shall be signed as follows:

For a corporation -- by a principal executive officer of at least the level of vice-president;

For a partnership or sole proprietorship -- by a general partner or the proprietor, respectively;

For a municipality, state, federal, or other public agency -- by either a principal executive officer or ranking elected official;

or

By a duly authorized representative for any of the above. A person is a duly authorized representative only if:

1. The authorization is made in writing by one of the described principals;

2. The authorization specifies either an individual or position having responsibility for the overall operation of the regulated facility or activity; and
3. The written authorization is submitted to the Administrator.

If an authorization is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to the Administrator prior to or together with any reports or information, to be signed by the new authorized representative.

#### S. Noncompliance

The permittee shall comply with all conditions of this permit. Any permit noncompliance constitutes a violation of Chapter 13 of the Wyoming Water Quality Rules and Regulations and is grounds for enforcement action, permit termination, revocation, or modification. Conformed noncompliance resulting in an excursion shall be reported to the Administrator orally within twenty-four (24) hours, and a written submission shall be provided within five (5) days of the time the permittee becomes aware of the excursion. The written report shall contain the sections specified in Section K of this permit. Any permit non-compliance constitutes a violation of this permit.

The filing of any request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

#### T. Permit Transfer

Any transfer of this permit shall be accomplished by the submission of the proper forms for permit transfer to the Administrator. Transfer of this permit must first be approved by the Administrator, and the Director, and no transfer shall be approved unless the proposed permittee agrees to bring any and all non compliance issues into compliance with this permit.

The permittee is alone responsible for the operation of the facility covered by this permit. Sale of the facility and subsequent operation of this facility by another is a violation of this permit unless a transfer of this permit has first been accomplished.

#### U. Property Rights

This permit does not convey any property rights of any sort, or any exclusive privilege. This permit does not authorize injury to private property or any invasion of personal rights, nor any infringement of federal, state or local laws, or regulations.

#### V. Severability

Nothing in this permit shall be construed to preclude the institution of any legal action or to relieve the permittee from any responsibilities, liabilities or penalties established pursuant to any applicable state law or regulation.

The provisions of this permit are severable, and if any provision of the permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 98-002RR  
SPECIAL CONDITIONS

Basin Area Water Supply Project - Phase III

This permit hereby authorizes the applicant:

South Big Horn County Water Supply, Joint Powers Board  
P.O. Box 599  
Basin, WY 82410

to construct rural pipelines ranging from 2-inch to 8-inch diameter according to the procedures and conditions of application number 98-002RR. The facility is located in T50,51,52N, R92, 93W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of three (3) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

1-7-99  
\_\_\_\_\_  
Date of Issuance

JH/mad 90063.LTR

STATEMENT OF BASIS

General information.

Permit Number: 98-002RR

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on December 17, 1998 . Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-003  
SPECIAL CONDITIONS

### Dean Flahaven Septic System

This permit hereby authorizes the applicant:

Dean Flahaven  
5403 Raven Street  
Gillette, WY 82718

to construct, install or modify septic system according to the procedures and conditions of the application number 98-003. The facility is located in NE/4, Section 5, Township 50 North, Range 66 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

1-27-98  
\_\_\_\_\_  
Date of Issuance

BDM/pr:01/20/98  
b/80257.ltr

cc: Crook County Small Wastewater File 98-003  
Gene Cox, Cox Construction, Box 609, Moorcroft, WY 82721

## STATEMENT OF BASIS

General information.

A. Permit Number: 98-003

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian Mark, Senior Analyst, and completed on January 20, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

BDM/bb/80257.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-004  
SPECIAL CONDITIONS

### Marathon Storage Building Fire Line - Cody

This permit hereby authorizes the applicant:

Marathon Oil Company  
1501 Stampede Ave.  
Cody, WY 82414

to construct a 4-inch water main about 127 feet long with a double check valve back flow device according to the procedures and conditions of application number 98-004. The facility is located in SW1/4 SE1/4 Sec.32 (Tract 79 of Resurvey) T53N, R101W in the county of Park, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

1-23-98  
\_\_\_\_\_  
Date of Issuance

JH/bal/ks 80179.ltr

## STATEMENT OF BASIS

General information.

Permit Number: 98-004

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on January 15, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-006  
SPECIAL CONDITIONS

## Cheyenne BOPU 1998 Sewer Rehabilitation Project - Lions Park

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities  
Attn. Herman Noe  
P.O. Box 1469  
Cheyenne, Wyoming 82003-1469

to construct, install, or modify sewer utility mains by either replacement or relining according to the procedures and conditions of the application number 98-006. The facility is located in the NE 1/4 of Section 25, T14N, R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; AX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 7. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 7. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 7. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. All **modifications or deviations** from the authorized plans **must be highlighted**.
- 4 of 7. Variance from Minimum Slope Requirements Granted - A variance from the minimum sewer pipe slope requirements of Chapter 11, Section 9(c)(i)(C) is hereby granted in accordance with SPO Policy 13.9.13, with the following conditions:
  - a. The new or replacement gravity sewer main segments must be constructed using either ASTM D3034 SDR 35 PVC pipe or ASTM D 3035 Polyethylene pipe.
  - b. The pipe must be installed using a sewer laser to ensure an accurate and uniform grade.
  - c. The pipe must be bedded with Type 1 bedding material using Type A Trench Backfill methods or cement treated fill in accordance with the Wyoming Public Works Standard Specifications, Section 02225.

d. All flat grade sewers shall be installed under the supervision of a full time inspector.

- 5 of 7. Variance from Minimum Sewer Size for "Insituform" Lined Sewer Granted - A variance from the minimum sewer size requirements of Chapter 11, Section 9(c)(i)(B) is hereby granted, because the relined sewer segments will have better performance even though the diameter has been slightly reduced.
- 6 of 7. Disposal of Trench Dewatering Water Shall be in Accordance with National Pollution Discharge Elimination System(NPDES) Requirements - If dewatering is necessary a **Temporary Discharge Permit** may be required. If the water is to be discharged into the sanitary sewer a permit will not be necessary. However, if the water is to be discharged onto the ground surface or the storm water runoff system, then a permit from this office will be required. To satisfy this requirement contact the Water Quality Division NPDES Section, either Todd Parfitt at 777-7082 or Leah Krafft at 777-7093, for the proper forms and application procedures.
- 7 of 7. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

2/26/98  
\_\_\_\_\_  
Date of Issuance

## STATEMENT OF BASIS

### I. General information.

A. Permit Number: 98-006

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

Yes

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Variance 1 - Chapter 11, Section 9(c)(i)(B) - Minimum size requirements for gravity sewers.

Variance 2 - Chapter 11, Section 9(c)(i)(C) - Minimum slope requirements for gravity sewers.

B. Briefly state the basis for the deviation.

Basis 1: This variance is to allow segments of six(6) inch diameter sewer pipe to be relined with "Insituform" cured in place lining. The basis is that even though the diameter will be slightly reduced the pipe will have better performance then before. Also, the hydraulic loads on this sewer line are limited as it only serves three(3) restrooms and a maintenance shop in a public park. Total average loads are estimated to be 1800 gallons per day with no additional loading sources. Finally, the WQD has previously approved "Insituform" for relining water mains, therefore it should be ok for sewer mains.

- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Basis 2: Approved Policy 13.9.13 for Flat Grade Sewers - This policy allows for the replacement of existing sewer lines already installed at less than minimum slopes to avoid the need for lift stations. The basis is that today's materials have better performance than the old sewer pipe materials and can therefore be laid at less slope without problems.

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

- VI. Deleted

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on February 25, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-007  
SPECIAL CONDITIONS

### Pine Haven Whispering Pines Waterline

This permit hereby authorizes the applicant:

John Betts  
17 Rose Lane  
Pine Haven, WY 82721

to construct, install or modify a waterline extension according to the procedures and conditions of the application number 98-007. The facility is located in Section 5, Township 50 North, Range 66 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

2-2-98  
\_\_\_\_\_  
Date of Issuance

BDM/pr:01/27/98  
b/80303.ltr

cc: Bret Wolz, P.E., Falcon Consulting Services, P.O. Box 3943, Gillette, WY 82717  
Mayor Velma Brandenburg, Town of Pine Haven, 24 Waters Dr., Pine Haven, WY 82721-9761

## STATEMENT OF BASIS

General information.

A. Permit Number: 98-007

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian Mark, Senior Analyst, and completed on January 27, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

BDM/bb/80303.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-008  
SPECIAL CONDITIONS

### Adams Septic Tank/Leach Field

This permit hereby authorizes the applicant:

Clair and Anita Adams  
533 Mountain View Road  
Thermopolis, WY 82443

to construct a septic tank/leach field to serve a four bedroom residence according to the procedures and conditions of application number 98-008. The facility is located in SE 1/4 Sec.24, T42N, R95W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements,


representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

1-22-98  
Date of Issuance

JH/bal  
b/80203.ltr

STATEMENT OF BASIS

I. General information.

Permit Number: 98-008

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on January 16, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JCH/bb/80203.ltr

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-009  
SPECIAL CONDITIONS

### Miller Septic Tank / Leach Field

This permit hereby authorizes the applicant:

Fred and Linda Jo Miller  
P.O. Box 174  
Cowley, WY 82420

to construct a septic tank/ contour trench leach field according to the procedures and conditions of application number 98-009. The facility is located in E1/2 NE1/4 Sec.19, T57N, R96W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3-12-98  
\_\_\_\_\_  
Date of Issuance

JCH/bal/ks  
80913.ltr

## STATEMENT OF BASIS

### I. General information.

Permit Number: 98-009

### II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. N/A

### V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on March 11, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-010  
SPECIAL CONDITIONS

## Overland Trails, Fifth Filing - Sanitary Sewer Improvements

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities  
Attn. Herman Noe, Manager Engineer  
P.O. Box 1469  
Cheyenne, Wyoming 82003

to construct and install sanitary sewer utility improvements according to the procedures and conditions of the application number 98-010. The facility is located in the NE 1/4 of Section 14, T13N, R67W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 4. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. All **modifications or deviations** from the authorized plans **must be highlighted**.

PERMIT NO. 98-010

of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3-2-98  
\_\_\_\_\_  
Date of Issuance

PLE:ks  
704.ltr

## STATEMENT OF BASIS

### I. General information.

A. Permit Number: 98-010

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

- VI. Deleted

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on February 26, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 98-011  
SPECIAL CONDITIONS

### UPR Patrick Draw Gas Plant

This permit hereby authorizes the applicant:

Union Pacific Resources  
P.O. Box 7, MS 2807  
Fort Worth, TX 76101-0007

to construct, install or modify a series of groundwater monitoring wells according to the procedures and conditions of the application number 98-011. The facility is located in SE, Section 25, T19N, R99W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: WDEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; telephone (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any violation of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. of 5 No monitoring well/piezometer shall be abandoned without prior approval from the Water Quality Division. After the monitoring well(s)/piezometer(s) have fulfilled their purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. In addition, borings in public use areas, particularly paved streets and alleys, shall be abandoned in accordance with City and/or Highway Department requirements.
2. of 5 WDEQ/WQD personnel shall be given at least two (2) weeks notice prior to the installation of monitor well(s)/piezometer(s) and sample collection so that they may be on site if deemed necessary.
3. of 5 The applicant is responsible for obtaining any Permits required by the State Engineer's Office (777-7354).
4. of 5 The results of any other analyses conducted on soil or water removed from these wells/piezometers or boreholes shall be provided to the department as soon as they are available.
5. of 5 ***Environmental Monitoring Program for Groundwater of the State:***
  - a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity and performed in accordance with WDEQ or EPA approved Standard Procedures or Quality Assurance/Quality Control (QA/QC) Plan.
  - b. The permittee shall maintain records of all monitoring information for a period of at least 3 years.
  - c. Records of monitoring information shall include:
    - i. The date, exact place, and time of sampling or measurements;
    - ii. The name(s) of individual(s) who performed the sampling or measurements;
    - iii. The Mean Sea Level elevation of the water table to the closest .01 ft., and the depth to water (to the closest .01 ft.) from a marked measuring point at the top of casing.
    - iv. Sampling procedures and sample preservation accomplished;
    - v. The date(s) analyses were performed;
    - vi. Names of individuals who performed the analyses;
    - vii. The analytical techniques or methods used; and
    - viii. The results of such analyses.
    - ix. Monitor wells shall be sampled and the groundwater analyzed as indicated on the following table:

PERMIT NO. 98-011

WELL NAME OR NUMBER	SAMPLING FREQUENCY	ANALYTICAL METHOD(S)	PARAMETER(S) ANALYZED	PERMIT LIMIT *
All wells	Quarterly	EPA 8020	BETX	-----
All wells	Quarterly	EPA 8015M	TPH-GRO	-----
All wells	Quarterly	EPA 8015M	TPH-DRO	-----

\* Permit Limits (i.e. Groundwater Protection Standards) are only required for compliance monitoring wells. All chemical concentrations in this permit are expressed in mg/l unless otherwise noted.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

1-27-98  
\_\_\_\_\_  
Date of Issuance

KLE:ks  
80243.ltr

cc: IPS, Lander

**GROUNDWATER POLLUTION CONTROL PROGRAM**  
**REVIEW COMMENTS:**  
**PLANS/SPECIFICATIONS/PROPOSALS/REPORTS**

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
250 Lincoln Street  
Lander, Wyoming 82520  
(307)332-3144

**PROJECT:** COMBINATION (SITE CHARACTERIZATION & REMEDIATION)

**APPLICANT:** John Rector  
Union Pacific Resources  
801 Cherry Street  
Fort Worth, TX 76102-6803

**ENGINEER/  
CONSULTANT:** Ed Ullmer  
Laidlaw Environmental Services  
5665 Flatiron Parkway  
Boulder, CO 80301

**WATER QUALITY DIVISION REFERENCE (PERMIT) NUMBER:** 98-011

EXISTING       NEW       AS BUILT

**TITLE:** UPR Patrick Draw Monitoring Well Installation  
 PLANS       SPECS       PROPOSAL       REPORT  
[Check all that APPLY]

**DATE ON PROPOSAL/PLANS/REPORT:** January 20, 1998

**IS THIS PROPOSAL SUBMITTED PURSUANT TO:**

'CONDITIONS' TO ANY WQD PERMIT?  NO       YES

AN LOV, NOV OR OTHER ENFORCEMENT?  NO       YES [DATE]

**REVIEWING ENGINEER:** \_\_\_\_\_  
Keith L. Estenson

**DATE OF THIS REVIEW:** January 21, 1998

**ACTION:** APPROVED with conditions

## **COMMENTS: GROUNDWATER SECTION**

### **1.0 SUMMARY OF EXISTING CONTAMINATION:**

**1.1 Historical.** On August 9, 1991, DEQ/WQD was notified by Union Pacific Resources Company (UPRC) of a subsurface release of natural gas liquids at the Patrick Draw Gas Plant. The release was discovered when free product was found in an existing monitor well at the plant's landfill. The spill originated from improperly installed valves in the condensate skimmer system, inadvertently injecting product to the subsurface during the period of 1973 through April 1991. The valves were replaced in May 1991. An estimated minimum of 1.26 million gallons of condensate was released.

**1.2 Current.** Three individual hydrostratigraphic units are monitored, and referred to as the "H", "J", and "L" aquifers (telephone conversation of 1/9/98 with John Rector indicates that the data collected for the 1997 annual report may reveal a fourth aquifer unit). Depth to water varies from 18 to 45 feet from surface. Skimming has decreased product thickness, although product still exists.

### **2.0 CONCLUSION OF ADEQUACY OF WORK COMPLETED TO DATE:**

**2.1 Historical.** WDEQ/WQD Permit to Construct #91-319 was issued for a subsurface investigation. Between October 1991 and June 1992, thirty one monitor wells were placed.

In December 1993, Permit to Construct #93-445 was issued to install additional monitor wells and soil borings to further delineate the subsurface contamination. Also, in December 1993, Permit to Construct #93-453 was issued for the construction of the initial phase of a free product recovery system.

In the April 1997 GPC review of the annual monitoring report, it was recommended to reduce the frequency of gauging, sampling, and reporting to an annual basis due to the sufficient accumulation of historical data, and minimal seasonal fluctuation in groundwater elevation. Since benzene concentrations have been elevated in the third and fourth quarters, annual gauging and sampling activities are to be conducted early in the fourth quarter. Hydrocarbon recovery data will be evaluated quarterly to determine the effectiveness of the recovery systems.

**2.2 Hydrocarbon Recovery.** Hydrocarbon recovery was initiated in 1994 using pneumatically operated skimmer pumps. Six wells are utilized for product recovery. The total amount of hydrocarbons recovered from the skimming systems as of December 1996 was 3,232 gallons. Bail down tests were performed on two additional wells demonstrating that recovery systems on these two wells are not feasible.

**2.3 Installation of Proposed Monitoring Wells.** The 1996 annual report, submitted February 1997, proposed to conduct a groundwater investigation concurrent with the 1997 plant expansion activities to address the relocation of monitor wells (numerous monitoring wells were abandoned during the plant expansion). WDEQ requested that the investigation include further delineation of the southeastern limits of the "J" plume.

GROUNDWATER POLLUTION CONTROL PROGRAM  
REVIEW COMMENTS: 98-011  
PLANS/SPECIFICATIONS/PROPOSALS/REPORTS

As of this review, the plant expansion is nearing completion. To expedite the permitting process, John Rector (UPR) agreed in writing to a list of conditions (noted in my 1/9/98 letter to Mr. Rector as Attachment II - "Potential Conditions").

**3.0 REQUESTS/REQUIREMENTS/RECOMMENDATIONS:**

The permit for the construction of monitoring wells will be issued with a list of standard conditions. Quarterly sampling of the new monitoring wells will be required for the first year.

**END OF REVIEW**

XC: Keith Estenson (File: UPRC, Patrick Draw Gas Plant, Sweetwater; 1998 West District Review Forms; 1998 Southwest District Running Record; Chronological)  
Application for Permit to Construct (3)  
Kevin Frederick, Supervisor, GPC Program, WQD/Cheyenne

KLE:ks  
80242.ltr

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-012  
SPECIAL CONDITIONS

### WOOTEN LODGE SEPTIC SYSTEM

This permit hereby authorizes the applicant:

Beverly Wooten  
170 River Road  
Alva, WY 82711

to construct, install or modify a septic system according to the procedures and conditions of the application numbers 98-012. The facility is located in the NW/4 of the SW/4 of Section 4 of T54N R64W in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (DEQ/WQD), upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ/WQD the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, DEQ/WQD, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any violation of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Administrator  
Water Quality Division

1-27-98  
\_\_\_\_\_  
Date of Issuance

  
\_\_\_\_\_  
Director  
Department of Environmental Quality

DRM/pr/ks 80241.ltr

Enclosures: Notification Post Card  
Certificate of Completion  
Statement of Basis

## STATEMENT OF BASIS

### General information.

A. Permit Number: 98-012

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of Section VI. from the Statement of Basis.)

N/A

VI. N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Donald R. McKenzie, Northeast District DEQ/WQD-SPO Program Principal, and completed on January 20, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-013  
SPECIAL CONDITIONS

### City of Casper East Second Street Water and Sewer Replacements W.O. #97-68

This permit hereby authorizes the applicant:

City of Casper  
ATTN: Hal Hutchinson, P.E.  
200 North David  
Casper, WY 82601

to construct, install or modify a sewage collection system and a water distribution system according to the procedures and conditions of the application number 98-013. The facility is located in Sections 9 and 10, Township 33 North, Range 79 West in the county of Natrona, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

2-12-98  
\_\_\_\_\_  
Date of Issuance

BDM/pr:02/10/98  
b/80464.LTR

cc: Robert Bennett, P.E., CEPI, 355 North Lincoln, Casper, WY 82601  
Mike Jennings, Natrona County Health, 1200 E. 3rd, Casper WY 82601  
Tom Curren, Natrona County Planning, 120 W. 1st, #200, Casper, WY 82601

## STATEMENT OF BASIS

### General information.

A. Permit Number: 98-013

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian Mark, Senior Analyst, and completed on February 10, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

BDM/bb/80464.LTR

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-014  
SPECIAL CONDITIONS  
REF/PERMIT #

## Town of Sundance Booster Pump and PRV Installation 1998

This permit hereby authorizes the applicant:

Town of Sundance  
ATTN: Mayor James Miller  
P.O. Box 542  
Sundance, WY 82729

to construct, install or modify a potable water booster pump station and pressure reducing vault according to the procedures and conditions of the application number 98-014. The facility is located in SE/4 Section 14, and the NE/4 Section 23, Township 51 North, Range 63 West in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 5 An operation and maintenance manual will be provided to the Northeast District Office for approval prior to facility startup per the terms of Wyoming Water Quality Rules and Regulations Chapter 12 Section 16.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

2-12-98  
Date of Issuance

BDM/pr:02/09/98

b/80461.LTR

cc: Ralph Goodson, P.E., Bearlodge LTD, Inc., P.O. Box 130, Sundance, WY 82729

## STATEMENT OF BASIS

### General information.

A. Permit Number: 98-014

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian Mark, Senior Analyst, and completed on February 9, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

BDM/bb/80461.LTR

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 98-015  
SPECIAL CONDITIONS

### SUNDANCE LANDFILL FIRE HYDRANT

This permit hereby authorizes the applicant:

Town of Sundance  
P.O. Box 542  
Sundance, WY 82729

to construct, install or modify a water system according to the procedures and conditions of the application numbers 98-015. The facility is located in the NE/4 of Section 18 of T51N R62W in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

1-27-98  
\_\_\_\_\_  
Date of Issuance

DRM/pr:01/22/98

b/80252.ltr

xc: Ken Rathbun, Bearlodge Ltd., P.O. Box 130, Sundance, 82729

## STATEMENT OF BASIS

### I. General information.

A. Permit Number: 98-015

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11        No

B. Chapter 12        Yes

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

1.) Section 14(b)(ii) of Chapter 12 of the WWQRR allows a maximum run of six (6) inch waterline from one direction to be 250 feet when it serves a fire hydrant.

2.) Section 14(c) of Chapter 12 of the WWQRR requires valving on watermains at intervals of 800 feet.

B. Briefly state the basis for the deviation.

1.) The intent of this requirement is to ensure adequate line pressure. Hydraulic analysis indicates the required minimum residual pressure will be met for the desired fire flow at the landfill facility.

2.) The proposed waterline extension will only serve the landfill facility and the valve to be installed at the tie-in point is adequate for isolation.

- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable (N/A)

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

- B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Don McKenzie, SPO Northeast District Program Principal, and completed on January 22, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-016  
SPECIAL CONDITIONS  
REF/PERMIT# 92-339R

### The Line Shack

This permit hereby authorizes the applicant:

Merle Long  
P.O. Box 9917  
Helen, GA 30545

to construct two on-site sewage disposal systems with four septic tanks and 1182 feet of Infiltrator leach chambers according to the procedures and conditions of application number 98-016R. The facility is located in SW1/4 Sec.27, T42N, R108W in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of three (3) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

4-3-98  
\_\_\_\_\_  
Date of Issuance

## STATEMENT OF BASIS

General information.

Permit Number: 98-016

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on March 31, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 98-017  
SPECIAL CONDITIONS

### Wyoming Premium Farms, LLC - Finisher Unit #1: Office Septic System

This permit hereby authorizes the applicant:

Wyoming Premium Farms, LLC  
Doug DeRouchey - Manager  
P.O. Box 457  
Wheatland, Wyoming 82201-0457

to construct and install a business septic system with leach field for domestic waste according to the procedures and conditions of the application number 98-017. The facility is located in the SE 1/4 of Section 31, T26N, R67W in the county of Platte, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce

any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations** from the authorized plans **must be highlighted**.
- 4 of 5. Fill Soil Compaction and Verification Requirement - The fill soil beneath the rock and distribution piping shall be compacted to greater than five(5) minutes per inch **before** the rock and pipe is placed. This **shall be verified** by percolation tests after the fill soil has been placed and compacted. If the fill soil compaction is less than 5 minutes per inch it shall be reworked and retested before proceeding.

Permit Number 98-017

5 of 5. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

2-2-98  
\_\_\_\_\_  
Date of Issuance

LE/mad 80342.LTR

## STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 98-017
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.  
Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.  
No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.  
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.  
NOT Applicable
- B. Briefly state the basis for the deviation.  
NOT Applicable
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).  
NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

- VI. Deleted

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on January 30, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

# PERMIT TO CONSTRUCT

☑ New  
Renewal  
Modified

PERMIT NO. 98-018  
SPECIAL CONDITIONS

## Wyoming Premium Farms, LLC - Finisher Unit #2: Office Septic System

This permit hereby authorizes the applicant:

Wyoming Premium Farms, LLC  
Doug DeRouchey - Manager  
P.O. Box 457  
Wheatland, Wyoming 82201-0457

to construct and install a business septic system with leach field for domestic waste according to the procedures and conditions of the application number 98-018. The facility is located in the SE 1/4 of Section 36, T25N, R67W in the county of Platte, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 5. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. All **modifications or deviations** from the authorized plans **must be highlighted**.
- 4 of 5. Fill Soil Compaction and Verification Requirement - The fill soil beneath the rock and distribution piping shall be compacted to greater than five(5) minutes per inch **before** the rock and pipe is placed. This **shall be verified** by percolation tests after the fill soil has been placed and compacted. If the fill soil compaction is less than 5 minutes per inch it shall be reworked and retested before proceeding.

Permit Number 98-018

of 5. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

2-2-98  
\_\_\_\_\_  
Date of Issuance

RLE/mad 80351.LTR

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 98-018

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

- VI. Deleted

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on January 30, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 98-020  
SPECIAL CONDITIONS

### Cemetery Road Water and Sewer - Powell

This permit hereby authorizes the applicant:

City of Powell  
P.O. Box 1008  
Powell, WY 82435

to construct a sewer collector and 12-inch ductile iron water main according to the procedures and conditions of application number 98-020. The facility is located in Lot 62-A; Tract 2, Lot 74, T55N, R99W Resurvey in the county of Park, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any violation of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

2-6-98  
\_\_\_\_\_  
Date of Issuance

## STATEMENT OF BASIS

### I General information.

Permit Number: #98-020

### II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. Yes

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. N/A

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

B. Briefly state the basis for the deviation.

C. Permit based on general or statewide deviation contained in approved policy statement

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.
- N/A
- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)
- A. Facility will not allow a discharge to groundwater. Briefly describe:
- B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:
- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:
- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:
- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:
- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.
- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on January 30, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

→ New  
Renewal  
Modified

PERMIT NO. 98-021  
SPECIAL CONDITIONS

## Saratoga Inn Overlook Subdivision Water Main Extension and Testing

This permit hereby authorizes the applicant:

Saratoga Inn Corporation  
Zoe A. Larson, Owner  
P.O. Box 869  
Saratoga, Wyoming 82331

to construct, install, and modify water main utilities according to the procedures and conditions of the application number 98-021. The facility is located in the SW 1/4 of Section 12, T17N, R84W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 6. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 6. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 6. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**
- 4 of 6. **Backflow Prevention** - Backflow prevention is not specifically discussed. Therefore, all the residential or domestic nature service taps connected to **new water mains** shall be protected by at least a **check valve** in accordance with the DEQ/WQD Rules and Regulations Chapter XII Section 14(I)(A). Those taps providing other than residential or "domestic nature only" commercial service must have backflow prevention as recommended by AWWA Standard M14.

- 5 of 6. Disposal of Trench Dewatering Water Shall be in Accordance with National Pollution Discharge Elimination System(NPDES) Requirements - If dewatering is necessary a **Temporary Discharge Permit** may be required depending on how the water is to be disposed. If the water is to be discharged into a sanitary sewer system, a permit will not be necessary. Permission from the municipality, sewer district, or homeowners association should be obtained before proceeding. However, if the water is to be discharged onto the ground surface or into a storm sewer runoff system, then a permit from this office will be required. To satisfy this requirement contact the Water Quality Division NPDES Section, either Todd Parfitt at 777-7082 or Leah Krafft at 777-7093, for the proper forms and application procedures.
- 6 of 6. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3-2-98  
\_\_\_\_\_  
Date of Issuance

## STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 98-021
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. No
- B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- NOT Applicable
- B. Briefly state the basis for the deviation.
- NOT Applicable
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on February 26, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-022  
SPECIAL CONDITIONS  
REF/PERMIT NO. 78-177MR, 79-334

## Wyoming High Security/Special Needs Facility

This permit hereby authorizes the applicant:

Wyoming Department of Corrections and the Wyoming State Prison Project  
801 West 20th Street  
Cheyenne, WY, 82002

to construct, install or modify water distribution and sanitary sewer lines for new State Penitentiary and Administration/Warehouse Complex according to the procedures and conditions of the application number 98-022. The facility is located in Sections 27 & 28 T21N R87W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of five years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 7 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 7 The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 7 The water supply to the High Security/Special Needs Facility and the existing prison must be reliable. This shall be accomplished by looping the supply line from the Rawlins Water Storage Tank Farm to the prison. This looping shall be designed to be completely redundant so that the failure of any single component shall not cause extended interruption of the water supply to the prison. The supply line shall be fully looped to the prison before the high security/special needs facility is placed in service.
- 4 of 7 Revision drawings C7.18 to C7.21, as approved, replace Drawing C7.1 and designated details of drawings C7.11 to C7.14.
- 5 of 7 Backflow prevention shall be installed at all service taps, fire lines, and other locations in accordance with Chapter XII, Section 14 (I) and AWWA M14, Recommended Practice for Backflow Prevention and Cross-Connection Control.
- 6 of 7 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 7 of 7 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Gary Beach  
Administrator  
Water Quality Division



Dennis Hemmer  
Director  
Department of Environmental Quality

6-8-98  
Date of Issuance

LBH:ks 81679.ltr

cc: Paul Musselman, City of Rawlins

## STATEMENT OF BASIS

### General information.

A. Permit Number: 98-022

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

N/A

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

The supply line to the prison from the City of Rawlins is not looped nor is there potable water storage on site. Consequently the water supply to the prison cannot be considered reliable due to the lack of redundancy. Because the population served is in confinement, the lack of a reliable, redundant water supply represents a significant threat to public health and safety.

B. Briefly state the basis for the deviation.

Permit condition No. 3 requires that the supply line be fully looped to the prison before the high security/special needs facility is placed in service. The Department of Administration and Information, the Department of Environmental Quality and the Governor's office have agreed on the necessity to seek funding to complete the looped water line before the high security/special needs facility is placed in service.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NO

- VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on June 5, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

REVIEW OF PLANS AND SPECIFICATIONS  
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION

Herschler Bldg., 4 West  
Cheyenne, Wyoming 82002

PROJECT: Wyoming High Security/Special Need Facility Water and Sewer Services

ENGINEER: JFC Engineers, Architects, and Surveyors

APPLICANT: State of Wyoming Department of Corrections

WATER QUALITY DIVISION REFERENCE NUMBER: 98-022

REVIEWING ENGINEER: Lou Harmon

DATE OF REVIEW: March 26, 1998



**ACTION:** NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 12 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. The present design of the water distribution system does not provide a reliable supply for fire flows or the daily consumption. This is a violation of Section 14, Distribution Systems of Chapter 12 of the Wyoming Department of Environmental Quality/Water Quality Division Rules and Regulations. Section 14 (b)(iii) requires that fire flows can be served. Section 14 (b)(vi) requires that dead-ends be minimized by looping. The present and proposed system depends on a single high pressure pipeline approximately two miles long to provide water to the prison complex. The present main is a cement asbestos pipe that is operating near its maximum pressure limits. This type of water main is particularly vulnerable to water hammer induced failure. Closing one fire hydrant rapidly could be anticipated to cause such a failure, leaving the entire prison complex without water until repairs to the main could be made. Such a repair effort would almost certainly take 24 hours or longer.
  - a. According to the Wyoming State Fire Marshall's Office, the required fire flow for the existing prison complex is 5500 gpm for 4 hours. This equates to 1,320,000 gallons.
  - b. An adequately designed water supply system must be looped to water storage equal to the fire flow requirements plus the average daily demand or 1.5 million gallons. The present main may be looped back to the City of Rawlins tank farm, or storage constructed on site.

Review Plans/Specs

Permit #98-022

Page 2

2. After the on-site storage or the looped high pressure main, a looped water distribution should be designed to serve the existing prison facilities and the new facilities proposed for construction. All fire hydrant leads should be served by looped main. Valving must comply with the provisions of Chapter 12, Section 14 (c). The present design consists of three dead-end distribution lines, each with a loop of pipe at the dead-end. A dead-end run with a loop at the end is still a dead-end and does not meet the requirements of Chapter 12, Section 14(b)(vi) that dead-ends be minimized.
3. The specifications discuss backflow prevention. The backflow devices may appear on mechanical drawings that did not otherwise need to be submitted with the permit application. Please add notes to the plan and profile sheets indicating the type and location of backflow prevention to be provided at each service connection. Please note that any buildings containing hospital, laboratory, or industrial systems connected to the water supply need to be protected by reduced pressure principal or air gap backflow devices.
4. Please report the results of the extended monitoring and comparison of potable water flows to sewage flows being conducted at the present. If excessive infiltration or pumping of groundwater to the sanitary sewer is occurring, this must be corrected.
5. Please describe how manholes installed in the highly corrosive soil areas will be designed to prevent deterioration.

LBH/bb/81038.Itr

cc: Gary Beach  
Larry Robinson  
Ken Burnett, State Fire Marshall's Office  
Doug Shope, Department of Corrections

Mr. Bruce Florquist  
City of Rawlins  
521 West Cedar  
Rawlins, WY 82301



THE STATE OF WYOMING

JIM GERINGER  
GOVERNOR



## Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES (307) 332-5085	AIR QUALITY (307) 332-6755	LAND QUALITY (307) 332-3047	SOLID & HAZARDOUS WASTE (307) 332-6924	WATER QUALITY (307) 332-3144
-----------------------------------	-------------------------------	--------------------------------	---	---------------------------------

February 9, 1998

Mr. Mark C. Eatinger  
Rio Verde Engineering  
P.O. Box 642  
Pinedale, WY 82941

Dear Mark:

Permit application #96-432, McAmis Septic System is being returned to you because this project has been resubmitted with a new design and is currently in the application process as application #98-023.

Randall Taylor  
Water Quality Division  
SW Dist. Supervisor

Enclosure

xc: John McAmis  
3125 South Cave Lane  
Chico, CA 95928

DEQ, IPS Section  
Cheyenne, WY

file: Chrono

## PERMIT TO CONSTRUCT

\_\_\_\_ New  
\_\_\_\_ Renewal  
\_\_\_\_ Modified

PERMIT NO. 98-023  
SPECIAL CONDITIONS  
REF/PERMIT #

### McAmis Septic System

This permit hereby authorizes the applicant:

John McAmis  
3125 South Cave Lane  
Chico, CA 95928

to construct a small wastewater system according to the procedures and conditions of application number 98-023. The facility is located in SW 1/4S3 T33N R107W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

2-12-98  
\_\_\_\_\_  
Date of Issuance

RRT:ks 80456.ltr

cc: Sublette Co. Planning; P.O. Box 506; Pinedale, WY 82941

## STATEMENT OF BASIS

### General information.

Permit Number: 98-023

### II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations.

Not Applicable

### V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, SW District Supervisor, and completed on 09 February 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 98-024  
SPECIAL CONDITIONS

## WPHPA Museum & Interpretive Center - Sewer System

This permit hereby authorizes the applicant:

Western Plains Historic Preservation Association  
c/o George Zeimens  
P.O. Box 381  
Lingle, Wyoming 82223

to construct and install a business septic system with "Infiltrator" leach field according to the procedures and conditions of the application number 98-024. The facility is located in the SW 1/4 SW 1/4 of Section 33, T26N, R63W in the county of Goshen, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; AX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 5. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. All **modifications or deviations** from the authorized plans **must be highlighted**.

PERMIT NO. 98-024

- 4 of 5. Septic Tank Riser Requirement - Either a 6 inch diameter clean-out or the manways on the septic tank must be extended to the ground surface.
- 5 of 5. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

2/26/98  
\_\_\_\_\_  
Date of Issuance

RLE:ks  
80642.ltr

cc: Mel Eaton, Goshen County Planner/Sanitarian

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 98-024

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on February 24, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

☐ New  
☐ Renewal  
☐ Modified

PERMIT NO. 98-025  
SPECIAL CONDITIONS

### Lost Cabin Gas Plant Sediment Control Pond

This permit hereby authorizes the applicant:

Louisiana Land and Exploration Company  
3300 N. "A" Street, Bldg.6  
Midland, Texas 79705-5406

to construct a 1.12 acre stormwater runoff pond to serve an industrial site according to the procedures and conditions of application number 98-025. The facility is located in SE 1/4 NW 1/4 Sec.11, T38N, R90W in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

2-19-98  
\_\_\_\_\_  
Date of Issuance

## STATEMENT OF BASIS

I. General information.

Permit Number: 98-025

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on February 17, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. #98-026  
SPECIAL CONDITIONS

## Meeteetse Fire Hydrant/Valve Replacement

This permit hereby authorizes the applicant:

Town of Meeteetse  
P.O. Box 38  
Meeteetse, WY 82433

to install 9 new fire hydrants and 5 new valves according to the procedures and conditions of application number 98-026. The facility is located in SW ¼ Section 4 and NW ¼ Section 9, T48N, R 100W in the county of Park, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

2/26/98  
\_\_\_\_\_  
Date of Issuance

## STATEMENT OF BASIS

I. General information.

Permit Number: #98-026

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on February 25, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

☐ New  
☐ Renewal  
☐ Modified

PERMIT NO. 98-027R  
SPECIAL CONDITIONS

### Morrison Family Cabin Septic Tank/Leach Field

This permit hereby authorizes the applicant:

Louisa M. Morrison  
c/o Bruce Morrison  
330 Carmon Ave.  
Lovell, WY 82431

to construct a septic tank/chamber leach field to serve up to eight people according to the procedures and conditions of application number 98-027R. The facility is located in Lot E, Porcupine Summer Home Group Section 18, T56N, R91W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3/31/98  
\_\_\_\_\_  
Date of Issuance

JH/bal  
b/81031.ltr

## STATEMENT OF BASIS

General information.

Permit Number: 98-027R

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on March 24, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JCH/bb/81031.ltr

# PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 98-028  
SPECIAL CONDITIONS

## Madison Junction WWTP Monitor Well

This permit hereby authorizes the applicant:

National Park Service, Yellowstone National Park  
P.O. Box 168  
Mammoth Hot Springs, WY 82190

to install a monitor well according to the procedures and conditions of application number #98-028. The facility is located in NE 1/4 Sec. 20, T 54N, R 116 W in the county of Teton, in the State of Wyoming. This permit shall be effective for a period of three (3) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or noncompliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 16 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 16 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 16 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - A. Date that construction of the facility was completed; and
  - B. Date that the facility was placed in operation; and
  - C. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - D. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 16 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis."
- 5 of 16 After the monitoring well(s)/piezometer(s) have fulfilled their useful purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. No monitoring well/piezometer shall be abandoned without prior approval from the Water Quality Division.
- 6 of 16 WDEQ/WQD personnel shall be given at least two (2) weeks notice prior to the installation of monitor well(s)/piezometer(s) and sample collection so that they may be on site if deemed necessary.
- 7 of 16 The applicant is responsible for obtaining any Permits required by the State Engineer's Office (777-7354).
- 8 of 16 The results of any other analyses conducted on soil or water removed from these wells/piezometers or boreholes shall be provided to the department as soon as they are available.
- 9 of 16 Environmental Monitoring Program for Groundwater of the State:
  - A. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity and performed in accordance with WDEQ or EPA approved Standard Procedures or Quality Assurance/Quality Control (QA/QC) Plan.

- B. The permittee shall maintain records of all monitoring information for a period of at least 3 years.
- C. Records of monitoring information shall include:
  - 1. The date, exact place, and time of sampling or measurements;
  - 2. The name(s) of individual(s) who performed the sampling or measurements;
  - 3. The Mean Sea Level elevation of the water table to the closest .01 ft., and the depth to water (to the closest .01 ft.) from a marked measuring point at the top of casing.
  - 4. Sampling procedures and sample preservation accomplished;
  - 5. The date(s) analyses were performed;
  - 6. Names of individuals who performed the analyses;
  - 7. The analytical techniques or methods used; and
  - 8. The results of such analyses.

10 of 16 Pursuant to Wyoming Water Quality Rules and Regulation, Chapter XI, Section 63(A), a deviation is hereby granted for those well(s) piezometer(s) prevented by physical limitations to adherence to the requirements on minimum depths of seal below the ground surface as detailed in Chapter XI, Part G. However, a sufficient seal shall be installed according to standard engineering practice.

11 of 16 Field Documentation of Design, Construction and Installation of Monitoring Wells:

- A. The following information shall be documented during actual construction and installation of monitoring wells. The information shall be submitted to the Water Quality Division before or at the time of the first monitoring report.
  - 1. Date/time of construction.
  - 2. Person developing information/other person(s) on site and their association to the project.
  - 3. Drilling method and if drilling fluid was used.
  - 4. Well location ( $\pm$  0.5 ft.).
  - 5. Well depth ( $\pm$  0.1 ft.).
  - 6. Bore hole diameter and well casing diameter.
  - 7. Drilling and lithologic logs (including visual, olfactory and vapor detection observations). (*See attached 'Borehole Installation Diagram'*).
  - 8. Casing material.
    - i. Screen materials and design/location.
    - ii. Casing and screen joint type.

- iii. Screen slot size/length.
- iv. Filter pack material/size, grain analysis.
- v. Filter pack volume calculated/actually installed.
- vi. Filter pack placement method/location.
- vii. Sealant (annular space) materials.
- viii. Sealant volume used.
- ix. Sealant placement method/location.
- x. Surface seal design/construction.
- xi. Well development procedure used.
- xii. Type of protective well cap (top and bottom).
- xiii. Surveyed elevation ( $\pm$  0.01 ft. Mean Sea Level) of:
  - (1) ground surface
  - (2) surveyor's well reference point
  - (3) top of well casing
  - (4) top of protective structure
- xiv. Location of well number stamp or identification marking.
- xv. Detailed 'as-built' construction drawing of well, including dimensions to all well features. (*See attached 'Monitor Well Installation Diagram'*)

*NOTE: The detailed drawing(s) to be submitted must indicate all well features with relation to stratigraphic sections.*

12 of 16 The monitoring well/piezometer shall be developed by the use of a pump or bailer so that representative groundwater samples can be collected.

13 of 16 Well caps shall be kept locked at all times other than for monitoring purposes. Any tampering with the monitor well(s)/piezometer(s) shall be reported immediately to the Division. The wells shall be clearly numbered using either a stamp to permanently engrave the number into the steel top or by writing the number in the wet concrete of the base.

14 of 16 In accordance with Section 13(a)(iv) of Chapter III of WDEQ/WQD rules and regulations, the following items relating to monitoring well/piezometer construction contained in Sections 64 - 69 of Part G of Chapter XI of WDEQ/WQD rules and regulations take precedence over permit application content and shall be implemented when the well(s)/piezometer(s) are constructed, installed and developed:


1. Filter pack, annular seal, and surface seal material shall be entered into the monitoring well/piezometer in a manner such that no voids or bridging occur.
2. A minimum two (2) foot thickness of bentonite or bentonite grout is required at the top of the filter pack to serve as an annular seal. After the bentonite has been placed in the annular space, it shall be hydrated to insure a proper seal.


PERMIT NO. 98-028

15 of 16 Prior to sampling, monitoring well(s)/piezometer(s) shall be purged until a minimum of three (3) casing volumes have been removed, or until purged dry, whichever occurs first.

16 of 16 Sample collection, preservation, transportation and laboratory analytical procedures.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3/6/98  
\_\_\_\_\_  
Date of Issuance

JCH/bal/ks  
80799.ltr

## STATEMENT OF BASIS

I. General information.

Permit Number: #98-028

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on February 24, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



The State  
of Wyoming



## Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---

October 27, 1999

Wesley K. Nash, Jr. P.E.  
Environmental Engineer Associate  
FMC Corporation  
P.O. Box 872  
Green River, WY 82935

RE: FMC Underground Tailings Injection, Permit UIC 90-152, Sweetwater County, Wyoming

Dear Mr. Nash:

On February 2, 1998 FMC applied for a modification to allow the operation of up to twenty injection wells. The present permit limits you to ten. In response to that request, this department asked that you wait until the general permit to cover underground tailings injection was issued, since that general permit will not have limitations on the number of wells. On February 19, 1999, General UIC Permit 5B1-98-1 was issued in final form. That general permit will allow any number of wells and allow FMC to operate in the same manner that it has been operating under individual permit 90-152. Since that date, FMC has failed to apply for coverage under the general permit or take any action to obtain the modified individual permit.

With this letter, your request for a modified permit is being withdrawn. That request was assigned application number 98-029. Please respond by either applying for coverage under the general permit or by again requesting a modified individual permit. For your convenience, I am enclosing a copy of the general permit 5B1-98-1. I think you will find that this general permit will allow FMC the flexibility that it needs to operate this injection system for the disposal of tailings underground.

Sincerely,

Robert Lucht, P.E. & P.G.  
UIC and AUST Program Principal  
Water Quality Division

RFL/bb/92737.ltr  
Enclosure

FMC Corporation

Box 872  
Green River Wyoming 82935  
307 875 2580

Certified Mail No.:P532 942 447

January 29, 1998

**FMC**

Mr. Robert Lucht - UIC Program Supervisor  
Department of Environmental Quality  
Water Quality Division  
Herschler Building 4W  
122 West 25th  
Cheyenne, Wyoming 82002

**RECEIVED**

FEB 2 1998

98-029

WATER QUALITY DIVISION  
WYOMING

RE: Permit No. UIC 90-152, UIC Class 5x13

Dear Mr. Lucht:

FMC Corporation requests modification of DEQ/WQD Permit 90-152, Class 5X13 which authorizes the operation of its underground tailings disposal system. Specifically, FMC requests that Part C: Authorized Operations be modified to allow the operation of ten (10) additional injection wells, bringing the total up to twenty (20), and to allow the injection of slurry make up water or plant process river water without a tailings solids component. No change is requested regarding the permitted volume for injection or the number of recovery wells. This modification is requested only to allow further flexibility in the operation of the underground tailings disposal system.

Since permit approval FMC has gained extensive operational experience regarding this unique tailings disposal system. We have determined that by varying the injection location and slurry composition, tailings deposition efficiencies are dramatically affected. The flexibility gained by the requested permit modification is required to provide the opportunity to vary the flow patterns in the tailings deposition area around older injection wells, and to optimize the deposition area as much as possible.

It is FMC Corporation's understanding that this request represents a minor permit modification and that by this letter Water Quality Division may proceed with considering the action without further notification forms or submittals. If this is incorrect, please call and let us know what further information or documentation is required.

Thank you for your help in expediting this request for permit modification.

Sincerely,



Wesley K. Nash, Jr PE  
Environmental Engineer Associate

cc: CK Templeton, ED File - office

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-030  
SPECIAL CONDITIONS

### MOUNTAIN VIEW BUSINESS PARK

This permit hereby authorizes the applicant:

Larry Suchor & Gary Decker  
2020 Schoonover Road  
Gillette, WY 82716

to construct, install or modify water and sewer lines according to the procedures and conditions of the application number 98-030. The facility is located in the SE/4 of Section 23 of T56N R84W in the county of Sheridan, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3/31/98  
\_\_\_\_\_  
Date of Issuance

DRM/pr:3/26/98  
b/81053.ltr

xc: Jim Willey, M-W Consultants, #2 Taylor Pl., N. Main St., Sheridan, 82801

## STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 98-030
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter 11      Yes
- B. Chapter 12      Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- Not Applicable (N/A)
- B. Briefly state the basis for the deviation.
- N/A
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Don McKenzie, SPO Northeast District Program Principal, and completed on March 26, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

DRM/bb/81053.ltr



THE STATE

OF WYOMING



**JIM GERINGER**  
GOVERNOR

# Department of Environmental Quality

Herschler Building ● 122 West 25th Street ● Cheyenne, Wyoming 82002

ADMINISTRATION (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 634-0799	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 634-0799	SOLID & HAZARDOUS WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	---	---

February 23, 1998

Tom Miller  
293 Red Lane  
Thermopolis, WY 82443


RE: As-Built Permit To Construct, WQD Reference Number #98-031

Dear Mr. Miller:

The Department of Environmental Quality/Water Quality Division (DEQ/WQD) has reviewed the above referenced As-Built Application. Our review of the information and as-constructed plans submitted to this office indicates that the application meets DEQ/WQD regulations and the enclosed As-Built Permit To Construct is hereby issued. The enclosed permit covers the septic tank and leach field which has already been constructed.

Please be advised that the system must be constructed, installed and operated in accordance with the statements, representations and procedures presented in the application and all supporting documentation as well as the terms and conditions of the permit. You are urged to be familiar with all aspects of the permit application, permit and permit conditions. Any person objecting to a permit issued by the DEQ and desiring affirmative relief may request a hearing before the Environmental Quality Council in accordance with the Rules of Practice and Procedure for the Department of Environmental Quality and the Wyoming Administrative Procedures Act.

Sincerely,



Dennis Hemmer  
Director  
Department of Environmental Quality

DH/JCH/ks 80612b.ltr

Enclosure

cc: Gretchen Hurley, Hot Springs Co. Planner

**AS-BUILT**  
**PERMIT TO CONSTRUCT**

New  
 Renewal  
 Modified

PERMIT NO. 98-031  
SPECIAL CONDITIONS

**Tom Miller Residence Septic Tank/Leach Field**

This permit hereby authorizes the applicant:

Tom Miller  
293 Red Lane  
Thermopolis, WY 82443

to have constructed a septic tank and leach chamber disposal field according to the procedures and conditions of application number 98-031. The facility is located in Parcel D, Block 2, of Artois Subdivision, Sec.24, T43N, R95W resubdivision in the county of Hot Springs, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, meets applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee has constructed and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 1 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

2/26/98  
\_\_\_\_\_  
Date of Issuance

JH/bal/ks  
80612a.ltr

## STATEMENT OF BASIS

I. General information.

Permit Number: 98-031

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII.

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on February 13, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-032  
SPECIAL CONDITIONS

### City of Gillette Water Supply Wells S-22, S-26 and S-27

This permit hereby authorizes the applicant:

City of Gillette  
ATTN: Kurt Siebenaler  
P.O. Box 3003  
Gillette, WY 82717-3003

to construct, install or modify public water supply wells according to the procedures and conditions of the application number 98-032. The facilities are located in NW/4 of the SE/4 Section 19, Township 50 North, Range 71 West, the NW/4 of the SE/4 Section 32, Township 50 North, Range 72 West, and the SW/4 of the SE/4 Section 21, Township 50 North, Range 72 West in the county of Campbell, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property, invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Director  
Department of Environmental Quality

2-17-98  
\_\_\_\_\_  
Date of Issuance

BDM/pr/ks 80517.ltr

cc: Larry Wester, P.E., Wester-Wetstein & Associates, Inc., P.O. Box 29, Laramie, WY 82720

STATEMENT OF BASIS

I. General information.

A. Permit Number: 98-032

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Wyoming Water Quality Rules and Regulations Chapter XII Section 9(b)(iii)(C) parts(I), (III), and IV).

B. Briefly state the basis for the deviation.

Part (I) requires specific construction standards for the well casing. API grade casing is proposed and approved for two reasons: 1) the contractors are more familiar with the handling and use of typical oilfield materials for the relatively deep well constructions, and 2) the casing exceeds the DEQ/WOD standard line pipe specifications.

Part (III) requires sieve analysis for determining the well screen opening. The proposed and approved screen size determination is based on past experience in completing local Fort Union Formation water wells. Sieve analysis has been utilized in the past for area Fort Union Formation wells and often yielded screen openings which have either plugged or allowed sand entry.

Part (IV) requires a wellbore and casing clearance of two inches or more. The proposed and approved clearance is less than the minimum two inches, but within standard oilfield drilling and completion practices. The DEQ/WQD two inch requirement does not necessarily insure a good cement seal. Proper borehole conditioning and adequate spacing between the casing and wellbore are more critical factors affecting the quality of the cement seal.

Part (IV) 1. requires cement conforming to ASTM standard C150. The proposed and approved API cement is similar in composition to the DEQ/WQD standard and the contractor is more familiar with the accepted oil industry "deep" well completion materials and techniques.

- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III. See footnote. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not applicable. public water supply

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian D. Mark, Senior Environmental Analyst, and completed on February 11, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

Footnote: Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-033  
SPECIAL CONDITIONS

### H F Bar Ranch Water Treatment Plant Modification

This permit hereby authorizes the applicant:

Margi Schroth  
H F Bar Ranch  
Saddlestring, WY 82840

to construct, install or modify a privately owned water treatment plant according to the procedures and conditions of the application number 98-033. The facility is located in NE/4 of the SE/4, Section 24, Township 52 North, Range 84 West in the county of Johnson, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 5 An operation and maintenance manual will be provided to the Northeast District Office for review and approval prior to providing potable water from the facility to the guest ranch.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

2/26/98  
\_\_\_\_\_  
Date of Issuance

BDM/pr:mad 80683.LTR

cc: Doyl Fritz, P.E., WWC Engineering, 1849 Terra Avenue, Sheridan, WY 82801

## STATEMENT OF BASIS

General information.

A. Permit Number: 98-033

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

1) Chapter 12 Section 10.(i)(i) does not allow pressure filters to be used for filtration of surface water.

2) Chapter 12 Section 10.(k)(ii) requires provisions for applying disinfectant to the raw water, filter influent and filtered water.

B. Briefly state the basis for the deviation.

1) The engineer has provided documentation that similar facilities are successfully producing potable water meeting drinking water requirements. This satisfies Section 5.(a)(iii). EPA classifies any unit operation placed above bag or cartridge filters as pre-treatment. Cartridge filters will be placed in series; the upstream will be a 10-20 micron filter and the downstream a 1-2 micron filter.

2) Disinfection will be provided after filtration. Disinfection of raw water is believed to be capable of producing precursors such as trihalomethanes. This undesirable situation should be avoided.

- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable (N/A)

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian Mark, Senior Analyst, and completed on March 25, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 98-034  
SPECIAL CONDITIONS

### Tilton Concrete, Inc. Sanitary Sewer

This permit hereby authorizes the applicant:

Tilton Concrete  
P.O. Box 2998  
Cheyenne, WY 82003

to construct, install or modify 4" lateral sewer line to 16" sanitary main according to the procedures and conditions of the application number 98-034. The facility is located in SW 1/4 Section 31 T14N R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to DEQ/WOD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to DEQ/WOD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

5-13-98  
\_\_\_\_\_  
Date of Issuance

LBH:ks 80851.ltr

cc: Cheyenne Board of Public Utilities

## STATEMENT OF BASIS

### General information.

A. Permit Number: 98-034

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. YES

B. Chapter XII. NO

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

YES

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

NO

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

N/A

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NO

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on May 8, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

X      New  
         Renewal  
         Modified

PERMIT NO. 98-036  
SPECIAL CONDITIONS

### Cheyenne BOPU Second 1998 Rehab Project

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities  
2406 Snyder Avenue  
Cheyenne, WY, 82001

to construct, install or modify rehabilitation of various sewer lines according to the procedures and conditions of the application number 98-036. The facility is located in Sections 32, 32, T14 N R66W; Sections 4, 5 T13N R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3-10-98  
\_\_\_\_\_  
Date of Issuance

## STATEMENT OF BASIS

- I. General information.
  - A. Permit Number: 98-036
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
  - A. Chapter XI. YES
  - B. Chapter XII. NO
- III. Basis for issuing permit. (Indicate yes or no for each section.)
  - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.  
YES
  - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.  
NO
  - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.  
N/A
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
  - A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.  
N/A
  - B. Briefly state the basis for the deviation.  
N/A
  - C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).  
N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NO

- VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on March 9, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LBH/bb/80867.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 98-035RR  
SPECIAL CONDITIONS

### Wexpro Company - Fire Hydrant

This permit hereby authorizes the applicant:

Wexpro Company  
2300 Foothill Blvd.  
Rock Springs, WY 82901

to construct an 8-inch watermain to supply a fire hydrant according to the procedures and conditions of application number 98-035RR. The facility is located in SE 1/4 S4 T18N R105W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective for a period of three years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-22-98  
\_\_\_\_\_  
Date of Issuance

RRT/mad 83003.LTR

cc: City of Rock Springs; Public Works; 212 D Street; Rock Springs, WY 82901

## STATEMENT OF BASIS

General information.

Permit Number: 98-035RR

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, SW District Engineering Supervisor, and completed on 16 October 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 98-037  
SPECIAL CONDITIONS

## Duncan Livestock - Residential Septic System

This permit hereby authorizes the applicant:

Duncan Livestock  
Harry Duncan, Owner/President  
Box 14  
Dixon, Wyoming 82323

to construct and install a residential septic system with "Infiltrator" leach field according to the procedures and conditions of the application number 98-037. The facility is located in the SW 1/4 of Section 03, T12N, R90W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 5. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**

4 of 5. Septic Tank Requirements - The Copeland Concrete septic tank is not on the list of preapproved septic tanks for Wyoming. The tank was reviewed and found to be acceptable provided that the following conditions are met:


- a. Both the inlet and outlet shall be provided with a tee or baffle that extends into the middle third of the water depth.
- b. Either a six(6) inch diameter cleanout riser shall be provided in each tank compartment which extends to the ground surface, or the manways on each tank compartment shall be extended to the ground surface.

5 of 5. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Gary Beach  
Administrator  
Water Quality Division



Dennis Hemmer  
Director  
Department of Environmental Quality

3-2-98

Date of Issuance

RLE:ks  
80752.ltr

cc: Carbon County Planner/Sanitarian

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 98-037

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

- VI. Deleted

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on February 27, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

# ROAD APPLICATION PERMIT

△ New  
Renewal  
Modified

PERMIT NO. 98-038  
SPECIAL CONDITIONS  
REF/PERMIT #94-090RR

## Lost Cabin Gas Plant

This permit hereby authorizes the applicant:

Burlington Resources  
3300 North A Street, Bldg.6  
Midland, TX 79705

to road apply and provide water for compaction; produced, condensed, opened and closed drain system, and storm water from the two on-site wastewater storage ponds according to the procedures and conditions of application number 98-038. The application site is located in SE1/4 Sec.11, T38N, R90W in the county of Fremont, in the State of Wyoming. This permit shall be effective for five (5) years.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 6 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307) 332-3183.
- 2 of 6 The permittee will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
- 3 of 6 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 4 of 6 The produced, condensed, opened and closed drain system and storm water from the two on-site wastewater storage ponds shall be applied uniformly on the roadbed or soils to be compacted. Application shall not be initiated at times saturated soil conditions exist.
- 5 of 6 The application site slope shall not exceed eight percent (8%) for vehicular application.
- 6 of 6 Only the roads and construction areas designated in this permit are authorized for application of the produced, condensed, opened and closed drain system and storm water from the two on-site wastewater storage ponds. Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.

AUTHORIZED BY:



Gary Beach  
Administrator  
Water Quality Division



Dennis Hemmer  
Director  
Department of Environmental Quality

3/31/98  
Date of Issuance

JH/bl/mad 81008.LTR

## STATEMENT OF BASIS

General information.

Permit Number: 98-038

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are not numeric standards or criteria in Chapter XI for road application and soil compaction water. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed modified or operated.

B. Briefly state the basis for the deviation.

Road application and wastewater use for compaction is permitted when a beneficial use of the wastewater to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement.

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish

criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the wastewater onto the roadbed.

- B. Quality of waste is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on March 19, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 98-039  
SPECIAL CONDITIONS

## Dakota Ranch Headquarters - Residential Wastewater Disposal Facility

This permit hereby authorizes the applicant:

Dakota Ranches  
Mark Bayer, Owner  
426 Kittell Road  
Wheatland, Wyoming 82201

to construct and install a residential septic system with leach field according to the procedures and conditions of the application number 98-039. The facility is located in the SE 1/4 of Section 34, T24N, R70W in the county of Platte, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 5. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. All **modifications or deviations** from the authorized plans **must be highlighted**.
- 4 of 5. Septic Tank Riser Requirement - On Windmeier Construction septic tanks either a six(6) inch diameter clean-out or the manway must be extended to the ground surface.

PERMIT NO. 98-039

of 5. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3-5-98  
\_\_\_\_\_  
Date of Issuance

PLE:ks  
30772.ltr

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 98-039

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

- VI. Deleted

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on March 3, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-040R  
SPECIAL CONDITIONS

### Jackson Hole High School Water & Sewer

This permit hereby authorizes the applicant:

Teton County School District  
P.O. Box 568  
Jackson, WY 83001

to construct 8-inch PVC sewer main and 8-inch ductile iron water main with appurtenance according to the procedures and conditions of application number 98-040R. The facility is located in NW1/4 SE1/4 Sec. 6, T40N, R116W in the county of Teton, in the State of Wyoming. This permit shall be effective for a period of three (3) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, once constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

4-3-98  
\_\_\_\_\_  
Date of Issuance

JH/bl  
b/81095.ltr

## STATEMENT OF BASIS

General information.

Permit Number: 98-040

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on March 30, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JCH/bb/81095.ltr

## PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 98-041  
SPECIAL CONDITIONS

### South Cheyenne Water and Sewer District Waterline Extensions (1998)

This permit hereby authorizes the applicant:

#### South Cheyenne Water and Sewer District

ATTN: Cheryl Porter

215 Allison Road

Cheyenne, WY 82007

to construct, install or modify water distribution according to the procedures and conditions of the application number 98-041. The facility is located in the SW/4 of Section 9, Township 13 North, Range 66 West in the county of Laramie in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 8 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 8 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 8 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
- a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 8 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 8 Separation of water mains and sewers will be maintained at all times in accordance with WPSS Section 02665, Part 3, Execution, 3.01 Construction, F.
- 6 of 8 An additional valve will be installed in the new 10" ductile iron pipe proposed for Avenue C in order to meet the 500 foot minimum spacing requirement for commercial districts as required by Section 14.(c), Chapter XII, Wyoming Water Quality Rules and Regulations.
- 7 of 8 The residential service connections identified on drawing C2 shall be provided with a check valve in accordance with Section 14, Chapter XII, Wyoming Water Quality Rules and Regulations.
- 8 of 8 Any new service connections will be provided with the appropriate backflow prevention device in accordance with section 14.(l), Chapter XII, Wyoming Water Quality Rules and Regulations.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3-20-98  
Date of Issuance

LR/bb/80999.LTR

cc: James Johnson, Johnson Engineering Assoc., 1807 Beaufort St., Laramie, WY 82072

## STATEMENT OF BASIS

i. General information.

A. Permit Number: 98-041

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Larry Robinson, Program Manager and completed on March 19, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LRR/bb/80999.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
 Renewal  
Modified

PERMIT NO. 98-042  
SPECIAL CONDITIONS  
REF/PERMIT #95-409

### Yellowstone Regional Airport ARFF Station Treated Water Main

This permit hereby authorizes the applicant:

Yellowstone Regional Airport  
3001 Duggleby Dr.  
Cody, WY 82414

to construct the balance of 5500 feet of 8-inch ductile iron pipe looped to the city of Cody treated water system according to the procedures and conditions of application number 98-042. The facility is located in Tract 60, T52N and T53N, R101W, Resurvey in the county of Park, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

2/26/98  
\_\_\_\_\_  
Date of Issuance

JCH/bal/ks  
80613.ltr

STATEMENT OF BASIS

I. General information.

Permit Number: 98-042 / Ref.# 95-409

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on February 20, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-043  
SPECIAL CONDITIONS

## Mashie and Niblick Club Water Mains

This permit hereby authorizes the applicant:

City of Cody  
P.O. Box 2200  
Cody, WY 82414

to construct about 678 L.F. of 8-inch AWWA C900, Class 150 PVC water pipe, two hydrants, and valves according to the procedures and conditions of application number 98-043. The facility is located in SE 1/4 NE 1/4 Sec.1, T52N, R102W in the county of Park, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3/11/98  
\_\_\_\_\_  
Date of Issuance

JH/bal/mad 80892.LTR

## STATEMENT OF BASIS

I. General information.

Permit Number: 98-043

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

B. Briefly state the basis for the deviation.

C. Permit based on general or statewide deviation contained in approved policy statement

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.
- N/A
- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)
- A. Facility will not allow a discharge to groundwater. Briefly describe:
- B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:
- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:
- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:
- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:
- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.
- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on March 9, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-044  
SPECIAL CONDITIONS

### Torrington Brown Addition 8" Sanitary Sewer

This permit hereby authorizes the applicant:

Town of Torrington  
P.O. Box 250  
Torrington, WY, 82240

to construct, install or modify a 8" sanitary sewer line extension according to the procedures and conditions of the application number 98-044. The facility is located in Sections 14 and 15 T24N R61W in the county of Goshen, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Gary Beach  
Administrator  
Water Quality Division



Dennis Hemmer  
Director  
Department of Environmental Quality

3/31/98

Date of Issuance

LBH:ks  
81064.ltr

## STATEMENT OF BASIS

- I. General information.
  - A. Permit Number: 98-044
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
  - A. Chapter XI. Yes
  - B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
  - A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.  
Yes
  - B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.  
No
  - C. Permit based on deviation from applicable regulations in accordance with approved policy statement.  
N/A
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
  - A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.  
N/A
  - B. Briefly state the basis for the deviation.  
N/A
  - C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).  
N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

No

- VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on March 27, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

3  
New  
Renewal  
Modified

PERMIT NO. 98-045  
SPECIAL CONDITIONS

### Town of Torrington Water and Sanitary Sewer Improvements - 13th Avenue, East P and Highway 26

This permit hereby authorizes the applicant:

Town of Torrington  
ATTN: Gary Gerhard  
P.O. Box 250  
Torrington, WY 82240

to construct, install or modify water distribution and sewage collection systems according to the procedures and conditions of the application number 98-045. The facility is located in Section 14, Township 24 North, Range 61 West in the county of Goshen, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3-17-98  
Date of Issuance

## STATEMENT OF BASIS

General information.

A. Permit Number: 98-045

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Brian Mark, Program Principle, and completed on March 17, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51931.DOC

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

REVIEW OF PLANS AND SPECIFICATIONS  
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
Herschler Bldg., 4 West  
Cheyenne, Wyoming 82002

PROJECT: Laramie Ridge Estates Water and Sewer Extensions


ENGINEER: Gertsch/Baker & Associates

APPLICANT: Grant L. Lindstrom, et al

WATER QUALITY DIVISION REFERENCE NUMBER: 98-046

REVIEWING ENGINEER: Lou Harmon

DATE OF REVIEW: March 27, 1998



**ACTION:** **NOT AUTHORIZED FOR CONSTRUCTION.** In accordance with Section 12 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

**COMMENTS, INADEQUACIES, AND QUESTIONS:**

1. The engineering design report is deficient in the following areas:
  - a. The vicinity plan does not show the projects relationship to other development and facilities in the area.
  - b. The static pressure and residual pressure in the water mains at projected fire flow should be projected. The fire flow should be based on fire department requirements for the church evidently planned for construction on Lot 1.
2. The plans and specifications are deficient in the following areas:
  - a. The plans must be signed and sealed by the engineer.

REVIEW OF PLANS AND SPECIFICATIONS  
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION

WQD REFERENCE NUMBER: 98-046

March 27, 1998

Page 2

- b. No specifications are included with the application. The requirement for specifications could be satisfied by something as simple as a note on the plans that Wyoming Public Works Standard Specifications of 1993 will be used.
3. The dead-end water line into the cul-de-sac is acceptable. The dead-end water line on Hayford Avenue must be justified. Part of that justification should be coordination with the City of Laramie for looping the line in orderly fashion as development continues. Plans for looping the Hayford water main should be discussed in the design report.

LBH:ks  
81057.ltr

## PERMIT TO CONSTRUCT

✓ New  
Renewal  
Modified

PERMIT NO. 98-046  
SPECIAL CONDITIONS

### Laramie Ridge Estates Water and Sewer Line Extensions

This permit hereby authorizes the applicant:

Grant L. Lindstrom et al  
1403 Thomes  
Laramie, WY, 82072

to construct, install or modify a water and sewer line extension according to the procedures and conditions of the application number 98-046. The facility is located in Section 26 T16N R73W in the county of Albany, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

4-9-98  
\_\_\_\_\_  
Date of Issuance

LBH/bb/81153.ltr

cc: City of Laramie Engineering Dept.

## STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 98-046
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- N/A
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- N/A
- B. Briefly state the basis for the deviation.
- N/A
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

No

- VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on April 7, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LBH/bb/81153.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-047  
SPECIAL CONDITIONS  
REF/PERMIT NO.

### F.E. Warren AFB Child Development Center Water and Sewer Service

This permit hereby authorizes the applicant:

F.E. Warren AFB  
300 Vesle Drive  
Cheyenne, WY, 82009

to construct, install or modify a water and sewer services according to the procedures and conditions of the application number 98-047. The facility is located in Section 25 T14N R67W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; and
  - d. Certification that the temporary sewer line constructed to the Wherry housing units to be destroyed later has been removed or grouted full.
  - e. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

4-3-98  
\_\_\_\_\_  
Date of Issuance

LBH/bb/81069.ltr

cc: Cheyenne Board of Public Utilities

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 98-047

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. YES

B. Chapter XII. YES

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

YES

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

NO

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

N/A

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NO

- VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on March 30, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LBH/bb/81069.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## LAND APPLICATION PERMIT

New  
\_ Renewal  
\_ Modified

PERMIT NO. 98-048  
SPECIAL CONDITIONS

### Land Application at Lawrence Brown Disposal Lagoon

This permit hereby authorizes the applicant:

Waste Inc.  
219 7th Street  
Evanston, WY 82930

to land apply 250,000 gallons of treated oilfield produced water according to the procedures and conditions of application number 98-048. The application site is located in NW1/4 S7 T17N R120W in the county of Uinta, in the State of Wyoming. This permit shall be effective until 01 November 1998.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the land application design herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the land application. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 7 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached postcard. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183.

- 2 of 7 The permittee shall provide immediate oral and/or written notice to the SW District , State of Wyoming, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
- 3 of 7 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the SW District , State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the attached Certification of Completion form the following information:
- A. Date that the land application was completed; and
  - B. Certification the land application was done in accordance with the terms and conditions of the permit; or
  - C. Certification the land application was completed with changes or modifications. Submit the information necessary to clearly indicate the land application as actually performed. This information shall include a contour map depicting only those sections that actually received the land application.
- 4 of 7 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 7 The land application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
- 6 of 7 The wastewater is to be treated to reduce the total dissolved solids (TDS) to a maximum of 2,100 mg/l, and there is to be only minimal amounts of oil (TPH < 100 mg/l). The specific treated wastewater to be discharged shall be tested for TDS to verify meeting the standard, and if there is a question about the acceptability of the amount of oil, then the wastewater shall be tested for Total Petroleum Hydrocarbons (TPH) using EPA test method modified 8015.
- 7 of 7 The treated wastewater shall be applied uniformly across the ground surface in quantities that do not exceed the infiltration rate of the soil such that there is no runoff that leaves the property. The land application shall not exceed 1 gal/sq-ft or 1.6-inches of depth, and the total application shall not exceed 250,000 gallons. The shallow depth of application is to provide minimal opportunity for percolation to groundwater.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3-2-98  
\_\_\_\_\_  
Date of Issuance

## STATEMENT OF BASIS

- I. General information.
- Permit Number: 98-048
- II. Application reviewed for compliance with the following regulations.
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit.
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations.
- Not Applicable
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.
- Applicable
- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)
- A. Facility will not allow a discharge to groundwater. Briefly describe:

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the treated wastewater over the land surface at 1 gallon per square foot, which is a depth of 1.6-inches.

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

NA

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

NA

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

NA

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

NA

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

NA

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

NA

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, SW District Supervisor, and completed on 24 February 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 98-049  
SPECIAL CONDITIONS

## Fremont County Fire District Admin.Bldg. Sewer

This permit hereby authorizes the applicant:

Fremont County Fire Joint Powers Board  
1440 Cowboy Lane  
Riverton, WY 82501

to 109 feet of 8-inch sewer and one manhole according to the procedures and conditions of application number 98-049. The facility is located in NW1/4 Sec.36, T1N, R4E Wind River Meridian in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3/11/98  
\_\_\_\_\_  
Date of Issuance

JH/bal/mad 80893.LTR

## STATEMENT OF BASIS

I. General information.

Permit Number: 98-049

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

B. Briefly state the basis for the deviation.

C. Permit based on general or statewide deviation contained in approved policy statement

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on March 9, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

↳ New  
Renewal  
Modified

PERMIT NO. 98-050  
SPECIAL CONDITIONS

### Cody 14th Street Sewerline Replacement

This permit hereby authorizes the applicant:

City of Cody  
P.O. Box 2200  
Cody, WY 82414

to construct 1200 L.F. of 12-inch PVC sewer and manholes according to the procedures and conditions of application number 98-050. The facility is located in NE1/4 Sec.32, T53N, R101W original survey in the county of Park, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3-12-98  
Date of Issuance

JCH/bal/ks  
80914.ltr

## STATEMENT OF BASIS

General information.

Permit Number: 98-050

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on March 10, 1998. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."