

# PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 99-251  
**\*SPECIAL CONDITIONS\***  
Permit Expiration Date

## Gardens North Subdivision - Sewer and Water - Lots 7,8,9

This permit hereby authorizes the applicant:

Gardens North Homeowners Association  
13 Gardens North Drive  
Riverton, WY 82501

to construct a water distribution system extension and a sanitary sewer collection system extension according to the procedures and conditions of application number 99-251. The facility is located in SW1/4 Section 13, T1N, R4E in the county of Fremont, in the State of Wyoming. **This permit shall be effective until October 1, 1999 for the construction of the water system extension and for a period of two (2) years from the date of issuance of this permit for the sanitary sewer system extension.**

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the NW District, State of Wyoming, DE, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the NW District, State of Wyoming, DE, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the NW District, State of Wyoming, DE, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-29-99  
\_\_\_\_\_  
Date of Issuance

DHC/mad 91876.ltr

cc: Fremont County, Planning & Rural Addressing, 450 No. 2nd St., Lander, WY 82520

STATEMENT OF BASIS

I. General information.

Permit Number: 99-251

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle H. Conklin, Environmental Senior Analyst, and completed on July 23, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-252  
SPECIAL CONDITIONS

### Schumm Residential Septic System

This permit hereby authorizes the applicant:

David & Nadine Schumm  
Box 1801  
Saratoga, Wyoming 82331

to construct and install a residential septic system with chamber type leach field according to the procedures and conditions of the application number 99-252. The facility is located in the NW 1/4 of Section 33, T18N, R83W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**
- 4 of 5. Septic Tank Riser Requirement - On Vaughn Concrete Products septic tanks either a 6 inch diameter clean-out riser or the manway on each compartment must be extended to the ground surface.
- 5 of 5. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

11-13-99  
\_\_\_\_\_  
Date of Issuance

RLE/bb/91718.ltr

cc: Carbon County Planner/Sanitarian

STATEMENT OF BASIS

I. General information.

A. Permit Number: 99-252

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on July 8, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/bb/91718.ltr

## PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 99-253  
SPECIAL CONDITIONS

### Jensen Septic System

This permit hereby authorizes the applicant:

Jens Jensen  
612 Cedar Avenue  
Elmhurst Illinois 60126

to construct, install or modify a septic tank and side hill drain field for a 3 bedroom house according to the procedures and conditions of the application number 99-253. The facility is located in NE 1/4 Section 20 T14N R83W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of three years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the follow permit conditions:

- 1 of 5 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 The effluent line from the septic tank shall flow into a Tee or a distribution box to divide the flow evenly between the two rows of infiltration chambers.
- 4 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 5 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-1-99  
\_\_\_\_\_  
Date of Issuance

LBH/mad 91600.ltr  
cc: Carbon County Planning Office

## STATEMENT OF BASIS

- I. Permit Number: 99-253
- II. Application reviewed for compliance with the following regulations.
- A. Chapter XI. YES
- B. Chapter XII. NO
- III. Basis for issuing permit.
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- YES
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- NO
- IV. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III.
- NO
- V. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on June 28, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 99-255  
SPECIAL CONDITIONS

## First Interstate Inn Sanitary Sewer Connection - Douglas

This permit hereby authorizes the applicant:

Rite-A-Way Industries Inc.  
P.O. Box 760  
Kimball, Nebraska 69145

to construct and install a sanitary sewer extension according to the procedures and conditions of the application number 99-255. The facility is located in the NW1/4 NW1/4 of Section 23, T32N, R71W in the county of Converse, in the State of Wyoming. This permit shall be effective for a period of 4 months from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-6-99  
\_\_\_\_\_  
Date of Issuance

RLE/bb/91666.ltr

cc: Steve Bennett, Director of Public Works, City of Douglas

STATEMENT OF BASIS

I. General information.

A. Permit Number: 99-255

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on July 6, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/bb/91666.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-256  
SPECIAL CONDITIONS

## DEWAYNE & ERICA HOKANSON RESIDENTIAL SEPTIC SYSTEM

This permit hereby authorizes the applicant:

Dewayne & Erica Hokanson  
P. O. Box 255  
Newcastle, WY 82701

to construct, install or modify a septic system according to the procedures and conditions of the application numbers 99-256. The facility is located in the NE/4 of Section 9 of T45N R61W in the county of Weston, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (DEQ/WQD), upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ/WQD the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Casper WDEQ Field Office, 3030 Energy Lane, Suite 200, Casper, WY 82604, telephone (307) 473-3452; FAX (307) 473-3458.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Casper Field Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Casper Field Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach, Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer, Director  
Department of Environmental Quality

7-29-99  
\_\_\_\_\_  
Date of Issuance

JDL/pr/mad 91881.ltr

Enclosures: Notification Post Card  
Certificate of Completion  
Statement of Basis

## STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 99-256
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- Not Applicable (N/A)
- B. Briefly state the basis for the deviation.
- N/A
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of Section VI. from the Statement of Basis.)

N/A

VI. N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, Northeast District DEQ/WQD-SPO Senior Analyst, and completed on July 27, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-257  
SPECIAL CONDITIONS

## Range Guard III Leach Field

This permit hereby authorizes the applicant:

Wyoming Army National Guard  
Camp Guernsey Annual Training Site  
P.O. Box 399  
Guernsey, Wyoming 82214-0399

to construct and install a military septic system with a chamber type leach field for domestic waste according to the procedures and conditions of the application number 99-257. The facility is located in the SW1/4 NW1/4 of Section 21, T28N, R66W in the county of Platte, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION) the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**

4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-15-99  
\_\_\_\_\_  
Date of Issuance

RLE/mad 91751.ltr

## STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 99-257
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.  
Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.  
No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.  
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.  
NOT Applicable
- B. Briefly state the basis for the deviation.  
NOT Applicable
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).  
NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on July 13, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

DEPARTMENT OF ENVIRONMENTAL QUALITY  
STATE OF WYOMING  
UNDERGROUND INJECTION CONTROL PERMIT  
AUTHORIZATION TO DISCHARGE INTO UNDERGROUND RECEIVERS  
ISSUED UNDER CHAPTER 16, WATER QUALITY RULES AND REGULATIONS

(X) New  
( ) Modified

Permit Number: UIC 99-258  
Subclass Number: 5E3

In compliance with the Wyoming Environmental Quality Act (W.S. 35-11-101 through 1104, specifically 301(a)(i) through (iv), Laws 1973, Ch. 250, Section 1) and Water Quality Rules and Regulations, Chapter 3 (1988), and Chapter 16 (1998),

Applicant: Rick Colling  
Snowy Range Ski Area  
6416 Mountain Mist Court  
Laramie, WY 82070  
(307) 745-8358

is authorized to operate the Snowy Range Ski Area Wastewater Facility in the NW¼, Section 20, Township 16 North, Range 78 West, of the 6th Principal Meridian; according to the procedures and conditions of application # 99-258 and other conditions of this permit as contained on pages 1 through 9.

This permit shall become effective on date of issuance.

  
\_\_\_\_\_  
Administrator  
Water Quality Division  
Herschler Building, 122 West 25th Street  
Cheyenne, WY 82002  
Phone: (307) 777-7781

8/18/99  
\_\_\_\_\_  
Date

  
\_\_\_\_\_  
Director  
Department of Environmental Quality  
Herschler Building, 122 West 25th Street  
Cheyenne, WY 82002

8/18/99  
\_\_\_\_\_  
Date

## TABLE OF CONTENTS

A.	DISCHARGE ZONE AND AREA OF REVIEW . . . . .	3
	Discharge Zone: . . . . .	3
	Area of Review . . . . .	3
B.	GROUNDWATER CLASSIFICATION . . . . .	3
C.	AUTHORIZED OPERATIONS . . . . .	4
D.	ENVIRONMENTAL MONITORING PROGRAM FOR GROUNDWATERS OF THE STATE . . . . .	4
	Samples and measurements . . . . .	4
	records of all monitoring information . . . . .	4
	information shall include . . . . .	4
	groundwater in the receiving formation . . . . .	4
	waive further monitoring . . . . .	5
E.	REQUIREMENTS FOR MONITORING THE DISCHARGE . . . . .	5
F.	RECORDS AND REPORTS . . . . .	5
	retain copies of all reports . . . . .	5
	planned physical alterations or additions . . . . .	5
	submitted no later than 30 days . . . . .	6
	report any noncompliance . . . . .	6
	other information . . . . .	6
	noncompliance with a permit condition or malfunction . . . . .	6
	written submission shall be provided within 5 days . . . . .	6
	noncompliance not reported otherwise . . . . .	6
	failed to submit any relevant facts . . . . .	6
	retain all records concerning the nature and composition . . . . .	6
	public notice and an opportunity for hearing . . . . .	6
	annual report of operations . . . . .	6
	report for an aborted or curtailed operation . . . . .	6
G.	GENERAL PERMIT CONDITIONS . . . . .	7
	permit may be modified, suspended or revoked . . . . .	7
	reviewed at least once every 5 years . . . . .	7
	modified at any time as may be required . . . . .	7
	Public notice of the permit review . . . . .	7
	Any permit noncompliance constitutes a violation . . . . .	7
	filing of a request . . . . .	7
	(permittee) is always responsible for permit compliance . . . . .	7
	legal action . . . . .	7
	does not convey any property rights . . . . .	7
	provisions of this permit are severable . . . . .	7
	waste which migrates into an aquifer . . . . .	7
	permit is for a term of ten years . . . . .	7
	modification which may result in a violation . . . . .	8
	construction requirements . . . . .	8
	notify the administrator . . . . .	8

	construction is complete . . . . .	8
H.	DUTIES OF THE PERMITTEE . . . . .	8
	Comply with all permit conditions . . . . .	8
	Halt or reduce activity . . . . .	8
	Take all reasonable steps . . . . .	8
	Furnish to the administrator . . . . .	8
	Operate and maintain all facilities . . . . .	8
	enter the premises where a regulated facility . . . . .	8
I.	SPECIAL MEASURES THE DIRECTOR FINDS NECESSARY: . . . . .	8
	sewage is found to be surfacing . . . . .	8
J.	SIGNATORIES REQUIREMENT . . . . .	9
	For a corporation . . . . .	9
	For a partnership or sole proprietorship . . . . .	9
	By a duly authorized representative . . . . .	9
	authorization is no longer accurate . . . . .	9
	certification . . . . .	9

\*\*\*\*\*

**A. DISCHARGE ZONE AND AREA OF REVIEW**

**1. Discharge Zone:**

This injection facility (sanitary leachfield) is authorized to inject into the Alluvial Aquifer at the Snowy Range Ski Area which is found at this location from zero to approximately 50 feet below the ground surface.

**2. Area of Review**

The facility authorized by this permit is located in:

Township 16 North, Range 78 West, 6th Principal Meridian  
Section 20: NE¼

The Area of Review around this facility is legally described as:

Township 16 North, Range 78 West, 6th Principal Meridian  
Section 20: NE¼

**B. GROUNDWATER CLASSIFICATION**

1. The groundwater in the alluvial aquifer at the Snowy Range Ski Area is classified as class I (Domestic) under Chapter 8 of Wyoming Water Quality Rules and Regulations (March 11, 1993). This classification was made because:

a. The groundwater in this formation meets all of the quality standards set forth in Chapter 8 for class I water;

b. The groundwater in this formation is currently being used for domestic purposes at several points of withdrawal; and

2. Groundwater of class I shall not be degraded so as to make it unusable as a source of water for this purpose. Any parameters which do not meet the class of use standard shall not be degraded whatsoever.

**C. AUTHORIZED OPERATIONS**

1. Rick Colling is authorized to inject 214 barrels per day, (9,000 gallons per day) of wastewater as described: Sanitary waste only a ski area with a disposable service restaurant. The operator is authorized to inject at a pressure of no more than atmospheric pressure as measured at the leachfield. This pressure is controlled by gravity drainage and is not required to be monitored.
2. **Hazardous Waste** This permit does not allow for the injection of any hazardous waste as defined by 40 CFR 261. Injection of any substance defined as hazardous waste, whether hazardous by listing or by characteristic is a violation of this permit.

**D. ENVIRONMENTAL MONITORING PROGRAM FOR GROUNDWATERS OF THE STATE**

1. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
2. Rick Colling shall prepare records of all monitoring information to be retained for a period of at least 3 years after closure of the facility.
3. Records of monitoring information shall include:
  - a. The date, exact place, and time of sampling or measurements;
  - b. The name(s) of individual(s) who performed the sampling or measurements;
  - c. The date(s) analyses were performed;
  - d. Names of individuals who performed the analyses;
  - e. The analytical techniques or methods used; and
  - f. The results of such analyses.
4. The groundwater in the receiving formation shall be sampled and the following parameters analyzed on the following schedule and from the following wells.

WELL NAME OR NUMBER	SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT (UCL)*
Wetherill No. 1, State Engineer's Permit Number UW53597	Annually in the Spring after the ski area shuts down	EPA 200 Series Methods	Cadmium	.010
			Chromium	.050
			Lead	.050
		Microbiological Methods for Monitoring the Environment p. 108	Total Coliform	1 colony/100ml
		EPA Method 350.3	Ammonia as N	.500
		EPA Method 353.2	Nitrate as N	10.0

\*All chemical concentrations in this permit are expressed in mg/l unless otherwise noted.

The above Upper Control Limit (UCL) is not to be exceeded in any sample. Exceedance of this value is a violation of this permit and shall require corrective action.

After the first two years of operation, the Water Quality Division may, without reissuing this permit, waive further monitoring of any parameter from the above list or may require additional monitoring based on new information about the nature of the waste. The Water Quality Division may also, after the first two years of operation, approve a more or less stringent monitoring schedule.

## **E. REQUIREMENTS FOR MONITORING THE DISCHARGE**

Rick Colling shall monitor the quality of the injectate fluid on the following schedule. The following parameters shall be analyzed by the listed methods and reported quarterly:

<b>SAMPLING SCHEDULE</b>	<b>ANALYTICAL METHOD</b>	<b>PARAMETER ANALYZED</b>	<b>PERMIT LIMIT (UCL) *</b>
Once during January, Once during May of each year.	EPA Method 350.3	Ammonia as N	50.0
	EPA Method 353.2	Nitrate as N	15.0
	EPA 200 Series Methods	Cadmium	.10
		Chromium	.10
Lead		.10	

\*All chemical concentrations in this permit are expressed in mg/l unless otherwise noted. The above Upper Control Limit (UCL) is not to be exceeded in any sample. Exceedance of this value is a violation of this permit and shall require corrective action. In the event that any contaminant is found to exceed the above UCL's Rick Colling shall undertake a study to determine and eliminate the source of that contaminant from the waste stream. Any parameter found to be exceeding the above UCL shall be sampled for in the downgradient wells if not already sampled for. After the first two years of operation, the Water Quality Division may, without reissuing this permit, waive further monitoring of any parameter from the above list or may require additional monitoring based on new information about the nature of the waste. The Water Quality Division may also, after the first two years of operation, approve a more or less stringent monitoring schedule.

## **F. RECORDS AND REPORTS**

1. Rick Colling shall retain copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the report or application.
2. Rick Colling shall give notice to the administrator as soon as possible of any planned physical alterations or additions, other than authorized operation and maintenance, to the permitted facility and receive authorization prior to implementing the proposed alteration or addition.
3. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 30 days following each schedule date.

4. Rick Colling shall report any noncompliance which may endanger health or the environment, orally within 24 hours from the time The operator becomes aware of the circumstances. The report should include:
  - a. Any monitoring or other information which indicates that any contaminant may cause a endangerment to a usable groundwater of the state.
  - b. Any noncompliance with a permit condition or malfunction of the discharge (injection) system which may cause fluid migration into or between usable groundwaters of the state.
  - c. A written submission shall be provided within 5 days of the time The operator becomes aware of the circumstances. This written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected; the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
5. Rick Colling shall report all instances of noncompliance not reported otherwise, at the time monitoring reports are submitted; such reports shall contain the information listed in 4. above.
6. When Rick Colling becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the administrator, it shall promptly submit such facts or information.
7. Rick Colling shall retain all records concerning the nature and composition of injected fluids until 5 years after completion of any specified plugging and abandonment procedures. The administrator may require the owner/operator to deliver the records to the administrator at the conclusion of the retention period.
8. A subsurface discharge (injection) facility may not commence subsurface discharge (injection) until, following public notice and an opportunity for hearing, an underground injection control permit has been issued by the department for the proposed operation.
9. The annual report of operations for this facility shall be submitted on forms provided by the department and shall include the following information:
  - a. Any permit exceedances within the previous year.
  - b. The analytical results for sampling for the injected water and any groundwater sampling results required under Section D or E of this permit.
  - c. Annual reports are due in the Cheyenne office of the Water Quality Division no later than December 1 of each year.
10. A comprehensive report for an aborted or curtailed operation authorized by this permit shall be submitted to the administrator within 30 days of complete termination of the injection (discharge) or associated activity, in lieu of an annual report.

## **G. GENERAL PERMIT CONDITIONS**

1. After notice and opportunity for a hearing, a permit may be modified, suspended or revoked in whole or part during its term for cause which includes, but is not limited to, any of the following:

- a. Violation of the permit;
  - b. Obtaining a permit by misrepresentation or failure of the discharge well or system.
2. Each permit is reviewed at least once every 5 years, and may be reviewed more frequently.
  3. A permit may be modified at any time as may be required, including for conformity with changes in regulations or standards which occur after the permit is issued. A permit may be modified in whole or part in order to apply more, or less, stringent standards; or prohibitions for a toxic or other substance present in Rick Colling's discharge, as may be ordered by the council. This permit can be terminated by authority of the administrator for one or more permit violations.
  4. Public notice of the permit review and request for public comment will be made every 10 years by the administrator.
  5. Any permit noncompliance constitutes a violation of the permit and is grounds for enforcement action, permit termination, revocation, or modification.
  6. The filing of a request by Rick Colling for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
  7. The owner/operator of record (permittee) is always responsible for permit compliance. A permit holder cannot transfer his permit without approval of the department director, and no such transfer will be approved if the facility is not in compliance with the existing permit unless the proposed permittee agrees to bring the facility into compliance.
  8. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve Rick Colling from any responsibilities, liabilities or penalties established pursuant to any applicable state law or regulation.
  9. The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.
  10. The provisions of this permit are severable, and if any provision of the permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.
  11. Pollution or waste which migrates into an aquifer containing a usable groundwater of the state is a violation of the permit.
  12. This permit is for a term of ten years. If Rick Colling wishes to continue injection after the expiration date of this permit, they will be required to apply to the Administrator for, and obtain, a new permit.
  13. Any modification which may result in a violation of a permit condition shall be reported to the administrator, and any modification that will result in a violation of a permit condition shall be reported to the administrator through the submission of a new or amended permit application.
  14. The injection facility covered by this permit shall meet the construction requirements found in Section 10 of Chapter 16, and Part D of Chapter 11, Water Quality Rules and Regulations. The permittee

shall submit notice of completion or construction to the administrator and allow for inspection of the facility upon completion of construction prior to commencing any injection activity.

15. the permittee shall notify the administrator seven (7) days prior to conversion of this facility to any other use, or final abandonment of the facility.
16. Injection shall not commence until all construction is complete.

#### **H. DUTIES OF THE PERMITTEE**

It is a duty of the permittee to:

1. Comply with all permit conditions;
2. Halt or reduce activity -- it shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce Rick Colling activity in order to maintain compliance with the permit conditions;
3. Take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with this permit; and
4. Furnish to the administrator within a reasonable time, any information which the administrator may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit; and furnish to the administrator, upon request, copies of records required to be kept by this permit.
5. Operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding and operator staffing and training, and adequate laboratory and process controls including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.
6. Allow the administrator, or an authorized representative of the administrator, upon the presentation of credentials, during normal working hours, to enter the premises where a regulated facility is located, or where records are kept under conditions of this permit, and inspect the discharge and related facilities, review and copy reports and records required by the permit, collect fluid samples for analysis, measure and record water levels, and perform any other function authorized by law or regulation.

#### **I. SPECIAL MEASURES THE DIRECTOR FINDS NECESSARY:**

1. In the event that sewage is found to be surfacing from the leachfield covered by this permit, this is a violation of this permit and shall be reported immediately as required by Section F of this permit. Rick Colling shall submit a modified application showing plans for a replacement leachfield (or other type of waste disposal method) within 90 days of determining that the primary leachfield has failed.

#### **J. SIGNATORIES REQUIREMENT**

1. All reports required by this permit and other requested information shall be signed as follows:

- a. For a corporation -- by a principal executive officer of at least the level of vice-president;
  - b. For a partnership or sole proprietorship -- by a general partner or the proprietor, respectively;
  - c. By a duly authorized representative for any of the above. A person is a duly authorized representative only if:
    1. The authorization is made in writing by one of the described principals;
    2. The authorization specifies either an individual or position having responsibility for the overall operation of the regulated facility or activity; and
    3. The written authorization is submitted to the administrator.
2. If an authorization is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to the administrator prior to or together with any reports or information, to be signed by an authorized representative.
  3. Any person signing a report or other requested information shall make the following certification:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

RL/mad 91684.ltr

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-259R  
SPECIAL CONDITIONS

## Point of Rocks No. 2

This permit hereby authorizes the applicant:

Western Hi-Point LLC  
P.O. Box 130  
Point of Rocks, WY 82942

to construct water lines and a storage tank according to the procedures and conditions of application number 99-259R. The facility is located in SW1/4S27 T20N R101W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective until 30 September 1999.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and


permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-29-99  
\_\_\_\_\_  
Date of Issuance

RRT/mad 91852.ltr

## STATEMENT OF BASIS

I. General information.

Permit Number: 99-259R

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, SW District Supervisor, and completed on 23 July 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-260  
**\*SPECIAL CONDITIONS\***  
Permit Expiration Date

## Riverview Ranch Subdivision - Water Lines

This permit hereby authorizes the applicant:

Thunder Investments, LLC  
633 Chestnut Street, Suite 1310  
Chattanooga, TN 37450-1310

to construct two water distribution system extensions according to the procedures and conditions of application number 99-260. The facility is located in SW1/4 Section 10 and NW1/4 Section 15, T40N, R117W in the county of Teton, in the State of Wyoming. **This permit shall be effective until October 1, 1999.**

**If capacity development is demonstrated by the Rivermeadows Water District before October 1, 1999, the expiration date of this permit will be extended to two (2) years from the date of issuance of this permit.**

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and this permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
for Gary Beach  
Administrator  
Water Quality Division

  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-29-99  
Date of Issuance

DHC/mad 91860.ltr

cc: Teton County, Planning Dept., 181 South King, Jackson, WY 83001  
Rivermeadows Water District, P.O. Box 20200, Jackson, WY 83002

## STATEMENT OF BASIS

I. General information.

Permit Number: 99-260

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

**CERTIFICATION**

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle H. Conklin, Environmental Senior Analyst, and completed on July 23, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-261  
SPECIAL CONDITIONS

### Linden Way / Mountain Road Storm Drainage Improvements

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities  
P.O. Box 1469  
Cheyenne WY 82003-1469

to construct, install or modify a six water main adjustments, 41 water service tap adjustments and installation of 450 feet of sanitary sewer main according to the procedures and conditions of the application number 99-261. The facility is located in Section 21 T14N R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 Backflow devices may be omitted for service connections to residences that have been certified to be free of potential backflow conditions. For those residential connections where a backflow device is installed, the residence shall have an thermal expansion tank installed, or the property owner shall sign a statement acknowledging the potential problems associated with unrelieved thermal expansion.
- 4 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 5 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-15-99  
\_\_\_\_\_  
Date of Issuance

LBH/mad 91746.ltr  
enclosure: Backflow Prevention Device Installation Letter

## STATEMENT OF BASIS

I. Permit Number: 99-261

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. YES

B. Chapter XII. YES

III. Basis for issuing permit. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

NO

IV. Facilities not specifically covered by regulations

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter 12, Section 14, Distribution System, Paragraph (i) (A) requires that all residences have at least a check valve in the service connection.

B. Briefly state the basis for the deviation.

Thermal expansion due to the hot water heater in a residence will cause an over pressure condition if the back flow device prevents expansion backflow and there is no expansion tank or relief within the residential piping. The volume of thermal expansion is less than 0.25 gallons, so it does not constitute a contamination risk.

C. Permit based on general or statewide deviation contained in approved policy statement.

NO, but a policy is being developed.

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III.

NO

**VI. Documentation of Statement of Basis.**

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

**CERTIFICATION**

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on July 13, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



The State  
of Wyoming



# Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH 307-777-7758 FAX 777-3610	ABANDONED MINES 307-777-6145 FAX 777-6462	AIR QUALITY 307-777-7391 FAX 777-5616	INDUSTRIAL SITING 307-777-7369 FAX 777-6937	LAND QUALITY 307-777-7756 FAX 777-5864	SOLID & HAZ. WASTE 307-777-7752 FAX 777-5973	WATER QUALITY 307-777-7781 FAX 777-5973
--	---	---	---	--	--	---

July 13, 1999

Herman Noe  
Cheyenne Board of Public Utilities  
P.O. Box 1469  
Cheyenne, WY 82003-1469

Bruce Perryman  
AVI p.c.  
2035 Westland Road  
Cheyenne, WY 82001

Subject: Backflow Prevention Device Installation for Residential Taps

Dear Gentlemen:

This letter is to elaborate on condition 3 of Permit 99-261 for the service line re-connections on Mountain Road and Linden Way. There are several concerns that must be addressed when the water services are reconnected. Each commercial service or residential service without backflow prevention needs to be examined to determine the appropriate level of backflow prevention device to be installed. AWWA Guideline M14 and the Foundation for Cross Connection Control "Manual of Cross-Connection Control" should be used to make these determinations. Services with an increased risk of backflow need to have the appropriate level of backflow prevention device installed. Generally the required level of backflow prevention device will be a testable dual check.


In other communities when backflow prevention devices have been added at the meter to a residential service, frequent problems have been encountered with thermal expansion causing over pressure conditions within the residence. The Water Quality regulations end with the requirement for backflow protection. However, I strongly recommend that the engineer and the water utility make the residential and domestic properties with backflow prevention devices aware of the need for an expansion tank to accommodate thermal expansion.

July 13, 1999

Page 2

Where existing residential services do not have backflow prevention devices, the requirement for backflow protection may be waived based on a certification that the connection is free of an increased risk of backflow. If a situation that represents an increased risk of backflow, the appropriate level of backflow prevention must be installed. The minimum level is a testable dual check.

Sincerely,

A handwritten signature in cursive script that reads "Louis B. Harmon". The signature is written in black ink and is positioned above the typed name and title.

Louis B. Harmon PE  
SE District Engineering Supervisor  
Water Quality Division

LBH/mad 91745.ltr

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-262  
SPECIAL CONDITIONS

## Day Septic Tank/Leach Field

This permit hereby authorizes the applicant:

Paul and Holly Day  
P. O. Box 243  
Thermopolis, WY 82443

to construct a septic tank/leach field to serve a three bedroom residence according to the procedures and conditions of application number 99-262. The facility is located in Bobcat Estates Subdivision, Sec. 11, T42N, R95W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of 2 (two) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and this permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

9-13-99  
\_\_\_\_\_  
Date of Issuance

STATEMENT OF BASIS

I. General information.

Permit Number: 99-262

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

---

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on July 7, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JCH/bb/91715.ltr

# PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 99-263

## Rollins Shop Septic Tank/Leach Field

This permit hereby authorizes the applicant:

Elaine Rollins  
845 Amoretti  
Thermopolis, WY 82443

to construct a septic tank/leach field for a bathroom in a shop building according to the procedures and conditions of application number 99-263. The facility is located in Sec.5, T42N, R94W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of 2 (two) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Gary Beach  
Administrator  
Water Quality Division



Dennis Hemmer  
Director  
Department of Environmental Quality

7-26-99  
Date of Issuance

JCH/mad 91808.ltr  
cc: Hot Springs County

## STATEMENT OF BASIS

### I. General information.

Permit Number: 99-263

### II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

Yes

### IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter XI, Part D, Sections 38 and 41, includes sizing for trench, bed, and seepage pit systems. Infiltrators are new technology not included in the regulations.

B. Briefly state the basis for the deviation.

Research data provides sizing criteria found to be acceptable.

C. Permit based on general or statewide deviation contained in approved policy statement

13.41.2 This policy is the acceptable criteria for sizing leachfields using standard chamber units.

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on 7/19/99. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-264  
SPECIAL CONDITIONS

## Robbins Septic Tank/Leach Field

This permit hereby authorizes the applicant:

Frank Robbins  
346 Amoretti  
Thermopolis, WY 82443

to construct a septic tank/leach field to serve a 3 bedroom residence and bathroom in adjacent building according to the procedures and conditions of application number 99-264. The facility is located in Sec.32, T43N, R98W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of 2 (two) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



---

Gary Beach  
Administrator  
Water Quality Division



---

Dennis Hemmer  
Director  
Department of Environmental Quality

9-26-99  
Date of Issuance

JCH/mad 91811.ltr  
cc: Hot Springs County

## STATEMENT OF BASIS

### I. General information.

Permit Number: 99-264

### II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

Yes

### IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter XI, Part D, Sections 38 and 41, includes sizing for trench, bed, and seepage pit systems. Infiltrators are new technology not included in the regulations.

B. Briefly state the basis for the deviation.

Research data provides sizing criteria found to be acceptable.

C. Permit based on general or statewide deviation contained in approved policy statement

13.41.2 This policy is the acceptable criteria for sizing leach fields using standard chamber units.

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on July 19, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-265R  
SPECIAL CONDITIONS

## Bighorn Canyon NRA Ranger/Visitor Contact Station - Septic Tank/Leachfield

This permit hereby authorizes the applicant:

Bighorn Canyon N.R.A.  
#20 Highway 14A East  
Lovell, WY 82431

to construct a septic tank and leachfield for employee and visitor restrooms at a ranger station/visitor center according to the procedures and conditions of application number 99-265R. The facility is located in SE1/4 Section 34, T58N, R95W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

8-4-99  
\_\_\_\_\_  
Date of Issuance

STATEMENT OF BASIS

I. General information.

Permit Number: 99-265R

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle H. Conklin, Environmental Senior Analyst, and completed on August 2, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-266  
SPECIAL CONDITIONS

### BROOKS WATER SYSTEMS IMPROVEMENTS 1999 PHASE II

This permit hereby authorizes the applicant:

Town of Mills  
P.O. Drawer 789  
Mills, WY 82644

to construct, install or modify a water distribution system according to the procedures and conditions of the application numbers 99-266. The facility is located in Sections 1 of T33N R80W in the county of Natrona, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Casper WDEQ Field Office, 3030 Energy Lane, Casper, WY 82604, telephone (307) 473-3452; FAX (307) 473-3458.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

8-23-99  
\_\_\_\_\_  
Date of Issuance

JDL/pr:mad 92082.ltr

Enclosures: Construction Notice Post Card, Certificate of Completion and Statement of Basis

## STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 99-266
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter 11      No
- B. Chapter 12      Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- N/A
- B. Briefly state the basis for the deviation.
- N/A
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, NE Water & Wastewater Section Senior Analyst, and completed on August 17, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-267  
SPECIAL CONDITIONS

## North 4th Street Sanitary Sewer Interceptor Replacement - Douglas

This permit hereby authorizes the applicant:

City of Douglas  
P.O. Box 1030  
Douglas, Wyoming 82633

to construct, install, and modify sewer utility mains according to the procedures and conditions of the application number 99-267. The facility is located in the SW 1/4 of Section 4 and the NW 1/4 of Section 9, T32N, R71W in the county of Converse, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-19-99  
\_\_\_\_\_  
Date of Issuance

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 99-267
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.  
Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.  
No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.  
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.  
NOT Applicable
- B. Briefly state the basis for the deviation.  
NOT Applicable
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).  
NOT Applicable
- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

(Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on July 16, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/bb/91792.ltr

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-268  
SPECIAL CONDITIONS  
Permit Expiration Date

## CY AVENUE RECONSTRUCTION

This permit hereby authorizes the applicant:

City of Casper  
200 North David Street  
Casper WY, 82601

to construct, install or modify a water distribution system according to the procedures and conditions of the application numbers 99-268. The facility is located in Sections 17 & 48 T33N R79W in the county of Natrona, in the State of Wyoming. **This permit shall be effective until October 1, 1999. If capacity development is demonstrated by the City of Casper before October 1, 1999, the expiration date of this permit shall be extended to one year from the date of issuance of this permit.**

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Casper WDEQ Field Office, 3030 Energy Lane, Casper, WY 82604, telephone (307) 473-3452; FAX (307) 473-3458.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-29-99  
\_\_\_\_\_  
Date of Issuance

JDL/pr/mad 91882.ltr

Enclosures: Construction Notice Post Card, Certificate of Completion and Statement of Basis

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 99-268

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11 Yes

B. Chapter 12 Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

- B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

N/A

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

**CERTIFICATION**

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, NE Water & Wastewater Section Senior Analyst, and completed on July 27, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
Renewal  
 Modified

PERMIT NO. 99-269  
SPECIAL CONDITIONS  
REF/PERMIT NO. 84-580

## Torrington Well No. 15 Pump Replacement

This permit hereby authorizes the applicant:

Town of Torrington  
P.O. Box 250  
Torrington WY 84240-0250

to construct, install or modify a replacement of the existing 850 gpm pump with a single stage Goulds 11CLC pump with a 100 hp motor or equal operating at 1500 to 1600 gpm according to the procedures and conditions of the application number 99-269. The facility is located in Section 15 T24N R61W in the county of Goshen, in the State of Wyoming. This permit shall be effective until September 30, 1999.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-16-99  
\_\_\_\_\_  
Date of Issuance

LBH/mad 91788.ltr

## STATEMENT OF BASIS

- I. Permit Number: 99-269
- II. Application reviewed for compliance with the following regulations.
- A. Chapter XI. NO
- B. Chapter XII. YES
- III. Basis for issuing permit: Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- IV. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III.
- NO
- V. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on July 15, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
Renewal  
 Modified

PERMIT NO. 99-270  
SPECIAL CONDITIONS  
REF/PERMIT NO. 95-517

## Extension of Centennial Water System - Modified

This permit hereby authorizes the applicant:

Robert D. Ort  
P.O. Box 32  
Centennial, Wyoming 82055

to construct an extension to the publicly owned distribution system according to the procedures and conditions of the application number 99-270. The facility is located in the SW 1/4 of Section 02, T16N, R78W in the county of Albany, in the State of Wyoming. This permit shall be effective until September 30, 1999.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. All **modifications or deviations** from the authorized plans **must be highlighted**.

of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

August 12, 1999  
\_\_\_\_\_  
Date of Issuance

LE/mad 91932.ltr

## STATEMENT OF BASIS

### General information.

A. Permit Number: 99-270

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. Yes

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on August 9, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-271  
SPECIAL CONDITIONS

## Lots 1-10, Block 3, Richards Park, 6th Add. Laramie, Water and Sewer Improvements

This permit hereby authorizes the applicant:

TOG Development, Inc.  
407 Garfield Street  
Laramie WY 82070

to construct, install or modify 311 feet of 8" water main and 261 feet of 8" sewer main into Dale Court according to the procedures and conditions of the application number 99-271. The facility is located in SE 1/4 Section 27 T16N R73W in the county of Albany, in the State of Wyoming. This permit shall be effective until September 30, 1999.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-15-99  
\_\_\_\_\_  
Date of Issuance

LBH/bb/91758.ltr

cc: City of Laramie

## STATEMENT OF BASIS

- I. Permit Number: 99-271
- II. Application reviewed for compliance with the following regulations.
- A. Chapter XI. YES
- B. Chapter XII. YES
- III. Basis for issuing permit: Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- IV. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III.
- NO
- V. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on July 14, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LBH/bb/91758.ltr



The State  
of Wyoming



# Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

<b>ADMIN/OUTREACH</b> (307) 777-7758 FAX 777-3610	<b>ABANDONED MINES</b> (307) 777-6145 FAX 777-6462	<b>AIR QUALITY</b> (307) 777-7391 FAX 777-5616	<b>INDUSTRIAL SITING</b> (307) 777-7369 FAX 777-6937	<b>LAND QUALITY</b> (307) 777-7756 FAX 777-5864	<b>SOLID &amp; HAZ. WASTE</b> (307) 777-7752 FAX 777-5973	<b>WATER QUALITY</b> (307) 777-7781 FAX 777-5973
---	--	--	--	---	---	--

July 10, 2001

Larry R. Gallagher  
Summit Engineering, LLC  
5907 Townsend Place  
Cheyenne, WY 82009

RE: **Time Extension for Permit # 99-272:** Cheyenne Ranch Subdivision Water & Sanitary Sewer Extensions

Dear Mr. Gallagher:

The Wyoming Department of Environmental Quality/Water Quality Division has received your request for a time extension on the above mentioned project. The current expiration date for this permit is August 13, 2001.

Whereas your letter requesting the time extension states that the last phase of this project is still planned to be constructed as per the original permitted design, with no significant changes; the Water Quality Division hereby approves and authorizes a time extension until August 13, 2003.

If you should have any further questions, please call me at (307) 777-6183.

Sincerely,

Ronald L. Ewald  
Environmental Senior Analyst  
Southeast District, Water Quality Division

RLE/bb/11715.ltr

cc: ✓IPS Tracking File

Permit # 99-272 Archive

Cheyenne Board of Public Utilities, P.O. Box 1469, Cheyenne, Wyoming 82003

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-272  
SPECIAL CONDITIONS

## Cheyenne Ranch Subdivision Water & Sanitary Sewer Extensions

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities  
P.O. Box 1469  
Cheyenne, Wyoming 82003

to construct, install, and modify water and sanitary sewer utilities according to the procedures and conditions of the application number 99-272. The facility is located in the NE 1/4 of Section 34, T14N, R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 4. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION) the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**

4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Gary Beach  
Administrator  
Water Quality Division



Dennis Hemmer  
Director  
Department of Environmental Quality

8-13-99  
Date of Issuance

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 99-272

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on August 11, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-273  
SPECIAL CONDITIONS

### SHERIDAN PRODUCTS TERMINAL

This permit hereby authorizes the applicant:

CONOCO, INCORPORATED  
600 North Dairy Ashford  
Houston, TX 77252-2197

to construct, install or modify monitor wells according to the procedures and conditions of the application number 99-273. The facility is located in Section 7, Township 54 North, Range 83 West in the county of Sheridan, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Wyoming Department of Environmental Quality, Water Quality Division, Groundwater Program, 1043 Coffeen Avenue, Sheridan, WY 82801; telephone 307-672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1. The Subsurface Investigation and Report of Investigation shall be conducted in accordance with the conditions and policies listed in Water Quality Division, Groundwater Pollution Control Program Guidelines Number 2 (Subsurface Investigation) and Number 3 (Report of Investigation). These documents were supplied to the SECOR International, Inc. office in Billings, Montana.
2. Soil and groundwater samples will be analyzed for BTEX and MTBE by EPA Method 8021, and TPH (GRO) and TPH (DRO) by EPA Method 8015 Modified. A groundwater sampling schedule for this facility will be established by the department after review of the Report of Investigation.
3. All correspondence concerning this facility shall be submitted to the following address: Groundwater Program Supervisor, Wyoming Department of Environmental Quality, Water Quality Division, 1043 Coffeen Ave., Sheridan, WY 82801.


AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

1-15-99  
\_\_\_\_\_  
Date of Issuance

DF/bb/91760.ltr



**GROUNDWATER POLLUTION CONTROL PROGRAM**  
**REVIEW COMMENTS:**  
**PLANS/SPECIFICATIONS/PROPOSALS/REPORTS**

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
1043 COFFEEN AVENUE, SUITE D  
Sheridan, WY 82801

PROJECT: Site Investigation

FACILITY: Conoco Sheridan Products Terminal

LOCATION: Section 7/Township 54N/Range 83W; Approximately 5 miles south of Sheridan,  
geographic coordinates: 106.903259 West Long, 44.663774 North Latitude

APPLICANT: Conoco Incorporated  
600 North Dairy Ashford  
Houston, TX 77252-2197  
Attn: Andrew Stow  
Phone: (281) 293-2582

CONSULTANT: SECOR International, Inc.  
2905 Montana Ave.  
Billings, MT 59101  
Attn: Jim Sullivan  
Phone (406) 245-7600

WATER QUALITY DIVISION REFERENCE (PERMIT) NUMBER: 99-273  
 EXISTING  NEW  AS-BUILT

TITLE: Sheridan Products Terminal Site Investigation

PLANS  SPECS  PROPOSAL  REPORT

DATE ON PROPOSAL/PLANS/REPORT: 7/8/99

IS THIS PROPOSAL SUBMITTED PURSUANT TO:

'CONDITIONS' TO ANY WQD PERMIT?  NO  YES

AN LOV, NOV OR OTHER ENFORCEMENT?  NO  YES

REVIEWING GEOLOGIST: Don Fischer, North District Program Principal, Groundwater Program  
DATE OF THIS REVIEW: 7/13/99

ACTION: Permit to Construct Number 99-273 authorized pursuant to attached conditions.

**COMMENTS: GROUNDWATER SECTION**

**I. SUMMARY OF EXISTING CONTAMINATION:**

In July, 1998 SECOR installed four hand auger borings near the north side of the Sheridan Products Terminal for the purpose of collecting soil samples for analyses. Each boring was augered to depth of 5.2 feet below ground surface. The lithology consisted of medium to very plastic brown/green clay with interbedded sand lenses.

Based on field screening for PID readings, seven soil samples were submitted for laboratory analyses. The samples were analyzed for benzene, toluene, ethylbenzene, and xylenes (BTEX), 8015 Modified for gasoline range organics (GRO) and 8015 Modified for diesel range organics (DRO). Samples SB-1 3.2' and SB-3 3.8' were analyzed by EPA Method 6010 for lead.

<b>TABLE 2</b>												
<b>SUMMARY OF SOIL SAMPLING RESULTS</b>												
<b>SHERIDAN PRODUCTS TERMINAL</b>												
<b>SHERIDAN, WYOMING</b>												
<b>SECOR Project No. 2C701-006-01</b>												
<b>Soil</b>	<b>Sample</b>	<b>Benzene</b>	<b>Toluene</b>	<b>Ethyl- Benzene</b>	<b>Total Xylenes</b>	<b>DRO</b>	<b>DRO as Diesel</b>	<b>THE</b>	<b>GRO</b>	<b>GRO as Gasoline</b>	<b>TVH</b>	<b>Lead</b>
<b>Sample</b>	<b>Date</b>	<b>(mg/kg)</b>	<b>(mg/kg)</b>	<b>(mg/kg)</b>	<b>(mg/kg)</b>	<b>(mg/kg)</b>	<b>(mg/kg)</b>	<b>(mg/kg)</b>	<b>(mg/kg)</b>	<b>(mg/kg)</b>	<b>(mg/kg)</b>	<b>(mg/kg)</b>
SB-1 3.2'	7/31/98	ND	ND	ND	ND	305	305	305	23	ND	223	ND
SB-1 5.0'	7/31/98	ND	ND	ND	2.1	1290	1290	1290	62	ND	766	NA
SB-2 4.2'	7/31/98	ND	ND	ND	ND	33	33	35	ND	ND	25	NA
SB-3 3.8'	7/31/98	ND	ND	ND	1.7	1180	1180	1180	56	ND	250	ND
SB-3 5.2'	7/31/98	ND	ND	ND	ND	92	92	92	10	ND	36	NA
SB-4 3.5'	7/31/98	ND	1.1	ND	8.2	3800	3800	3800	127	ND	518	NA
SB-4 5.2'	7/31/98	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NA
<b>Notes:</b>												
DRO - Diesel Range Organics												
GRO - Gasoline Range Organics												
THE - Total Extractable Hydrocarbons												
TVH - Total Volatile Hydrocarbons												
mg/kg - Milligram per kilogram												
ND - Parameter not detected at Practical Quantitation Limit (PQL)												
NA - Not Analyzed												

## II. METHODOLOGY

1. To investigate potential impacts to groundwater, six borings will be drilled to a depth of 15 feet, with each boring completed as a monitor well. During the installation of the borings soil samples will be collected every five feet for field screening and lithology descriptions. The monitor wells will be constructed utilizing two inch casing. Soil and groundwater samples will be analyzed for BTEX and MTBE by EPA Method 8021, TPH (GRO) and TPH (DRO) by EPA Method 8015 Modified.

## III. REQUESTS/REQUIREMENTS/RECOMMENDATIONS:

1. The Subsurface Investigation and Report of Investigation shall be conducted in accordance with the conditions and policies listed in Water Quality Division, Groundwater Pollution Control Program Guidelines Number 2 (Subsurface Investigation) and Number 3 (Report of Investigation). These documents were supplied to the SECOR International, Inc. office in Billings, Montana.
2. All correspondence concerning this facility shall be submitted to the following address: Groundwater Program Supervisor, Wyoming Department of Environmental Quality, Water Quality Division, 1043 Coffeen Ave., Sheridan, WY 82801.

**END OF REVIEW**

DF/bb/91761.ltr

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-274  
SPECIAL CONDITIONS

## BP-Amoco Greybull Refinery Monitor Wells

This permit hereby authorizes the applicant:

BP-Amoco Corporation  
P.O. Box 160  
Casper, WY 82602

to construct, install or modify monitor wells and direct push wells according to the procedures and conditions of the application number 99-274. The facility is located in NE and NW ¼, Section 17, Township 52 North Range 93 West in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Wyoming Department of Environmental Quality, Water Quality Division, Groundwater Program, 1043 Coffeen Avenue, Sheridan, WY 82801; telephone 307-672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


1. All samples from monitor wells that are sampled under this investigation shall be analyzed for BTEX and trimethylbenzenes utilizing EPA Method 8260.
2. The department will establish a sampling and analyses schedule upon completion of review of the Report of Investigation. The Report of Investigation shall be submitted to the WDEQ Sheridan office in the schedule stated in Section 4 of the permit application.

**AUTHORIZED BY:**

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-22-99  
\_\_\_\_\_  
Date of Issuance



**GROUNDWATER POLLUTION CONTROL PROGRAM**  
**REVIEW COMMENTS:**  
**PLANS/SPECIFICATIONS/PROPOSALS/REPORTS**

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
1043 COFFEEN AVENUE, SUITE D  
SHERIDAN, WYOMING 82801

PROJECT: Site Investigation

FACILITY: Amoco Former Greybull Refinery

APPLICANT: Amoco Corporation

ENGINEER: Joe Deschamp  
Amoco Corporation  
P.O. Box 160  
Casper, WY 82602

CONSULTANT: ThermoRetec, Inc.  
1726 Cole Blvd.  
Building 22, Suite 150  
Golden, CO 80401  
Attn: Tim Richards

WATER QUALITY DIVISION REFERENCE (PERMIT) NUMBER: 99-274

EXISTING  NEW  AS BUILT

TITLE: 1999 Groundwater Investigation Work Plan, Former Refinery Property, BP Amoco Oil Company, Greybull, Wyoming

PLANS  SPECS  PROPOSAL  REPORT

DATE ON PROPOSAL/PLANS/REPORT: Received 7/1/99

IS THIS PROPOSAL SUBMITTED PURSUANT TO:

'CONDITIONS' TO ANY WQD PERMIT?  NO  YES

AN LOV, NOV OR OTHER ENFORCEMENT?  NO  YES

REVIEWING GEOLOGIST: Don Fischer, North District Program Principal, Groundwater Program

DATE OF THIS REVIEW: July 16, 1999

ACTION: Permit Number 99-274 authorized

## COMMENTS: GROUNDWATER SECTION

### I. LOCATIONAL AND BACKGROUND DATA

The former refinery is located on the southwest side of the town of Greybull in Big Horn County. It is bounded on the east by the BN Railroad and the town of Greybull, the west and south by undeveloped land, and by an active oil production field to the north. The "legal" location of the facility is the NE&NW ¼ Section 17, Township 52 North, Range 93 West.

Most of the site is vacant, and most of the structures have been dismantled and removed from the site. Most of the property is owned by the town of Greybull. Presently, Amoco does not own any of the former refinery property.

### II. SUMMARY OF EXISTING CONTAMINATION:

#### **Objectives of Workplan**

- 1) Determine the status of several groundwater monitor wells at the site, and if necessary, repair, abandon, or replace them;
- 2) Further delineate the areal extent of dissolved benzene, toluene, ethylbenzene, and xylene concentrations that exceed MCL's;
- 3) Investigate the source of the free phase hydrocarbon plume.

The following wells could not be located for the 1998 sampling event: MW-19A, MW-21, MW-41, MW-42, MW-47D, MW-48D, and OW-11. Monitor well MW-8 has been destroyed. The flush mounted lid on MW-23 could not be removed.

BP Amoco proposes to research all available files and coordinates for these wells. MW-8 will be properly abandoned if the well casing is intact. MW-23 will be repaired.

#### **Free Phase Hydrocarbons**

Of the 46 monitor wells sampled during the 1998 event, six wells contained measurable free phase hydrocarbons. The wells were as follows: MW-30, MW-44S, MW-43D, MW-46D, OW-1, and OW-7. The actual hydrocarbon thickness measured in the wells are as listed in the following table:

MONITOR WELL NUMBER	DEPTH TO FPH	DEPTH TO WATER	THICKNESS OF FPH
MW#43D	29.35	30.17	0.82
MW#44S	25.97	25.98	0.01
MW#46D	20.9	21.30	0.40
OW-1	20.65	20.70	0.05
OW-7	8.53	13.20	4.67

\*All measurements in feet

\*FPH = free phase hydrocarbons

Trenching and monitor wells will be installed to further delineate the extent of the free product plume.

**DISSOLVED PHASE HYDROCARBONS**

According to the report, at least one or more the BETX constituents were detected in six of the nine wells that were sampled and benzene was detected above the MCL in five of the nine wells sampled ( MW-6, MW-7, MW-16A, MW-27, and MW-37D).

<b>HYDROCARBON ANALYSES OF GROUNDWATER SAMPLES</b>							
<b>Well I.D.</b>	<b>Benzene (ug/l)</b>	<b>Toluene (ug/l)</b>	<b>Ethylbenzene (ug/l)</b>	<b>Xylene (ug/l)</b>	<b>1,3,5-TMB (ug/l)</b>	<b>1,2,4-TMB (ug/l)</b>	<b>1,2,3-TMB (ug/l)</b>
MW-4	<10.0	<10.0	<10.0	<20.0	<10.0	<10.0	<10.0
MW-6	5.2	<10.0	<10.0	<20.0	<10.0	<10.0	<10.0
MW-7	73.3	<10.0	<10.0	<20.0	<10.0	<10.0	<10.0
MW-9	<10.0	<10.0	<10.0	<20.0	<10.0	<10.0	<10.0
MW-16A	72.6	<20.0	279	40.4	<20.0	88.2	<20.0
MW-18	<5.0	<5.0	<5.0	<10.0	<5.0	<5.0	<5.0
MW-27	1,220	454	570	760	218	544	298
MW-37D	194	87.8	45.4	346	39.4	118	61.4
OW-3	<20.0	<20.0	32	151.6	67.8	167	126

\*The MCL for benzene is 5 micrograms/liter (parts per billion)

Delineation of BTEX concentrations in groundwater is proposed in the vicinity of monitoring wells MW-16A, MW-27, and MW-7. The workplan is designed to investigate the source and downgradient limits of the dissolved phase hydrocarbons. Both direct push techniques and monitor wells will be utilized.

**III. REQUESTS/REQUIREMENTS/RECOMMENDATIONS**

1. The following monitor wells will be sampled during the 1999 monitoring event: MW-4, MW-6, MW-7, MW-9, MW-16A, MW-18, MW-27, MW-36, MW-37D, MW-48D, and OW-3. These wells will also be sampled for background parameters for bio-parameters (methane, nitrates, sulfates, ferrous iron, and dissolved oxygen). The depth to groundwater and presence of free phase hydrocarbon will also be documented.
2. All samples from monitor wells that are sampled under this investigation shall be analyzed for BTEX and trimethylbenzenes using EPA method 8260.
3. The Report of Investigation shall be submitted to the WDEQ Sheridan office as stated in Section 4 of the permit application.

**END OF REVIEW**

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-275  
SPECIAL CONDITIONS

## AMOCO GREYBULL PILOT REMEDIATION SYSTEMS

This permit hereby authorizes the applicant:

BP-AMOCO  
PO BOX 160  
CASPER, WY 82602

to construct, install or modify pilot scale enhanced fluid recovery and air sparge systems according to the procedures and conditions of the application number 99-275. The facility is located in NE & NW ¼ Section 17, Township 52 North, Range 93 West in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Wyoming Department of Environmental Quality, Water Quality Division, Groundwater Program, 1043 Coffeen Avenue, Sheridan, WY 82801; telephone 307-672-6457.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

**1. Monitoring**

Monitoring requirements and frequency during the IAS test are listed in Table 2 of the permit application. Monitor parameters will include dissolved oxygen and pressure.

The following monitor wells will be sampled approximately 3 months after the long term IAS pilot test has been in operation: MW-4, MW-27, MW-28S, OW-5, OW-3, OW-4, and any sparge monitoring wells in the area of MW-27. Water samples from these wells will be analyzed for BTEX and trimethylbenzenes using EPA Method 8260 and for DO using field instruments. In addition, the concentrations of dissolved carbon dioxide and methane will be measured.

**2. Reporting**

The completed EFR and IAS pilot tests activities will be submitted in a report to the WDEQ within 90 days of receipt of the laboratory results from final groundwater sampling scheduled to take place 3 months after the long term IAS pilot test startup. The report will contain the following:

- Documentation of all fieldwork including boring logs, well completion logs, and survey coordinates;
- Summary of all analytical data;
- Summary of the groundwater monitoring status;
- Groundwater elevation map;
- Extent of free phase and dissolved phase hydrocarbons.

**EFR Pilot Test**


- Table of operating flow rates and vacuum at each EFR well;
- Table summarizing the volume of FPH removed from each EFR well;
- Table of VOC concentrations in the air stream;
- Table of water level measurements and FPH thickness at each EFR well;
- Table of FPH recovery following the pilot test at each EFR well;
- Plot of FPH recovery vs. time.

**IAS Pilot Test**

- Table of operating flow rates and pressures at each sparge point;
- Table of pressures at each sparge monitoring well;
- Table of oxygen, carbon dioxide, and VOC concentrations at each sparge sparge point and sparge monitoring well;
- Table of water level measurements and FPH thickness (if encountered) at each sparge monitoring well;
- Plot showing pressure in vadose zone vs. distance from sparge points;
- Plot of oxygen, carbon dioxide, and VOC concentrations vs. time for each sparge point and sparge monitoring well.

The pilot test report will present the conclusions based upon the evaluation of the EFR and IAS pilot tests and present recommendations for further investigation and remediation activities at the site.

AUTHORIZED BY:



Gary Beach  
Administrator  
Water Quality Division




Dennis Henner  
Director  
Department of Environmental Quality

8-2-99

Date of Issuance

df/mad 91889.ltr





**GROUNDWATER POLLUTION CONTROL PROGRAM**  
**REVIEW COMMENTS:**  
**PLANS/SPECIFICATIONS/PROPOSALS/REPORTS**

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
1043 COFFEEN AVENUE, SUITE D  
SHERIDAN, WYOMING 82801

PROJECT: Site Investigation

FACILITY: Amoco Former Greybull Refinery

APPLICANT: Amoco Corporation

ENGINEER: Joe Deschamp  
Amoco Corporation  
P.O. Box 160  
Casper, WY 82602

CONSULTANT: ThermoRetec Consulting Corporation  
23 Old Town Square, Suite 250  
Fort Collins, CO 80524  
Attn: Tim Richards

WATER QUALITY DIVISION REFERENCE (PERMIT) NUMBER: 99-275

EXISTING  NEW  AS BUILT

TITLE: EFR and IAS Pilot Testing Work Plan, Former Refinery Property, BP Amoco Oil Company, Greybull, Wyoming

PLANS  SPECS  PROPOSAL  REPORT

DATE ON PROPOSAL/PLANS/REPORT: Received 7/1/99

IS THIS PROPOSAL SUBMITTED PURSUANT TO:  
'CONDITIONS' TO ANY WQD PERMIT?  NO  YES

AN LOV, NOV OR OTHER ENFORCEMENT?  NO  YES

REVIEWING GEOLOGIST: Don Fischer, North District Program Principal, Groundwater Program  
REVIEWING ENGINEER: Scott Forister  
DATE OF THIS REVIEW: July 28, 1999

ACTION: Permit Number 99-275 authorized

**COMMENTS: GROUNDWATER SECTION**

**I. LOCATIONAL AND BACKGROUND DATA**

The former refinery is located on the southwest side of the town of Greybull in Big Horn County. It is bounded on the east by the BN Railroad and the town of Greybull, the west and south by undeveloped land, and by an active oil production field to the north. The "legal" location of the facility is the NE&NW ¼ Section 17, Township 52 North, Range 93 West.

Most of the site is vacant, and most of the structures have been dismantled and removed from the site. Most of the property is owned by the town of Greybull. Presently, Amoco does not own any of the former refinery property.

**II. SUMMARY OF EXISTING CONTAMINATION:**

**Free Phase Hydrocarbons**

Of the 46 monitor wells sampled during the 1998 event, six wells contained measurable free phase hydrocarbons. The wells were as follows: MW-30, MW-44S, MW-43D, MW-46D, OW-1, and OW-7. The actual hydrocarbon thickness measured in the wells are as listed in the following table:

MONITOR WELL NUMBER	DEPTH TO FPH	DEPTH TO WATER	THICKNESS OF FPH
MW#43D	29.35	30.17	0.82
MW#44S	25.97	25.98	0.01
MW#46D	20.9	21.30	0.40
OW-1	20.65	20.70	0.05
OW-7	8.53	13.20	4.67

- \*All measurements in feet
- \*FPH = free phase hydrocarbons

Trenching and monitor wells will be installed to further delineate the extent of the free product plume.

**DISSOLVED PHASE HYDROCARBONS**

According to the report, at least one or more the BETX constituents were detected in six of the nine wells that were sampled and benzene was detected above the MCL in five of the nine wells sampled ( MW-6, MW-7, MW-16A, MW-27, and MW-37D).

<b>HYDROCARBON ANALYSES OF GROUNDWATER SAMPLES</b>							
<b>Well I.D.</b>	<b>Benzene (ug/l)</b>	<b>Toluene (ug/l)</b>	<b>Ethylbenzene (ug/l)</b>	<b>Xylene (ug/l)</b>	<b>1,3,5-TMB (ug/l)</b>	<b>1,2,4-TMB (ug/l)</b>	<b>1,2,3-TMB (ug/l)</b>
MW-4	<10.0	<10.0	<10.0	<20.0	<10.0	<10.0	<10.0
MW-6	5.2	<10.0	<10.0	<20.0	<10.0	<10.0	<10.0
MW-7	<b>73.3</b>	<10.0	<10.0	<20.0	<10.0	<10.0	<10.0
MW-9	<10.0	<10.0	<10.0	<20.0	<10.0	<10.0	<10.0
MW-16A	<b>72.6</b>	<20.0	279	40.4	<20.0	88.2	<20.0
MW-18	<5.0	<5.0	<5.0	<10.0	<5.0	<5.0	<5.0
MW-27	<b>1,220</b>	454	570	760	218	544	298
MW-37D	<b>194</b>	87.8	45.4	346	39.4	118	61.4
OW-3	<20.0	<20.0	32	151.6	67.8	167	126

\*The MCL for benzene is 5 micrograms/liter (parts per billion)

Given the direction of groundwater flow, the relative positions of the dissolved benzene concentrations, and the FPH plume, the FPH plume does not appear to be the sole source for all of the dissolved benzene concentrations. Multiple sources relating to previous operations and disposal practices likely resulted in several sources that now contribute to groundwater contamination.

### Objectives of Workplan

The objectives of the proposed pilot tests are to evaluate the effectiveness of Enhanced Fluid Recovery (EFR) and In-Situ Air Sparging (IAS) at the former refinery property. The data from the proposed test will be used to:

- Evaluate the feasibility of using EFR to remove free phase product from the surface of the site;
- Design a full scale IAS system.

The Scope of Work for this permit includes the following:

#### EFR Pilot Test

- Installing a free phase interceptor trench adjacent to groundwater monitoring well OW-7 to enhance free phase hydrocarbon recovery;
- Conducting pilot EFR testing at three locations to evaluate the effectiveness of EFR at the site.

### IAS Pilot Test

- Installing sparge points and sparge monitoring wells at three selected areas (based on delineation of benzene concentrations) to facilitate IAS pilot testing;
- Conducting IAS pilot testing to evaluate the effectiveness of IAS at reducing dissolved benzene concentrations in the groundwater.

### EFR PILOT TEST

The proposed EFR pilot test system will include the following components:

- EFR wells (OW-7, MW-43D, and OW-1)
- FPH recovery trench (adjacent to OW-7)
- Extraction "stinger" and piping
- Flow and pressure regulator
- Vacuum truck

#### *Evaluation and Continuation/Termination*

After the evaluation of the 1-hour extraction period, FPH thickness in the wells will be measured at 0, 1, 5, 10, 15, 30, 60, 100, 500, and 1000 minutes using an oil water interface probe to determine whether significant recovery of FPH has taken place. If after 100 minutes more than 50 percent of the initial FPH thickness has accumulated in the EFR well, FPH thickness measurements will be discontinued and second EFR test will be performed. The volume and removal rate of FPH collected during the first test will guide the Length of the second test. FPH recovery will also be measured after the second test at the same intervals above.

If EFR pilot testing suggests that the FPH can be removed with this technique, BP Amoco proposes to evaluate the use of EFR on a regular basis. The evaluation criteria will be based on measured thickness of FPH in the wells, extraction rates, and recovery rates following pilot testing. Recommendations will be included in the Report of Investigation.

### IN-SITU AIR SPARGING PILOT TEST

The primary purpose of the proposed IAS pilot test is to maximize the amount of constituents removed by biodegradation, not air stripping or volatilization. This technique would also be referred to as biosparging. The IAS is proposed for removing dissolved benzene in the three pilot test areas, and for removing residual FPH at the facility.

Sparge points and performance monitor wells will be installed in the three areas (MW-16A, MW-27, and MW-6/MW-7) where the delineation of benzene exceeds the MCL. The components of the IAS pilot test systems include:

- sparge points
- sparge monitoring wells
- air compressor and distribution piping.

The total number and locations of sparge points will depend of the results of the benzene delineation work completed as part of the groundwater investigation plan (Permit 99-274). In general, sparge points will be installed downgradient from the benzene sources and upgradient of a permanent monitoring well. The sparge points will be placed in a line perpendicular to groundwater flow direction and will not be installed further apart than 30 feet, which corresponds to a 15 foot radius of influence.

The wells will be used to measure changes in dissolved oxygen (DO) concentrations during the test as well as being used for groundwater sampling for the long-term IAS pilot test.

#### *Pilot Test Duration and Operation*

IAS pilot testing consists of injecting air into the sparge points and monitoring the effects in surrounding monitor wells. Injection air rates and pressures will be recorded during the tests to allow calculation of the requirements for permanent installations.

The short term test results will be used to estimate the radius of influence that can be expected during IAS operation. The long-term results will provide analytical results that can be used to predict the effects of air stripping, volatilization, and biodegradation of benzene concentrations at the site.

### **III. REQUESTS/REQUIREMENTS/RECOMMENDATIONS**

#### *Monitoring*

Monitoring requirements and frequency during the IAS test are listed in Table 2 of the permit application. Monitor parameters will include dissolved oxygen and pressure.

The following monitor wells will be sampled approximately 3 months after the long term IAS pilot test has been in operation: MW-4, MW-27, MW-28S, OW-5, OW-3, OW-4, and any sparge monitoring wells in the area of MW-27. Water samples from these wells will be analyzed for BTEX and trimethylbenzenes using EPA Method 8260 and for DO using field instruments. In addition, the concentrations of dissolved carbon dioxide and methane will be measured.

#### *Reporting*

The completed EFR and IAS pilot tests activities will be submitted in a report to the WDEQ within 90 days of receipt of the laboratory results from final groundwater sampling scheduled to take place 3 months after the long term IAS pilot test startup. The report will contain the following:

- Documentation of all fieldwork including boring logs, well completion logs, and survey coordinates;
- summary of all analytical data;
- summary of the groundwater monitoring status
- groundwater elevation map;
- extent of free phase and dissolved phase hydrocarbons

#### EFR Pilot Test

- table of operating flow rates and vacuum at each EFR well;
- table summarizing the volume of FPH removed from each EFR well;
- table of VOC concentrations in the air stream;
- table of water level measurements and FPH thickness at each EFR well;
- table of FPH recovery following the pilot test at each EFR well;
- plot of FPH recovery vs. time

#### IAS Pilot Test

- table of operating flow rates and pressures at each sparge point;
- table of pressures at each sparge monitoring well;
- table of oxygen, carbon dioxide, and VOC concentrations at each sparge sparge point and sparge monitoring well;
- table of water level measurements and FPH thickness (if encountered) at each sparge monitoring well;
- plot showing pressure in vadose zone vs. distance from sparge points;
- plot of oxygen, carbon dioxide, and VOC concentrations vs. time for each sparge point and sparge monitoring well.

The pilot test report will present the conclusions based upon the evaluation of the EFR and IAS pilot tests and present recommendations for further investigation and remediation activities at the site.

### END OF REVIEW

f:/.../sites\_gpc/amoco/greybull/99-275.rev

WDF/mad 91890.ltr

# PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 99-276  
SPECIAL CONDITIONS  
REF/PERMIT #94-090RR

## Spray System for Evaporation Pond

This permit hereby authorizes the applicant:

Burlington Resources  
P. O. Box 51810  
Midland, TX 79710-1810

to install a spray system to enhance evaporation according to the procedures and conditions of application number 99-276. The facility is located in SW1/4 NE1/4 Sec. 11, T38N, R90W in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of 2 (two) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of this permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-26-99  
\_\_\_\_\_  
Date of Issuance

JCH/jm  
b/91820.ltr

## STATEMENT OF BASIS

I. General information.

Permit Number: 99-276

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III.

N/A

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by, Jeff Hermansky, Northwest District Supervisor, and completed on July 20, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JCH/bb/91820.ltr

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-277  
SPECIAL CONDITIONS

## First Avenue Waterline Extension

This permit hereby authorizes the applicant:

Town of Afton  
416 Washington  
Afton, WY 83110

to construct a waterline extension according to the procedures and conditions of application number 99-277. The facility is located in NW 1/4 S30 T32W R118W in the county of Lincoln, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 5 Disinfection and pressure testing of the waterlines shall be as required by Chapter 12 of the Water Quality Rules and Regulations.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-29-99  
\_\_\_\_\_  
Date of Issuance

## STATEMENT OF BASIS

I. General information.

Permit Number: 99-277

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, SW District Supervisor, and completed on 20 July 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

x New  
Renewal  
Modified

PERMIT NO. 99-278R  
SPECIAL CONDITIONS

### Electric Addition Utility Rehabilitation - Phase V PWS #WY5601181

This permit hereby authorizes the applicant:

City of Green River  
50 East 2nd North  
Green River, WY 82935

to modify a water distribution system by looping lines and replacing existing lines with 100 feet of 6" PVC line, 960 feet of 8" PVC line, 20 feet of 12" PVC line, and 40 feet of 16" PVC line (plus related valves and fire hydrants), and replacement of 1,683 feet of existing sanitary sewer (including some manholes) with 8" PVC sanitary sewer line according to the procedures and conditions of application number 99-278R. The facility is located in SE1/4 Section 22, T18N, R107W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
- a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

6-12-00  
\_\_\_\_\_  
Date of Issuance

DHC/dc  
b/01481.ltr

cc: Green River-Rock Springs-Sweetwater County JPWB, Attn: Bryan Seppie, P.O. Box 1299, Green River, WY 82935

## STATEMENT OF BASIS

General information.

Permit Number: 99-278R

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

Not Applicable

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle Conklin, SW District Engineering Supervisor, and completed on June 7, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

DHC/bb/01481.ltr

PERMIT TO CONSTRUCT

New  
Renewal  
 Modified

PERMIT NO. 99-279  
SPECIAL CONDITIONS  
REF/PERMIT NO. 96-487

Wyoming Premium Farms Finisher No. 1

This permit hereby authorizes the applicant:

Wyoming Premium Farms  
P.O. Box 457  
Wheatland WY 82201

to install of 5 @ 5hp Aeromix Tornado Surface Aspirating Aerators according to the procedures and conditions of the application number 99-279. The facility is located in SE 1/4 Section 31 T26N R67W in the county of Platte, in the State of Wyoming. This permit shall be effective for a period of 6 months from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 7 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 7 The applicant will provide immediate oral or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 7 The dissolved oxygen content and fluctuations of Cell #1 without aeration through out the diurnal cycle should be measured. The dissolved oxygen content should be measured at six points across the lagoon surface at depths of 12", 24", and 36" at sun up, early afternoon, and 30 minutes after sundown. The air temperature, water temperature, wind velocity and direction, and sky conditions should be recorded for each measurement period. These measurement should be taken for a minimum of two 24 hour periods. The same measurements should be repeated after the aerators have been operating for a minimum of 72 hours.
- 4 of 7 Please provide as-built drawings of the aerator installation. The as-built information should include the oxygen transfer rate of the individual aerators as tested, a calculation of the transfer rate at the altitude of the installation, and the mixing zone of each aerator.
- 5 of 7 In December of 1999 please submit an operation and maintenance manual for use of the aerators to reduce odors. This O&M manual should reflect the lessons learned during the initial six months of operation.
- 6 of 7 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.

7 of 7 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-15-99  
\_\_\_\_\_  
Date of Issuance

LBH/mad 91747.ltr

## STATEMENT OF BASIS

- I. Permit Number: 99-279
- II. Application reviewed for compliance with the following regulations.
- A. Chapter XI. YES
- B. Chapter XII. NO
- III. Basis for issuing permit.
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- NO
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- YES
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- NO
- IV. Facilities not specifically covered by regulations
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- The applicable regulation is Chapter 11 of the Water Quality Division Rules and Regulations. Section 29 describes wastewater retention systems for feedlots, which really doesn't apply to swine confinement facilities. Section 18, Lagoons, was written to apply to the disposal and treatment of sewage. The wastewater disposal at a swine confinement facility is similar in operation to sewage collection and treatment processes. The WPF Finisher No. 1 lagoons are designed to be deep, anaerobic cells. However, section 18 describes only facultative and aerated lagoons.

B. Briefly state the basis for the deviation.

The anaerobic lagoon known as cell #1 at WPF Finisher Site No. 1 is generating pervasive objectionable odors at certain times. The odors seem to be caused by gases being generated in the anaerobic zone in the bottom of the lagoon. It is hoped that by creating a zone of water with high dissolved oxygen content at the surface that escaping gases will be oxidized. Oxidation is thought to eliminate the odor causing potential of the gases generated in a reducing environment. Wyoming Premium Farms is adding aeration to reduce the odors.

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III.

NO

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on July 13, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-280  
SPECIAL CONDITIONS

## Mark Shanahan Farm Small Wastewater Treatment Facility

This permit hereby authorizes the applicant:

Mark A. Shanahan  
2312 Tunnel Road  
Wheatland, Wyoming 82201

to construct and install a residential type septic system with leach field according to the procedures and conditions of the application number 99-280. The facility is located in the SE 1/4 of Section 21, T23N, R68W in the county of Platte, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 5. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION) the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**
- 4 of 5. **Septic Tank Riser Requirement** - On Windmeier Construction septic tanks, either a 6 inch diameter clean-out riser or the manway must be extended to the ground surface.

5 of 5. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Gary Beach  
Administrator  
Water Quality Division



Dennis Hemmer  
Director  
Department of Environmental Quality

7-26-99

Date of Issuance

RLE/bb/91816.ltr

STATEMENT OF BASIS

I. General information.

A. Permit Number: 99-280

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on July 20, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/bb/91816.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

REVIEW OF PLANS AND SPECIFICATIONS  
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION

Herschler Bldg., 4 West  
Cheyenne, Wyoming 82002

PROJECT: Cherokee Meadows Subdivision, Lot 46: Residential Septic System

ENGINEER: None

APPLICANT: Richard Blake  
P.O. Box 133  
Encampment, Wyoming 82325

WATER QUALITY DIVISION REFERENCE NUMBER: 99-281

REVIEWING ENGINEER: Ronald L. Ewald *RLE*  
Phone: (307) 777-6183

DATE OF REVIEW: July 19, 1999

**ACTION:** NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 12 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

**COMMENTS, INADEQUACIES, AND QUESTIONS:**

1. Percolation Tests Not Properly Completed and Incorrectly Calculated - You show your slowest perk rate as 7 minutes per inch (mpi) when it should be 24mpi (6 minute/0.25 inch = 24.0 mpi). Additionally, the tests should be run until the water level drop rate is consistent for three (3) consecutive measurements as per instruction (d)(I). Test hole 3 never did stabilize ( 1.75 inch, then 1.25", 1.0", 0.5", 0.5", 0.25") for 3 consecutive readings. The other test holes also need to be rerun until 3 consecutive measurements are within 1/8 of an inch. Please redo the percolation test and then recalculate the leach field area required.

A more detailed "PERCOLATION TEST RESULTS" form is included with this review for your use. An example test is shown on the right side of the page and the example time interval (ti) is 5 minutes. If more than 10 time intervals are needed keep going until the drop rate stabilizes. If the test holes need to be refilled part way through the test, refill it and note it on the form.

2. Where is the Nearest Surface Water? - Is it the Encampment River, and how far away is it from your site? And, in what direction? Also, which way is north?
3. Seasonal High Groundwater Depth - Your application indicates that it is more than 10 feet to groundwater as determined by a backhoe cut on July 6, 1999. The "seasonal high groundwater level" needs to be determined, not just the groundwater level on the day the test pit was made. To determine the seasonal high groundwater level you need someone who is able to "read the soil column." An experienced person, such as a Professional Engineer, can determine the seasonal high groundwater level even during the dry season by reading the soil. Please have a qualified person help you determine the seasonal high groundwater level at your site. This is a critical factor for the proper design of a leach field and needs to be determined accurately.

RLE/bb/91814.ltr

Enclosure: Supplementary "PERCOLATION TEST RESULTS" form

# PERMIT TO CONSTRUCT

✓  
New  
Renewal  
Modified

PERMIT NO. 99-281  
SPECIAL CONDITIONS

## Cherokee Meadows Subdivision, Lot 46: Residential Septic System

This permit hereby authorizes the applicant:

Richard Blake  
P.O. Box 133  
Encampment, Wyoming 82325

to construct and install a residential septic system with a chamber type leach field according to the procedures and conditions of the application number 99-281. The facility is located in the South ½ South ½ of Section 31, T15N, R83W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 6. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 6. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions this permit.
- 3 of 6. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**
- 4 of 6. **Septic Tank Riser Requirement** - On Vaughn Concrete Products septic tanks, either a 6 inch diameter clean-out riser or the manway must be extended to the ground surface from each compartment.

- of 6. Flow Equalization Required - Because the "Infiltrator" leach trenches are not interconnected, an equal amount of effluent from the septic tank must be delivered to the head of each trench. This can be accomplished by either using a distribution box or a combination of simple pipe tee's placed perpendicular to the flow. Either 2, 3, or 4 equal length trenches can be used so long as a **minimum of 25 sections of "Infiltrator" chambers** are installed. If 3 trenches are used, then a distribution box should be installed between the septic tank and the head of the 3 trenches. If either 2 or 4 trenches are used, then the flow can be equally divided by installing the pipe tee's in a cascading arrangement. See note on plan sheet.
- 6 of 6. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

9-2-99  
\_\_\_\_\_  
Date of Issuance

RLE/mad 92188.ltr

cc: Carbon County Planner/Sanitarian

## STATEMENT OF BASIS

### General information.

A. Permit Number: 99-281

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

- VI. Deleted

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on August 30, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-282  
SPECIAL CONDITIONS

## Jim and Mary Oaks Residential Septic System, Ryan Park

This permit hereby authorizes the applicant:

Jimmy C. and Mary E. Oaks  
419 East Murray  
Rawlins, Wyoming 82301

to construct and install a residential septic system with leach field according to the procedures and conditions of the application number 99-282. The facility is located in the South ½ of Section 28, T16N, R81W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to

enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 8. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 8. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 8. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**
- 4 of 8. Septic Tank Riser Requirement - On Vaughn Concrete Products septic tanks, either a 6 inch diameter clean-out or the manway must be extended to the ground surface from each tank compartment.
- 5 of 8. Leach Field Trench Depths Restricted - Because of locally shallow groundwater depths (approximately 4 to 4.5 feet), **the leach trenches shall not be made more than 6 to 8 inches deep** - just enough to remove the roots of the plants and even out the trench bottoms. Six(6) inches of washed rock shall then be placed in the trench and the perforated pipe placed on top of the rock. More rock shall then be added to cover the pipe by at least two(2) inches, then a layer of untreated building paper or straw, followed by at least two(2) feet of cover soil. This will create a mound approximately 2 ½ to 3 feet high. Enough cover soil shall be placed to protect the system from freezing.

- of 8. Septic Tank Freeze Protection Required - Because the septic tank will have to be very near to the natural ground surface in order to accommodate the shallow leach trenches described above, the septic tank will have to be protected from freezing. The tank shall be protected on all four sides (to within one foot of the bottom of the tank) and the top (including the manhole covers) by gluing rigid foam insulation (recommended for contact with the soil) to the tank. The insulation shall have a minimum "R" value of at least:

$$"R" = 5 + [1.25 * (\text{Local elevation(ft)}/1000 - 4.0) ]$$

For the Ryan Park area (elevation 8300 feet) this works out to a minimum "R" value of 10.5. Additionally, several feet of cover soil should then be mounded up over the septic tank as needed to protect against the local winter conditions. Note - insulation is not required on the bottom of the tank.

- 7 of 8. Inspection Required - Before the final cover soil is applied, the WQD shall be notified to perform an inspection. The top 1 foot of the septic tank should be exposed (including the sides of the tank with insulation in place), and the trench construction should be viewable. Contact Ron Ewald at least two days before the inspection is needed at (307) 777-6183.
- 8 of 8. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

8-19-99  
\_\_\_\_\_  
Date of Issuance

RLE/mad 92045.ltr

cc: Carbon County Planner/Sanitarian

## STATEMENT OF BASIS

General information.

A. Permit Number: 99-282

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

- VI. Deleted

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on August 17, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.



The State  
of Wyoming



## Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH	ABANDONED MINES	AIR QUALITY	INDUSTRIAL SITING	LAND QUALITY	SOLID & HAZ. WASTE	WATER QUALITY
307-777-7758	307-777-6145	307-777-7391	307-777-7369	307-777-7756	307-777-7752	307-777-7781
FAX 777-3610	FAX 777-6462	FAX 777-5616	FAX 777-6937	FAX 777-5864	FAX 777-5973	FAX 777-5973

August 17, 1999

Jim and Mary Oaks  
419 East Murray  
Rawlins, Wyoming 82301

RE: **Inspection and Reporting Requirements** for Permit # - 99-282

Dear Mr. and Mrs. Oaks:

Included with this letter you will find your approved "Permit to Construct". This permit includes conditions which require you, the recipient of the permit, to submit follow-up information and/or reports concerning the implementation of this permit. **Standard reporting requirements** include the following:

1. Estimated Construction Schedule Post Card (Condition 1)
2. Notify the WQD of any changes (Condition 2)
3. Submission of CERTIFICATION OF COMPLETION form within 60 days of completion of the project, along with as-constructed plans if changes were made in accordance with condition 2 of the permit (Condition 3)

In addition to the requirements listed above, this permit includes an **inspection requirement** which is **specific to this project**. Because Ryan Park is a sensitive area, the Water Quality Division (W.D.) has decided that an on-site inspection by W.D. personnel before the final cover material is placed is necessary. Therefore:

4. Condition 7 requires that you notify the W.D. at least two(2) days prior to placing the final cover to arrange for an on-site inspection.

Please read all of the permit conditions carefully and follow through as required. Finally, bear in mind that the inspection and submittal of these items are requirements of the permit and must be adhered to and properly completed in order for you to be in compliance with the terms and conditions of your permit.

If you have any questions regarding these matters, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald  
Senior Analyst  
SE District, Water Quality Division

RLE/mad 92044.ltr

Enclosure: Permit Referenced Above

AS-BUILT  
PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 99-283  
SPECIAL CONDITIONS  
REF/PERMIT #99-160

Union Pacific Railyard, Rawlins, WY

This permit hereby authorizes the applicant:

Union Pacific Railroad Company  
1416 Dodge St.  
Omaha, NE 68179

to have constructed, installed or modified monitoring wells and bore holes according to the procedures and conditions of the application number 99-283. The facility is located in Rawlins in the county of Carbon, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, meets applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee has constructed and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


1. No monitoring well/piezometer shall be abandoned without prior approval from the Water Quality Division. After the monitoring well(s)/piezometer(s) have fulfilled their purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. In addition, borings in public use areas, particularly paved streets and alleys, shall be abandoned in accordance with City and/or Highway Department requirements.
2. WDEQ/WQD personnel shall be given at least two (2) weeks notice prior to the installation of monitor well(s)/piezometer(s) and sample collection so that they may be on site if deemed necessary.
3. The applicant is responsible for obtaining any Permits required by the State Engineer's Office (777-7354).
4. The results of any other analyses conducted on soil or water removed from these wells/piezometers or boreholes shall be provided to the department as soon as they are available.
5. ***Environmental Monitoring Program for Groundwater of the State:***
  - a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity and performed in accordance with WDEQ or EPA approved Standard Procedures or Quality Assurance/Quality Control (QA/QC) Plan.
  - b. The permittee shall maintain records of all monitoring information for a period of at least 3 years.
  - c. Records of monitoring information shall include:
    - i. The date, exact place, and time of sampling or measurements;
    - ii. The name(s) of individual(s) who performed the sampling or measurements;
    - iii. The Mean Sea Level elevation of the water table to the closest .01 ft., and the depth to water (to the closest .01 ft.) from a marked measuring point at the top of casing.
    - iv. Sampling procedures and sample preservation accomplished;
    - v. The date(s) analyses were performed;
    - vi. Names of individuals who performed the analyses;
    - vii. The analytical techniques or methods used; and
    - viii. The results of such analyses.
    - ix. Monitor wells shall be sampled and the groundwater analyzed as indicated on the following table:


Well Name	SAMPLING FREQUENCY	ANALYTICAL METHOD(S)	PARAMETER(S) ANALYZED	PERMIT LIMIT*
GW1, GW5, GW6, GW7	Quarterly	EPA 8015	TVH-Gasoline	10.0
GW1, GW5, GW6, GW7	Quarterly	EPA 8020	Benzene	0.005
GW1, GW5, GW6, GW7	Quarterly	EPA 8020	Toluene	1.0
GW1, GW5, GW6, GW7	Quarterly	EPA 8020	Ethylbenzene	0.7
GW1, GW5, GW6, GW7	Quarterly	EPA 8020	Total Xylenes	10.0

\* Permit Limits (i.e. Groundwater Protection Standards) are only required for compliance monitoring wells. All chemical concentrations in this permit are expressed in mg/l unless otherwise noted.

6. The permittee shall notify the Department of Environmental Quality of any permit limit exceedances in monitoring wells GW1, GW5, GW6, or GW7 within twenty four hours of detection.

AUTHORIZED BY:

  
 Gary Beach  
 Administrator  
 Water Quality Division

  
 Dennis Hemmer  
 Director  
 Department of Environmental Quality

7-26-99  
 Date of Issuance

DM/bb/91797.ltr

cc: Curt Dominicak/BCSS  
 Kevin Frederick/WQD

## REVIEW OF PROPOSALS/PLANS

### WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY

Herschler Bldg., 4 West  
Cheyenne, Wyoming 82002

PROJECT: **Union Pacific Railroad, Rawlins Railyard Gasoline Release, Rawlins, WY**

APPLICANT: **Union Pacific Railroad Company**

WATER QUALITY DIVISION REFERENCE (PERMIT) NUMBER: **Appl 99-283**

TITLE: **Subsurface Investigation Permit Review**

PROPOSAL     PLANS     REPORT    (Check each that applies)


DATE ON PROPOSAL/PLANS/REPORT: **July 14, 1999**

REVIEWING GEOLOGIST: **Daniel Moore, PG**

DATE OF LAST REVIEW: **NA**

DATE OF THIS REVIEW: **July 16, 1999**

ACTION: **Permit 99-283 issued.**



#### COMMENTS:

1. This permit is issued for an *as-built* Subsurface Investigation. The scope of this investigation is to determine the nature and extent of contamination in groundwater resulting from a natural gasoline spill that occurred January 02, 1999 at the Union Pacific railyard in Rawlins, WY.
2. The application materials for this investigation consist of two letters, dated June 10, 1999 and June 28, 1999, provided by Boots and Coots Special Services on behalf of the Union Pacific Railroad Company. The letters outline the scope of work for the subsurface investigation.
3. The investigation activities include installing boreholes (geoprobe) and monitoring wells in the vicinity of the spill. Groundwater samples collected from the geoprobe holes were analyzed in the field using a gas chromatograph with fixed base laboratory confirmation.

July 16, 1999

Page 2

Groundwater samples collected from the monitoring wells were sent to a fixed base laboratory for analysis.

4. The Union Pacific Railroad shall provide DEQ with a Report of Investigation within 60 days of obtaining groundwater sampling results generated in this investigation.

**End of Review**

DM/bb/91796.ltr



The State  
of Wyoming



## Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH	ABANDONED MINES	AIR QUALITY	INDUSTRIAL SITING	LAND QUALITY	SOLID & HAZ. WASTE	WATER QUALITY
307-777-7758	307-777-6145	307-777-7391	307-777-7369	307-777-7756	307-777-7752	307-777-7781
FAX 777-3610	FAX 777-6462	FAX 777-5616	FAX 777-6937	FAX 777-5864	FAX 777-5973	FAX 777-5973

July 16, 1999

Mr. Gary L. Honeyman  
Manager of Environmental Field Operations  
Union Pacific Railroad  
221 Hodgeman  
Laramie, WY 82072

Re: Permit to Construct [Subsurface Investigation], Union Pacific Railroad, Natural Gasoline Release, 100 Front St., Rawlins, WY, WQD Permit #99-283

Dear Mr. Honeyman:

Please find enclosed Wyoming Department of Environmental Quality, Water Quality Division (WQD), As Built Permit to Construct #99-283. The WQD has reviewed the permit application materials provided by Union Pacific Railroad Company for a Subsurface Investigation. The purpose of the investigation is to determine the nature and extent of groundwater contamination resulting from a natural gasoline spill at the Rawlins railyard. The Union Pacific has addressed WQD comments on draft application materials and, therefore, the WQD approves the Union Pacific's permit application. Please note that the DEQ is requiring a Report of Investigation within 60 days of obtaining groundwater sampling results. If you have any questions concerning this letter please contact me at (307) 777-7092.

Sincerely,

Daniel Moore  
Program Principal  
Water Quality Division

DM/bb/91795.ltr

cc: Curtis Dominicak/BCSS  
Kevin Frederick/WQD

# PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 99-284  
SPECIAL CONDITIONS

## Ty & Rebecca Kaisler Residential Septic System

This permit hereby authorizes the applicant:

Ty Kaisler  
P.O. Box 155  
Savery, Wyoming 82332

to construct and install a residential septic system with leach field according to the procedures and conditions of the application number 99-284. The facility is located in the SW 1/4 of Section 22, T13N, R89W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 5. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION) the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**
- 4 of 5. Norwesco Septic Tank Installation Requirements - To ensure structural integrity, the manufacturer's **instructions** regarding filling the tank with water during burial and immediately after pumping it out, **must be followed** during installation.

5 of 5. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Gary Beach  
Administrator  
Water Quality Division



Dennis Hemmer  
Director  
Department of Environmental Quality

7-26-99  
Date of Issuance

RLE/bb/91819.ltr

cc: Carbon County Planner/Sanitarian

## STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 99-284
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. Yes
- B. Chapter XII. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.  
Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.  
No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.  
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.  
NOT Applicable
- B. Briefly state the basis for the deviation.  
NOT Applicable
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).  
NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on July 20, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/bb/91819.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-285  
**\*SPECIAL CONDITIONS\***  
Permit Expiration Date

### City of Worland - Water Main Replacements - Various Intersections

This permit hereby authorizes the applicant:

City of Worland  
P.O. Box 226  
Worland, WY 82401

to replace water mains at four street intersections according to the procedures and conditions of application number 99-285. The facility is located in NW1/4 NE1/4 Section 25, T47N, R93W and SW1/4 NW1/4 Section 30, T47N, R92W in the county of Washakie, in the State of Wyoming. **This permit shall be effective until October 1, 1999. If capacity development is demonstrated by the City of Worland before October 1, 1999, the expiration date of this permit will be extended to two (2) years from the date of issuance of this permit.**

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and this permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-29-99  
\_\_\_\_\_  
Date of Issuance

STATEMENT OF BASIS

I. General information.

Permit Number: 99-285

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle H. Conklin, Environmental Senior Analyst, and completed on July 26, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-286  
SPECIAL CONDITIONS  
Reference 99-046

## SUNDANCE WEST WATER DISTRIBUTION SYSTEM

This permit hereby authorizes the applicant:

F&F CONSTRUCTION, LLC  
P.O. Box 1540  
Mills, WY 82644

to construct, install or modify a water distribution system according to the procedures and conditions of the application numbers 99-286. The facility is located in the E/2 of Section 10, SW/4 of Section 11, NW/4 of Section 14 and the NE/4 of Section 15 of T51N R63W in the county of Crook, in the State of Wyoming. The permit shall be effective until October 1, 1999. If capacity development is demonstrated by the Town of Sundance, the expiration date of the permit shall be one (1) year from the date of issuance.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.

4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

8-4-99  
\_\_\_\_\_  
Date of Issuance

DRM/pr/mad 91913.ltr

Enclosures: Construction Notice Post Card, Certificate of Completion and Statement of Basis

xc: Ralph Goodson, Bearlodge, POB 130, Sundance, WY 82729

John Kiplinger, Town of Sundance, Sundance, WY 82729

## STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 99-286
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter 11      No
- B. Chapter 12      Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- No
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- Part(b)(i) of Section 14 of Chapter 12 of the WWQRR requires water systems to maintain a normal working pressure of 35 psi.
- B. Briefly state the basis for the deviation.
- The applicant's consultant has run hydraulic analysis on the proposed water system. The analysis indicates only two of the 55 lots in the subdivision will have normal working pressures under 35 psi. The rest of the lots will be between 35 and 112 psi. The two lots in question are located near the proposed storage tank and the hydraulic analysis yields normal working pressures of 30 psi for each lots, which should be satisfactory for rural residential use.

- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

Not Applicable (N/A)

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

- B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

**CERTIFICATION**

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Don McKenzie, NE Water & Wastewater Section Program Principal, and completed on August 2, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## LAND APPLICATION PERMIT

Y  
New  
Renewal  
Modified

PERMIT NO. 99-287  
SPECIAL CONDITIONS  
Reference 98-402

### KN POWDER RIVER 16" PIPELINE HYDROSTATIC TEST WATER LAND APPLICATION

This permit hereby authorizes the applicant:

KN Energy  
370 Van Gordon Street  
Lakewood, CO 80228-8304  
Attention: Michael Crisman

to land apply uncontaminated hydrostatic test water according to the procedures and conditions of the application number 99-287. The application site is located in the NE/4 of the NE/4 of Section 22 in T43N R71W in Campbell County in the State of Wyoming. This permit shall be effective until November 1, 1999.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the land application described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the land application. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (DEQ/WQD), upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this land application permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall land apply the uncontaminated hydrostatic test water in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 6 The permittee shall notify representatives from the DEQ/WQD the day the land application commences and give an estimate of completion of the project with the attached POST CARD. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Northeast District Aphacia Coffeen Avenue, Suite D, Sheridan, Wyoming, 82801, Attention: Don McKenzie; telephone (307) 672-6457; FAX (307) 674-5060.

- 2 of 6 The applicant will provide immediate oral and/or written notice to the DEQ/WQD Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 6 Within sixty (60) days of completion of the land application, the applicant will submit to the DEQ/WQD Northeast District Office the attached CERTIFICATION OF COMPLETION form.
- 4 of 6 The discharged hydrostatic test water will not contain any additives, such as corrosion inhibitors and surfactants, and shall be analyzed for benzene (EPA Method 602) prior to land application. The tested hydrostatic test water will not be land applied if the benzene concentration exceeds 5 parts per billion.
- 5 of 6 The discharged hydrostatic test water shall not reach any surface water, including stream and drainages.
- 6 of 6 The review and approval of this permit is based upon the items identified in the attached STATEMENT OF BASIS.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach, Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer, Director  
Department of Environmental Quality

7-16-99  
\_\_\_\_\_  
Date of Issuance

DRM/mad 91781.ltr

Enclosures: Post Card, Certification of Completion, Statement of Basis

xc: Nick Mathis, Greystone, 5231 South Quebec St., Greenwood Village, CO, 80111

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 99-287

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Not Applicable. The quality of the hydrostatic test water to be land applied will not impact groundwater.

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Don McKenzie, Northeast Water & Wastewater Program Principal, and completed on July 15, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-288  
SPECIAL CONDITIONS

## Olson Septic Tank/Leach Field

This permit hereby authorizes the applicant:

Joan Olson  
P. O. Box 128  
Thermopolis, WY 82443

to construct a septic tank/leach field to serve a 3 bedroom residence according to the procedures and conditions of application number 99-288. The facility is located in NE1/4 SE1/4 Sec. 6, T8N, R4E Wind River Meridian in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of 2 (two) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

4-29-99  
\_\_\_\_\_  
Date of Issuance

## STATEMENT OF BASIS

### I. General information.

Permit Number: 99-288

### II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

Yes

### IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter XI, Part D, Sections 38 and 41, includes sizing for trench, bed, and seepage pit systems. Infiltrators are new technology not included in the regulations.

B. Briefly state the basis for the deviation.

Research data provides sizing criteria found to be acceptable.

C. Permit based on general or statewide deviation contained in approved policy statement

13.41.2 This policy is the acceptable criteria for sizing leach fields using standard chamber units.

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on July 26, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

# PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 99-289  
SPECIAL CONDITIONS

## James & Jan Garrett Residential Septic System

This permit hereby authorizes the applicant:

James Garrett  
Box 6234  
Laramie, Wyoming 82073

to construct and install a residential septic system with chamber type leach bed according to the procedures and conditions of the application number 99-289. The facility is located in parts of Sections 07, 08, 17, and 18, T18N, R79W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 4. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;  
or

- d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. All **modifications or deviations** from the authorized plans **must be highlighted**.

4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-18-99  
\_\_\_\_\_  
Date of Issuance

RLE/mad 92627.ltr

cc: Carbon County Planner/Sanitarian

## STATEMENT OF BASIS

General information.

A. Permit Number: 99-289

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 14, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.



The State  
of Wyoming



## Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---

January 3, 2000

Mr. Bryon Rogers  
Flying J Travel Plaza  
2250 Etchepare Drive  
Cheyenne WY 82007

Subject: Cheyenne Plaza Stormwater Operations, DEQ/WQD Permit Application # 99-290

Dear Mr. Rogers:

Thank you for your letter to follow up our meeting December 29, 1999. We appreciate your cooperation to address the stormwater runoff impacts from the Cheyenne Travel Plaza.

As you indicate in your letter that you will be changing consulting engineers, the present permit application #99-290 is being returned without further action. The final detention pond of the present system is not part of a permitted design. To comply with the renewal of your NPDES permit dated 25 August 1999, an approved permit for the stormwater treatment system must be obtained.

The Water Quality Division will grant Flying J an additional three months to April 3, 2000 to submit a new application for permit to construct with a design report, plans, and specifications for a storm water waste treatment and disposal system. DEQ approval must be obtained by July 3, 2000, including supplying satisfactory responses to any issues raised as part of WQD reviews. The project shall be completed by October 30, 2000.

Sincerely,

Louis B. Harmon PE  
SE District Engineering Supervisor  
Water Quality Division

LBH/bb/00012.ltr

cc: Roland Peterson

ec: Maggie Davison, Leah Krafft, Brian Mark

REVIEW OF PLANS AND SPECIFICATIONS  
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION

Herschler Bldg., 4 West  
Cheyenne, Wyoming 82002

PROJECT: Cheyenne Flying J Travel Plaza Oil-Water Separator Detention Pond Upgrade

ENGINEER: Maxim Technologies, Inc., Casper, WY

APPLICANT: Cheyenne Flying J Travel Plaza

WATER QUALITY DIVISION REFERENCE NUMBER: 99-290

REVIEWING ENGINEER: Louis B. Harmon

DATE OF REVIEW: July 15, 1999



**ACTION:** NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 12 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. The design report uses as a basis of design a detention pond capable of holding a 2-year/2-hour storm event. As a matter of practice, if the facility is to not have a NPDES permit, the detention pond should be designed to hold a 24-hour/100-year storm.
2. The design report should establish the volume of water to be disposed of annually. In addition to storm run-off that is collected, a significant amount of water used for cleaning is introduced to the system. The facility should have maintenance records that will be useful for preparing rate and total volume of flow to be treated.
3. If the facility is to maintain a NPDES permit, then the design report should demonstrate the treatment process is capable of producing an effluent that will meet the NPDES permit limits.
4. Three copies of the design report, plans and specifications should accompany the Chapter III Application for Permit to Construct. The application for permit to construct must be signed by the owner or the owner's authorized representative.

LBH/bb/91793.ltr

Enclosure: 3 copies of Chapter III Permit to Construct

cc: Leah Krafft

## ROAD APPLICATION PERMIT

New  
 Renewal  
 Modified

PERMIT NO. 99-291R  
SPECIAL CONDITIONS

### Santa Fe Snyder Corporation - Beaver Creek Field

This permit hereby authorizes the applicant:

Santa Fe Snyder Corporation  
P.O. Box 1190  
Riverton, WY 82501

to road apply approximately 9,370 cubic yards of waste crude oil sludges according to the procedures and conditions of application number 99-291R. The application site is located in Sections 3, 4 and 34, T33N, T96W in the county of Fremont, in the State of Wyoming. This permit shall be effective until November 1, 1999.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 8 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307) 332-3183.
- 2 of 8 The permittee will provide immediate oral and/or written notice to the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
- 3 of 8 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the attached Certification of Completion form, the following information:
- A. Date that the road application was completed; and
  - B. Certification the road application was done in accordance with the terms and conditions of the permit; or
  - C. Certification the road application was completed with changes or modifications. Submit the information necessary to clearly indicate the road application as actually performed. This information shall include a contour map depicting only those sections of road that actually received the approximately 9,370 cubic yards of waste crude oil sludges.
- 4 of 8 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 8 Approximately 9,300 cubic yards of waste crude oil sludges shall be applied uniformly and incorporated into the roadbed. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. Waste crude oil sludges shall not be applied during the period from November 1 to April 10.
- 6 of 8 The application site slope shall not exceed eight percent (8%) for vehicular application.
- 7 of 8 The waste crude oil sludge application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.

3 of 8 Only the roads designated in this permit are authorized for application of the . Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

9-27-99  
\_\_\_\_\_  
Date of Issuance

DHC/mad 92432.ltr

cc: BLM, Lander Field Office, Attn: Lynn Harrison, P.O. Box 589, Lander, WY 82520  
Office of State Land & Investments, Attn: Jim Whalen, 122 West 25th Street, Cheyenne, WY 82002  
Darren Smith, SIERRA Environmental, 21 Hwy 10, Jelm, WY 82063

## STATEMENT OF BASIS

### I. General information.

Permit Number: 99-291R

### II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. No

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are not numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed modified or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement.

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria

for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter I

Applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the 9,370 cubic yards of waste crude oil sludges onto the roadbed. These segments of roadbed will be monitored for the accumulation of hazardous substances by roadbed analyses prior to permitting future road applications to the same roadbed segments.

- B. Quality of waste is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle H. Conklin, Environmental Senior Analyst, and completed on September 21, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-292  
SPECIAL CONDITIONS

## Town of Afton - Ben Nield #2 Addition Waterline Extension

This permit hereby authorizes the applicant:

Town of Afton  
P.O. Box 310  
Afton, WY 83110

to construct an 8-inch water line extension according to the procedures and conditions of application number 99-292. The facility is located in NE1/4 S36 T32N R119W in the county of Lincoln, in the State of Wyoming. This permit shall be effective until 30 September 1999.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 5 The water line shall be disinfected in accordance with AWWA 651.

AUTHORIZED BY:

  
Gary Beach  
Administrator  
Water Quality Division

  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-26-99  
Date of Issuance

## STATEMENT OF BASIS

I. General information.

Permit Number: 99-292

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, SW District Supervisor, and completed on 22 July 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RRT/bb/91836.ltr

## PERMIT TO CONSTRUCT

X New  
- Renewal  
- Modified

PERMIT NO. 99-293  
SPECIAL CONDITIONS

### 1600 Dewar Drive water main extension and sewer collection system extension

This permit hereby authorizes the applicant:

Great Western Auto Plex  
2100 Elk Street  
Rock Springs, WY 82901

to construct water and sewer mainline extensions and appurtenances according to the procedures and conditions of application number 99-293. The facility is located in the City of Rock Springs at 1600 Dewar Drive S34 T19N R109W in the county of Sweetwater, in the State of Wyoming. This permit shall be effective until 30 September 1999 for the water system extension and for a period of two years from the date of issuance of this permit for the sewer system extension.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of this permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 5 The waterlines shall be disinfected in accordance with the methods of AWWA 651. The water lines shall be pressure tested according to the requirements of Chapter 12 of the DEQ/WQD Water Quality Rules and Regulations, and the sewer lines shall be tested for deflection and for infiltration/exfiltration according to the requirements of Chapter 11 of the Water Quality Rules and Regulations (these requirements are also consistent with the latest edition of the Wyoming Public Works specifications).

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

7-29-99  
\_\_\_\_\_  
Date of Issuance

RRT/mad 91848.ltr

cc: Joint Powers Water Board; P.O. Box 1299; Green River, WY 82935

STATEMENT OF BASIS

I. General information.

Permit Number: 99-293

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, SW District Supervisor, and completed on 23 July 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-294  
**\*SPECIAL CONDITIONS\***  
Permit Expiration Date

### Wal-Mart, Rock Springs, WY (Store #1461-01)

This permit hereby authorizes the applicant:

Wal-Mart Real Estate Business Trust  
702 SW 8th St.  
Bentonville, AR 72716

to construct water and sanitary sewer pipelines according to the procedures and conditions of application number 99-294. The facility is located in SE1/4 S33 and SW1/4 S34 T19N R105W in the county of Sweetwater, in the State of Wyoming. **This permit shall be effective until October 1, 1999 for construction of the water line, and for a period of two (2) years from the date of issuance of this permit for construction of the sanitary sewer line. If capacity development is demonstrated by the City of Rock Springs before October 1, 1999, the expiration date for construction of the water line will be extended to two (2) years from the date of issuance of this permit.**

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and this permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

8-4-99  
\_\_\_\_\_  
Date of Issuance

RRT/mad 91912.ltr

cc: City of Rock Springs; 212 D Street; Rock Springs, WY 82901  
Michael Crowson, P.E., Pacific Land Design, 9709 Third Ave. NE, Suite 203, Seattle, WA 98115

## STATEMENT OF BASIS

I. General information.

Permit Number: 99-294

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Randall Taylor, SW District Supervisor, and completed on 26 July 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 99-295R  
**\*SPECIAL CONDITIONS\***  
Permit Expiration Date

## Shoshoni Senior Citizens Housing Development - Phase I

This permit hereby authorizes the applicant:

Town of Shoshoni  
P.O. Box 267  
Shoshoni, WY 82649

to construct a 210 linear foot water main extension and a 180 linear foot sanitary sewer main extension according to the procedures and conditions of application number 99-295R. The facility is located in NE1/4 Section 28, T38N, R94W in the county of Fremont, in the State of Wyoming. This permit shall be effective until October 1, 1999 for construction of the water main extension, and for a period of two (2) years from the date of issuance of this permit for construction of the sanitary sewer main extension. If capacity development is demonstrated by the Town of Shoshoni before October 1, 1999, the expiration date for construction of the water main extension will be extended to two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner

and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

August 12, 1999  
\_\_\_\_\_  
Date of Issuance

STATEMENT OF BASIS

I. General information.

Permit Number: 99-295R

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle H. Conklin, Environmental Senior Analyst, and completed on August 6, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 99-296R  
**\*SPECIAL CONDITIONS\***  
Permit Expiration Date

### Wentworth Apartments - Evanston

This permit hereby authorizes the applicant:

Thomas Development  
413 W. Idaho Street, Suite 200  
Boise, ID 83702

to construct a water distribution system extension and a sanitary sewer collection system extension according to the procedures and conditions of application number 99-296R. The facility is located in Section 27, T15N, R120W in the county of Uinta, in the State of Wyoming. This permit shall be effective until October 1, 1999 for construction of the water system extension, and for a period of two (2) years from the date of issuance of this permit for construction of the sanitary sewer system extension. If capacity development is demonstrated by the City of Evanston before October 1, 1999, the expiration date for construction of the water system extension will be extended to two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents a permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

8-13-99  
\_\_\_\_\_  
Date of Issuance

DHC/mad 91980.ltr

cc: City of Evanston, Attn: Brian Honey, 1200 Main Street, Evanston, WY 82930

## STATEMENT OF BASIS

### I. General information.

Permit Number: 99-296R

### II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. Yes

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations.

Not Applicable

### V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle H. Conklin, Environmental Senior Analyst, and completed on August 10, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-297  
SPECIAL CONDITIONS

### Thermopolis Water Tank Monitoring System

This permit hereby authorizes the applicant:

Town of Thermopolis  
P. O. Box 603  
Thermopolis, WY 82443

to install a radio telemetry unit and programmable controller according to the procedures and conditions of application number 99-297. The facility is located in SW1/4 Sec.1, T42N, R95W and NW1/4 Sec.36, T43N, R95W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective until September 30, 1999.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to Jeff Hermansky, Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of this permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

8-2-99  
\_\_\_\_\_  
Date of Issuance

## STATEMENT OF BASIS

I. General information.

Permit Number: 99-297

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. No

B. Chapter XII. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III.

N/A

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Supervisor, and completed on July 28, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-298R  
SPECIAL CONDITIONS

## Five Springs Campground - Holding tank

This permit hereby authorizes the applicant:

BLM - Cody Field  
1002 Blackburn Ave.  
Cody, WY 82414

to construct a holding tank for seasonal use by a small camp trailer or motor home according to the procedures and conditions of application number 99-298R. The facility is located in NE1/4 Section 30, T56N, R92W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the NW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-18-99  
\_\_\_\_\_  
Date of Issuance

## STATEMENT OF BASIS

I. General information.

Permit Number: 99-298R

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle H. Conklin, Environmental Senior Analyst, and completed on August 9, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

X New  
Renewal  
Modified

PERMIT NO. 99-299  
SPECIAL CONDITIONS

## Sublette County Ag Center - Septic Tank/Leachfield

This permit hereby authorizes the applicant:

Sublette County  
P.O. Box 250  
Pinedale, WY 82941

to construct a septic tank and leachfield system according to the procedures and conditions of application number 99-299. The facility is located in NE1/4 Section 17, T30N, R111W in the county of Sublette, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

8-3-99  
Date of Issuance

DHC/dhc  
b/91920.ltr

cc: Keith Raney, Sublette County Sanitarian, P.O. Box 722, Pinedale, WY 82941

STATEMENT OF BASIS

General information.

Permit Number: 99-299

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>.

Not Applicable

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle H. Conklin, Environmental Senior Analyst, and completed on August 3, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

DHC/bb/91920.ltr

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 99-300  
SPECIAL CONDITIONS

## HOLLY PONDS COMMERCIAL AREA

This permit hereby authorizes the applicant:

Holly Ponds, LLC  
P.O. Box 6793  
Sheridan, WY 82801  
Attention: Jim Willey

to construct, install or modify water distribution and wastewater collection systems according to the procedures and conditions of the application numbers 99-300. The facility is located in the SE/4 of Section 21 of T56N R84W in the county of Sheridan, in the State of Wyoming. This permit shall be effective until October 1, 1999. If capacity development is demonstrated by the City of Sheridan before October 1, the expiration of the permit shall be one (1) year from the date of issuance.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and this permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of this permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

8-4-99  
\_\_\_\_\_  
Date of Issuance

DRM/pr/mad 91914.ltr

Enclosures: Post Card, Certificate of Completion & Statement of Basis  
xc: Bill Mentock, M-W, #2 Taylor Pl. 1030 N.Main, Sheridan, 82801  
Susan Fields, City of Sheridan, P.O. Box 848, un

## STATEMENT OF BASIS

### I. General information.

A. Permit Number: 99-300

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11 Yes

B. Chapter 12 Yes

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

**CERTIFICATION**

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Don McKenzie, NE Water & Wastewater Section Program Principal, and completed on August 2, 1999. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

