

**AS-BUILT**  
**PERMIT TO CONSTRUCT**

New  
Renewal  
Modified

PERMIT NO. 00-351R  
SPECIAL CONDITIONS

**Cannady Septic Tank and Leach Field**

This permit hereby authorizes the applicant:

Steven and Margo Cannady  
P.O. Box 93  
Shell, Wyoming 82411

to have constructed a small waste treatment facility consisting of a 1000 gallon septic tank and 28 infiltration chambers according to the procedures and conditions of application number 00-351R. The facility is located in S 1/2 NE 1/4 Section 28, T53N, R91W in the county of Big Horn, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, meets applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee has constructed and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 1 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

3-21-01  
Date of Issuance

MDB/bb/10611.ltr

STATEMENT OF BASIS

I. General information.

Permit Number: 00-351R

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement.

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter III<sup>1</sup>.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

- VI. If Section 17 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on March 16, 2001. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/10611.ltr



The State  
of Wyoming



# Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

<b>ADMIN/OUTREACH</b> (307) 777-7758 FAX 777-3610	<b>ABANDONED MINES</b> (307) 777-6145 FAX 777-6462	<b>AIR QUALITY</b> (307) 777-7391 FAX 777-5616	<b>INDUSTRIAL SITING</b> (307) 777-7369 FAX 777-6937	<b>LAND QUALITY</b> (307) 777-7756 FAX 777-5864	<b>SOLID &amp; HAZ. WASTE</b> (307) 777-7752 FAX 777-5973	<b>WATER QUALITY</b> (307) 777-7781 FAX 777-5973
---------------------------------------------------------	----------------------------------------------------------	------------------------------------------------------	------------------------------------------------------------	-------------------------------------------------------	-----------------------------------------------------------------	--------------------------------------------------------

March 19, 2001

Margo Cannady  
P.O. Box 93  
Shell, Wyoming 82411


RE: As-Built Permit To Construct, WQD Reference Number 00-351R

Dear Ms. Cannady:

The Department of Environmental Quality/Water Quality Division (DEQ/WQD) has reviewed the above referenced As-Built Application submitted by you. Our review of the information and as-constructed plans submitted to this office indicates that the application meets DEQ/WQD regulations and the enclosed As-Built Permit To Construct hereby issued. The enclosed permit covers construction of a small waste treatment facility consisting of a 1000 gallon septic tank and 28 infiltration chambers which has already been constructed.

Please be advised that the system must be constructed, installed, and operated in accordance with the statements, representations, and procedures presented in the application and all supporting documentation as well as the terms and conditions of the permit. You are urged to be familiar with all aspects of the permit application, permit and permit conditions. Any person objecting to a permit issued by the DEQ and desiring affirmative relief may request a hearing before the Environmental Quality Council in accordance with the Rules of Practice and Procedure for the Department of Environmental Quality and the Wyoming Administrative Procedures Act.

Sincerely,

  
Dennis Hemmer  
Director  
Department of Environmental Quality

DH/mdb/bb/10611.ltr  
Enclosure



**M GERINGER**  
GOVERNOR



1-2-01  
Barb

## Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES  
(307) 332-5085

AIR QUALITY  
(307) 332-6755

LAND QUALITY  
(307) 332-3047

SOLID & HAZARDOUS WASTE  
(307) 332-6924

WATER QUALITY  
(307) 332-3144

December 26, 2000

Mrs. Margo Cannady  
P.O. Box 93  
Shell, WY 82411

Dear Mrs. Cannady:

Our Records indicate your application for permit to construct has not been resubmitted to this office for review and authorization. The specific information for your proposed project are:

Facility Name: Cannady Septic Tank/Leach Field  
DEQ/WQD Reference Number: #00-351  
DEQ/WQD Reviewing Engineer: Jeff Hermansky  
Date of DEQ/WQD Review: September 28, 2000

According to Chapter III of the Water Quality Rules and Regulations Section 7 (b) (2), "If an application is denied because of incompleteness necessitating a request for additional information, the applicant shall have a maximum of six months to comply with the request. If the applicant fails to provide the requested information within that period, the entire incomplete application shall be returned."

Please indicate below the status of your application and return this form to our office:

The application will not be resubmitted as the proposed project has been cancelled.

The application will be resubmitted within 30 days.

The facility has been constructed or is under construction. As built construction plans and specifications will be submitted within 30 days.


Other remarks \_\_\_\_\_

You must still address the questions and comments in my September 28, 2000 review letter unless you have cancelled the project.

You are reminded that the construction, installation, or modification of any sewerage system, treatment works, disposal system, or other facility capable of causing or contributing to pollution, or public water supply system without a Permit to Construct is a violation of Wyoming State Statutes, Unless the Water of the receipt of this letter, follow-up action will be taken.

If you have any questions regarding my review comments or this letter, please contact either Mark Baron or me.

Sincerely,

A handwritten signature in black ink that reads "Jeff Hermansky". The signature is written in a cursive style with a long, sweeping underline.

Jeff Hermansky  
Northwest District Supervising Engineer

JH/bp

Enclosure: Review Letter

cc: IPS

file (3)

# LAND APPLICATION PERMIT

New  
Renewal  
Modified

PERMIT NO. 00-352  
SPECIAL CONDITIONS

## SIERRA CONSTRUCTION ROAD APPLICATION

This permit hereby authorizes the applicant:

Sierra Construction Company  
P.O. Box 210  
Linch, WY 82640

to land apply waste crude oil according to the procedures and conditions of the application number 00-352. The location of the application is in NW/4 of the SE/4 of Section 14 of Township 42 North, Range 78 West, et al. (See application for complete description) in the county of Johnson, in the State of Wyoming. This permit shall be effective until November 1, 2000.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (DEQ/WQD) upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 9. The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: DEQ/WQD NE District Office, 1043 Coffeen Avenue, Suite D, Sheridan Wyoming, 82801, Telephone (307) 672-6457, FAX (307) 674-6050.
- 2 of 9. The permittee shall provide immediate oral and/or written notice to the NE District Office in accordance with the provisions of Section 11 of Chapter 3 of the Wyoming Water Quality Rules and Regulations (WWQRR) of any changes or modifications to the approved permit package.
- 3 of 9. The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the NE District Office on the attached Certification of Completion form.
- 4 of 9. The permittee shall submit a contour map depicting only those sections of road that actually received waste crude oil within sixty (60) days of the project completion to the NE District Office.
- 5 of 9. The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
- 6 of 9. The waste crude oil shall be applied uniformly. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist.
- 7 of 9. The application site slope shall not exceed eight percent (8%) for vehicular application.
- 8 of 9. The waste crude oil application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes, and reservoirs.
- 9 of 9. Any waste crude oil application after November 1, 2000 must be re-permitted.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach, Administrator  
Water Quality Division

9-18-2000  
Date of Issuance

  
\_\_\_\_\_  
Dennis Hemmer, Director  
Department of Environmental Quality

DRM/dm: September 18, 2000

b/02339.ltr

## STATEMENT OF BASIS

### I. General information.

A. Permit Number: 00-352

### II. Application reviewed for compliance with the following WWQRR regulations. (Indicate yes or no for each section.)

A. Chapter 11 No

B. Chapter 12 No

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are no numeric standards or criteria in Chapter 11 for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish

criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

- V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable, delete all of section VI. from the Statement of Basis.)

Applicable

- VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the waste crude oil onto the roadbed. Repeated applications of waste crude oil on the same sections of road will be monitored by roadbed analyses.

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, WWQRR. This review was performed by Don McKenzie, NE Water & Wastewater Program Principal and completed on September 18, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

DRM/bb/02339.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

# LAND APPLICATION PERMIT

New  
 Renewal  
 Modified

PERMIT NO. 00-353  
SPECIAL CONDITIONS

## BIG SKY ESTATES ROAD APPLICATION

This permit hereby authorizes the applicant:

Orcan Oilfield Services  
P.O. Box 534  
Gillette, WY 82718

to land apply waste crude oil according to the procedures and conditions of the application number 00-353. The location of the application is in W/2 of Section 5 of Township 49 North Range 73 West in the county of Campbell, in the State of Wyoming. This permit shall be effective until November 1, 2000.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (DEQ/WQD) upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 9. The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: DEQ/WQD NE District Office, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming, 82801, Telephone (307) 672-6457, FAX (307) 674-6050.
- 2 of 9. The permittee shall provide immediate oral and/or written notice to the NE District Office in accordance with the provisions of Section 11 of Chapter 3 of the Wyoming Water Quality Rules and Regulations (WWQRR) of any changes or modifications to the approved permit package.
- 3 of 9. The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the NE District Office on the attached Certification of Completion form.
- 4 of 9. The permittee shall submit a contour map depicting only those sections of road that actually received waste crude oil within sixty (60) days of the project completion to the NE District Office.
- 5 of 9. The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
- 6 of 9. The waste crude oil shall be applied uniformly. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist.
- 7 of 9. The application site slope shall not exceed eight percent (8%) for vehicular application.
- 8 of 9. The waste crude oil application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes, and reservoirs.
- 9 of 9. Any waste crude oil application after November 1, 2000 must be re-permitted.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach, Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer, Director  
Department of Environmental Quality

9-18-2000  
\_\_\_\_\_  
Date of Issuance

DRM/dm: September 18, 2000

b/02338.ltr

## STATEMENT OF BASIS

### I. General information.

A. Permit Number: 00-353

### II. Application reviewed for compliance with the following WWQRR regulations. (Indicate yes or no for each section.)

A. Chapter 11 No

B. Chapter 12 No

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are no numeric standards or criteria in Chapter 11 for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish

criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

- V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Applicable

- VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the waste crude oil onto the roadbed. Repeated applications of waste crude oil on the same sections of road will be monitored by roadbed analyses.

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, WWQRR. This review was performed by Don McKenzie, NE Water & Wastewater Program Principal and completed on September 18, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

DRM/bb/02338.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

REVIEW OF PLANS AND SPECIFICATIONS  
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION

Herschler Building 4 West  
Cheyenne, Wyoming 82002


PROJECT: A Bar A Ranch Wastewater Land Application System

ENGINEER:

APPLICANT: A Bar A Ranch

WATER QUALITY DIVISION REFERENCE NUMBER: 00-354

REVIEWING ENGINEER: Louis B. Harmon



DATE OF REVIEW: September 18, 2000

**ACTION:** NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 9 (a)(ii), Chapter 3, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with said Section 9. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. This project involves the installation of a chlorinator and the construction of a pipeline or ditch to convey the water from the lagoons to the area of application. The construction, especially the selection and installation of the chlorinator, must be designed by a Wyoming licensed engineer in accordance with Chapters 3 and 11 of the Water Quality Division regulations. The plans and specifications for the construction must be signed and sealed by a Wyoming licensed engineer.
2. The permit application should include a map showing the area of land application and its relationship to buildings, surface water features, and topography.
3. The potential to impact groundwater must be evaluated. The reuse (irrigation) of the wastewater shall not affect the groundwater quality.
4. An operations and maintenance manual satisfying the requirements of Chapter 21, Section 17 shall be submitted with the permit application.

LBH/bb/02354.ltr

# PERMIT TO CONSTRUCT

New  
Renewal  
X Modified

PERMIT NO. 00-355R  
SPECIAL CONDITIONS  
REF/PERMIT (supersedes 96-250)

## City of Worland Block 6 Kister Addition Water Main PWS # WY5600197

This permit hereby authorizes the applicant:

City of Worland  
P.O Box 226  
Worland, WY 82401

to construct a water distribution system upgrade including 390 linear feet of 6 inch PVC water main with various valves and fittings, according to the procedures and conditions of application number 00-355R. The facility is located in SE 1/4SE1/4 Section 24 OGS, T47N, R92W, in the county of Washakie, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with charge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimate completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

11-27-2000  
Date of Issuance

MDB/mdb  
b/02921.ltr

STATEMENT OF BASIS

General information.

Permit Number: 00-355R

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. No

B. Chapter 12. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

N/A

VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on November 16, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/02921.ltr

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-357  
SPECIAL CONDITIONS

### NORTH BY-PASS SEWER EXTENSION

This permit hereby authorizes the applicant:

Gary Marshall  
53 Foothill Lane  
Buffalo, WY 82834

to construct, install or modify a sewer collection system according to the procedures and conditions of the application numbers 00-357. The facility is located in the SW/4 of Section 26 of T51N R82W in the county of Johnson, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of a constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

9-22-00  
\_\_\_\_\_  
Date of Issuance

DRM/mad/02361.ltr

Enclosures: Construction Notice Post Card, Certificate of Completion and Statement of Basis

xc: Keith Nuestel, Grizzly Engineering, POB 1004, Buffalo, 82834  
Ken Gross, City of Buffalo, 46 N. Main, Buffalo, 82834  
Rick Durfee, Johnson County, 76 N. Main, Buffalo, 82834

## STATEMENT OF BASIS

### I. General information.

A. Permit Number: 00-357

### II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11 Yes

B. Chapter 12 No

### III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

- B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter 8. Briefly describe:

N/A

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

N/A

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Don McKenzie, NE Water & Wastewater Section Program Principal, and completed on September 19, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

## PERMIT TO CONSTRUCT

— New  
Renewal  
Modified

PERMIT NO. 00-358  
SPECIAL CONDITIONS

### City of Cody 23<sup>rd</sup> Street Water and Sewer Extension PWS # WY5600207

This permit hereby authorizes the applicant:

City of Cody  
P.O. Box 2200  
Cody, WY 82414

to construct a water distribution system extension including 400 linear feet of 8 inch PVC water main, 1 fire hydrant and various valves, fittings and services; and 164 linear feet of 6 inch PVC sewer main which includes 1 manhole and services according to the procedures and conditions of application number 00-358. The facility is located in SW1/4 Section 33, T53N, R101W, in the county of Park, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-16-2000  
Date of Issuance

## STATEMENT OF BASIS

General information.

Permit Number: 00-358

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

Yes

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter 11, Part B, Section 9 (c)(i)(C) states that minimum slope of a 6 inch sewer pipe is 0.006 ft/ft for a gravity system.

B. Briefly state the basis for the deviation.

Policy - Flat grade sewer variance.

C. Permit based on general or statewide deviation contained in approved policy statement

Policy 13.9.13. Flat grade sewers granted variance because using PVC pipe, the calculated flow velocity is at least 2 ft/sec., the minimum flushing velocity, at the slopes listed in the policy.

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

N/A

VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Senior Environmental Analyst, and completed on October 9, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/02640.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

# ROAD APPLICATION PERMIT

New  
 Renewal  
 Modified

PERMIT NO. 00-359  
SPECIAL CONDITIONS  
Ref/Permit 00-222

## Land Application of Lost Cabin Gas Plant Pond Water Madden Field

This permit hereby authorizes the applicant:

Burlington Resources  
P. O. Box 51810  
Midland, TX 79710

to road apply 100 barrels per day of wastewater from the NPDES Storage Ponds for road maintenance according to the procedures and conditions of application number 00-359. The application sites are located in T38N and T39N, R89W through R91W in the county of Fremont, in the State of Wyoming. This permit shall be effective for five (5) years.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 6 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates with the attached post card. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: Mark Baron, Northwest District, State of Wyoming, DEQ, Water Quality Division, 25 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307) 332-3183.
- 2 of 6 The permittee will provide immediate oral and/or written notice to the Northwest District Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
- 3 of 6 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 4 of 6 The wastewater shall be applied uniformly and incorporated into the roadbed to be maintained. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. Wastewater shall not be applied during the period from November 1 to April 10.
- 5 of 6 The application road slope shall not exceed eight percent (8%) for vehicular application.
- 6 of 6 Only the roads designated in this permit are authorized for application of the wastewater. Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-25-00  
\_\_\_\_\_  
Date of Issuance

MDB/mdb  
b/02726.ltr

## STATEMENT OF BASIS

General information.

Permit Number: 00-359

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are not numeric standards or criteria in Chapter XI for road or land application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement.

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter III<sup>1</sup>.

Applicable

VI. If Section 17 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the wastewater onto the roadbed during maintenance.

B. Quality of waste is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on October 19, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/02726.ltr

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-360  
SPECIAL CONDITIONS

## CENTER AND F STREET WATER MAIN REPLACEMENT PWS NO. 5600009

This permit hereby authorizes the applicant:

City of Casper  
200 North David Street  
Casper, WY, 82601

to construct, install or modify a water distribution system according to the procedures and conditions of the application numbers 00-360. The facility is located in the SE/4 of Section 4 T33N R79W in the county of Natrona, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Casper WDEQ Field Office, 3030 Energy Lane, Casper, WY 82604, telephone (307) 473-3452; FAX (307) 473-3458.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and the permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.

\_\_\_ of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-6-2000  
Date of Issuance

JDL/mad/02525.ltr

Enclosures: Construction Notice Post Card, Certificate of Completion and Statement of Basis

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 00-360

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11 No

B. Chapter 12 Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

- B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

N/A

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, NE Water & Wastewater Section Senior Analyst, and completed on October 10, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-361  
SPECIAL CONDITIONS

## Black Boulevard and Buena Vista Drive Water System Reconstruction PWS # WY5600176

This permit hereby authorizes the applicant:

City of Lander  
240 Lincoln Street  
Lander, WY 82520

to construct a water distribution system upgrade including 1000 linear feet of 8 inch and 40 linear feet of 6 inch PVC water main along with various valves, fittings, services and one fire hydrant for Buena Vista Drive; 715 linear feet 6 inch PVC water main along with various valves, fittings, services and one fire hydrant for Black Boulevard; also included is the repair of two 10 foot sections of VCP sewer main with PVC pipe in Black Boulevard, according to the procedures and conditions of application number 00-361. The facility is located SE 1/4 and SW 1/4 Section 18, T33N, R99W in the county of Fremont in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plan and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-25-00  
\_\_\_\_\_  
Date of Issuance

MDB/mad/02668.ltr

STATEMENT OF BASIS

I. General information.

Permit Number: 00-361

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on October 16, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on September 21, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

## STATEMENT OF BASIS

### I. General information.

Permit Number: 00-362

### II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. No

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

Yes

### IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter XI, Part D, Sections 38 and 41 includes sizing for trench, bed, and seepage pit systems. Infiltrators are new technology not included in the regulations.

B. Briefly state the basis for the deviation.

Research data provides sizing criteria found to be acceptable.


C. Permit based on general or statewide deviation contained in approved policy statement(indicate the policy number and briefly summarize the nature of the deviation).


13.41.2 This policy is the acceptable criteria for sizing leach fields using standard chamber units.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

9-28-2000  
Date of Issuance

MDB/mad/02414.ltr

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-362  
SPECIAL CONDITIONS

## McCauley Septic Tank and Leach Field

This permit hereby authorizes the applicant:

Cletus M. McCauley  
945 Arapahoe St.  
Thermopolis, WY 82443

to construct a septic tank/leach field to serve a three bedroom residence, according to the procedures and conditions of application number 00-362. The facility is located in NW 1/4 SW 1/4 Section 8, T43N, R94W, in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

# PERMIT TO CONSTRUCT

X New  
— Renewal  
— Modified

PERMIT NO. 00-363  
SPECIAL CONDITIONS  
REF/PERMIT NO. 81-127

Winchester Hills Pump Station Improvements  
PWS: 5600779

This permit hereby authorizes the applicant:

Winchester Hills Utility Company  
1124 Dunn Avenue  
Cheyenne WY 82001

to construct, install or modify a upgrade of pump station capacity and automation according to the procedures and conditions of the application number 00-363. The facility is located in NE 1/4 Section 31 <sup>T13N R66W</sup> ~~N T66W~~ in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 As-built drawings must be submitted with the certificate of completion.
- 4 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 5 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-6-2000  
\_\_\_\_\_  
Date of Issuance

## STATEMENT OF BASIS

Permit Number: 00-363

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. NO

B. Chapter XII. YES

III. Basis for issuing permit: Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

IV. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.

NO

V. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on October 5, 2000. Permit issuance is commended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

X New  
— Renewal

PERMIT NO. 00-364  
SPECIAL CONDITIONS

Sunrise Estates - Third Filing water and sewer extensions  
PWS# 5600011

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities  
P.O. Box 1469  
Cheyenne WY 82003-1469

to construct, install or modify an extension of 8" and 10" sewer line extensions and an 8" diameter water line loop according to the procedures and conditions of the application number 00-364. The facility is located in NW 1/4 Section 35 T14N S66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 4 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



---

Gary Beach  
Administrator  
Water Quality Division



---

Dennis Hemmer  
Director  
Department of Environmental Quality

10-6-2000  
Date of Issuance

LBH/bb/02575.ltr

## STATEMENT OF BASIS

- I. Permit Number: 00-364
- II. Application reviewed for compliance with the following regulations.
- A. Chapter XI. YES
- B. Chapter XII. YES
- III. Basis for issuing permit: Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- IV. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.
- NO
- V. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on October 6, 2000. Permit issuance is commended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LBH/bb/02575.ltr

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-365  
SPECIAL CONDITIONS

## Sewerline Extension - Shelter Park Improvement District

This permit hereby authorizes the applicant:

Shelter Park Improvement District  
Attn: Patrick C. Mattimoe  
P.O. Box 783  
Pinedale, WY 82941

to construct approximately 1,820 feet of 8-inch diameter sanitary sewer collection main according to the procedures and conditions of application number 00-365. The facility is located in SE1/4 and NE1/4 Section 33, T34N, R109W in the county of Sublette, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property, or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-11-00  
Date of Issuance

DHC/mad/02594.ltr

cc: Keith Raney, Sublette County Sanitarian; P.O. Box 722; Pinedale, WY 82941  
Town of Pinedale; P.O. Box 709; Pinedale, WY 82941

STATEMENT OF BASIS

I. General information.

Permit Number: 00-365

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

Not Applicable

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle Conklin, SW District Engineering Supervisor, and completed on October 9, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-366  
SPECIAL CONDITIONS

### Merrill Sub-Surface Septic System

This permit hereby authorizes the applicant:

Betty Merrill  
P.O. Box 202  
Encampment, Wyoming 82325

to construct and install a residential septic system with a chamber type leachfield according to the procedures and conditions of the application number 00-366. The facility is located in the SE 1/4 of Section 31, T15N, R83W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**
- 4 of 5. Leachfield Layout - A minimum of at least three(3) feet of undisturbed soil must be maintained between the individual trenches.
- 5 of 5. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-6-2000  
Date of Issuance

RLE/mad/02468.ltr

cc: Carbon County Planner/Sanitarian

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 00-366
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter 11. Yes
- B. Chapter 12. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.  
Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.  
No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.  
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.  
NOT Applicable
- B. Briefly state the basis for the deviation.  
NOT Applicable
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).  
NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

- VI. Deleted

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on September 29, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-367  
SPECIAL CONDITIONS  
Reference 97-418

## HOLLY PONDS PUD UNITS 4 & 5 WATER AND SEWER EXTENSIONS PWS 5600052

This permit hereby authorizes the applicant:

Holly Ponds LLC  
P.O. Box 6793  
Sheridan, WY 82801

to construct, install or modify a distribution and collection system according to the procedures and conditions of the application numbers 00-367 and 97-418. The facility is located in the NW/4 of the SE/4 of Section 21 of T56N R84W in the county of Sheridan, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and the permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-6-2000  
Date of Issuance

DRM/mad/02474.ltr

Enclosures: Construction Notice Post Card, Certificate of Completion and Statement of Basis  
xc: Jim Willey, M-W, 1030 N. Main, #2 Taylor Pl., Sheridan, 82801  
Susan Fields, City of Sheridan, POB 848, Sheridan, 82801

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 00-367

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11 Yes

B. Chapter 12 Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

- B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter 8. Briefly describe:

N/A

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

N/A

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Don McKenzie, NE Water & Wastewater Section Program Principal, and completed on September 29, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

# PERMIT TO CONSTRUCT

New  
 Renewal

PERMIT NO.00-368  
SPECIAL CONDITIONS

## Trefren@Fox Farm and Avenue C Sewer Line Extension

This permit hereby authorizes the applicant:

South Cheyenne Water and Sewer District  
215 East Allison Road  
Cheyenne WY 82007

to construct, install or modify a 405 ft long branch sewer line according to the procedures and conditions of the application number 00-368. The facility is located in NW 1/4 Section 9 T13N R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-6-2000  
Date of Issuance

LBH/bb/02576.ltr

## STATEMENT OF BASIS

- I. Permit Number: 00-368
- II. Application reviewed for compliance with the following regulations.
- A. Chapter XI. YES
- B. Chapter XII. NO
- III. Basis for issuing permit: Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- IV. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on October 6, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

BH/bb/02576.ltr

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
AS-BUILT  
PERMIT TO CONSTRUCT

PERMIT NO. 00-369R

Lewis Lake and Indian Creek Campgrounds Water Storage Tanks  
PWS #5680081 & PWS #5680078

This permit hereby authorizes the applicant:

Nancy Ward  
Supervisory Civil Engineer  
National Park Service  
P.O. Box 168  
Yellowstone NP, WY 82190

to have constructed two 13,000-gallon bolted steel water storage tanks, one at the Lewis Lake Campground and one at the Indian Creek Campground; according to the procedures and conditions of the application number 00-369R. The facilities are located within NE ¼, Section 30, Township 50 North and Range 114 West, in the county of Teton and within SE ¼, Section 26, Township 57 North and Range 115 West in the county of Park, in the State of Wyoming.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not


relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1 of 1 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
John F. Wagner  
Administrator  
Water Quality Division

  
John V. Corra  
Director  
Department of Environmental Quality

11/26/07  
Date of Issuance

JSB/DRM/cs7-1016  
*SR* 11/24/7

## STATEMENT OF BASIS

1. Permit Number: 00-369R
2. Application reviewed for compliance with the following regulations:  
Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above? Yes
4. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.  
No
5. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.  
Public water systems are exempted from review by Chapter 3, Section 17.
6. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this as-built permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by James S. Brough, [jbrough@state.wy.us](mailto:jbrough@state.wy.us), Northwest District Engineer and completed on November 21, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."

Cc: Sherri Jones, RTW Engineering, 1576 Sherman St., Suite 100, Denver, CO 80203-1713  
Steve Iobst, Chief of Park Maintenance, P.O. Box 168, Yellowstone National Park, WY 82190

F:\DIVISION\WQD\W&WW Section\2000 Older Permits & Reviews\2000 Permits & Reviews\00-369R.pc.jsb.doc

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-370  
SPECIAL CONDITIONS

## Town of Lovell Kansas Water Main PWS # WY5600031

This permit hereby authorizes the applicant:

Town of Lovell  
P.O Box 188  
Lovell, WY 82431

to construct a water distribution system upgrade including 1060 linear feet of 8 inch PVC water main with various valves, fittings, services and one fire hydrant according to the procedures and conditions of application number 00-370. The facility is located in T56N, R96W, in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not


relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-11-00  
\_\_\_\_\_  
Date of Issuance

MDB/mad/02586.ltr

STATEMENT OF BASIS

I. General information.

Permit Number: 00-370

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. No

B. Chapter 12. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

N/A

VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on October 6, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

— New  
Renewal  
Modified

PERMIT NO. 00-371R  
SPECIAL CONDITIONS

### Brooks Lake Lodge Sewage System Improvements

This permit hereby authorizes the applicant:

BL Property L.L.C.  
458 Brooks Lake Road  
Dubois, Wy 82513

to construct relocation of about 468 feet of 6-inch PVC sewer line and add buttress fill to the lower wastewater lagoon dike to stabilize and raise the dike according to the procedures and conditions of application number 00-371R. The facility is located in Section 25, T44N, R110W in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of 2 (two) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Jeff Hermansky, Northwest District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statement representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

11-8-00  
\_\_\_\_\_  
Date of Issuance

STATEMENT OF BASIS

— General information.

Permit Number: 00-371R

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

N/A

VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Engineering Supervisor, and completed on November 2, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JCH/bb/02806.ltr

# PERMIT TO CONSTRUCT

New  
 Renewal

PERMIT NO. 00-372  
SPECIAL CONDITIONS

Cheyenne BOPU 26th Street Water Main Replacement  
PWS# 5600011

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities  
P.O. Box 1469  
Cheyenne WY 82003-1469

to construct, install or modify a water line replacement in 26th Street between Evans and House according to the procedures and conditions of the application number 00-372. The facility is located in NE 1/4 Section 31 T14N R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-10-2000  
Date of Issuance

LBH/bb/02581.ltr

## STATEMENT OF BASIS

- I. Permit Number: 00-372
- II. Application reviewed for compliance with the following regulations.
- A. Chapter XI. NO
- B. Chapter XII. YES
- III. Basis for issuing permit: Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- IV. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.
- NO
- V. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on October 6, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LBH/bb/02581.ltr

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-373  
SPECIAL CONDITIONS

## Probst Septic Tank and Leach Field

This permit hereby authorizes the applicant:

Tyson Probst  
547 Greybull Ave.  
Greybull, WY 82426

to construct a septic tank/leach field to serve a two bedroom residence, according to the procedures and conditions of application number 00-373. The facility is located in NE corner Lot 4, Section 3, T52N, R93W, in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-6-2000  
Date of Issuance

MDB/mad/02465.ltr

STATEMENT OF BASIS

I. General information.

Permit Number: 00-373

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on September 28, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

X New  
— Renewal  
Modified

PERMIT NO. 00-374  
SPECIAL CONDITIONS

## KELLER SEPTIC SYSTEM

This permit hereby authorizes the applicant:

Frank and Betty Keller  
3503 Crestline Circle  
Gillette, WY 82716

to construct, install or modify a septic system according to the procedures and conditions of the application numbers 00-374. The facility is located in the NW/4 of the SW/4 of Section 5 of T50N R66W in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (DEQ/WQD), upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ/WQD the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Casper WDEQ Field Office, 3030 Energy Lane, Suite 200, Casper, WY 82604, telephone (307) 473-3452; FAX (307) 473-3458.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Casper Field Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Casper Field Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".


AUTHORIZED BY:



Gary Beach, Administrator  
Water Quality Division

19-28-2000

Date of Issuance



Dennis Hemmer, Director  
Department of Environmental Quality

JDL/mad/02448.ltr

Enclosures: Notification Post Card  
Certificate of Completion  
Statement of Basis

## STATEMENT OF BASIS

General information.

A. Permit Number: 00-374

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of Section VI. from the Statement of Basis.)

N/A

VI. N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, Northeast District DEQ/WQD Senior Analyst, and completed on September 27, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

# PERMIT TO CONSTRUCT

X New  
— Renewal  
Modified

PERMIT NO. 00-375  
SPECIAL CONDITIONS

## SOUTH LITTLE HORN AVENUE WATER LINE REPLACEMENT

PWS NO. 5600037

This permit hereby authorizes the applicant:

Town of Moorcroft  
PO Box 70  
Moorcroft, WY, 82730

to construct, install and replace 1315 feet of cast iron water line and associated improvements according to the procedures and conditions of the application numbers 00-375. The facility is located in the NE/4 of Section 6 T49N R67W in the county of Crook, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Casper WDEQ Field Office, 3030 Energy Lane, Casper, WY 82604, telephone (307) 473-3452; FAX (307) 473-3458.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and this permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-11-00  
Date of Issuance

JDL/mad/02587.ltr

Enclosures: Construction Notice Post Card, Certificate of Completion and Statement of Basis

## STATEMENT OF BASIS

General information.

A. Permit Number: 00-375

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11      No

B. Chapter 12      Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

- B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, NE Water & Wastewater Section Senior Analyst, and completed on October 6, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

REVIEW OF PLANS AND SPECIFICATIONS  
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION

Herschler Bldg., 4 West  
Cheyenne, Wyoming 82002

PROJECT: Hidden Treasure Cabin Septic System

ENGINEER: None

APPLICANT: Gary Buck  
Box 694  
Encampment, Wyoming 82325  
Ph(winter res): (573) 377-2034

WATER QUALITY DIVISION REFERENCE NUMBER: 00-377

REVIEWING ENGINEER: Ronald L. Ewald <sup>RLE</sup>  
Phone: (307) 777-6183

DATE OF REVIEW: October 2, 2000

**ACTION:** NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 12 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

**COMMENTS, INADEQUACIES, AND QUESTIONS:**

1. Septic Tank NOT Approved - The Kordane fiberglass septic tank which you listed is not on our DEQ/Water Quality Division (WQD) "Approved Septic Tank List." It may be possible to approve this tank, but first you must submit the manufacturer's specifications and dimensions for review. Is this tank round, rectangular, or oval? If it is round or curved in shape, it may not be possible to attach the necessary insulation (see next item). A copy of the DEQ/WQD Approved Septic Tank list is included with this review should you decide to use a different septic tank.

2. Septic Tank Freeze Protection Required - Because this tank will be installed at an elevation of approximately 9500 feet, the septic tank will have to be protected from freezing. The septic tank shall be protected on all four sides (to within one foot of the bottom of the tank) and the top (including the manhole covers) by gluing rigid foam insulation (recommended for contact with the soil) to the tank. The insulation shall have a minimum "R" value of at least:

$$\text{"R"} = 5.0 + [ 1.25 * ( \text{local elevation(ft)} / 1000 - 4.0 ) ]$$

For the Sierra Madre area (elevation 9500 feet) this works out to a minimum "R" value of 12.0. Additionally, several feet of cover soil should then be mounded up over the septic tank as needed to protect against the local winter conditions. Note - insulation is not required on the bottom of the tank.

3. Leachfield Layout - The plans show three(3) - 100 foot long trenches only 24 inches apart. One hundred foot long trenches are too long to ensure that the effluent will reach the end of the trench. Also, it is difficult to get equal distribution of the septic tank effluent to three trenches. Therefore, it would be better to use four (4) - 75 foot long trenches and flow splitting tees to equalize the flow. The effluent from the septic tank can first be split by a tee into two equal branches, and then each of these branches can be split again by a tee joint so that the flow is roughly equal to each of the four trenches.

Also, a minimum of at least three (3) feet of undisturbed soil must be maintained between each of the individual trenches.

RLE/bb/02492.ltr

Enclosure: Approved Septic Tank list

THE STATE



OF WYOMING



JIM GERINGER  
GOVERNOR

## Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES  
(307) 332-5085

AIR QUALITY  
(307) 332-6755

LAND QUALITY  
(307) 332-3047

SOLID & HAZARDOUS WASTE  
(307) 332-6924

WATER QUALITY  
(307) 332-3144

### NOTIFICATION OF COVERAGE

November 29, 2000

West Jackson Partners, L.L.C.  
1519 Bunkhouse Drive  
Jackson, Wyoming 83001

RE: Centerpiece Building - 4 inch Water Line, Permit Number 00-376R  
Teton County  
PWS # WY5600213

Dear Mr. Todd H. Ellingson:

The above application for coverage under General Permit to Construct, Install, Modify or Operate, 121 linear feet of 4 inch DIP water service and back flow prevention devices, in accordance with Chapter 3 and Section 14 Chapter 12, of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements, outlined in Section O, Part V, of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron  
Environmental Senior Analyst  
Water Quality Division

Jeff Hermansky, P.E.  
Northwest District Engineer  
Water Quality Division

cc: IPS, Cheyenne

encl: General Permit For Public Water Supply Distribution Systems

# PERMIT TO CONSTRUCT

— New  
Renewal  
Modified

PERMIT NO. 00-377  
SPECIAL CONDITIONS

## Hidden Treasure Cabin Septic System

This permit hereby authorizes the applicant:

Gary Buck  
Box 694  
Encampment, Wyoming 82325

to construct and install a residential septic system with a rock and pipe leachfield and an insulated septic tank according to the procedures and conditions of the application number 00-377. The facility is located in the SW 1/4 of Section 28, T14N, R85W in the county of Carbon, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representation, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 6. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 6. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 6. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit, or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. All **modifications or deviations** from the authorized plans **must be highlighted**.
- 4 of 6. Septic Tank Riser Requirement - The Kordane / AK Industries polyethylene septic tank is approved with the following condition. Either a 6 inch diameter clean-out riser or the manways from each compartment must be extended to the ground surface for cleaning and/or servicing purposes.
- 5 of 6. Septic Tank Freeze Protection Required - Because this tank will be installed at an elevation of approximately 9500 feet, The septic tank will have to be protected from freezing. The septic tank shall be protected on all four sides (to within one foot of the bottom of the tank) and the top (including the manhole covers) by wrapping two layers of the "PLY-FOIL" brand flexible insulation around the tank. The insulation shall have a minimum "R" value of at least:

$$"R" = 5.0 + [ 1.25 * ( \text{local elevation(ft)} / 1000 - 4.0 ) ]$$

For the Sierra Madre area (elevation 9500 feet) this works out to a minimum "R" value of 12.0. Additionally, several feet of cover soil should then be mounded up over the septic tank as needed to protect against the local winter conditions. Note - insulation is not required on the bottom of the tank

6 of 6. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

11-17-00  
\_\_\_\_\_  
Date of Issuance

LE/mad/02876.ltr

cc: Carbon County Planner/Sanitarian

STATEMENT OF BASIS

I. General information.

A. Permit Number: 00-377

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11. Yes

B. Chapter 12. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

- VI. Deleted

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on November 15, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

# PERMIT TO CONSTRUCT

X New  
— Renewal  
Modified

PERMIT NO. 00-378  
SPECIAL CONDITIONS

## WDOT POLE CREEK MAINTENANCE CAMP - NEW DRAINFIELD & MODIFIED SEPTIC TANK

This permit hereby authorizes the applicant:

WDOT, Attention: Mr. Lawrence Koneteki  
P. O. Box 668  
Sheridan, WY 82801

to construct, install or modify a septic system according to the procedures and conditions of the application number 00-378. The facility is located in Section 14 of T84N R49W in the county of Johnson, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (DEQ/WQD), upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ/WQD the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, DEQ/WQD, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Administrator, Gary Beach  
Water Quality Division

  
\_\_\_\_\_  
Director, Dennis Hemmer  
Department of Environmental Quality

10-6-2000  
Date of Issuance

DRM/dm:09/28/00  
b/02459.ltr

Enclosures: Notification Post Card  
Certificate of Completion  
Statement of Basis

xc: Rick Durfee, Johnson County Sanitarian, Buffalo

## STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 00-378
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter 11. Yes
- B. Chapter 12. No
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.  
Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.  
No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.  
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.  
N/A
- B. Briefly state the basis for the deviation.  
N/A
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).  
N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of Section VI. from the Statement of Basis.)

N/A

VI. N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Donald R. McKenzie, NE Water & Wastewater Section Program Principal, and completed on September 28, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

DRM/bb/02459.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 00-379  
SPECIAL CONDITIONS  
Ref/Permit 97-463R

## Wilson Meadows Affordable Housing, Phase II

This permit hereby authorizes the applicant:

Teton County Housing Authority  
P.O. Box 4073  
Jackson, WY 83001

to construct an extension of the Wilson Meadows Wastewater collection system for 8 housing units, including 120 feet of 8 inch PVC sewer main and one manhole. Also included is the extension of 1 1/2 inch water mains to serve the 8 housing units; according to the procedures and conditions of application number 00-379. The facility is located in SE 1/4 Section 22, T41N, R117W, in the county of Teton, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
- a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-25-00  
Date of Issuance

MDB/mbd  
b/02689.ltr

cc: Alicia Cannell, High Mountain Group, P.O. Box 1190, Wilson, WY 83014-1190

STATEMENT OF BASIS

I. General information.

Permit Number: 00-379

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on October 17, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/02689.ltr

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-380  
SPECIAL CONDITIONS

## MEADOW SPRINGS WATER SYSTEM

PWS NO. NOT ASSIGNED

This permit hereby authorizes the applicant:

John Melgaard  
722 Sinclair Street  
Gillette, WY 82717

to construct and install a privately owned water supply storage tank, water well, distribution system, and improvements according to the procedures and conditions of the application number 00-380. The facility is located in the Sections 11,12, and 13 of T 50N R72W in the county of Campbell, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by January 25, 2003.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Casper WDEQ Field Office, 3030 Energy Lane, Casper, WY 82604, telephone (307) 473-3452; FAX (307) 473-3458.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 11, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

1-29-02  
\_\_\_\_\_  
Date of Issuance

JDL/1/25/02  
b/2-0290.ltr

Enclosures: Construction Notice Post Card, Certificate of Completion and Statement of Basis

## STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 00-380
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter 11      Yes
- B. Chapter 12      Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
- No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- N/A
- B. Briefly state the basis for the deviation.
- N/A
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
- N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. If Section 17 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, NE District Water & Wastewater Supervisor, and completed on January 25, 2002. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JDL/bb/2-0290.ltr

# PERMIT TO CONSTRUCT

New  
Renewal  
 Modified

PERMIT NO. 00-381  
SPECIAL CONDITIONS  
Reference 99-200

## WALLY'S CAMPGROUND PWS EXTENSION & SEPTIC SYSTEM PWS #5600191

This permit hereby authorizes the applicant:

Kay Waldrop  
#2 Hays Blvd  
Pine Haven, WY 82721

to construct, install or modify a water distribution and septic system according to the procedures and conditions of the application numbers 00-381 and 99-200. The facility is located in the NW/4 of the SW/4 of Section 5 of T50N R66W in the county of Crook, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (DEQ/WQD), upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The permittee shall notify representatives from the DEQ/WQD the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District Office, DEQ/WQD, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statement, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the Northeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 5 An operation and maintenance manual for the booster pump facility is required prior to activation of the water system.

AUTHORIZED BY:

  
\_\_\_\_\_  
Administrator, Gary Beach  
Water Quality Division

  
\_\_\_\_\_  
Director, Dennis Hemmer  
Department of Environmental Quality

10-6-2000  
\_\_\_\_\_  
Date of Issuance

DRM/mad/02483.ltr

Enclosures: Notification Post Card, Certificate of Completion, Statement of Basis

xc: Town of Pine Haven, 24 Waters Drive, Pine Haven, 82721  
Thayne Gray, POB 729, Moorcroft, 82721

## STATEMENT OF BASIS

I. General information.

A. Permit Number: 00-381

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11. Yes

B. Chapter 12. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No.

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of Section VI. from the Statement of Basis.)

N/A

VI. N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Donald R. McKenzie, NE Water & Wastewater Section Program Principal, and completed on September 29, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

51933.DOC

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 00-382  
SPECIAL CONDITIONS  
REF/PERMIT NO. 92-141

Torrington Industrial Park W&S and WWTP Improvements  
PWS: 5600164

This permit hereby authorizes the applicant:

City of Torrington  
P.O. Box 250  
Torrington WY 82240

to construct, install or modify water lines and sewer mains in the Industrial Park, to add a pump with force main, utilize an existing lined lagoon as an equalization basin and a duplex pump station from the equalization basin to aerated cell #1 according to the procedures and conditions of the application number 00-382. The facility is located in NW 1/4 Section 14 T24N R61W in the county of Goshen, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-6-2000  
Date of Issuance

LBH/mad/02563.ltr

cc: SRF

STATEMENT OF BASIS

Permit Number: 00-382

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. YES

B. Chapter XII. YES

III. Basis for issuing permit: Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

IV. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.

NO

V. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Luis B. Harmon, Southeast District Engineering Supervisor, and completed on October 5, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

## PERMIT TO CONSTRUCT

X New  
— Renewal  
— Modified

PERMIT NO. 00-383R  
SPECIAL CONDITIONS

### Yellowstone National Park Sewer System Rehabilitation- Mammoth, Lake and Fishing Bridge

This permit hereby authorizes the applicant:

Yellowstone National Park  
David L. Cole  
P.O. Box 168  
Yellowstone National Park, WY 82190

to rehabilitate sewer mains, by installing cured-in-place (CIPP) lining and replacing select sections. The amounts of sewer main rehabilitation consist of the following. At Mammoth: 843 linear feet (LF) of 12 inch, 952 LF 10 inch, 2621 LF of 8 inch and 457 LF of 6 inch CIPP ; 198 LF of 10 inch, 1090 LF of 8 inch and 751 LF of 6 inch replacement. At Lake: 2901 LF of 10 inch and 182 LF of 8 inch CIPP; 648 LF of 10 inch replacement. At Fishing Bridge: 1569 LF of 12 inch CIPP; 458 LF of 12 inch replacement. Also included; at Mammoth is the replacement of 19 and repair of 36 manholes; at Lake is the replacement of 5 and repair of 20 manholes; at Fishing Bridge is the replacement of 1 and repair of 5 manholes, according to the procedures and conditions of application number 00-383R. The facility is located in SW 1/4 Section 30, T58N, R114W- (Mammoth Hot Springs), Section 20 & 21, T53N, R112W- (Fishing Bridge), Section 19 & 20, T53N, R112W-(Lake), in the county of Park (Mammoth Hot Springs), Park & Teton (Fishing Bridge), Teton (Lake), in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

11-29-2000  
Date of Issuance

MDB/mdb  
b/02974.ltr

## STATEMENT OF BASIS

General information.

Permit Number: 00-383R

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Section 5 (a)(i), Chapter 11, states that data obtained from a full scale, comparable installation which demonstrates the acceptability of the design should be included.

B. Briefly state the basis for the deviation.

Cured-in-place (CIPP) sewer relining is new technology with no approved policy statement.

C. Permit based on general or statewide deviation contained in approved policy statement

No policy has been written but industry experience and data has shown that sewers relined with the new CIPP technology perform as expected. CIPP, must meet the ASTM F-1216 standard practice for the rehabilitation of existing pipelines and conduits.

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

N/A

VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on November 27, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/02974.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.



THE STATE OF WYOMING

JIM GERINGER  
GOVERNOR



## Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES  
(307) 332-5085

AIR QUALITY  
(307) 332-6755

LAND QUALITY  
(307) 332-3047

SOLID & HAZARDOUS WASTE  
(307) 332-6924

WATER QUALITY  
(307) 332-3144

### NOTIFICATION OF COVERAGE

May 7, 2001

Craig Sorenson, Mayor  
Town of Deaver  
P.O. Box 207  
Deaver, Wyoming 82421

RE: Deaver - Cowley Emergency Water Connection, Permit Number: 00-384R,  
Tract 10, Section 29, T57N, R97W  
Big Horn County, PWS# WY5600016

Dear Mr. Sorenson:

The above application for coverage under General Permit to Construct an extension of a water distribution system, consisting of a backup water connection between Deaver and Cowley which includes 237 of 6 inch PVC, a manhole/meter pit and appurtenances in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, E.I.T.  
Environmental Senior Analyst  
Water Quality Division

Jeff Hermansky, P.E.  
District Engineer  
Water Quality Division

cc: IPS, Cheyenne

encl: General Permit For a Public Water Supply Distribution System

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-385  
SPECIAL CONDITIONS

## Hill Septic Tank and Leach Field

This permit hereby authorizes the applicant:

Fred W. Hill II  
362 Bobcat Rd.  
Thermopolis, WY 82443

to construct a septic tank/leach field to serve a three bedroom residence, according to the procedures and conditions of application number 00-385. The facility is located in Section 11, T42N, R95W, in the county of Hot Springs, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-6-2000  
Date of Issuance

MDB/mdb  
b/02537.ltr

STATEMENT OF BASIS

I. General information.

Permit Number: 00-385

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

Yes

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter XI, Part D, Sections 38 and 41 includes sizing for trench, bed, and seepage pit systems. Infiltrators are new technology not included in the regulations.

B. Briefly state the basis for the deviation.

Research data provides sizing criteria found to be acceptable.

C. Permit based on general or statewide deviation contained in approved policy statement(indicate the policy number and briefly summarize the nature of the deviation).

13.41.2 This policy is the acceptable criteria for sizing leach fields using standard chamber units.

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on October 3, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/02537.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-386  
SPECIAL CONDITIONS

F.E. Warren AFB: Building 1294 - Fire Sprinkler System  
PWS #WY5680122

This permit hereby authorizes the applicant:

F.E. Warren Air Force Base  
Attn. Deborah Myers, Chief Environmental Flight  
300 Vesle Drive, Suite 600  
F.E. Warren AFB, Wyoming 82005-2793

to construct and install a fire sprinkler system with backflow protection according to the procedures and conditions of the application number 00-386. The facility is located in the SE 1/4 of Section 22, T14N, R67W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of 3 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5. The applicant will provide immediate oral and/or written notice to the DE/W.D. Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DE/W.D. Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. **Submittal of as-constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. **All modifications or deviations from the authorized plans must be highlighted.**
- 4 of 5. **Backflow Prevention** - The specific make and model of backflow protection device was not identified in the design submittal. Therefore, **the building fire protection system shall have backflow prevention** as recommended by AWWA Standard M14 and in accordance with the DE/W.D. Rules and Regulations Chapter 12, Section 14(i), and the Cheyenne Board of Public Utilities "Rules & Regulations For Cross Connection & Backflow Prevention". Additionally, all backflow prevention devices shall be approved by the University of Southern California - Foundation for Cross Connection Control(USC-FCCC).
- 5 of 5. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-6-2000  
\_\_\_\_\_  
Date of Issuance

RLE/mad/02570.ltr  
cc: Cheyenne BOPU

STATEMENT OF BASIS

I. General information.

A. Permit Number: 00-386

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11. No

B. Chapter 12. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

- V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on October 5, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

## PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 00-387R  
SPECIAL CONDITIONS

### Cooper Subdivision Sewer

This permit hereby authorizes the applicant:

Judy B. Rountree  
2103 Glen Meade Road  
Wilmington, NC 28403

to abandon an existing septic system, and install a new manhole and one sewer main to connect the subdivision to the city sanitary sewer system according to the procedures and conditions of application number 00-387R. The facility is located in SE1/4 SW1/4 Section 27 (Orig. Survey), T53N, R101W in the county of Park, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed; certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-25-00  
\_\_\_\_\_  
Date of Issuance

DHC/mad/02675.ltr

cc: City of Cody; Public Works Director; P.O. Drawer 2200; Cody, WY 82414

STATEMENT OF BASIS

I. General information.

Permit Number: 00-387R

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

Not Applicable

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle Conklin, SW District Engineering Supervisor, and completed on October 17, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-388  
SPECIAL CONDITIONS

## Bischoff Septic Tank and Leach Field

This permit hereby authorizes the applicant:

Royal and Ruth Bischoff  
1014 Lane 12  
Lovell, WY 82431

to construct a septic tank/leach field to serve a four bedroom residence, according to the procedures and conditions of application number 00-388. The facility is located in Tract 77B, Section 22, T56N, R96W, in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
Gary Beach  
Administrator  
Water Quality Division

  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-6-2000  
Date of Issuance

MDB/mdb  
b/02553.ltr

## STATEMENT OF BASIS

### I. General information.

Permit Number: 00-388

### II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. No

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

Yes

### IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter XI, Part D, Sections 38 and 41 includes sizing for trench, bed, and seepage pit systems. Infiltrators are new technology not included in the regulations.

B. Briefly state the basis for the deviation.

Research data provides sizing criteria found to be acceptable.

C. Permit based on general or statewide deviation contained in approved policy statement(indicate the policy number and briefly summarize the nature of the deviation).

13.41.2 This policy is the acceptable criteria for sizing leach fields using standard chamber units.

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on October 4, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/02553.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

# PERMIT TO CONSTRUCT

New  
Renewal  
Modified

PERMIT NO. 00-389RRR  
SPECIAL CONDITIONS  
REF Permit - NPDES # WY0042218

## Lake Lodge Resort

This permit hereby authorizes the applicant:

Larry Craig  
P.O. Box 86  
Ten Sleep, WY 82442

to construct a 44 ft X 48 ft X 2 ft recirculating sand filter (RSF) sewage treatment system with a surface discharge into East Ten Sleep Creek, included with the RSF are: four approximately 6000 gallon septic tanks, one approximately 6000 gallon pump dosing vault with four pumps, a flow distribution vault, a ultraviolet disinfection facility and outfall. The RSF is designed to treat a peak domestic sewage flow of 10,498 gpd from a resort with a restaurant/lodge which has a capacity of 112 guests and 30 employees, according to the procedures and conditions of application number 00-389RRR. The facility is located in Section 33, T49N, R86W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee, and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


Issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

1-2-2001  
\_\_\_\_\_  
Date of Issuance

MDB/mdb  
b/03140.ltr

cc: Ms. Gail Laurent, Big Horn National Forest, 2013 Eastside Second Street, Sheridan, WY.82801

## STATEMENT OF BASIS

General information.

Permit Number: 00-389RRR

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Section 5 (a)(i), Chapter 11, states that data obtained from a full scale, comparable installation which demonstrates the acceptability of the design should be included.

B. Briefly state the basis for the deviation.

A recirculating sand filter (RSF) sewage treatment system is new technology with no approved policy statement.

C. Permit based on general or statewide deviation contained in approved policy statement.

No policy has been written, but industry experience and data has shown that recirculating sand filter (RSF) sewage treatment system technology performs as expected. Examples and discharge data from comparable RSF systems are included in the permit application.

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on December 19, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/03140.ltr

THE STATE



OF WYOMING



**JIM GERINGER**  
GOVERNOR

## Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES  
(307) 332-5085

AIR QUALITY  
(307) 332-6755

LAND QUALITY  
(307) 332-3047

SOLID & HAZARDOUS WASTE  
(307) 332-6924

WATER QUALITY  
(307) 332-3144

### NOTIFICATION OF COVERAGE

November 29, 2000

Mayor Ronald Paris  
Town of Dubois  
P.O. Box 555  
Dubois, WY 82513

RE: Dubois Medical Clinic Water and Sewer, Permit Number 00-390R, PWS #WY5600177  
Fremont County

Dear Mayor Paris:

The above application for coverage under General Permits to Construct, Install, Modify or Operate both Public Water Distribution Systems and Extensions or Modification of Sewage collection systems in accordance with Chapter 3, Section 7 (a) (ii) of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facilities in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section 0 of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

A handwritten signature in cursive script that reads "Jeff Hermansky".

Jeff Hermansky  
Northwest District Engineering Supervisor  
Water Quality Division

cc: IPS, Cheyenne

encl: Copy of Sewage Collection Systems & Public Water Supply Distribution System general permits.

# PERMIT TO CONSTRUCT

New  
 Renewal

PERMIT NO. 00-391  
SPECIAL CONDITIONS

City of Laramie Connors Avenue Water and Sanitary Sewer Extensions  
PWS: 5600029

This permit hereby authorizes the applicant:

City of Laramie  
P.O. Box C  
Laramie WY 82073

to construct, install or modify an extension of City of Laramie water and sanitary sewer lines to serve 4 additional users according to the procedures and conditions of the application number 00-391. The facility is located in NW 1/4 Section 6 T15N R73W in the county of Albany, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-10-2000  
Date of Issuance

LBH/bb/02578.ltr

## STATEMENT OF BASIS

- I. Permit Number: 00-391
- II. Application reviewed for compliance with the following regulations.
- A. Chapter XI. YES
- B. Chapter XII. YES
- III. Basis for issuing permit: Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- IV. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.
- NO
- V. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on October 6, 2000. Permit issuance is commended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LBH/bb/02578.ltr

# PERMIT TO CONSTRUCT

X New  
— Renewal  
— Modified

PERMIT NO. 00-392R  
SPECIAL CONDITIONS

## Northern Food & Dairy, Inc. Wastewater Lift Station

This permit hereby authorizes the applicant:

Northern Food & Dairy, Inc.  
601 3rd Ave. West  
P.O. Box 98  
Alexandria, MN 56308

to construct a wastewater pump station and approximately 1,000 feet of 4-inch force main to connect a food processing plant to the Town of Afton wastewater collection system according to the procedures and conditions of application number 00-392R. The facility is located in NE1/4 Section 25, T32N, R119W in the county of Lincoln, in the State of Wyoming. This permit shall be effective for a period of two (2) years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

11-29-2000  
Date of Issuance

DHC/dc  
b/02975.ltr

cc: Town of Afton; Attn: J. Scott Darrington; P.O. Box 310; Afton, WY 83110-0310

STATEMENT OF BASIS

I. General information.

Permit Number: 00-392R

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

Not Applicable

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle Conklin, SW District Engineer, and completed on November 27, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

DHC/bb/02975.ltr

## PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-393  
SPECIAL CONDITIONS

### City of Riverton Wastewater Treatment Plant Pump Replacement

This permit hereby authorizes the applicant:

City of Riverton  
816 N. Federal  
Riverton, WY 82501

to construct, install or modify a wastewater treatment plant pump replacement according to the procedures and conditions of the application number 00-393R. The facility is located in NW1/4 of Section 36, Township 36 North, Range 92 West in the county of Fremont, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SRF Program, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4. The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4. The applicant will provide immediate oral and/or written notice to the Cheyenne Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4. Within sixty days of completion of construction of the authorized facility, the applicant will submit to Cheyenne Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Director  
Department of Environmental Quality

10-31-00  
\_\_\_\_\_  
Date of Issuance

PBS/bb/02749.ltr

cc: Vern Heisler, City of Riverton  
Jeff Hermansky, WDEQ/WQD Lander

## STATEMENT OF BASIS

General information.

A. Permit Number: **00-393**

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. *yes*

B. Chapter XII. *no*

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

*yes*

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

*no*

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

*no*

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

*not applicable*

B. Briefly state the basis for the deviation.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

*not applicable*

- V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter III<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

*not applicable*

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Phillip Stump, Senior Environmental Analyst, and completed on October 26, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PBS/bb/02749.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

# PERMIT TO CONSTRUCT

✓ New  
— Renewal

PERMIT NO. 00-394  
SPECIAL CONDITIONS

Cheyenne BOPU Frontier Street Water Line Replacement  
PWS# 5600011

This permit hereby authorizes the applicant:

Cheyenne Board of Public Utilities  
P.O. Box 1469  
Cheyenne WY 82003-1469

to construct, install or modify a emergency replacement of one block of water main on Frontier Street between Ridge Road and Winwood Drive according to the procedures and conditions of the application number 00-394. The facility is located in NW 1/4 Section 34 T14N R66W in the county of Laramie, in the State of Wyoming. This permit shall be effective for a period of two years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-10-2000  
Date of Issuance

LBH/bb/02582.ltr

STATEMENT OF BASIS

Permit Number: 00-394

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. NO

B. Chapter XII. YES

III. Basis for issuing permit: Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

IV. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.

NO

V. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on October 6, 2000. Permit issuance is commended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LBH/bb/02582.ltr

**AS-BUILT**  
**PERMIT TO CONSTRUCT**

— New  
Renewal  
Modified

PERMIT NO. 00-395RR  
SPECIAL CONDITIONS

**AMFAC Resorts- Yellowstone National Park Lake Village RV Park**  
**PWS # WY 56800079**

This permit hereby authorizes the applicant:

National Park Service-YNP  
Edna Good  
P.O. Box 168  
Yellowstone National Park, WY 82190

to have constructed a water distribution system extension for 88 recreational vehicle (RV) sites and two comfort stations consisting of 2900 feet of 4 inch ductile iron pipe and appurtenances; also constructed was 2920 feet of 6 inch and 8 inch PVC sewer main and appurtenances for the RV sites and comfort stations according to the procedures and conditions of application number 00-395RR. The facility is located at a Latitude of 44° 33' 40" and at a Longitude of 110° 23 ' 50" in the county of Teton, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, meets applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee has constructed and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 1 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

4-18-01  
\_\_\_\_\_  
Date of Issuance

MDB/mdb  
b/10809.ltr

## STATEMENT OF BASIS

### I. General information.

Permit Number: 00-395RR

### II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. Yes

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

### IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Section 9 (d)(I), Chapter 11-Manholes and cleanouts.

B. Briefly state the basis for the deviation.

Cleanouts have been installed where there is a horizontal change in direction between manholes based on paragraphs 4-8 , 2.6, 2.7, and 2.8 of ANSI A119.4/NFPA 1194 Standard for Recreational Vehicle Parks and Campgrounds.

C. Permit based on general or statewide deviation contained in approved policy statement.

No

### V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter III<sup>1</sup>.

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

VI. If Section 17 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on April 10, 2001. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/10809.ltr



The State  
of Wyoming



## Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--------------------------------------------------	---------------------------------------------------	-----------------------------------------------	-----------------------------------------------------	------------------------------------------------	------------------------------------------------------	-------------------------------------------------

April 12, 2001

National Park Service-YNP  
Edna Good  
P.O. Box 168  
Yellowstone National Park, WY 82190


RE: As-Built Permit To Construct, WQD Reference Number: 00-395RR

Dear Ms. Good:

The Department of Environmental Quality/Water Quality Division (DEQ/WQD) has reviewed the above referenced As-Built Application submitted by your engineer, Eugene C. Jackson. Our review of the information and as-constructed plans submitted to this office indicate that the application meets DEQ/WQD regulations and the enclosed As-Built Permit To Construct is hereby issued. The enclosed permit covers a previously constructed water distribution system extension and sewerage collection system for 88 recreational vehicles (RV) sites and two comfort stations which has already been constructed. Please be advised that the construction of all public water and sewerage systems within the Wyoming portion of Yellowstone National Park must be permitted by the Wyoming Department of Environmental Quality.

Please be advised that the system must be constructed, installed, and operated in accordance with the statements, representations and procedures presented in the application, and all supporting documentation as well as the terms and conditions of the permit. You are urged to be familiar with all aspects of the permit application, permit, and permit conditions. Any person objecting to a permit issued by the DEQ and desiring affirmative relief may request a hearing before the Environmental Quality Council in accordance with the Rules of Practice and Procedure for the Department of Environmental Quality and the Wyoming Administrative Procedures Act.

Sincerely,

  
Dennis Hemmer  
Director

Department of Environmental Quality

LA/mdb/bb/10809.ltr

Enclosure



— GERINGER  
GOVERNOR

## Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES  
(307) 332-5085

AIR QUALITY  
(307) 332-6755

LAND QUALITY  
(307) 332-3047

SOLID & HAZARDOUS WASTE  
(307) 332-6924

WATER QUALITY  
(307) 332-3144

### NOTIFICATION OF COVERAGE

January 10, 2001

The Teton Lodge, LLC  
P.O. Box 564  
Teton Village, WY 83025

RE: The Teton Lodge, Permit Number 00-396R  
Teton County  
PWS # 5600218

Dear Mr. DesLauriers:

The above application for coverage under General Permit to Construct, 492 linear feet of 8 inch ductile iron water main and 85 linear feet of 8 inch PVC sewer main to serve a 5 story condominium resort with 182 bedrooms in accordance with, Section 7 Chapter 3, Section 9 Chapter 11, and Section 14 Chapter 12, of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, E.I.T.  
Environmental Senior Analyst  
Water Quality Division

Jeff Hermansky, P.E.  
Northwest District Engineer  
Water Quality Division

cc: IPS, Cheyenne  
encl: (Water Line General Permit Previously Sent)

# PERMIT TO CONSTRUCT

X New  
— Renewal  
— Modified

PERMIT NO. 00-397  
SPECIAL CONDITIONS

## Big Horn County Jail - Water & Sewer Extension PWS # WY5600004

This permit hereby authorizes the applicant:

Big Horn County  
420 West C Street  
Basin, WY 82410

to construct, 85 linear feet of 4 inch PVC water service for domestic use and 85 linear feet of 6 inch PVC water service for fire protection along with various valves and fittings. Also included in this construction is, 282 linear feet of 6 inch PVC sewer main and 9 manholes, according to the procedures and conditions of application number 00-397. The facility is located in NW 1/4 Section 21, T51N, R93W in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 5 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

5 of 5 Approval of the proposed backflow prevention device (Ames Model 2001SS) for the 6 inch fire service, as required by Section 14 (i)(C) Chapter 12 of the Water Quality Rules and Regulations, is pending. Approval by the Foundation for Cross-Connection Control and Hydraulic Research at the University of Southern California is required before the Ames Model 2001SS can be installed.

AUTHORIZED BY:



Gary Beach  
Administrator  
Water Quality Division



Dennis Hemmer  
Director  
Department of Environmental Quality

11-29-2000

Date of Issuance

MDB/mdb  
02958.ltr

## STATEMENT OF BASIS

I. General information.

Permit Number: 00-397

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

N/A

VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on November 21, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/02958.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

# PERMIT TO CONSTRUCT

X New  
— Renewal  
Modified

PERMIT NO. 00-398  
SPECIAL CONDITIONS

## Town of Greybull Sewer System Rehabilitation Project-Phase I

This permit hereby authorizes the applicant:

Town of Greybull  
P.O. Box 271  
Greybull, WY 82476

to install, either cured in place pipe or fold and form pipe, in approximately 4200 linear feet of existing 6 inch vetrified clay pipe (VCP) and 700 linear feet of existing 8 inch VCP ; along with the replacement, of 700 linear feet of 6 VCP with 8 inch PVC, and 6 manholes, according to the procedures and conditions of application number 00-398. The facility is located in the SE 1/4 & NE 1/4 Section 8, T52N, R93W, in the county of Big Horn, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does


not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

12-7-00  
\_\_\_\_\_  
Date of Issuance

MDB/mdb  
b/03051.ltr

## STATEMENT OF BASIS

### I. General information.

Permit Number: 00-398

### II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. No

### III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

Yes

### IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

1) Section 5 (a)(i), Chapter 11, states that data obtained from a full scale, comparable installation which demonstrates the acceptability of the design should be included.

2) Chapter 11, Part B, Section 9 (c)(i)(C) states that minimum slope of a 6 inch sewer pipe is 0.006 ft/ft and 8 inch is 0.004 ft/ft for a gravity system.

B. Briefly state the basis for the deviation.

1) Cured-in-place pipe (CIPP) and fold and form pipe sewer relining is new technology with no approved policy statement.

2) This permit involves the replacement of sewer pipe which contains flat grade sewers and or low spots (zero slope) where the sewage stands in the pipe. These low spots will not be corrected using either CIPP or fold and form pipe.

C. Permit based on general or statewide deviation contained in approved policy statement

1) No policy has been written but industry experience and data has shown that sewers relined with either the new CIPP or the fold and form pipe technology perform as expected. CIPP, must meet

the ASTM F-1216 standard specifications for the rehabilitation of existing pipelines and conduits. Fold and form pipe, must meet the ASTM F-1504 standard specifications for the rehabilitation of existing sewers and conduits.

- 2) Policy 13.9.13 Flat grade sewers granted variance because using PVC pipe, the calculated flow velocity is at least 2 ft/sec., the minimum flushing velocity, at the slopes listed in the policy.

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>.

N/A

VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on December 4, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/03051.ltr

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-399  
SPECIAL CONDITIONS  
Reference 99-300

HOLLY PONDS COMMERCIAL AREA  
PWS NUMBER 5600052

This permit hereby authorizes the applicant:

Holly Ponds, LLC  
P.O. Box 6793  
Sheridan, WY 82801  
Attention: Jim Willey

to construct, install or modify water distribution and water collection systems according to the procedures and conditions of the application number 00-399 and 99-300. The facility is located in the SE/4 of Section 21 of T56N R84W in the county of Sheridan, in the State of Wyoming. This permit shall be effective for two (2) years from the date of issuance.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northeast District, State of Wyoming, DEQ, Water Quality Division, 1043 Coffeen Avenue, Suite D, Sheridan, Wyoming 82801; telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

10-16-2000  
Date of Issuance

DRM:dm 101200

b/O2638.ltr

Enclosures: Post Card, Certificate of Completion & Statement of Basis

xc: Jim Willey, M-W, #2 Taylor Pl. 1030 N.Main, Sheridan, 82801  
Susan Fields, City of Sheridan

## STATEMENT OF BASIS

General information.

A. Permit Number: 00-399

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11 Yes

B. Chapter 12 Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter 8. Briefly describe:

N/A

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, place of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Don McKenzie, NE Water & Wastewater Section Program Principal, and completed on October 12, 2000. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# PERMIT TO CONSTRUCT

New  
 Renewal  
 Modified

PERMIT NO. 00-400  
SPECIAL CONDITIONS

## Grizzly Processing - Waste Products Holding Tanks and Disposal

This permit hereby authorizes the applicant:

Jerry Miller  
1105 East Richards Street  
Douglas, Wyoming 82633

to construct and install slaughter house waste holding tanks according to the procedures and conditions of the application number 00-400. The facility is located in the NE1/4NE1/4 of Section 05, T32N, R71W in the county of Converse, in the State of Wyoming. This permit shall be effective for a period of 2 years from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits, or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District Engineering Supervisor, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5. The applicant will notify the DEQ/WQD Southeast District Office by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5. The applicant will provide immediate oral and/or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. **Submittal of a constructed plans and specifications** for the system as it was constructed, certified by an engineer if appropriate. All **modifications or deviations** from the authorized plans **must be highlighted**.
- 4 of 5. Waste Disposal - The liquid and solid waste products shall be disposed of at either the City of Douglas Septic waste Disposal facility or the Douglas Landfill in accordance with the conditions set forth by the City of Douglas.
- 5 of 5. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
Gary Beach  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
Dennis Hemmer  
Director  
Department of Environmental Quality

1-30-1  
\_\_\_\_\_  
Date of Issuance

RLE/bb/10215.ltr

cc: Stephen F. Bennett, Director of Public Works, City of Douglas, 420 West Grant, Douglas, Wyoming 82633

STATEMENT OF BASIS

I. General information.

A. Permit Number: 00-400

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11. Yes

B. Chapter 12. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

NOT Applicable

B. Briefly state the basis for the deviation.

NOT Applicable

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

NOT Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3<sup>1</sup>. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NOT Applicable

---

<sup>1</sup>Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

VI. Deleted

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, Senior Analyst, and completed on January 29, 2001. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/bb/10215.ltr

REVIEW OF PLANS AND SPECIFICATIONS  
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION

Herschler Bldg., 4 West  
Cheyenne, Wyoming 82002

PROJECT: Grizzly Processing - Waste Products Holding Tanks and Disposal

ENGINEER: John A. Lambert  
John A. Lambert & Assoc.  
P.O. Box 34  
Douglas, Wyoming 82633

APPLICANT: Jerry Miller  
1105 East Richards Street  
Douglas, Wyoming 82633

WATER QUALITY DIVISION REFERENCE NUMBER: 00-400

REVIEWING ENGINEER: Ronald L. Ewald *RLE*  
Phone: (307) 777-6183

DATE OF REVIEW: October 18, 2000

**ACTION:** NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 12 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

**COMMENTS, INADEQUACIES, AND QUESTIONS:**

1. Holding Tank Waste Composition and Letter of Acceptance - Please identify the specific waste products which will end up in the holding tanks; [i.e., primary blood, other fluids (not blood), guts, bones, other solids, wash down water, or any other waste stream]. Additionally, a letter of approval and acceptance, signed by an appropriate city official, from the Wastewater Treatment Plant and/or the Landfill must be provided indicating that they will accept this type of waste mixture.