

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 02-151
SPECIAL CONDITIONS

2002 Water Transmission Lines - Phase 1
PWS NO. 5600022

This permit hereby authorizes the applicant:

Town of Greybull
PO Box 271
Greybull, WY 82426

to construct, modify, or install approximately 7570 feet of 8 in., 12 in., and 14 in. water mains including crossing the Big Horn River, replacement of approximately 55 water services, installation of a pressure reducing valve and vault, installation of fire hydrants and related appurtenances according to the procedures and conditions of the application numbers 02-151. The facility is located in the Section 8, 9, 17, 18, 19, Township 52N, Range 93W in the county of Big Horn, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by December 31, 2005.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Herschler Bldg. 4W, 122 W. 25th St., Cheyenne, WY 82002; telephone (307) 777-6267; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 11, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.

- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Gary Beach
Administrator
Water Quality Division



Dennis Hemmer
Director
Department of Environmental Quality

8-29-02

Date of Issuance

PBS/bb/2-2763.ltr

cc: Tom Crank, Crank Companies, Incorporated, PO Box 631, Kemmerer, WY 83101
Ted Coyer, Wyoming Water Development Office
Jeff Hermansky, WDEQ/WQD, Lander

STATEMENT OF BASIS

I. General information.

A. Permit Number: 02-151

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11 No

B. Chapter 12 Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

- VI. If Section 17 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

- B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Phillip Stump and Jeff Hermansky, and completed on August 27, 2002. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

PBS/bb/2-2763.ltr



The State
of Wyoming



Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---

August 27, 2002

Mr. Ross Jorgensen, Public Works Director
Town of Greybull
PO Box 271
Greybull, WY 82426

RE: WQD's Permit to Construct No. 02-151R for Greybull's 2002 Water Transmission Lines - Phase 1

Dear Mr. Jorgensen:

Please see the enclosed WQD Permit to Construct. The Wyoming Department of Environmental Quality, Water Quality Division (WDEQ/WQD) has concerns about the presence of shallow hydrocarbon contamination along the existing 12 inch PVC water main on the former BP Amoco refinery property and at the existing fire hydrant located at the intersection with 5th Avenue South. RETEC's August 9, 2002 Water Line Investigation Report indicated significant concentrations of hydrocarbon contaminated soils and shallow groundwater contamination in this area. The diesel and gasoline contaminants can permeate PVC water mains and gaskets resulting in contamination of drinking water.

WDEQ/WQD will be working closely with you, and all other parties involved, to resolve these existing drinking water contamination threats and to resolve the proposed Phase 2 water main location in the former refinery area. Please call me directly about any questions that you have regarding this Permit to Construct 307-777-7267.

Sincerely,

Phillip Stump
Phillip Stump, P.E.
Senior Analyst, SRF Program
Water Quality Division

PBS/bb/2-2762.ltr

encl: WQD Permit to Construct

cc: Tom Crank, Amy Butler, Crank Companies, Incorporated, PO Box 631, Kemmerer,
WY 83101 (w/encl)
Dorothy Hall, WDEQ/SHWD Lander
Jeff Hermansky, WDEQ/WQD Lander (w/encl)
Ted Coyer, WWDC (w/encl)
Mike Hackett, WWDC



The State
of Wyoming

Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Jim Geringer, Governor



6-3-02
Barb

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

May 29, 2002

Mr. Richard Kerschbaum
1801 Cliff Davis Drive
Gillette, WY 82716

RE: Richard Kerschbaum Residential Septic, Permit # 02-152

Dear Mr. Kerschbaum:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of small wastewater septic in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457.

Thank you.

Sincerely,

Rick J. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Town of Pine Haven
Rob Anderson - Contractor

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 02-153
SPECIAL CONDITIONS

JOHNSON COUNTY LANDFILL HOLDING TANK

This permit hereby authorizes the applicant:

Johnson County Solid Waste Board
76 N. main
Buffalo, WY 82834

to construct and install a holding tank for septage according to the procedures and conditions of the application numbers 02-153. The facility is located in the NE/4 of Section 5 T50N R81W in the county of Johnson, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by June 1, 2003.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Casper WDEQ Field Office, 3030 Energy Lane, Casper, WY 82604, telephone (307) 473-3452; FAX (307) 473-3458.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the appropriate district office of the Water Quality Division, Department of Environmental Quality, by the attached post card of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 11, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 5 The permittee shall have a contract with a septage hauler to pump the holding tank on a regular schedule and provide a copy of the contract to DEQWQD in Casper.
- 5 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Gary Beach
Administrator
Water Quality Division



Dennis Hemmer
Director
Department of Environmental Quality

5-21-2002
Date of Issuance

JDL/14/05/02
b/2-1573.ltr

Enclosures: Construction Notice Post Card, Certificate of Completion and Statement of Basis

STATEMENT OF BASIS

General information.

A. Permit Number: 02-153

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11 Yes

B. Chapter 12 No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Chapter 11 Section 43. Holding Tanks. This section prohibits septage holding tanks for new construction.

B. Briefly state the basis for the deviation.

The facility is an office trailer for worktime use at the Johnson County Landfill. This landfill already has problems with groundwater contamination and the introduction of wastewater into the subsurface could potentially create further problems. The area near where the trailer is to be located may have buried garbage and or highly permeable scoria/clinker in the subsurface. It was agreed by DEQ Solid and Hazardous Waste, Water Quality, and Johnson County that a holding tank would help prevent potential groundwater contamination. The Johnson County solid Waste Board has agreed to have a contract in place for a septage hauler to pump and properly dispose of the septage on a regular schedule.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. If Section 17 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, NE District Water & Wastewater Supervisor, and completed on May 14, 2002. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JDL/bb/2-1573.ltr

THE STATE



OF WYOMING

JIM GERINGER
GOVERNOR



Department of Environmental Quality

250-Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

June 24, 2002

John A. Sulenta, President
Redstone Corporation
P.O. Box 377
Pinedale, WY 82941

RE: Fox Willow Park II and the Meadows Sewer and Water, Permit Number 02-154; SE 1/4
Section 4, T33N, R109W, Sublette County

Dear Mr. Sulenta:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems and Extensions to or Modification of Existing Sewage Collection Systems in accordance with Chapter 3, Section 7 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Subpart O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

A handwritten signature in black ink, appearing to read "Doyle Conklin".

Doyle Conklin
SW District Engineering Supv.
Water Quality Division

cc: IPS, Cheyenne
Town of Pinedale; P.O. Box 709; Pinedale, WY 82941



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

6-3-02
Barb

Jim Geringer, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

May 29, 2002

Mr. Jack Keller
504 E. Laramie
Gillette, WY 82716

RE: Jack Keller Residential Septic, Permit # 02-155



Dear Mr. Keller:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of small wastewater septic in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457.

Thank you.

Sincerely,

Rick J. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Town of Pine Haven
Rob Anderson - Contractor



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Jim Geringer, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

June 5, 2002

Keith A. Neustel, PE & LS #2085
Grizzly Engineering
P.O. Box 1004
Buffalo, WY 82834

RE: Livestock Market Park Water Main, Permit # 02-156

Dear Keith:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a water distribution system in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit.

If you have any questions please contact me.

Thank you.

Sincerely,

Rick J. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst

cc: IPS, Cheyenne
City of Buffalo - Utilities Department



The State
of Wyoming



Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

June 19, 2002

Richard & Sharron Jarrard
P.O. Box 198
Medicine Bow, Wyoming 82329

RE: Jarrard Residential Septic System, Application No. **02-157**
Location: S 1/2 SE 1/4, Section 16, T24N, R67W, Platte County

Dear Mr. & Mrs. Jarrard:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:


Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.

Mr. & Mrs. Jarrard
June 20, 2002
Page 2

The approval granted under this Notification Of Coverage and the General Permit shall expire on June 30, 2004. Please reference Application Number 02-157 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

A handwritten signature in cursive script that reads "Ronald L. Ewald".

Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bb/2-1988.ltr

cc: IPS, Cheyenne

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion



THE STATE OF WYOMING



JIM GERINGER
GOVERNOR

Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

*5-28-02
Parker*

ABANDONED MINES (307) 332-5085	AIR QUALITY (307) 332-6755	LAND QUALITY (307) 332-3047	SOLID & HAZARDOUS WASTE (307) 332-6924	WATER QUALITY (307) 332-3144
-----------------------------------	-------------------------------	--------------------------------	---	---------------------------------

NOTIFICATION OF COVERAGE

May 23, 2002

William Parker
1288 Missouri Flat Road
Thermopolis, WY 82443

RE: Parker Small Wastewater Evaporation Pond, Permit Number# 02-158
Hot Springs County

Dear Mr. Parker:

The above application for coverage under General Permit to Construct a small wastewater evaporation pond in accordance with Chapter 3, Section 7, Chapter 11, Part D of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Jeff Hermansky
Northwest District Supervising Engineer
Water Quality Division

cc: IPS, Cheyenne
encl: General Permit for Small Wastewater Facility (Evaporation Pond)



THE STATE OF WYOMING

JIM GERINGER
GOVERNOR



Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

June 25, 2002

Florence McLeish, General Manager
Star Valley Ranch Association
P.O. Box 159
Thayne, WY 83127

RE: Star Valley Ranch Association - Water Main Replacement, Permit Number: 02-159,
SW 1/4 Section 19, T35N, R118W, Lincoln County, PWS # WY5600287

Dear Mr. McLeish:

The above application for coverage under General Permit to Construct the replacement, of a public water supply system, consisting of 7900 L.F. of 6 - inch HDPE water main and appurtenances in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facilities in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, E.I.T.
Environmental Senior Analyst
Water Quality Division

Doyle Conklin, P.E.
Southwest District Engineer
Water Quality Division

cc: IPS, Cheyenne
encl: General Permit For a Public Water Supply



The State
of Wyoming



Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---

NOTIFICATION OF COVERAGE

July 29, 2002

Monique Lewis, President
Spencer Home Sites Sewer District
2 Welcome Rd.
Riverton, WY 82501

RE: Spencer Home Sites Sanitary Sewer Improvements, WQD Permit No. **02-160**, NE1/4NE1/4, Section 23, T 1N., R.4E., WRM.

Dear Ms. Lewis:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Sewage Collection Systems in accordance with Chapter 3, Section 7, and Chapter 11 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility(ies) in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

The approval granted under this Notification of Coverage and the General Permit shall expire on October 26, 2005. Please reference Permit 02-160 in any future correspondence.

If you have any questions, please contact me directly at (307) 777-7267.

Sincerely,

Phillip Stump
Phillip Stump
Senior Analyst
SRF Program
Water Quality Division

PBS/bb/2-2438.ltr

Enclosure

cc: IPS, Cheyenne
Bill Urbigkit, Public Works Director, City of Riverton, 816 N. Federal Blvd., Riverton, WY 82501
Terry Zenk, Apex Surveying, Inc., PO Box 1751, Riverton, WY 82501

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

Herschler Building 4 West
Cheyenne, Wyoming 82002


PROJECT: Wyoming Premium Farms Additional Farrowing Site Land Application Area

APPLICANT: Wyoming Premium Farms

WATER QUALITY DIVISION REFERENCE NUMBER: 02-161

REVIEWING ENGINEER: Louis B. Harmon

DATE OF REVIEW: July 1, 2002



ACTION: NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 9 (a)(ii), Chapter 3, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with said Section 9. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. A public meeting for discussion of this application will be scheduled after approval is recommended by the Southeast District of the Water Quality Division.
2. The application must include agreements signed by any land owners of record authorizing land application of swine waste and giving the Water Quality Division Administrator or his designated representatives the right of entry to conduct inspections and to take soil or water samples to determine compliance with this permit.
3. Details of the piping system to transport the liquid swine wastes to the proposed center pivot systems must be provided. A Wyoming licensed engineer must sign the drawings.
 - a. Chemigation valves meeting the requirements of Chapters 9, 10, and 11 of Title 195 of the Nebraska Department of Environmental Control must be installed at each well connected to center pivot sprinklers that may be used to apply swine manure before any application of waste is conducted.
 - b. The design should include fail safe provisions to prevent accidental releases as a result of piping or connection failures. Because the center pivots are at a lower elevation than the lagoons, siphonage increases the risk of a catastrophic release.

4. The permit must provide provisions for soil testing.
 - a. Center pivot irrigation areas shall be divided into quadrants. Each quadrant shall be considered a management parcel.
 - b. One soil test shall be taken from each parcel before land application of liquid wastes. A post application soil test shall be taken the following April-June after land application of liquid wastes.
 - c. A soil test for irrigated land shall consist of three samples tested individually. Each sample shall be a composite from four locations within the management parcel. One sample shall be from the 0" to 12" depth, one sample from the 12" to 24" depth, and one sample for the 24" to 48" depth. If test results of the 24"-48" horizon indicate increasing nutrient levels, additional sampling shall be conducted of the 48" to 72" horizon.
 - d. Standard soil tests shall be taken, including analysis for phosphorus and Nitrate as N reported as parts per million and as pounds per acre for the horizon represented by the sample.
 - e. Use pan tests under the traveling sprinkler to verify amount applied, total nitrogen applied, and to take samples for a fecal coliform test. At least one composite test using three pans shall be taken each week of application operations.
 - f. The nutrients supplied by a land application plus the residual nutrients in the soil shall not exceed the agronomic requirements of the crop to be seeded or the agronomics requirements of the vegetation on irrigated pasture. If agronomic rates are exceeded no additional applications may be made to that parcel until the situation is remedied.
 - g. The liquid applied by an application of animal wastes shall not exceed the retention capacity of the upper 12 inches of the soil less the pre-existing moisture content of the soil. The liquid application rates shall be adjusted as necessary for the most restrictive soil type within a management parcel.
 - h. The amount of phosphorus present in the upper 12 inches of soil shall be monitored using tests appropriate for the soil pH. If the phosphorus loading exceeds 300 pounds per acre, additional soil testing shall be undertaken to evaluate the potential for deleterious salt and alkali accumulations.
 - i. If phosphorus loading exceeds 300 pounds per acre or deleterious amounts of salt accumulate, land application to that management parcel shall stop until the parameter of concern is remedied.
5. The application should include an excerpt of the Platte County soil mapping for the areas proposed for swine waste application, a description of each soil type present, and the significant characteristics of that soil type.
6. Please describe any additional measures necessary to prevent run-off from the land application areas reaching Fish Creek.

LBH/bb/2-110.ltr

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 02-162
SPECIAL CONDITIONS

Town of Marbleton - Marbleton Well #6 Appurtenances

This permit hereby authorizes the applicant:

Town of Marbleton
P.O. Box 4160
Marbleton, WY 83113
PWS #WY5600223C

to construct a wellhouse with controls and desander, and install a pump and pitless adaptor in Marbleton Well #6 according to the procedures and conditions of application number 02-162. The facility is located in SE1/4 SE1/4 SW1/4 Section 20, T30N, R111W in the county of Sublette, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by August 31, 2004.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Gary Beach
Administrator
Water Quality Division



Dennis Hemmer
Director
Department of Environmental Quality

8-16-02

Date of Issuance

STATEMENT OF BASIS

I. General information.

Permit Number: 02-162

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. No

B. Chapter 12. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3¹.

Not Applicable

VII. Documentation of Statement of Basis.

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle Conklin, SW District Engineering Supervisor, and completed on August 15, 2002. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



JIM GERINGER
GOVERNOR

Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES (307) 332-5085	AIR QUALITY (307) 332-6755	LAND QUALITY (307) 332-3047	SOLID & HAZARDOUS WASTE (307) 332-6924	WATER QUALITY (307) 332-3144
-----------------------------------	-------------------------------	--------------------------------	---	---------------------------------

NOTIFICATION OF COVERAGE

September 30, 2002

Martin Cosat, Owner
2425 Big Horn Avenue
Cody, Wyoming 82414

RE: Cody- Powell Highway Subdivision Water Main Extension - Tracts 5 and 6,
Permit Number: 02- 163R, NW 1/4 NE 1/4, Tract 71,T53N,R101W,
Park County, PWS # WY5600207

Dear Mr. Cosat:

The above application for coverage under General Permit to Construct the extension of a public water system consisting of 170 linear feet of 8-inch PVC water main and appurtenances in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, E.I.T.
Environmental Senior Analyst
Water Quality Division

Doyle Conklin, P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
encl: General Permit for a Public Water Supply



The State
of Wyoming



Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---

NOTIFICATION OF COVERAGE

June 26, 2002

Mr. Wesley Bressler
City of Laramie
P.O. Box C
Laramie WY 82073

RE: City of Laramie 20/24 Inch Pipeline Replacement and Cathodic Protection Project, Application No.02-164, Albany County

Dear Mr. Bressler:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by 1 July 2005. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No.02-164 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/bb/2-2077.ltr

Enclosure

IPS, Cheyenne
James I. Cavalli, Banner Associates, Inc.
2020 East Grand Avenue, Suite 500
Laramie WY 82070

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

Herschler Building 4 West
Cheyenne, Wyoming 82002

PROJECT: City of Laramie 20/24-Inch Pipeline Replacement and Cathodic Protection Device


ENGINEER: Banner Associates, Inc. / Jim Cavalli

APPLICANT: City of Laramie

WATER QUALITY DIVISION REFERENCE NUMBER: 02-164

REVIEWING ENGINEER: Louis B. Harmon

DATE OF REVIEW: June 10, 2002



ACTION: NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 9 (a)(ii), Chapter 3, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with said Section 9. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. Valves need to be installed as close to the river crossing as possible in areas that are not subject to flooding. The proposed valve locations on the 20 inch line are too far from the crossing. The logical valve spacing would allow isolating the river crossing without the necessity of closing any valves to smaller diameter distribution lines.
2. The reduced pressure backflow devices proposed for the blow-offs at Spruce and Pine Streets are the inappropriate devices for the proposed applications. Backflow prevention for the blow-offs can most simply be provided by assuring the proper air gap is provided at the discharge end of the blow-off line. If this is not possible, then an atmospheric vacuum breaker would be adequate. The reduced pressure devices should only be installed in an area that provides adequate drainage for the full flow of the atmospheric discharge port. For an 8" device that flow is several hundred gallons per minute.
3. Inadequate drainage has been provided for the air/vac valves. The suggestion is made that the vent lines from the valves be extended to discharge to the surface through the vent lines attached to the vaults.

4. The design report, plans, and specifications provide inadequate details to determine that the control vault meet the necessary requirements for lighting and ventilation. Although Chapter 12 does not directly address control vaults, Section 12 covers pumping facilities. The control vault should be treated as an accessible, not normally occupied below ground pumping station. Please document that the control vault meets these requirements. Security of the control vault needs to be considered. The manhole and steps proposed would seem inadequate for the type of installation proposed. Value engineering and life cycle cost analysis might prove that the control vault could better be constructed entirely above ground.

LBH/bb/2-1895.ltr

PERMIT TO CONSTRUCT

Auth db
P8V
1-28-03

New
 Renewal
 Modified

PERMIT NO. 02-165
SPECIAL CONDITIONS

Powell Wastewater Treatment Facility Modifications

This permit hereby authorizes the applicant:

City of Powell
P.O. Box 1008
Powell, WY 82435

to modify the piping to provide metering and flow control systems according to the procedures and conditions of application number 02-165. The facility is located in SW1/4 Sec. 36, T56N, R99W in the county of Park, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by January 27, 2005.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility, in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 4 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

- 2 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.


- 3 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

- 4 of 4 A draft updated Operation and Maintenance Manual must be provided to the DEQ/WQD before 50% construction of this project is reached.

AUTHORIZED BY:



Gary Beach
Administrator
Water Quality Division



Dennis Hemmer
Director
Department of Environmental Quality

1-28-03
Date of Issuance

STATEMENT OF BASIS

I. General information.

Permit Number: 02-165

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3¹.

N/A

VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Engineering Supervisor, and completed on January 27, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



JIM GERINGER
GOVERNOR



Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

July 10, 2002

David Hardie, Authorized Representative
Flat Creek Business Center, LLC
P.O. Box 1108
Jackson, WY 83001

RE: Jackson - Flat Creek Business Center Water & Sewer Main Extension,
Revised Permit - Permit Number: 02-166 (Previous DEQ/WQD Permit # 02 - 090),
NE1/4 Section 6, T40N, R116W, Teton County, PWS # 5600213

Dear Mr. Hardie:

The above application for coverage under General Permits to Construct the extension of a public water supply system consisting of 856 linear feet (LF) of 8 - inch & 573 LF of 6 - inch DI water main and the extension of a sewage collection system consisting of 1020 LF of 8 - inch PVC sewer main and appurtenances in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, E.I.T.
Environmental Senior Analyst
Water Quality Division

Jeff Hermansky, P.E.
Northwest District Engineer
Water Quality Division

cc: IPS, Cheyenne
encl: General Permit For a Public Water Supply Distribution System,
General Permit For a Sewage Collection System

AS-BUILT
PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 02-167
SPECIAL CONDITIONS

Tom Rickard - 30 Holloway Road Septic

This permit hereby authorizes the applicant:

Tom Rickard
29 Beaver Road
Wheatland, Wyoming 82201

to have constructed and installed a residential septic system with a chamber type leachfield according to the procedures and conditions of the application number 02-167. The facility is located in the SE 1/4 of Section 23, Township 24N, Range 68W, in the county of Platte, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, meets applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee has constructed and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

AUTHORIZED BY:



Gary Beach
Administrator
Water Quality Division



Dennis Hemmer
Director
Department of Environmental Quality

6-24-2002

Date of Issuance

RLE/bb/2-1989.ltr



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Jim Geringer, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

June 14, 2002

Mr. William Brewer
159 Sierra Cr.
Gillette, WY 82716

RE: William Brewer Residential Septic, Permit # 02-168

Dear Mr. Brewer:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of small wastewater septic in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit.


If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457.

Thank you.

Sincerely,

Rick J. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst

cc: ~~IPS, Cheyenne~~





The State
of Wyoming

Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Jim Geringer, Governor



9-25-02
Barb

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

September 23, 2002

Mr. Bill Mentock, PE/LS 3864
Mentock -Willey Consultants
1030 N. Main St.
Sheridan, WY 82801

RE: Powder Horn Subdivision Wastewater Treatment Plant Equalization Valve , Permit # 02-169
As-Built Permit

Dear Bill:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a extension to the Powder Horn Wastewater Treatment Plant in accordance with Chapter 3 and Chapter 11 of the WWQRR has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits. All construction, installation, or modification allowed by this permit shall be completed by June 6, 2003.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457. Thank you.

Sincerely,

Rick J. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Powder Horn LLC, P.O. Box 2007, Sheridan, WY 82801

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 02-170
 SPECIAL CONDITIONS

COTTONWOOD BAY WELL NO. 1 PWS NO. 5600652

This permit hereby authorizes the applicant:

State of Wyoming Division of Parks and Historic Sites
Herschler Bldg; 1-E
Cheyenne, WY 82002

to construct and install a privately owned water supply well in the Fall River or Lakota Aquifer and improvements according to the procedures and conditions of the application numbers 02-170. The facility is located in the SE/4 of Section 27 T51N R66W in the county of Crook, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by July 10, 2003.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Casper WDEQ Field Office, 3030 Energy Lane, Casper, WY 82604, telephone (307) 473-3452; FAX (307) 473-3458.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and the permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 11, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit;
- 2 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 4 of 4 Prior to connecting the well to the Wrangler Estates water supply system the permittee shall submit for review and written approval by DEQ:
 - 1.) a water quality sample, after the well has been reworked, and
 - 2.) the results of the proposed aquifer test.

AUTHORIZED BY:



Gary Beach
Administrator
Water Quality Division



Dennis Hemmer
Director
Department of Environmental Quality

7-15-2002

Date of Issuance

JDL-7/8/02-bb/2-2248.ltr

Enclosures: Certificate of Completion and Statement of Basis

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 02-170
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter 11 Yes
- B. Chapter 12 Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
No
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- N/A
- B. Briefly state the basis for the deviation.
N/A
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
N/A
- V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)
- N/A
- VI. If Section 17 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, NE District Water & Wastewater Supervisor, and completed on July 8, 2002. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



THE STATE OF WYOMING

JIM GERINGER
GOVERNOR



Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

July 29, 2002

Tim Moyer, Pastor
Emmanuel Bible Church
P.O. Box 962
Thayne, WY 83127

RE: Emmanuel Bible Church Wastewater, Permit Number 02-171R, N1/2 NW1/4 Section 11,
T34N, R119W, Lincoln County

Dear Pastor Moyer:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 7 and Chapter 11, Part D of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Doyle Conklin
SW Distinct Engineering Supervisor
Water Quality Division

cc: IPS, Cheyenne
John Woodward; Lincoln County Planning & Zoning; P.O. Box 414; Afton, WY 83110
encl: General Permit to Construct A Small Wastewater Facility



The State
of Wyoming



Department of Environmental Quality

Jim Geringer, Governor

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

August 12, 2002

Holly Ponds LLC
P. O. Box 6793
Sheridan, WY 82801

RE: Holly Ponds PUD Units 6 & 7, Permit # 02-172

Dear Sir:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a extension to the City of Sheridan Wastewater Collection and Water Distribution system in accordance with Chapter 3, 11 and 12 of the WWQRR has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits. All construction, installation, or modification allowed by this permit shall be completed by August 1, 2003.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457. Thank you.

This letter replaces the July 31, 2002 Notice of Coverage to make a revision to the permit completion date identified in paragraph one.

Sincerely,



Rick J. Estes, P.E.

DEQ/WQD NE District Senior Environmental Analyst

cc: ~~IPS~~, Cheyenne

Jim Willey, PE # 4263, 1030 N. Main, #2 Taylor Place, Sheridan, WY 82801 (NOC Only)

Jackie Flowers, City of Sheridan Public Works Director-(NOC Only)



The State
of Wyoming

3



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Jim Geringer, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050


LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

April 15, 2002

Mr. Erik Miller, PE
TSP Two Inc.,
One S. Scott Street
P.O. Box 1039
Sheridan, WY 82801



RE: Whitney Commons Project, Permit # 02-173

Dear Erik:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a water distribution system in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit.

If you have any questions please contact me.

Thank you.

Sincerely,

Rick J. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst

cc: WDEQ IPS, Cheyenne
Jackie Flowers-Public Works Director, City of Sheridan

ROAD APPLICATION PERMIT

New
 Renewal
 Modified

PERMIT NO. 02-174
SPECIAL CONDITIONS
REF/PERMIT

Nickelson Little Farms Home Owners Association

This permit hereby authorizes the applicant:

Orcan Oilfield Services, Ltd.
P.O.Box 534, STE #180
Gillette, Wy 82718

to road apply DS-1000 according to the procedures and conditions of application number 02-174. The application site is located in Section 23 & 26 T49N R71W in the county of Campbell, in the State of Wyoming. This permit shall be effective until November 1, 2002.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 8 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates at least 48 hours before road application is started. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Casper WDEQ Field Office, 3030 Energy Lane, Casper, WY 82604, telephone (307) 473-3452; FAX (307) 473-3458 or Rick J. Estes, PE, 1043 Coffeen Ave., Suite D, Sheridan, WY, 82801, (307)-672-6457.

- 2 of 8 The permittee shall provide immediate oral and/or written notice to the one of the WDEQ Offices, identified in 1 of 8 above, in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
- 3 of 8 The permittee shall provide certification that the project was completed in accordance with the terms conditions of the permit within sixty (60) days of the project completion to the WDEQ Office on the attached Certification of Completion form.
- a. Date that the road application was completed; and
 - b. Certification the road application was done in accordance with the terms and conditions of the permit; or
 - c. Certification the road application was completed with changes or modifications. Submit the information necessary to clearly indicate the road application as actually performed. This information shall include a contour map depicting only those sections of road that actually received pit sludge and petroleum contaminated soils.
- 4 of 8 The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
- 5 of 8 DS-1000 shall be applied uniformly and incorporated into the road bed. .DS-1000 shall not be applied during the period from November 1 to April 10.
- 6 of 8 The application site slope shall not exceed eight percent (8%) for vehicular application.
- 7 of 8 DS-1000 application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
- 8 of 8 Only the roads designated in this permit are authorized for application of theDS-1000. Additional alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.

AUTHORIZED BY:



Gary Beach
Administrator
Water Quality Division



Dennis Hemmer
Director
Department of Environmental Quality

6-10-2002

Date of Issuance

RJE; 6/4/02

STATEMENT OF BASIS

I. General information.

A. Permit Number: 02-174

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are no numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

District Policy 10.2 (10/17/86)

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

NA

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the pit sludge and petroleum contaminated soils onto the roadbed. Repeated applications of pit sludge and petroleum contaminated soils on the same sections of road will be monitored by roadbed analyses.

B. Quality of waste is such that it will not cause a violation of groundwater standards. Briefly describe:

NA

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

NA

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

NA

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

NA

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

NA

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

NA

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Rick J. Estes, PE, Senior Environmental Analyst, and completed on June 4, 2002. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



The State
of Wyoming



Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

June 18, 2002

Mr. Harry LaBonde, City Manager
City of Laramie
P.O. Box C
Laramie Wyoming 82073

RE: City of Laramie Water Distribution System Pipe Bursting, Application No.02-175, Albany County

Dear Mr. LaBonde:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by 1 July 2004. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No.02-175 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/bb/2-1968.ltr

cc: IPS, Cheyenne

Robert D. Juve, City of Laramie
P. O. Box C
Laramie WY 82073

PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO. 02-176
SPECIAL CONDITIONS
REF/PERMITS #89-286 and #97-006

Naughton S.E. Plant FGD Pond 1

This permit hereby authorizes the applicant:

Pacificorp
P.O. Box 191
Kemmerer, WY 83101

to modify an existing non-discharging evaporative pond by increasing the height of the dikes 11.5 feet according to the procedures and conditions of application number 02-176. The facility is located in SW1/4 Section 28, T21N, R116W in the county of Lincoln, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by October 31, 2004.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner

and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 6 The applicant will provide immediate oral and/or written notice to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 6 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications, Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 3 of 6 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 4 of 6 Monitoring wells shall continue to be sampled at the same frequency and analyzed for the same parameters as established by the spring 2000 modification of the monitoring requirements of Permit to Construct #97-006, except that the two new monitoring wells DEQ 2A and DEQ 3A (that are to replace wells DEQ 2 and DEQ 3) shall be monitored quarterly for the first year for the same parameters that were required for wells DEQ 2 and DEQ 3, and at the same frequency and for the same parameters as the existing monitoring wells thereafter. Results of groundwater analyses shall be submitted to: Mark Thiesse, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520.
- 5 of 6 If it is determined that the groundwater is being degraded beyond the established limits, the permittee shall be required to determine the probable cause of the degradation. If it is from

leakage from this pond, the permittee shall repair the cause of the leakage in a timely manner or, if this is not possible, the permittee shall be required to prepare an alternate plan acceptable to the Department of Environmental Quality, Water Quality Division for the control, containment and remediation of the groundwater contamination or closure and/or replacement of the pond.

- 6 of 6 An operation and maintenance manual for this facility shall be submitted, meeting all applicable requirements of Chapter 11, Section 24 of the Wyoming Water Quality Rules and Regulations. A draft of the operation and maintenance manual must be submitted at 50 percent completion of construction of this project, and the final operation and maintenance manual shall be submitted for DEQ approval prior to placing equipment and piping installed as part of this project into operation.


AUTHORIZED BY:



Gary Beach
Administrator
Water Quality Division



Dennis Hemmer
Director
Department of Environmental Quality



Date of Issuance

DHC/dc

b/2-2315.ltr

cc: Lincoln County Planning Office; P.O. Box 468; Kemmerer, WY 83101

STATEMENT OF BASIS

I. General information.

Permit Number: 02-176

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. Yes

B. Chapter 12. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter 11, Section 30 (d)(iii) requires inner dike slopes to be sloped between one vertical to four horizontal and one vertical to three horizontal, unless they are surfaced with concrete paving or riprap, in which case they may be constructed at slopes of one vertical to two horizontal.

B. Briefly state the basis for the deviation.

This design proposes constructing the inner dike slopes at 2 1/2:1 (one vertical to two and one half horizontal) because of physical limitations of the site. These slopes will be covered with a 40 mil PVC lining (welded to the existing lining to extend it to the top of the raised dikes), which will be overlain by anchored 40 mil HDPE sheeting to protect it from ultraviolet rays and wave action. The outer dike slopes will be constructed between 2 1/4:1 and 2 1/2:1. Stability analyses submitted for the dike slopes indicate an adequate safety factor using this design. Ballast strips will be placed every 200 feet along the inner slopes of the pond (extending from the crest of the proposed dike to the crest of the existing dike) to hold the HDPE liner in place. These will provide a location within 100 feet where a person could exit the pond if they should fall into it.

C. Permit based on general or statewide deviation contained in approved policy statement

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3¹.

Applicable

VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

Not Applicable

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

Not Applicable

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

Not Applicable

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

The existing pond was permitted with a single 40 mil PVC lining. The proposed expansion will have the same construction by raising the dikes and extending the 40 mil PVC liner to the top of the dikes. It will have no leak detection system, but there are monitoring wells in place around the present pond. Two of the monitoring wells will be destroyed by the construction. They will be replaced with two new monitoring wells located as close as possible to the original well locations. Monitoring of groundwater quality and changes in the fluid level in the pond will be used to determine if leakage occurs from this facility.

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter 8. Briefly describe:

Not Applicable

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

Not Applicable

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

The two new monitoring wells will be sampled on a quarterly basis for the first year for the same parameters as the replaced wells. They and the existing monitoring wells (not including those for the landfill) will continue to be monitored at the frequency and for the parameters as modified in the spring of 2000. If it is determined that the groundwater is being degraded beyond the established limits because of leakage from th

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

pond, the permittee will be required to repair the cause of the leakage in a timely manner or, if this is not possible, the permittee will be required to prepare an alternate plan acceptable to the Department of Environmental Quality, Water Quality Division for the control, containment, and remediation of the groundwater contamination or closure and/or replacement of the pond.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle Conklin, SW District Engineering Supervisor and completed on July 15, 2002. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

DHC/bb/2-2315.ltr



JIM GERINGER
GOVERNOR

Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

September 27, 2002

Fremont County School District No. 1
William L. Hakonson, Superintendent
400 Baldwin Creek Road
Lander, WY 82520

RE: Lander - Lander Valley High School Water Main Extensions, Permit Number: 02- 177RR,
SE 1/4 Section 12,T33N,R100W, Fremont County, PWS # WY5600176

Dear Mr. Hakonson:

The above application for coverage under General Permit to Construct the extension of a public water supply system, consisting of 2715 linear feet (LF) of 8-inch PVC and 954 (LF) of 6-inch PVC, and appurtenances in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, E.I.T.
Environmental Senior Analyst
Water Quality Division

Jeff Hermansky, P.E.
Northwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
encl: General Permit for a Public Water System



The State
of Wyoming



Department of Environmental Quality

Jim Geringer, Governor

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

June 4, 2002

Mr. Ted Moline
1301 Inyan Kara Cr. Rd.
Sundance, WY 82729

RE: Ted Moline As-built Septic, Permit # 02-178

Dear Mr. Moline:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of small wastewater septic in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457.

Thank you.

Sincerely,

Rick J. Estes, P.E.
DEQ/WQD, NE District Senior Environmental Analyst

cc: IPS, Cheyenne





The State
of Wyoming



Department of Environmental Quality

Jim Geringer, Governor

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

June 4, 2002

Mr. Duane Carlson
P.O. Box 382
Osage, WY 82723

RE: Duane Carlson Residential Septic, Permit # 02-179

Dear Mr. Carlson:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of small wastewater septic in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457.

Thank you.

Sincerely,

Rick J. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Roger Reinke-USDA, 1949 Surgarland Dr. Suite 118, Sheridan, WY 82801-5749





The State
of Wyoming

Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

6-10-02
Barb

Jim Geringer, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

June 6, 2002

Mr. Bill Mentock, PE/LS 3864
Mentock -Willey Consultants
1030 N. Main St.
Sheridan, WY 82801

RE: Powder Horn 1, Ph-8 & Powder Horn 2, Ph-1 , Permit # 02-180

Dear Bill:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a extension to the Powder Horn Wastewater Collection System in accordance with Chapter 3 and Chapter 11 of the WWQRR has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits. All construction, installation, or modification allowed by this permit shall be completed by June 6, 2003.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457. Thank you.

Sincerely,

Rick J. Estes, P.E.
NE District Senior Environmental Analyst
DEQ/WQD

cc: ~~PS, Cheyenne~~
Powder Horn LLC, P.O. Box 2007, Sheridan, WY 82801



The State
of Wyoming



Department of Environmental Quality

Jim Geringer, Governor

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

June 20, 2002

Mr. Bruce Yates, PE
SAWS JPB
224 S. Main
Sheridan, WY 82801

RE: Powder Horn 1, Ph-8 & Powder Horn 2, Ph-1 Water, Permit # 02-181

Dear Bruce:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a extension to the SAWS JPB Water Distribution System in accordance with Chapter 3 and Chapter 11 of the WWQRR has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits. All construction, installation, or modification allowed by this permit shall be completed by June 20, 2003.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457. Thank you.

Sincerely,

Rick J. Estes, P.E.
NE District Senior Environmental Analyst
DEQ/WQD

cc: IPS, Cheyenne

Bill Mentock, PE/LS 3864, #2 Taylor Place, 1030 N. Main, Sheridan, WY 82801
Powder Horn LLC, P.O. Box 2007, Sheridan, WY 82801

**DEPARTMENT OF ENVIRONMENTAL QUALITY
STATE OF WYOMING
GROUNDWATER POLLUTION CONTROL PERMIT
AUTHORIZATION TO DISCHARGE INTO UNDERGROUND RECEIVERS
(Permit to Inject)**

(X) New
() Modified


Permit Number: UIC 02-182
Subclass Number: 5E3

In compliance with the Wyoming Environmental Quality Act (W.S. 35-11-101 through 1104, specifically 301(a)(i) through (iv), Laws 1973, Ch. 250, Section 1) and Water Quality Rules and Regulations, Chapter 3 (March 28, 1988), and Chapter 16 (April, 1998).

Applicant: Volunteers of America
P.O. BOX 1346
Gillette, WY 82717-1346
(307) 682-8505

is authorized to operate the Volunteers of America Community Correction Center Wastewater Facility (UIC Facility WYS 005-226) in the SW $\frac{1}{4}$ NW $\frac{1}{4}$, Section 11, Township 49 North, Range 72 West, of the 6th Principal Meridian (Lot 10, Block 4 Southern Drive Industrial Park); according to the procedures and conditions of application UIC 02-182 and requirements and other conditions of this permit as contained on pages 1 through 8.


This permit shall become effective on date of issuance.



Administrator
Water Quality Division
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002
Phone: (307) 777-7781

12/5/02

Date



Director
Department of Environmental Quality
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002

12/5/02

Date

TABLE OF CONTENTS

A. DISCHARGE ZONE AND AREA OF REVIEW 2
Discharge Zone: 2
Area of Review 2
B. GROUNDWATER CLASSIFICATION 2
C. AUTHORIZED OPERATIONS 3
D. ENVIRONMENTAL MONITORING PROGRAM FOR GROUNDWATERS OF THE STATE 3
E. REQUIREMENTS FOR MONITORING THE DISCHARGE 4
F. RECORDS AND REPORTS 5
G. GENERAL CONDITIONS 6
H. DUTIES OF Volunteers of America Community Correction Center 7
I. SPECIAL MEASURES THE DIRECTOR FINDS NECESSARY: 8
J. SIGNATORIES REQUIREMENT 8

DISCHARGE ZONE AND AREA OF REVIEW

Discharge Zone:

This injection facility (sanitary leachfield) is authorized to inject into the Wasatch Formation Aquifer (Surface aquifer) from zero to 50 feet below the ground surface.

Area of Review

The facility authorized by this permit is located in:

Township 49 North, Range 72 West, 6th Principal Meridian
Section 11: SW 1/4 NW 1/4

The Area of Review around this facility is legally described as:

Township 49 North, Range 72 West, 6th Principal Meridian
Section 11: NW 1/4

B. GROUNDWATER CLASSIFICATION

The groundwater in the Wasatch Aquifer is classified as class I (Domestic) under Chapter 8 of Wyoming Water Quality Rules and Regulations (March 11, 1993). This classification was made because:

- a. The groundwater in this formation does not meet all of the quality standards set forth in Chapter 8 for class I water; however

- b. The groundwater in this formation has been and may currently be used for domestic purposes at several points of withdrawal;

Groundwater of class I shall not be degraded so as to make it unusable as a source of water for this purpose. Any parameters which do not meet the class of use standard shall not be degraded whatsoever.

C. AUTHORIZED OPERATIONS

Volunteers of America Community Correction Center is authorized to inject 89 barrels per day, (3,744 gallons per day) of wastewater as described: Sanitary waste only from a privately run detention center. Volunteers of America Community Correction Center is authorized to inject at a pressure of no more than 10 psi as measured at the leachfield. This pressure is controlled by gravity drainage and is not required to be monitored.

Hazardous Waste This permit does not allow for the injection of any hazardous waste as defined by 40 CFR 261. Injection of any substance defined as hazardous waste, whether hazardous by listing or by characteristic is a violation of this permit.

In the event that additional facilities are constructed that add to the demand on this septic system, additional capacity will be required for the septic system. Any such expansion shall be reported to the DEQ in the form of a modified permit application showing the required additional drainfield capacity. Modifications within the subdivision which do not add to the total flow to the septic system may be made without modifying this permit.

D. ENVIRONMENTAL MONITORING PROGRAM FOR GROUNDWATERS OF THE STATE

1. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
2. Volunteers of America Community Correction Center shall prepare records of all monitoring information to be retained for a period of at least 3 years after closure of the facility.
3. Records of monitoring information shall include:
 - a. The date, exact place, and time of sampling or measurements;
 - b. The name(s) of individual(s) who performed the sampling or measurements;
 - c. The date(s) analyses were performed;
 - d. Names of individuals who performed the analyses;
 - e. The analytical techniques or methods used; and
 - f. The results of such analyses.
4. The groundwater in the receiving formation shall be sampled and the following parameters analyzed on the following schedule and from the following wells.

WELL NAME OR NUMBER	SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT (UCL)*
The downgradient monitor well shown on Sheet 1 of the septic system site plan submitted October 15, 2002.	Quarterly	EPA Method 350.3	Ammonia as N	.500
		EPA Method 353.2	Nitrate as N	10.0

*All chemical concentrations in this permit are expressed in mg/l unless otherwise noted.

The above Upper Control Limit (UCL) is not to be exceeded in any sample. Exceedance of this value is a violation of this permit and shall require corrective action. In the event that there is no water present in this monitor well, then Volunteers of America Community Correction Center shall monitor for the presence of water on a quarterly basis. In the event that any of the above UCL's are exceeded, the Volunteers of America Community Correction Center shall immediately sample all domestic use wells within the facility for Total Coliform Bacteria.

After the first two years of operation, the Water Quality Division may, without reissuing this permit, waive further monitoring of any parameter from the above list or may require additional monitoring based on new information about the nature of the waste. The Water Quality Division may also, after the first two years of operation, approve a more or less stringent monitoring schedule.

E. REQUIREMENTS FOR MONITORING THE DISCHARGE

Volunteers of America Community Correction Center shall monitor the quality of the effluent on the following schedule. The following parameters shall be analyzed by the listed methods and reported semiannually:

SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT (UCL)*
September each year	EPA 200 Series Methods	Cadmium	.010
		Chromium	.050
		Lead	.050
	EPA Method 420.1	Total Phenols	.250
	EPA Method 350.3	Ammonia as N	150.0

*All chemical concentrations in this permit are expressed in mg/l unless otherwise noted. The above Upper Control Limit (UCL) is not to be exceeded in any sample. Exceedance of this value is a violation of this permit and shall require corrective action. In the event that any contaminant is found to exceed the above UCL's the Volunteers of America Community Correction Center shall undertake a study to determine and eliminate the source of that contaminant from the waste stream. Any parameter found to be exceeding the above UCL shall be sampled for in the downgradient well if not already sampled for. Volunteers of America Community Correction Center shall sample the downgradient well within 30 days of the date that he becomes aware of any exceedance of the

above UCL's. After the first two years of operation, the Water Quality Division may, without reissuing this permit, waive further monitoring of any parameter from the above list or may require additional monitoring based on new information about the nature of the waste. The Water Quality Division may also, after the first two years of operation, approve a more or less stringent monitoring schedule.

F. RECORDS AND REPORTS

1. Volunteers of America Community Correction Center shall retain copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the report or application.
2. Volunteers of America Community Correction Center shall give notice to the administrator as soon as possible of any planned physical alterations or additions to the permitted facility.
3. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 30 days following each schedule date.
4. Volunteers of America Community Correction Center shall report any noncompliance which may endanger health or the environment, orally within 24 hours from the time Volunteers of America Community Correction Center becomes aware of the circumstances. The report should include:
 - a. Any monitoring or other information which indicates that any contaminant may cause an endangerment to a usable groundwater of the state.
 - b. Any noncompliance with a permit condition or malfunction of the discharge (injection) system which may cause fluid migration into or between usable groundwaters of the state.

A written submission shall be provided within 5 days of the time Volunteers of America Community Correction Center becomes aware of the circumstances. This written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected; the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

5. Volunteers of America Community Correction Center shall report all instances of noncompliance not reported otherwise, at the time monitoring reports are submitted; such reports shall contain the information listed in 4. above.
6. When Volunteers of America Community Correction Center becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the administrator, it shall promptly submit such facts or information.
7. Volunteers of America Community Correction Center shall retain all records concerning the nature and composition of injected fluids until 5 years after completion of any specific

plugging and abandonment procedures. The administrator may require the owner/operator to deliver the records to the administrator at the conclusion of the retention period.

8. A subsurface discharge (injection) well may not commence subsurface discharge (injection) until, following public notice and an opportunity for hearing, a groundwater pollution control permit has been issued by the department for the proposed operation, and:
 - a. Well construction is complete and Volunteers of America Community Correction Center has submitted notice of completion of construction to the administrator,
 - b. The administrator has inspected or otherwise reviewed the subsurface discharge (injection) well and finds it in compliance with the conditions of the permit; or Volunteers of America Community Correction Center has not received notice from the administrator of intent to inspect or otherwise review the facility within 13 days of the notice of a. above, in which case prior inspection or review is waived, and
 - c. Volunteers of America Community Correction Center has submitted, and the Water Quality Division has approved, an Operation and Maintenance Manual for both the septic system and the public water system.
9. The Quarterly report of operations for this facility shall be submitted on forms provided by the department and shall include the following information:
 - a. Any permit exceedances within the previous year.
 - b. The analytical results for sampling for the injected water and any groundwater sampling results required under Section D or E of this permit.
 - c. Quarterly reports are due in the Cheyenne office of the Water Quality Division no later than 30 days after the close of each calendar quarter.
10. A comprehensive report for an aborted or curtailed operation authorized by this permit shall be submitted to the administrator within 30 days of complete termination of the injection (discharge) or associated activity, in lieu of an annual report.

G. GENERAL CONDITIONS

1. After notice and opportunity for a hearing, a permit may be modified, suspended or revoked in whole or part during its term for cause which includes, but is not limited to, any of the following:
 - a. Violation of the permit;
 - b. Obtaining a permit by misrepresentation or failure of the discharge well or system.
2. Each permit is reviewed at least once every 5 years, and may be reviewed more frequently.
3. A permit may be modified at any time as may be required, including for conformity with changes in regulations or standards which occur after the permit is issued. A permit may be modified in whole or part in order to apply more, or less, stringent standards; or prohibitions for a toxic or other substance present in Volunteers of America Community Correction Center 's discharge,

as may be ordered by the council. This permit can be terminated by authority of the administrator for one or more permit violations.

4. Public notice of the permit review and request for public comment will be made every 10 years by the administrator.
5. Any permit noncompliance constitutes a violation of the permit.
6. The filing of a request by Volunteers of America Community Correction Center for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
7. The owner/operator of record (permittee) is always responsible for permit compliance. A permit holder cannot transfer his permit without approval of the department director.
8. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve Volunteers of America Community Correction Center from any responsibilities, liabilities or penalties established pursuant to any applicable state law or regulation.
9. The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.
10. The provisions of this permit are severable, and if any provision of the permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.
11. Pollution or waste which migrates into an aquifer containing a usable groundwater of the state is a violation of the permit.

H. DUTIES OF Volunteers of America Community Correction Center

It is a duty of Volunteers of America Community Correction Center to:

1. Comply with all permit conditions;
2. Halt or reduce activity -- it shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce Volunteers of America Community Correction Center activity in order to maintain compliance with the permit conditions;
3. Take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with this permit; and
4. Furnish to the administrator within a reasonable time, any information which the administrator may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit; and furnish to the administrator, upon request, copies of records required to be kept by this permit.

I. SPECIAL MEASURES THE DIRECTOR FINDS NECESSARY:

1. In the event that sewage is found to be surfacing from the leachfield covered by this permit, this is a violation of this permit and shall be reported immediately as required by Section F of this permit. In the event that the leachfield covered by this permit should fail, it is not necessary to modify this permit to allow for the replacement leachfield shown on sheet 1 of the septic system site plan to be installed, so long as the construction specifications remain the same. The Volunteers of America Community Correction Center shall notify the department that the replacement leachfield is to be installed within 90 days of determining that the primary leachfield has failed.

2. The Volunteers of America Community Correction Center shall notify the Campbell County Engineer 500 South Gillette Avenue, Gillette, Wyoming 82716, (307) 682-1970 at least three days prior to installing the septic system.

J. SIGNATORIES REQUIREMENT

1. All reports required by this permit and other requested information shall be signed as follows:

For a corporation -- by a principal executive officer of at least the level of Vice-President;

For a partnership or sole proprietorship -- by a general partner or the proprietor, respectively;

By a duly authorized representative for any of the above. A person is a duly authorized representative only if:

- a. The authorization is made in writing by one of the described principals;
- b. The authorization specifies either an individual or position having responsibility for the overall operation of the regulated facility or activity; and
- c. The written authorization is submitted to the administrator.

2. If an authorization is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to the administrator prior to or together with any reports or information, to be signed by an authorized representative.

3. Any person signing a report or other requested information shall make the following certification:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

RFL/mad/2-3970-ltr

STATEMENT OF BASIS FOR A UIC PERMIT

I. General information.

A. Permit Number: UIC 02-182

B. Facilities Covered: The Volunteers of America Wastewater System. Covers a new septic system to discharge into a new large scale leachfield with a capacity of 3,744 gallons per day.

C. Class of Facility: 5E3 (Under Chapter 16)

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 8. Yes

D. Chapter 12. No

B. Chapter 9. No

E. Chapter 13. No

C. Chapter 11. Yes

F. Chapter 16. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No.

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

NOT Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3. Note that sediment ponds, public water supplies, sewerage systems, and small wastewater systems are exempt from the requirements of Section 17. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Applicable. This is an new septic system which was required to obtain an individual UIC permit. A groundwater review has been completed in accordance with Section 17. This system will provide for a flow capacity to 3,744 gallons per day.

VI. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

VII. Applicant and Public Participation

A. The applicant has been provided with a draft permit prior to the permit being issued.

B. A Public Notice has been issued with a public notice period starting August 20, 2002 and ending on September 20, 2002 (30 day notice as required by Chapter 16.) This notice was published in Gillette on or before the start of the public comment period.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 5, Chapter 16, Wyoming Water Quality Rules and Regulations. This review was performed by Robert F. Lucht, P.E. and P.G., UIC Program Supervisor, and completed on August 12, 2002. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RFL/bv/2-2567.ltr

Revised November 20, 2001

**REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION**

Herschler Bldg., 4 West
Cheyenne, Wyoming 82002

PROJECT: Volunteers of America Community Correction Center

ENGINEER: Robert P. Swanson P.E. 5732
PCA Engineering
4506 Wigwam Blvd., P.O. Box 2185
Gillette, WY 82717-2185
(307) 687-0600

APPLICANT: Volunteers of America
P.O. Box 1346
Gillette, WY 82718
(307) 682-8505

WATER QUALITY DIVISION REFERENCE NUMBER: UIC 02-182

REVIEWING ENGINEER: ROBERT F. LUCHT, P.E.

DATE OF REVIEW: June 24, 2002

ACTION: NOT AUTHORIZED FOR CONSTRUCTION.

COMMENTS:

1. The total design flow for this single leachfield is 3,744 gallons per day, based on the following:

CATEGORY	SIZE	DESIGN FLOW IN GPD
Motel	72 single bed motel rooms at 40 g.p.d. / bed	2,880
Restaurant kitchen wastes	144 meals/day @ 6 g.p.d./meal	864
TOTAL:		3,744

Your calculated required wastewater volume is correct.

2. The water in the Wasatch Formation at this complex is Class I Groundwater of the State by use under Chapter 8, Wyoming Water Quality Rules and Regulations. If you have concrete information showing that none of the old Wasatch Formation wells are still being used for domestic purposes, then the aquifer could be classified as Class III.
3. All class V UIC Permits require a point of compliance with groundwater standards. That point of compliance varies from a monitoring well directly under a leachfield to a series of monitoring wells around the leachfield with the point of compliance defined as the down gradient well. The cost of installation varies with the type of compliance point, as does the stringency of the monitoring system. Please propose a point of compliance which will be protective of the groundwater in general, but which will have some likelihood of successfully showing compliance. A single monitoring well down gradient from the leachfield will be sufficient. A monitoring plan is required for all UIC facilities.
4. For a commercial kitchen, Chapter 11, Section 39(c) requires a grease trap. Such a grease trap should be located at the service connection to the kitchen to trap the grease before it clogs the collection system. No detail is provided for this grease trap and no size calculation has been provided.
5. Chapter 11, Appendix A requires that the design of a leachfield be based on at least three percolation test holes. If only three to five test holes are used, then the percolation rate used must be the most conservative of the measurements. If six test holes or more are used, then the percolation rate used may be the average. This design has been based on only three test holes, two of which are not even within the area of the leachfield, which is not acceptable. The subdivision study shows that leaching rates vary from just over 1 minute per inch to a maximum of 72 minutes per inch. Which this much variation, it is imperative that the test holes represent the area to be used. In addition, the data from each hole must be presented including the depth of the hole, the location of the holes in relationship to the leachfield, and the calculations showing how the percolation rate was determined.
6. The State Historic Preservation Office requires that you perform a Cultural Resources Survey unless you can show that the area has been previously cleared, or that the area has been previously disturbed. I asked Richard Currit if they will require this study and he said they will unless you can show that the area has been extensively disturbed in the past. I note that the topographic map shows a drill hole near this location. You may be able to show that the area was previously disturbed by the drilling of an oil well, if that is the case.

THE STATE



OF WYOMING

JIM GERINGER
GOVERNOR



Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

July 17, 2002

Chad Jensen, Mayor
Town of Afton
P.O. Box 310
Afton, WY 83110

RE: Nield String Waterline Replacement, Permit Number 02-183, Sections 25, 26, 35 & 36,
T32N, R119W, Lincoln County

Dear Mayor Jensen:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems in accordance with Chapter 3, Section 7 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

A handwritten signature in black ink, appearing to read "Doyle Conklin".

Doyle Conklin
SW District Engineering Supervisor
Water Quality Division

cc: IPS, Cheyenne

encl: General Permit for Extensions or Modifications of Existing Public Water Systems



The State
of Wyoming



Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---

NOTIFICATION OF COVERAGE

June 20, 2002

Howard Burton
1408 Highway 319
Glendo, Wyoming 82213

RE: Burton Trailer Court Septic System, Application No. **02-184**
Location: SE 1/4 SE 1/4, Section 08, T29N, R68W, Platte County

Dear Mr. Burton:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of each tank** must be extended to the ground surface.

Mr. Burton
June 20, 2002
Page 2

The approval granted under this Notification Of Coverage and the General Permit shall expire on September 30, 2002. Please reference Application Number 02-184 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,



Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bb/2-1987.ltr

cc: IPS, Cheyenne
John A. Lambert, P.E., John A. Lambert & Assoc., 215 Walnut St. (Box 34), Douglas,
Wyoming 82633

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Jim Geringer, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

September 4, 2002

Mr. Ralph Goodson, P.E.
Bearlodge, LTD, Inc.
P.O. Box 130
Sundance, WY 82729

RE: City of Sundance "Kaski" Development, PWS# 5600055 Permit # 02-185

Dear Ralph:

The above application for coverage under General Permit to Construct, Install, Modify or Operate an extension to the City of Sundance water distribution system in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. All construction, installation, or modification allowed by this Notice of Coverage shall be completed by September 30, 2003.

If you have any questions please contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Rick J. Estes".

Rick J. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst

cc: IPS, Cheyenne
City of Sundance - P.O. Box 542, Sundance, WY 82729



The State
of Wyoming

Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Jim Geringer, Governor



6-18-02
Barb

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

June 17, 2002

Mr. Richard Wellman
19 Boles Canyon RD
Newcastle, WY 82701

RE: Richard Wellman Residential Septic, Permit # 02-186

Dear Mr. Wellman:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of small wastewater septic in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457.

Thank you.

Sincerely,

Rick J. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst

cc: IPS, Cheyenne

THE STATE



OF WYOMING



JIM GERINGER
GOVERNOR

Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

July 5, 2002

Town of Mountain View
Attn: David K. Dasher
P.O. Box 249
Mountain View, WY 82939

RE: Watermain Connection and Meter Pit, Permit Number 02-187R, Sections 13 & 14, T15N,
R115W, Uinta County

Dear Mr. Dasher:

The above application for coverage under General Permit to Construct, Install, Modify or Operate an Extension to an Existing Public Water Supply Distribution System in accordance with Chapter 3, Section 7 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

A handwritten signature in black ink, appearing to read "Doyle Conklin".

Doyle Conklin
SW District Engr. Supv.
Water Quality Division

cc: IPS, Cheyenne
Bridger Valley Joint Powers Board; 100 E. Sage; Lyman, WY 82937

encl: General Permit for Extension of a Public Water Supply

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 02-188
SPECIAL CONDITIONS

Bairoil-Well No. 1 Completion & Pipeline PWS # 5600003

This permit hereby authorizes the applicant:

Sue Ann Rigano, Mayor
Town Bairoil
P.O. Box 58
Bairoil, Wyoming 82322

to construct public water supply systems consisting of approximately 10,100 of 4-inch water transmission line, a well house, well completion, connection vault, chlorination system and appurtenances, according to the procedures and conditions of application number 02-188. The facility is located in Section 20, T27N, R90W in the county of Sweetwater, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by October 21, 2007.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Southwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183, mbaron@state.wy.us.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit. The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not

relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Southwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by letter, e-mail or telephone of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Southwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; mbaron@state.wy.us, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Gary Beach
Administrator
Water Quality Division



Dennis Hemmer
Director
Department of Environmental Quality

2-12-03

Date of Issuance

MDB/mdb/bv/2-3432.ltr

STATEMENT OF BASIS

I. General information.

Permit Number: 02-188

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. No

B. Chapter 12. Yes

III. Basis for issue

A. Review identified applicable regulations

No

B. Permit Chapter 11, or 12.

No

C. Permit policy statement.

No

2/10/03

this permit has been held up since October waiting for submittal of capacity development info
harry

IV. Facilities not

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter 12, Section 9 (b)(ii)(A)(page 16) limits the design pumping rate to be 67 % of the test rate.

B. Briefly state the basis for the deviation.

The design pumping rate is being increased from 50 to 60 gallons per minute, which is 80 % of the test rate. The Town of Bairoil has two additional sources of water, therefore the new water well will only be pumped for extended periods during times of peak demand.

C. Permit based on general or statewide deviation contained in approved policy statement

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3¹.

N/A

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on October 21, 2002. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



THE STATE OF WYOMING

JIM GERINGER
GOVERNOR



Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

July 29, 2002

RaJean Strube Fossen, Sec-Tres
Strube Construction, LLC.
P.O. Box 1684
Lander, WY 82520

RE: Indian Lookout Second and Third Subdivision - Water and Sewer Main Extensions -
Permit Number: 02- 189R, NE1/4 NW 1/4, Section 13, T33N, R100W, Fremont County,
PWS # WY5600176

Dear Ms. Strube Fossen:

The above application for coverage under General Permits to Construct the extensions of a public water supply system consisting of 1134 LF of 8-inch PVC water main and a sewage collection system consisting of 72 LF of 10-inch, 670 LF of 8-inch and 302 LF of 6-inch PVC sewer main and appurtenances in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, E.I.T.
Environmental Senior Analyst
Water Quality Division

Jeff Hermansky, P.E.
Northwest District Engineer
Water Quality Division

cc: IPS, Cheyenne
encl: General Permit For a Sewage Collection System,
General Permit For Public Water Supply

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 02-190
SPECIAL CONDITIONS
REF/PERMIT NO. 01-483

3M Trout Ranch Sections 27 and 34 Land Application

This permit hereby authorizes the applicant:

3M Trout Ranch, Inc.
P.O. Box 67
Albin WY 82050

to land apply swine effluent to an additional of 855 acres of center pivot irrigation land and to replace the Malm 3-1 well (relocated) with the 3M Trout No.1, Wyoming State Engineer Permit U.W. 139366 according to the procedures and conditions of the application number 02-190. The facility is located in Section 27 and the E1/2 and the SW 1/4 of Section 34 T17N R60W in the county of Laramie, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by September 2007.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:


1 of 2 The applicant will provide immediate oral or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 2 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



Gary Beach
Administrator
Water Quality Division



Dennis Hemmer
Director
Department of Environmental Quality

9/17/2002

Date of Issuance

LBH/bb/2-2463.ltr

cc: Laramie County Commissioners

Champ, Inc.
P.O. Box 127
Albin, WY 82050

STATEMENT OF BASIS

Permit Number: 02-190

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. YES

B. Chapter XII. NO

III. Basis for issuing permit: Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

IV. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.

YES

V. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater.

N/A

D. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

The permit is based on groundwater modeling which indicated that all contamination entering the groundwater from the wastewater ponds will be captured by the 3M Trout No. 1 well. The 3M Trout No. 1 is located approximately one mile downgradient and must be pumped at a minimum of 400 gpm at all times. The pumping rate for the 3M Trout No. 1 well may be increased depending upon demand, however, it will not be less than the 400 gpm.

E. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

This permit allows the nitrates as N concentrations in the unconfined aquifer underlying the site to exceed the Chapter 8 standard of 10 ppm of nitrates as N. The limits of the allowable impact are the portions of Sections 33,34,35 T17N R60W that is owned by 3M Trout Ranch Inc. or subject to land application agreements benefitting the permit. The cone of drawdown produced by the continuous pumping of 3M Trout No. 1 well will confine the impacted waters of the aquifer to Sections 33,34,35 T17N R60.

F. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

The permit requires that the wells in the table below be monitored to verify the groundwater model and to verify that the groundwater is not impacted beyond the limits of Sections 33,34,35 T17N R60W. All four wells will be monitored for static water levels and nitrogen. The annual water production will be reported for the Malm 3-1 (relocated) well and irrigation wells in the land application areas. Monitoring shall be required until such time as the department is satisfied the groundwater modeling is accurate and that and adverse impacts to the aquifer have been restored to U.S. Safe Drinking Water Standards.

<u>Well Name</u>	<u>Permit Number</u>
3M Trout Nebraska Well	
3M Trout No. 1	P7479W
Anderson #2	P6845W
Malm 33-1	P2712

VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on August 1, 2002. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LBH/bb/2-2463.ltr

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

Herschler Building 4 West
Cheyenne, Wyoming 82002


PROJECT: 3M Trout Ranch Section 34 Land Application

APPLICANT: 3M Trout Ranch

WATER QUALITY DIVISION REFERENCE NUMBER: 02-190

REVIEWING ENGINEER: Louis B. Harmon

DATE OF REVIEW: June 27, 2002



ACTION: **NOT AUTHORIZED FOR CONSTRUCTION.** In accordance with Section 9 (a)(ii), Chapter 3, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with said Section 9. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. A public notice of the opportunity to request a public meeting to discuss this proposed permit will be made in the Wyoming Tribune Eagle and the Pine Bluffs Post. If the Water Quality Division Administrator determines that there is sufficient interest, a public meeting will be scheduled in Albin to discuss the proposed permit.
2. The application must include agreements signed by any land owners of record authorizing land application of swine waste and giving the Water Quality Division Administrator or his designated representatives the right of entry to conduct inspections and to take soil or water samples to determine compliance with this permit. Specifically, agreements should be provided for the 5 parcels in Section 34. Even though Section 27 is owned by entities controlled by the principals of 3M Trout Ranch, agreements for Section 27 would be in order.

LBH/bb/2-2111.ltr



The State
of Wyoming



Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---

NOTIFICATION OF COVERAGE

June 18, 2002

Mr. Harry LaBonde, City Manager
City of Laramie
P.O. Box C
Laramie Wyoming 82073

RE: City of Laramie 2002-3 Water Distribution System, Application No.02-191, Albany County

Dear Mr. LaBonde:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by 1 July 2004. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No.02-191 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/bb/2-1969.ltr

cc: IPS, Cheyenne

Robert D. Juve, City of Laramie
P. O. Box C
Laramie WY 82073



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

250 Lincoln Street • Lander, Wyoming 82520 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

February 14, 2003

Jim Liner, Adm. Assistant
Park County Fire District No. 1
211 E. Coulter
Powell, Wyoming 82435

RE: Powell- Fire Complex Water and Sewer Main Extensions, Permit Number: 02-192R,
Tract 2, Lot 74, Section O. S. 11, T55N, R99W, Park County, PWS # WY5600042

Dear Mr. Liner:

The above application for coverage under General Permits to Construct the extensions of a public water supply distribution system and sewage collection system consisting of 500 feet of 4 - inch PVC water main and 300 feet of 6 - inch sewer service and 250 feet of 4 - inch sewer service and appurtenances in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, E.I.T.
Environmental Senior Analyst
Water Quality Division

Jeff Hermansky, P.E.
Northwest District Engineer
Water Quality Division

cc: IPS, Cheyenne

encl: General Permit For a Public Water Supply Distribution System,
General Permit For a Sewage Collection



JIM GERINGER
GOVERNOR

Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

July 24, 2002

David Quinn
Melody Ranch Development
4750 South Park Loop Road
Jackson, Wyoming 83001

RE: Melody Ranch Development Residential Unit One, Sixth Filing (RU1-6) -
Water and Sewer Main Extensions -Permit Number: 02-193, NW1/4, Section 20,
T40N, R116W, Teton County, PWS # WY5601440

Dear Mr. Quinn:

The above application for coverage under General Permits to Construct the extensions a public water supply system consisting of 1500 linear feet (LF) of 8-inch PVC water main and a sewage collection system consisting of 1200 feet of 8-inch PVC sewer main and appurtenances in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, E.I.T.
Environmental Senior Analyst
Water Quality Division

Jeff Hermansky, P.E.
Northwest District Engineer
Water Quality Division

cc: IPS, Cheyenne
encl: General Permit For a Sewage Collection System,
General Permit For Public Water Supply



THE STATE OF WYOMING

JIM GERINGER
GOVERNOR



Department of Environmental Quality

250 Lincoln Street • Lander, Wyoming 82520-2848 • Fax (307) 332-7726

ABANDONED MINES (307) 332-5085	AIR QUALITY (307) 332-6755	LAND QUALITY (307) 332-3047	SOLID & HAZARDOUS WASTE (307) 332-6924	WATER QUALITY (307) 332-3144
-----------------------------------	-------------------------------	--------------------------------	---	---------------------------------

October 2, 2002

Harry L. Moore, P.E.
Uinta Engineering & Surveying, Inc.
808 Main Street
Evanston, WY 82930

RE: Withdrawal of Permit to Construct Application #02-194, Non-Biological Treatment Pond
- BP Painter Plant, Section 32, T16N, R119W, Uinta County

Dear Harry:

At the request of Mr. Bruce Williams of BP America, the above referenced application has been withdrawn and is being returned to you. It has been determined that this is a sump waste drying pad regulated by our Solid Waste Division under Solid Waste Guideline #8, and does not require a permit for construction.

If you have any questions regarding this withdrawal, please feel free to contact me.

Sincerely,

Doyle Conklin
SW District Engineering Supervisor

Enclosure

cc: Mr. Bruce Williams; BP America Production Company; Painter Complex O.C.; 1013
Cheyenne Dr., Suite A; Evanston, WY 82930



The State
of Wyoming



Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---

NOTIFICATION OF COVERAGE

June 24, 2002

Town of Encampment
Attn. Mark G. Rauterkus, Mayor
P.O. Box 5
Encampment, Wyoming 82325

RE: McCaffrey Sewer Line, Application No. **02-195**

Dear Mr. Mayor:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Sewage Collection Systems in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, the general permit, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

The approval granted under this Notification Of Coverage and the General Permit shall expire on June 30, 2004. Please reference Application Number **02-195** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bb/2-2023.ltr

Enclosures: GENERAL PERMIT - Extensions/Modifications of Existing Sewage Collection Systems/Certificate of Completion form

cc: IPS, Cheyenne
Jon Anderson, PMPC, P.O. Box 370, Saratoga, Wyoming 82331



The State
of Wyoming



Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---

NOTIFICATION OF COVERAGE

June 26, 2002

Dana Ehnle
P.O. Box 492
Encampment, Wyoming 82325

RE: Sixth Street Water Main Extension, Application No. **02-196**

Dear Mr. Ehnle:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

The approval granted under this Notification Of Coverage and the General Permit shall expire on June 30, 2004. Please reference Application Number **02-196** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bb/2-2062.ltr

Enclosures: GENERAL PERMIT - Extensions/Modifications of Existing Public Water Supply Distribution Systems/ Certificate of Completion Form

cc: IPS, Cheyenne
Jon Anderson, PMPC, P.O. Box 370, Saratoga, Wyoming 82331



The State
of Wyoming



Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---

NOTIFICATION OF COVERAGE

June 18, 2002

Mr. Herman Noe, Manager of Engineering
Cheyenne Board of Public Utilities
P.O. Box 1469
Cheyenne WY 82003-1469

RE: CFD Fire Hydrant, Application No.02-197, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by 1 July 2004. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No.02-197 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/bb/2-1971.ltr

cc: IPS, Cheyenne

Brandon Gebhart, States West Water Resources Corp.
1904 East 15th Street
Cheyenne WY 82001

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

Herschler Building 4 West
Cheyenne, Wyoming 82002

PROJECT: Scissors Ranch Waste Storage Facilities


ENGINEER: NRCS Field Office, Wheatland, Wyoming

APPLICANT: Joe Johnson Co.

WATER QUALITY DIVISION REFERENCE NUMBER: 02-198

REVIEWING ENGINEER: Louis B. Harmon

DATE OF REVIEW: August 13, 2002



ACTION: **NOT AUTHORIZED FOR CONSTRUCTION.** In accordance with Section 9 (a)(ii), Chapter 3, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with said Section 9. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. The Water Quality Division considers Detention 4 to be a retention pond as defined by Chapter 11, Section 29 of the Water Quality Rules and Regulations. The Water Quality groundwater section has determined that a liner is necessary to protect the relatively shallow groundwater reported in the area. Chapter 11, Section 29(e) requires that a liner equivalent to a permeability of 1×10^{-7} three foot thick be installed.
2. The NRCS memorandum of agreement has been extended to cover temporary detention ponds that are normally vegetated or under hoof in the pens and capable of gravity drainage. Detention 4 does not meet the requirement for gravity drainage. Standard operating procedures requiring the use of pumps to evacuate the retention pond are not an acceptable substitute.
3. If a soil liner is to be utilized, the soil permeability must be verified by testing of the soil to be installed, rather than using reference values. After the liner is installed, the in-place permeability should be verified by testing. If a soil liner is proposed the Water Quality Division may determine that monitoring wells are required.
4. Any of several types of synthetic liners should provide acceptable protection of the groundwater. The Water Quality Division strongly encourages the inclusion of leak collection and recovery features with synthetic liner designs. The leak collection and recovery features are acceptable substitutes for groundwater monitoring wells.

LBH/mad/2-2576-ltr

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 02-198
SPECIAL CONDITIONS
REF/PERMIT NO.

Scissors Ranch Feedlot

This permit hereby authorizes the applicant:

Joe E. Johnson Co.
P.O. Box 69
Wheatland WY 82201

to construct, install or modify a storm water retention structures for an existing cattle feedlot of greater than 1000 head capacity according to the procedures and conditions of the application number 02-198. The facility is located in SE 1/4 Section 13 T25N R68W in the county of Platte, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by August 11, 2006.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will provide immediate oral or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 4 Cattle must **not** be allowed to remain overnight in areas adjacent to the retention structures that do not drain into the retention areas. The loadout facility should not be used during periods of precipitation.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



John Corra
Director
Department of Environmental Quality

9/19/03

Date of Issuance

LBH/bb/3-1003.ltr

cc: Platte County Commissioners

STATEMENT OF BASIS

- I. Permit Number: 02-198
- II. Application reviewed for compliance with the following regulations.
- A. Chapter 11. YES
- B. Chapter 12. NO
- III. Basis for issuing permit: Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- IV. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.
- YES
- V. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)
- A. Facility will not allow a discharge to groundwater. Briefly describe: The retention structures are designed in accordance with Policy 13.29.4. The presence of the manure pack and the operation to discharge at agronomic rates within less than 10 days after any precipitation event is protective of the groundwater.
- VI. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on September 18, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LBH/bb/3-1003.ltr

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 02-199
SPECIAL CONDITIONS
Previous Permit No. 01-381

Boysen State Park - Fremont Bay & Cottonwood Campgrounds
PWS # WY5600658 Fremont Bay, PWS # WY5600659 Cottonwood

This permit hereby authorizes the applicant:

David E. Wilson, Superintendent Boysen State Park
Wyoming State Parks & Historic Sites/U.S.B.R.
122 West 25 th Street
Cheyenne, Wyoming 82002

to construct public water supply systems consisting of a well pump, a control & treatment building, a distribution system with 3 sanitary hydrants at Fremont Bay Campground and a well pump, a booster pump, a 1500 gallon storage tank, a control & treatment building, and a distribution system with 3 sanitary hydrants at Cottonwood Campground and appurtenances, according to the procedures and conditions of application number 02-199. The facilities are located in Fremont Bay Campground - SE1/4 Section 5, T3N, R6E (WRM) and Cottonwood Campground - NE 1/4 Section 12, T4N, R5E (WRM) the county of Fremont, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by July 18, 2004.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183, mbaron@state.wy.us.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not

relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will notify the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by letter, e-mail or telephone of the date construction will begin and the estimated completion date.
- 2 of 5 The applicant will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; mbaron@state.wy.us , in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis."
- 5 of 5 Water quality data must be submitted based on the National Primary Drinking Water Standards requirements before these wells are put into service. Each water well must be tested according to the 2002 PWS Drinking Water Phase II and V Parameters which includes the following:
 - a. Inorganic Contaminants (IOC) Source Monitoring including:
 1. Metals, 2. Fluoride, 3. Cyanide
 - b. Volatile Organic Contaminants (VOC) Source Monitoring.
 - c. Radiochemistry Source Monitoring.

AUTHORIZED BY:



Gary Beach
Administrator
Water Quality Division



Dennis Hemmer
Director
Department of Environmental Quality

7/19/02

Date of Issuance

MDB/mdb/bv/2-2353.ltr

STATEMENT OF BASIS

General information.

Permit Number: 02-199

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. No

B. Chapter 12. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

Yes

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter 12, Section 8 (b)(ii)(d) requires multiple units and equipment.

B. Briefly state the basis for the deviation.

This permit covers two small water system that serve campgrounds with three hydrants each and no residential connections. Policies, 11.3 and 14.4 state that not all the Chapter 12 requirements are applicable to public water supplies serving less that 15 service connections.

C. Permit based on general or statewide deviation contained in approved policy statement

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3¹.

N/A

VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on July 18, 2002. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.



The State
of Wyoming



Department of Environmental Quality

Jim Geringer, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---

NOTIFICATION OF COVERAGE

June 20, 2002

Marie Ward
439 Ayers Road
Wheatland, Wyoming 82201

RE: Ward Mobile Home Septic System,
Location: SW 1/4, Section 22, T24N, R68W,

Application No. **02-200**
Platte County

Dear Mrs. Ward:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from each **compartment of the tank** must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on June 30, 2004. Please reference Application Number 02-200 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bb/2-2005.ltr

cc: IPS, Cheyenne

Enclosures: GENERAL PERMIT - Small Wastewater Facility/Certificate of Completion