



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

June 30, 2003

Mr. Robert Cross, Director
Flying "X" Ranch
799 Halleck Canyon Road
Wheatland WY 82201

RE: Flying "X" Ranch Water Distribution and Sewer Collection Systems Expansion, Application No.03-251, Albany County

Dear Mr. Cross:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as water and sewer line extensions to serve 18 cottage lots, SW 1/4 Section 21 T22N R71W, Albany County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 11, 2006.

All service connections are required to have the appropriate backflow prevention device installed. For cottage lots that device is either a dual check conforming to ASSE Standard 1024 or a sanitary hydrant that conforms to ASSE Standard 1057.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 03-251 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/bb/3-0720.ltr

cc: IPS, Cheyenne

Larry Gallagher, Summit Engineering, 5907 Townsend Place, Cheyenne WY 82009



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

July 14, 2003

Mr. Herman Noe, Manager of Engineering
Cheyenne Board of Public Utilities
P.O. Box 1469
Cheyenne, WY 82003-1469

RE: Carter Brother's 4-Plex Water and Sewer Line Extensions, **Application No. 03-252**, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as water line loop and sewer line extension to six 4-plex apartment buildings, SW 1/4 Section 35 T14N R66W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 11, 2006.

All service connections must have the appropriate type of backflow prevention device installed as required by Chapter 12, Section 14 of the Wyoming Water Quality Division Rules and Regulations.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 03-252 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

BH/bv/3-0769.ltr

cc: IPS, Cheyenne
Larry Gallagher, Summit Engineering, LLC, 5907 Townsend Place, Cheyenne, WY 82009



The State of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

June 30, 2003

Mr. Herman Noe, Manager of Engineering
Cheyenne Board of Public Utilities
P.O. Box 1469
Cheyenne WY 82003-1469

RE: Sunrise Estates, Fifth and Sixth Filings, Application No.03-253, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as water distribution mains, sewer collection mains, fire hydrants, and appurtenances to serve 204 residential lots, NW 1/4 Section 35 T14N R66W, Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 11, 2006.

All service connections must have the appropriate type of backflow prevention device installed as required by Chapter 12, Section 14 of the Wyoming Water Quality Division Rules and Regulations.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 03-253 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/bb/3-0721.ltr

cc: IPS, Cheyenne

Lawrence R. Gallagher, Summit Engineering, LLC, 5907 Townsend Place, Cheyenne WY 82007



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

July 7, 2003

John Lokken
2224 E. 5th
Casper, Wyoming 82609

RE: Lokken Residential Septic System, Application No. **03-254**
Location: N ½ NW 1/4, Section 14, T29N, R68W, Platte County

Dear Mr. Lokken:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific conditions also apply:

1. Leachfield Layout - There shall be a minimum of four(4) feet of undisturbed soil between the sidewalls of the trenches (7 feet centerline to centerline). See detail sheet.
2. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on July 7, 2005. Please reference Application Number 03-254 in any future correspondence.

Mr. Lokken
July 7, 2003
Page 2

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

A handwritten signature in cursive script that reads "Ronald L. Ewald". The signature is written in dark ink and is positioned below the word "Sincerely,".

Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bb/3-0740.ltr

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne

AS-BUILT PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 03-255
SPECIAL CONDITIONS

JKR SUBDIVISION LIFT STATION

This permit hereby authorizes the applicant:

Jerry Ruby
P.O. Box 261
Buffalo, WY 82834

to construct, install, or modify a wastewater pump and tank to serve the Buffalo Exxon Convenience Store and one additional service that will be pumped to the Buffalo Wastewater Treatment Plant according to the procedures and conditions of the application numbers 03-255. The facility is located in the SE of Section 25, T51N, R82W in the County of Johnson, in the State of Wyoming. This permit shall be effective for a period of one (1) year from the date of issuance of this permit.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (DEQ/WQD), upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

The authorized DEQ representative in your area can be contacted at the following address: DEQ/WQD, Northeast WDEQ District Office, 1043 Coffeen Avenue, Suite D, Sheridan, WY 82801, telephone (307) 672-6457; FAX (307) 674-6050.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.

- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis."

AUTHORIZED BY:



John V. Corra, Director
Department of Environmental Quality

7-10-03

Date of Issuance

RJE/06/30/02

bb/3-0744.ltr

Enclosures: Certificate of Completion
Statement of Basis

STATEMENT OF BASIS

General information.

A. Permit Number: 03-255

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. N/A

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter 11, Section 9 (c) (ii) requires a minimum force main pipe size of 4".

B. Briefly state the basis for the deviation.

The permit deviation for a 2" force main was permitted as an as-built; technical data was also submitted that shows liquid velocity is greater than 2.5 ft/sec. Bury depth, trench dimensions, and construction of entire system was completed as a single service. This permit allows the connection of one addition service to be connected to the existing pump tank. The additional service will include a settling tank to be installed before the service enters the pump tank.

- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of Section VI. from the Statement of Basis.)

N/A

- VI. N/A

- VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Rick J. Estes, Northeast District DEQ/WQD Senior Environmental Analyst, and completed June 30, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RJE/bb/3-0744.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Dave Freudenthal, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

July 16, 2003

Keith A. Neustel, PE & LS #2085
Grizzly Engineering
P.O. Box 1004
Buffalo, WY 82834

RE: Cunningham Addition Sewer & Water Main Extensions, Permit # 03-256

Dear Keith:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a water distribution system and sewer collection system in accordance with Chapter 3 and Chapters 11 & 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit.


If you have any questions please contact me.

Thank you.

Sincerely,

Rick J. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst

cc: IPS, Cheyenne
City of Kaycee/PO Box 265/Kaycee/WY/82639/



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Dave Freudenthal, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

July 21, 2003

Mr. Bob Swanson, P.E.
PCA Engineering, Inc.
P.O. Box 2185
Gillette, WY 82717-2185

RE: Pine Hollow Subdivision Water System, PWS# 5600191 Permit # 03-257

Dear Bob:

The above application for coverage under General Permit to Construct, Install, Modify or Operate an extension to the Town of Pine Haven water distribution system in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. All construction, installation, or modification allowed by this Notice of Coverage shall be completed by August 31, 2004.

If you have any questions please contact me.

Sincerely,

Rick J. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst
cc: IPS, Cheyenne

Rob Anderson, 320 Pineridge Rd., Moorcroft, WY 82721
Town of Pine Haven- 12 Water St., Moorcroft, WY 82721



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

250 Lincoln Street • Lander, Wyoming 82520 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

September 12, 2003

Mr. David Quinn
Melody Ranch Development
4750 South Park Loop Road
Jackson, WY 83001

RE: Melody Ranch Development Residential Unit One, Seventh Filing (RUI-7), Permit Number 03-258, Teton County

Dear Mr. Quinn:

The above application for coverage under General Permit to Construct 1500 LF of 8-inch PVC Sewer Main and 1550 LF of 8-inch PVC Water Main in accordance with Chapter 3, Section 7 and Chapter 11, Part D and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section 0 of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Jeff Hermansky
Northwest District Engineering Supervisor
Water Quality Division

xc: IPS, Cheyenne

encl: General Permit to Construct Small Wastewater Facility

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 03-259
SPECIAL CONDITIONS

F.E.W. Carlin Heights Residential Water System Land Application

This permit hereby authorizes the applicant:

F.E. Warren Air Force Base
300 Vesle Drive
F.E.W. AFB WY 82005

to conduct land application of wash water and abrasives from residential water piping according to the procedures and conditions of the application number 03-259. The facilities are located at the Carlin Heights Housing Area located in Section 26 T13N R67W 6th P.M. in the county of Laramie, in the State of Wyoming. All land application allowed by this permit shall be completed by June 26, 2004.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the F. E. Warren AFB and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the F. E. Warren AFB.

Nothing in this permit constitutes an endorsement by the DEQ of the land application described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The F. E. Warren AFB are solely responsible for any liability arising from the land application. By issuing this permit, the state does not waive its sovereign immunity.

The F. E. Warren AFB shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the F. E. Warren AFB to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The F. E. Warren AFB shall deliver and insure the application of treated wastewater in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the F. E. Warren AFB from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the F. E. Warren AFB shall comply with all of the following permit conditions:

1 of 2 F. E. Warren AFB shall submit a complete analysis of the rinse water as soon as it is available.

2 of 2 F. E. Warren AFB shall be responsible for any additional restoration activities required as the result of the land application conducted under this permit.

AUTHORIZED BY:



John Corra

Director

Wyoming Department of Environmental Quality

6-30-03

Date of Issuance

LBH/bb/3-0707.ltr

STATEMENT OF BASIS

- I. Permit Number: 03-259
- II. Application reviewed for compliance with Chapter 21 and Chapter 3
- III. Basis for issuing permit: The residential water pipes are being coated with an NSF approved epoxy to reduce the leaching of lead into the potable water supply. The copper pipes are first cleaned with a garnet abrasive which is recovered. The pipes are then rinsed with an air-potable water mixture which is being land applied to the lawns at each residence. An Air Force environmental audit has raised the issue that this activity should be permitted. Because of the disruption of the families living in the residences, it is essential that the repair activities continue without interruption. F.E. Warren has committed to any additional measures that may be deemed necessary after test results of the rinse water become available.
- IV. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.
NO
- V. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on June 26, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LBH/bb/3-0707.ltr

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 03-260
 SPECIAL CONDITIONS

GOOSEWING RANCH SPRING
PWS NO. WY5601510NC

This permit hereby authorizes the applicant:

Goosewing Ranch LLC
PO Box 7760
Jackson, WY 83002

to construct and install a privately owned water supply spring according to the procedures and conditions of the application numbers 03-260. The facility is located in the SW/4 of SE/4 Section 34 T42N R112W in the county of Teton, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by August 31, 2004.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Casper WDEQ Field Office, 3030 Energy Lane, Casper, WY 82604, telephone (307) 473-3452; FAX (307) 473-3458.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 4 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 11, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

- a. Date that construction of the facility was completed; and
- b. Date that the facility was placed in operation; and
- c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
- d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.

3 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

4 of 4 Prior to connecting the well to the Goosewing Ranch water supply system the permittee shall submit for review and written approval by DEQ:

- 1.) all applicable water quality analytical data (constituent list as per EPA).

AUTHORIZED BY:



John V. Corra
Director
Department of Environmental Quality

8-21-03

Date of Issuance

JDL/8/15/03
bb/3-0894.ltr

Enclosures: Certificate of Completion and Statement of Basis

STATEMENT OF BASIS

General information.

A. Permit Number: 03-260

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11 No

B. Chapter 12 Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

N/A

VI. If Section 17 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

N/A

VII. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, NE District Water & Wastewater Supervisor, and completed on August 15, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JDL/bb/3-0894.ltr



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

July 11, 2003

Randy D. & Beverly J. Hobbs
P.O. Box 97
Glendo, Wyoming 82213

RE: As-Built Permit To Construct, WQD Reference Number 03-261

Dear Mr. & Mrs. Hobbs:

The Department of Environmental Quality/Water Quality Division (DEQ/WQD) has reviewed the referenced As-Built Application that you submitted. Our review of the information and as-constructed plans submitted to this office indicates that the application meets DEQ/WQD regulations and the enclosed As-Built Permit To Construct is hereby issued. The enclosed permit covers the septic tank and disposal field which had already been installed and constructed when you purchased the property several years ago.

Please be advised that the system must be constructed, installed, and operated in accordance with the statements, representations and procedures presented in the application and all supporting documentation as well as the terms and conditions of the permit. You are urged to be familiar with all aspects of the permit application, permit, and permit conditions. Any person objecting to a permit issued by the DEQ and desiring affirmative relief may request a hearing before the Environmental Quality Council in accordance with the Rules of Practice and Procedure for the Department of Environmental Quality and the Wyoming Administrative Procedures Act.

Sincerely,

John V. Corra
Director
Department of Environmental Quality

JVC/bb/3-0754.ltr
Enclosure
cc: Platte County Planner

AS-BUILT
PERMIT TO CONSTRUCT

New
_ Renewal
_ Modified

PERMIT NO. 03-261
SPECIAL CONDITIONS

Hobbs Residence North of Glendo

This permit hereby authorizes the applicant:

Randy D. & Beverly J. Hobbs
P.O. Box 97
Glendo, Wyoming 82213

to have acquired through property purchase an as-built residential septic system with a septic tank and a disposal field according to the procedures and conditions of the application number 03-261. The facility is located in the SE 1/4 of Section 04, Township 29N, Range 68W, in the county of Platte, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, meets applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any violation of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee has constructed and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

AUTHORIZED BY:



John Corra
Director
Department of Environmental Quality

7/10/03

Date of Issuance

RLE/bb/3-0755.ltr

cc: Platte County Planner

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 03-262
SPECIAL CONDITIONS
REF/PERMIT NO.

Douglas Improvements to Little Box Elder Spring House and Spring Control
PWS: 5600137

This permit hereby authorizes the applicant:

City of Douglas
P.O. Box 1030
Douglas WY 82633

to construct, install or modify the spring house and the spring control building with chlorination equipment according to the procedures and conditions of the application number 03-262. The facility is located in NW 1/4 Section 31 T33N R73W in the county of Converse, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by August 11, 2006.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 6 The applicant will provide immediate oral or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 6 The City of Douglas agrees to install chlorination equipment in the spring control building and following installation further agrees to continuously chlorinate the water being conveyed by the spring transmission pipeline. Chlorine residuals will be maintained in all sections of the spring transmission main downstream of the control building.
- 3 of 6 The City of Douglas agrees to maintain all double check backflow preventers on the water services connected to the spring transmission main including annual testing and repair of the individual backflow preventers.
- 4 of 6 The City of Douglas will not allow any additional taps to the spring transmission pipeline in areas where the operating pressure is below 35 psi.
- 5 of 6 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 6 of 6 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John Corra
Director
Department of Environmental Quality

10-13-03
Date of Issuance

LBH/mad/3-1071-ltr

STATEMENT OF BASIS

- I. Permit Number: 03-262
- II. Application reviewed for compliance with the following regulations.
- A. Chapter 11. NO
- B. Chapter 12. YES
- III. Basis for issuing permit.
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II, Chapter 3.
NO
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
YES
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
NO
- IV. Facilities not specifically covered by regulations
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
Chapter 12, Section 14 requires a minimum operating pressure of 35 psi, 20 psi during fire flows, for all distribution mains.
- B. Briefly state the basis for the deviation.
The spring transmission line was first constructed in the 1920's. In the early 1950's it was upgraded from wooden stave pipeline to asbestos cement pipe. The landowners along the right-of-way were given taps in return for easements. As the flow is gravity driven, there are sections of the pipeline where the operating pressure is as low as 5-8 psi. The City of Douglas has agreed to maintain back flow prevention devices and to continuously chlorinate the flow in the transmission line. To increase the minimum pressure in the pipeline 30 psi would require increasing the maximum pressures by the same amount. There is concern that the pipe could not withstand the increase in maximum pressures.
- V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.
NO
- VI. Documentation of Statement of Basis.
The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on October 8, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
Herschler Building 4 West
Cheyenne, Wyoming 82002

PROJECT: Douglas Little Box Elder Spring Improvements


ENGINEER: Tom Brauer, C.E.P.I.

APPLICANT: City of Douglas

WATER QUALITY DIVISION REFERENCE NUMBER: 03-262

REVIEWING ENGINEER: Louis B. Harmon

DATE OF REVIEW: June 30, 2003



ACTION: NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 14(a), Chapter 3, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with said Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. Chapter 12, Section 6 of the Water Quality Division Rules and Regulations require that an engineering design report be submitted with each application. The following items should be addressed in the engineering design report.
 - a. The water quality from the spring may or may not be determined to be a ground water under direct influence of surface water or contamination. The design report should provide information on the status of the "gwudi" determination.
 - b. Reconstruction of the spring house will probably result in contamination of the water in the spring box. How will this problem be addressed? If the intention is to maintain the spring in service during construction, daily testing and continuous disinfection must be accomplished.
 - c. Operating pressures, water hammer, emergency discharges, and bypass conditions and methods are not discussed.
2. Chapter 12, Section 8(c)(ii) requires that groundwater sources provide disinfection equipment and connections as a minimum. This means that the chlorination equipment must be installed as part of this project.

3. The plans and specifications should address the procedures for dealing with the cement asbestos pipe that will be cut as part of the project.
4. The plans and specifications do not provide instructions for the abandonment of the existing valve vault.
5. Valves between the Tee's for the bypass line and the control building would appear to be necessary to allow maintenance or replacement of the control valve and the flow meter in the control building.
6. A smooth nosed sampling tap, a chlorinator feed water tap, a chlorination injection tap, and a bottom of the main line drain valve in the control house pit should be included in the design.
7. The need for a blow-off hydrant just upstream of the upstream bypass Tee should be evaluated.
8. The control system apparently only reports the flow rate and position of the control valve. Current practices and technology would suggest that the SCADA should be reporting the status of the building (internal temperature and door openings), and the chlorinator equipment status. Probably the control system should also monitor the chlorine residual and allow or make automatic adjustments to the chlorine dosage rate.

LBH/bb/3-0727.ltr

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

Herschler Bldg., 4 West
Cheyenne, Wyoming 82002

PROJECT: SULPHUR CREEK RANCH ESTATES WASTEWATER SYSTEM

ENGINEER: Leland P. Davis P.E. 3657
Davis Laird Engineering
2147 North Rulon White Blvd., STE 207
Odgen, UT 84404-2796
(801) 782-9642
(801) 786-1559 FAX
mail@davis-lairdeng.com

GEOLOGIST: None

APPLICANT: Nadene K. Lester
Sulphur Creek Ranch LLC
1462 County Road 173
Evanston, WY 82930
(307) 789-9314

WATER QUALITY DIVISION REFERENCE NUMBER: UIC 03-263


REVIEWING ENGINEER: ROBERT F. LUCHT, P.E. & P.E.

DATE OF REVIEW: July 11, 2003

ACTION: NOT AUTHORIZED FOR CONSTRUCTION.

COMMENTS:

1. Uinta County is mis-spelled on the title blocks for all plan sheets.
2. This application came in on a small wastewater permit form. This is not a small wastewater system, and must be permitted under the Underground Injection Control program as a Class V injection system. Chapter 16, Wyoming Water Quality Rules and Regulations applies.
3. All UIC permits require a groundwater study to be done. This groundwater study requires the installation of a minimum of three monitor wells to show the depth to groundwater, the flow direction and gradient of the groundwater, and the baseline quality of the groundwater. No such study has been provided. In addition such a



study must be certified by a registered professional geologist, registered in Wyoming.

4. The construction of a public water supply on this site will require a permit to construct for a public water supply. W.S. 35-11-103(c)(viii) defines a public water supply as "a system for the provision to the public of water for human consumption through pipes or constructed conveyances, if such a system has at least fifteen (15) service connections or regularly serves at least twenty-five (25) individuals..." Chapter 12, Wyoming Water Quality Rules and Regulations covers the construction of public water systems. The application for the permit to construct should be address to Mark Baron, Wyoming Department of Environmental Quality, Water Quality Division, 250 Lincole Street, Lander, WY 82520.

5. Chapter 11, Section 35(a)(ii) requires that the minimum separation distance between any well and a leachfield be no less that 200 feet. The plan submitted must include the location of all water lines, service connections, storage tanks and wells.

6. The septic tank volume calculations will provide 36 hours of retention time. As a suggestion, a less expensive way to install this capacity could easily be designed by placing the tanks near the leach field.

7. The leachfield design submitted does not provide for equal distribution of effluent to the entire leachfield. The leachfield lines should be loaded from the middle not the end, and a single distribution box should be provided to provide equal flow to the middle of each leg.

8. The mounding affect on the groundwater table has not been checked or considered. This must be done in accordance with Chapter 11, Section 36(c).

9. All geologic studies submitted as a part of a permit application are now required to be certified by a registered professional geologist as required by Title 41 of the Wyoming State Code. No geologic study has been provided.

10. The six test pits dug for the percolation tests were not sited within the drainfield. The nearest test pit is located over 150 feet from the leachfield. At least three percolation tests must be provided from within the area of the leachfield. The percolation test holes must be to the depth where the leachfield will be constructed.

11. The design submitted shows a leachfield 4.0 feet deep to the bottom. This is too deep for proper operation of the field.

12. Is there a restaurant associated with this application? Any other septic system in the same five acre area under common ownership must be considered in the permit application.

13. Chapter 16, Section 6(c)(xi) defines who can sign for a corporation. This application was signed by Nadine K. Lester, who is not listed on the Secretary of State's database as having any of the positions which are allowed to sign. The only person listed on the Secretary of State's website for Sulphur Creek Ranch, LLC is ROY G. LESTER, 1462 COUNTY ROAD 173, EVANSTON, WY 82930.

xc: Mark Baron



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7152 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

April 6, 2004

Nadene K. Lester
Sulphur Creek Ranch LLC
1462 County Road 173
Evanston, WY 82930

Re: Application Number UIC 03-263
Uinta County, Wyoming

Your application is considered inactive and is being returned to you under the assumption that you do not wish to proceed with the permitting process.

This project has not been issued a permit, under any Water Quality Division program. Construction of this facility without a permit is a violation of the Environmental Quality Act and is punishable with fines not to exceed \$10,000 per day of violation. If this project has been constructed, it is your responsibility to immediately contact this office and follow through with the permitting process. Water Quality Division has now promulgated a new Chapter 16 which replaces Chapter 9 in regulating large capacity septic systems. If you wish to reconsider construction of this facility, then application procedures pursuant to Chapter 16, Water Quality Rules and Regulations must be followed. A copy of Chapter 16 is enclosed.

Sincerely,

Robert Lucht, P.E. and P.G.
UIC Program Supervisor
Water Quality Division

xc: Leland P. Davis P.E. 3657; Davis Laird Engineering; 2147 North Rulon White Blvd., STE 207; Odgen, UT 84404-2796



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

ave Freudenthal, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

September 11, 2003

Mayor Christensen
Town of Driggs, Idaho
PO Box 48
Driggs, ID 83422

RE: City of Driggs Transmission Line, PWS# 7410004, Permit # 03-264

Dear Mayor:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a extension to the City of Driggs Water Transmission system in accordance with Chapters 3 and 12 of the WWQRR has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your engineer is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. All construction, installation, or modification allowed by this permit shall be completed by September 30, 2004.

Sincerely,

Rick J. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Jason J. Linford, PE, Project Engineer, Sunrise Engineering, Inc., Afton, WY, 83110
Jeff Hermansky, PE, WDEQ/WQ NW District Engineer



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

ave Freudenthal, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

September 8, 2003

Keith A. Neustel, PE & LS #2085
Grizzly Engineering
P.O. Box 1004
Buffalo, WY 82834

RE: Village West Estates & Mobile Home Court, Permit # 03-265

Dear Keith:

The above application for coverage under General Permit to Construct, Install, Modify or Operate an extension of the Town of Buffalo water distribution system and sewer collection system in accordance with Chapter 3 and Chapters 11 & 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. All construction, installation, or modification allowed by this permit shall be completed by September 30, 2004.

If you have any questions please contact me.

Thank you.

Sincerely,

Rick J. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Ken Burton/P.O. Box 306/Buffalo/WY/82834

**DEPARTMENT OF ENVIRONMENTAL QUALITY
STATE OF WYOMING
GROUNDWATER POLLUTION CONTROL PERMIT
AUTHORIZATION TO DISCHARGE INTO UNDERGROUND RECEIVERS
(Permit to Inject)**

() New
(X) Modified

Permit Number: UIC 03-267
Subclass Number: 5E3
Reference: UIC 00-456

In compliance with the Wyoming Environmental Quality Act (W.S. 35-11-101 through 1104, specifically 301(a)(i) through (iv), Laws 1973, Ch. 250, Section 1) and Water Quality Rules and Regulations, Chapter 3 (March 28, 1988), and Chapter 16 (April, 1998).

Applicant: J Bar 9 Ranch
3110 South Fork Road
Cody, WY 82414
(307) 587-8578

is authorized to operate the J Bar 9 Ranch Wastewater Facility (UIC Facility WYS 029-089) in the NE ¼ NE ¼, Section 8 and the NW ¼ NW ¼, Section 9, Township 49 North, Range 105 West, of the 6th Principal Meridian; according to the procedures and conditions of application numbers 00-456, 03-267, and requirements and other conditions of this permit as contained on pages 1 through 8.

This permit shall become effective on date of issuance.



Administrator
Water Quality Division
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002
Phone: (307) 777-7781

9/4/03

Date



Director
Department of Environmental Quality
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002

9/8/03

Date

TABLE OF CONTENTS

A. DISCHARGE ZONE AND AREA OF REVIEW 2
Discharge Zone: 2
Area of Review 2

B. GROUNDWATER CLASSIFICATION 2

C. AUTHORIZED OPERATIONS 3

D. ENVIRONMENTAL MONITORING PROGRAM FOR GROUNDWATERS OF THE STATE 3

E. REQUIREMENTS FOR MONITORING THE DISCHARGE 4

F. RECORDS AND REPORTS 5

G. GENERAL CONDITIONS 6

H. DUTIES OF Frontier Correctional 7

I. SPECIAL MEASURES THE DIRECTOR FINDS NECESSARY: 8

J. SIGNATORIES REQUIREMENT 8

A. DISCHARGE ZONE AND AREA OF REVIEW

Discharge Zone:

This injection facility (sanitary leachfield) is authorized to inject into the alluvial aquifer along the Shoshone River from zero to 25 feet below the ground surface.

Area of Review

The facility authorized by this permit is located in:

Township 49 North, Range 105 West, 6th Principal Meridian

Section 8 NE ¼ NE ¼
Section 9: NW ¼ NW ¼

The Area of Review around this facility is legally described as:

Township 49 North, Range 105 West, 6th Principal Meridian

Section 8: NE ¼
Section 9: NW ¼

B. GROUNDWATER CLASSIFICATION

The groundwater in the alluvial aquifer along Shoshone River is classified as class I (Domestic) under Chapter 8 of Wyoming Water Quality Rules and Regulations (April 9, 1980). This classification was made because:

- a. The groundwater in this formation is currently being used for domestic purposes at several points of withdrawal;

This groundwater does not meet the quality standards for Class I groundwater of the state although it is being used for domestic purposes and is therefore Class I groundwater by use. Groundwater of class I shall not be degraded so as to make it unusable as a source of water for this purpose. Any parameters which do not meet the class of use standard shall not be degraded whatsoever.

C. AUTHORIZED OPERATIONS

J Bar 9 Ranch is authorized to inject 100.3 barrels per day, (4,350 gallons per day) of wastewater as described: Sanitary waste only from a privately run guest ranch and staff housing. J Bar 9 Ranch is authorized to inject at a pressure of no more than 10 psi as measured at the leachfield. This pressure is controlled by gravity drainage and is not required to be monitored. This permit covers two separate leachfields to accept domestic sewage from the fitness center, cabins and lodge area and from staff housing.

Hazardous Waste This permit does not allow for the injection of any hazardous waste as defined by 40 CFR 261. Injection of any substance defined as hazardous waste, whether hazardous by listing or by characteristic is a violation of this permit.

In the event that additional facilities are constructed that add to the demand on this septic system, additional capacity will be required for the septic system. Any such expansion shall be reported to the DEQ in the form of a modified permit application showing the required additional drainfield capacity. Modifications within the subdivision which do not add to the total flow to the septic system may be made without modifying this permit.

D. ENVIRONMENTAL MONITORING PROGRAM FOR GROUNDWATERS OF THE STATE

1. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
2. J Bar 9 Ranch shall prepare records of all monitoring information to be retained for a period of at least 3 years after closure of the facility.
3. Records of monitoring information shall include:
 - a. The date, exact place, and time of sampling or measurements;
 - b. The name(s) of individual(s) who performed the sampling or measurements;
 - c. The date(s) analyses were performed;
 - d. Names of individuals who performed the analyses;
 - e. The analytical techniques or methods used; and
 - f. The results of such analyses.

4. The groundwater in the receiving formation shall be sampled and the following parameters analyzed on the following schedule and from the following wells.

WELL NAME OR NUMBER	SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT (UCL) *
The J Bar 9 Water Supply Well	Annually during the fall	EPA Method 350.3	Ammonia as N	.500
		EPA Method 353.2	Nitrate as N	10.0

*All chemical concentrations in this permit are expressed in mg/l unless otherwise noted.

The above Upper Control Limit (UCL) is not to be exceeded in any sample. Exceedance of this value is a violation of this permit and shall require corrective action. In the event that there is no water present in this monitor well, then J Bar 9 Ranch shall monitor for the presence of water on a quarterly basis. In the event that any of the above UCL's are exceeded, the J Bar 9 Ranch shall immediately sample all domestic use wells within the facility for Total Coliform Bacteria.

After the first two years of operation, the Water Quality Division may, without reissuing this permit, waive further monitoring of any parameter from the above list or may require additional monitoring based on new information about the nature of the waste. The Water Quality Division may also, after the first two years of operation, approve a more or less stringent monitoring schedule.

E. REQUIREMENTS FOR MONITORING THE DISCHARGE

J Bar 9 Ranch shall monitor the quality of the effluent on the following schedule. The following parameters shall be analyzed by the listed methods and reported semiannually:

SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT (UCL) *
Annually in the fall	EPA 200 Series Methods	Lead	.050
	EPA Method 420.1	Total Phenols	.250
	EPA Method 350.3	Ammonia as N	100.0

*All chemical concentrations in this permit are expressed in mg/l unless otherwise noted. The above Upper Control Limit (UCL) is not to be exceeded in any sample. Exceedance of this value is a violation of this permit and shall require corrective action. In the event that any contaminant is found to exceed the above UCL's the J Bar 9 Ranch shall undertake a study to determine and eliminate the source of that contaminant from the waste stream. Any parameter found to be exceeding the above UCL shall be sampled for in the downgradient well if not already sampled for. After the first two years of operation, the Water Quality Division may, without reissuing this permit, waive further monitoring of any parameter from the above list or may require additional monitoring based on new information about the nature of the waste. The Water Quality Division may also, after the first two years of operation, approve a more or less stringent monitoring schedule.

F. RECORDS AND REPORTS

1. J Bar 9 Ranch shall retain copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the report or application.
2. J Bar 9 Ranch shall give notice to the administrator as soon as possible of any planned physical alterations or additions to the permitted facility.
3. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 30 days following each schedule date.
4. J Bar 9 Ranch shall report any noncompliance which may endanger health or the environment, orally within 24 hours from the time J Bar 9 Ranch becomes aware of the circumstances. The report should include:
 - a. Any monitoring or other information which indicates that any contaminant may cause an endangerment to a usable groundwater of the state.
 - b. Any noncompliance with a permit condition or malfunction of the discharge (injection) system which may cause fluid migration into or between usable groundwaters of the state:

A written submission shall be provided within 5 days of the time J Bar 9 Ranch becomes aware of the circumstances. This written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected; the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

5. J Bar 9 Ranch shall report all instances of noncompliance not reported otherwise, at the time monitoring reports are submitted; such reports shall contain the information listed in 4. above.
6. When J Bar 9 Ranch becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the administrator, it shall promptly submit such facts or information.
7. J Bar 9 Ranch shall retain all records concerning the nature and composition of injected fluids until 5 years after completion of any specified plugging and abandonment procedures. The administrator may require the owner/operator to deliver the records to the administrator at the conclusion of the retention period.
8. A subsurface discharge (injection) well may not commence subsurface discharge (injection) until, following public notice and an opportunity for hearing, a groundwater pollution control permit has been issued by the department for the proposed operation, and:
 - a. Well construction is complete and J Bar 9 Ranch has submitted notice of completion of construction to the administrator,

- b. The administrator has inspected or otherwise reviewed the subsurface discharge (injection) well and finds it in compliance with the conditions of the permit; or J Bar 9 Ranch has not received notice from the administrator of intent to inspect or otherwise review the facility within 13 days of the notice of a. above, in which case prior inspection or review is waived, and
 - c. J Bar 9 Ranch has submitted, and the Water Quality Division has approved, an Operation and Maintenance Manual for both the septic system and the public water system.
9. The annual report of operations for this facility shall be submitted on forms provided by the department and shall include the following information:
 - a. Any permit exceedances within the previous year.
 - b. The analytical results for sampling for the injected water and any groundwater sampling results required under Section D or E of this permit.
 - c. Annual reports are due in the Cheyenne office of the Water Quality Division no later than December 1 of each year.
10. A comprehensive report for an aborted or curtailed operation authorized by this permit shall be submitted to the administrator within 30 days of complete termination of the injection (discharge) or associated activity, in lieu of an annual report.

G. GENERAL CONDITIONS

1. After notice and opportunity for a hearing, a permit may be modified, suspended or revoked in whole or part during its term for cause which includes, but is not limited to, any of the following:
 - a. Violation of the permit;
 - b. Obtaining a permit by misrepresentation or failure of the discharge well or system.
2. Each permit is reviewed at least once every 5 years, and may be reviewed more frequently.
3. A permit may be modified at any time as may be required, including for conformity with changes in regulations or standards which occur after the permit is issued. A permit may be modified in whole or part in order to apply more, or less, stringent standards; or prohibitions for a toxic or other substance present in J Bar 9 Ranch 's discharge, as may be ordered by the council. This permit can be terminated by authority of the administrator for one or more permit violations.
4. Public notice of the permit review and request for public comment will be made every 10 years by the administrator.
5. Any permit noncompliance constitutes a violation of the permit.
6. The filing of a request by J Bar 9 Ranch for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

7. The owner/operator of record (permittee) is always responsible for permit compliance. A permit holder cannot transfer his permit without approval of the department director.
8. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve J Bar 9 Ranch from any responsibilities, liabilities or penalties established pursuant to any applicable state law or regulation.
9. The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.
10. The provisions of this permit are severable, and if any provision of the permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.
11. Pollution or waste which migrates into an aquifer containing a usable groundwater of the state is a violation of the permit.

H. DUTIES OF J Bar 9 Ranch

It is a duty of J Bar 9 Ranch to:

1. Comply with all permit conditions;
2. Halt or reduce activity -- it shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce J Bar 9 Ranch activity in order to maintain compliance with the permit conditions;
3. Take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with this permit; and
4. Furnish to the administrator within a reasonable time, any information which the administrator may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit; and furnish to the administrator, upon request, copies of records required to be kept by this permit.

I. SPECIAL MEASURES THE DIRECTOR FINDS NECESSARY:

1. In the event that sewage is found to be surfacing from the leachfield covered by this permit, this is a violation of this permit and shall be reported immediately as required by Section F of this permit. In the event that the leachfield covered by this permit should fail, it necessary to modify this permit to allow installation of a replacement leachfield. The J Bar 9 Ranch shall notify the department that the replacement leachfield is to be installed within 30 days of determining that the primary leachfield has failed with an application for a modified permit.
2. The J Bar 9 Ranch shall notify the Ken Markert, AICP, Park County Planning Coordinator, 1002 Sheridan Avenue, Cody, WY 82414, (307) 527-8540, at least three days prior to installing the septic system to arrange for an on-site inspection of the facility.

J. SIGNATORIES REQUIREMENT

1. All reports required by this permit and other requested information shall be signed as follows:

For a corporation -- by a principal executive officer of at least the level of vice-president;

For a partnership or sole proprietorship -- by a general partner or the proprietor, respectively;

By a duly authorized representative for any of the above. A person is a duly authorized representative only if:

- a. The authorization is made in writing by one of the described principals;
- b. The authorization specifies either an individual or position having responsibility for the overall operation of the regulated facility or activity; and
- c. The written authorization is submitted to the administrator.

2. If an authorization is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to the administrator prior to or together with any reports or information, to be signed by an authorized representative.

3. Any person signing a report or other requested information shall make the following certification:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

STATEMENT OF BASIS FOR A UIC PERMIT

I. General information.

A. Permit Number: 03-267

B. Facilities Covered: The J Bar 9 Septic Systems. Covers two large scale sanitary septic systems with a combined capacity of 4,350 gallons per day, sewer lines to serve that facility, septic tanks, and leachfields to reach that capacity.

C. Class of Facility: 5E3 (Under Chapter 16)

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 8 Yes

D. Chapter 12. No

B. Chapter 9 No

E. Chapter 13. No

C. Chapter 11. Yes

F. Chapter 16. Yes

III: Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

NOT Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter III. Note that sediment ponds, public water supplies, sewerage systems, and small wastewater systems are exempt from the requirements of Section 17.

Applicable. This is a replacement leachfield for a failed system. This permit provides for a flow capacity of 4,350 gallons per day as a total through two separate systems. Design flow rate, percolation rates, loading rates, and septic tank sizes have all been checked and found to be in compliance with Chapter 11 standards.

VI. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

VII. Applicant and Public Participation

- A. The applicant has been provided with a draft permit prior to the permit being issued.
- B. A Public Notice has been issued with a public notice period starting August 1, 2003 and ending on September 2, 2003 (30 day notice as required by Chapter 16.) This notice was published in the Cody Enterprise on or before the start of the public comment period.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 5, Chapter 16, Wyoming Water Quality Rules and Regulations. This review was performed by Robert F. Lucht, P.E. and P.G., UIC Program Supervisor, and completed on July 11, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RFL/mad/3-0945-ltr

**DEPARTMENT OF ENVIRONMENTAL QUALITY
STATE OF WYOMING
UNDERGROUND INJECTION CONTROL PERMIT
AUTHORIZATION TO DISCHARGE INTO UNDERGROUND RECEIVERS
ISSUED UNDER CHAPTER 16, WATER QUALITY RULES AND REGULATIONS**

(X) New
() Modified.

Permit Number: UIC 03-268
Subclass Number: 5E3

In compliance with the Wyoming Environmental Quality Act (W.S. 35-11-101 through 1104, specifically 301(a)(i) through (iv), Laws 1973, Ch. 250, Section 1) and Water Quality Rules and Regulations, Chapter 3 (1988), and Chapter 16 (1998),

Applicant: Wyoming Department of Transportation
P.O. Box 461
Basin, WY 82410
ATTN: Martin Kidner
(307) 568-3400

is authorized to operate the South Pass Rest Area Wastewater Facility in the NW¼SE¼, Section 20, Township 28 North, Range 101 West, of the 6th Principal Meridian; according to the procedures and conditions of application # 03-268 and other conditions of this permit as contained on pages 1 through 9.

This permit shall become effective on date of issuance.



Administrator
Water Quality Division
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002
Phone: (307) 777-7781

9/4/03

Date



Director
Department of Environmental Quality
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002

9/8/03

Date

TABLE OF CONTENTS

A.	DISCHARGE ZONE AND AREA OF REVIEW	3
	Discharge Zone:	3
	Area of Review	3
B.	GROUND WATER CLASSIFICATION	3
C.	AUTHORIZED OPERATIONS	4
D.	ENVIRONMENTAL MONITORING PROGRAM FOR GROUND WATERS OF THE STATE	4
	Samples and measurements	4
	records of all monitoring information	4
	information shall include	4
	ground water in the receiving formation	4
	waive further monitoring	4
E.	REQUIREMENTS FOR MONITORING THE DISCHARGE	5
F.	RECORDS AND REPORTS	5
	retain copies of all reports	5
	planned physical alterations or additions	5
	submitted no later than 30 days	5
	report any noncompliance	5
	other information	5
	noncompliance with a permit condition or malfunction	6
	written submission shall be provided within 5 days	6
	noncompliance not reported otherwise	6
	failed to submit any relevant facts	6
	retain all records concerning the nature and composition	6
	public notice and an opportunity for hearing	6
	annual report of operations	6
	report for an aborted or curtailed operation	6
G.	GENERAL PERMIT CONDITIONS	6
	permit may be modified, suspended or revoked	6
	reviewed at least once every 5 years	6
	modified at any time as may be required	7
	Public notice of the permit review	7
	Any permit noncompliance constitutes a violation	7
	filing of a request	7
	(permittee) is always responsible for permit compliance	7
	legal action	7
	does not convey any property rights	7
	provisions of this permit are severable	7
	waste which migrates into an aquifer	7
	permit is for a term of ten years	7
	modification which may result in a violation	7

construction requirements	7
notify the administrator	7
construction is complete	8
H. DUTIES OF THE PERMITTEE	8
Comply with all permit conditions	8
Halt or reduce activity	8
Take all reasonable steps	8
Furnish to the administrator	8
Operate and maintain all facilities	8
enter the premises where a regulated facility	8
I. SPECIAL MEASURES THE DIRECTOR FINDS NECESSARY:	8
sewage is found to be surfacing	8

A. DISCHARGE ZONE AND AREA OF REVIEW

1. **Discharge Zone:**
This injection facility (sanitary leachfield) is authorized to inject into an Alluvial Aquifer along the Sweetwater River which is found at this location from zero to 50 feet below the ground surface.

2. **Area of Review**
The facility authorized by this permit is located in:

Township 28 North, Range 101 West, 6th Principal Meridian
Section 20: NW ¼ SE ¼

The Area of Review around this facility is legally described as:

Township 28 North, Range 101 West, 6th Principal Meridian
Section 20: S ½ NE ¼, E ½ SW ¼, SE ¼ NW ¼, SE ¼

B. GROUND WATER CLASSIFICATION

1. The ground water in the Alluvial Aquifer along the Sweetwater River is classified as class I (Domestic) under Chapter 8 of Wyoming Water Quality Rules and Regulations (March 11, 1993). This classification was made because:
 - a. The ground water in this formation is presumed to meet all of the quality standards set forth in Chapter 8 for class I water;
 - b. The ground water in this formation is currently being used for domestic purposes at several points of withdrawal; and
2. Ground water of class I shall not be degraded so as to make it unusable as a source of water for this purpose. Any parameters which do not meet the class of use standard shall not be degraded whatsoever.

C. AUTHORIZED OPERATIONS

1. The Wyoming Department of Transportation is authorized to inject 86 barrels per day, (3,600 gallons per day) of wastewater as described: Sanitary waste only from a highway rest area. The waste to be disposed of is to be treated first in a septic tank. The operator is authorized to inject at a pressure of no more than atmospheric pressure as measured at the leachfield. This pressure is controlled by gravity drainage and is not required to be monitored.
2. **Hazardous Waste** This permit does not allow for the injection of any hazardous waste as defined by 40 CFR 261. Injection of any substance defined as hazardous waste, whether hazardous by listing or by characteristic is a violation of this permit.

D. ENVIRONMENTAL MONITORING PROGRAM FOR GROUND WATERS OF THE STATE

1. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
2. The Wyoming Department of Transportation shall prepare records of all monitoring information to be retained for a period of at least 3 years after closure of the facility.
3. Records of monitoring information shall include:
 - a. The date, exact place, and time of sampling or measurements;
 - b. The name(s) of individual(s) who performed the sampling or measurements;
 - c. The date(s) analyses were performed;
 - d. Names of individuals who performed the analyses;
 - e. The analytical techniques or methods used; and
 - f. The results of such analyses.
4. The ground water in the receiving formation shall be sampled and the following parameters analyzed on the following schedule and from the following wells.

WELL NAME OR NUMBER	SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT (UCL)*
Monitor Well South Pass 3	Quarterly	EPA Method 350.3	Ammonia as N	.500
		EPA Method 604	Phenol	.001
South Pass Domestic Water Supply Well(s) P05347W and P077177W		EPA Method 353.2	Nitrate as N	10.0
		Microbiological Methods for Monitoring the Environment p. 108	Total Coliform	1 colony/100ml

*All chemical concentrations in this permit are expressed in mg/l unless otherwise noted. Prior to taking the above samples, The Wyoming Department of Transportation shall monitor the static water level in monitor wells South Pass -1, South Pass -2 and South Pass -3. The results of those measurements shall be reported along with the sampling results.

5. After the first two years of operation, the Water Quality Division may, without reissuing this permit, waive further monitoring of any parameter from the above list or may require additional monitoring based on new information about the nature of the waste. The Water Quality Division may also, after the first two years of operation, approve a more or less stringent monitoring schedule.

E. REQUIREMENTS FOR MONITORING THE DISCHARGE

The Wyoming Department of Transportation shall monitor the quality of the effluent from the septic tank at the point where the flow leaves the tank on the following schedule. The following parameters shall be analyzed by the listed methods and reported annually:

SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT (UCL) *
Quarterly	EPA Method 420.1	Total Phenols	.500
	EPA Method 353.2	Nitrate as N	No Limit
	EPA Method 350.3	Ammonia as N	No Limit

*All chemical concentrations in this permit are expressed in mg/l unless otherwise noted. The above Upper Control Limit (UCL) is not to be exceeded in any sample. Exceedance of this value is a violation of this permit and shall require corrective action. In the event that any contaminant is found to exceed the above UCL's The Wyoming Department of Transportation shall undertake a study to determine and eliminate the source of that contaminant from the waste stream. Any parameter found to be exceeding the above UCL shall be sampled for in the downgradient wells if not already sampled for. After the first two years of operation, the Water Quality Division may, without reissuing this permit, waive further monitoring of any parameter from the above list or may require additional monitoring based on new information about the nature of the waste. The Water Quality Division may also, after the first two years of operation, approve a more or less stringent monitoring schedule.

F. RECORDS AND REPORTS

1. The Wyoming Department of Transportation shall retain copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the report or application.
2. The Wyoming Department of Transportation shall give notice to the administrator as soon as possible of any planned physical alterations or additions, other than authorized operation and maintenance, to the permitted facility and receive authorization prior to implementing the proposed alteration or addition.
3. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 30 days following each schedule date.

4. The Wyoming Department of Transportation shall report any noncompliance which may endanger health or the environment, orally within 24 hours from the time The operator becomes aware of the circumstances. The report should include:
 - a. Any monitoring or other information which indicates that any contaminant may cause an endangerment to a usable ground water of the state.
 - b. Any noncompliance with a permit condition or malfunction of the discharge (injection) system which may cause fluid migration into or between usable ground waters of the state.
 - c. A written submission shall be provided within 5 days of the time The operator becomes aware of the circumstances. This written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected; the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
5. The Wyoming Department of Transportation shall report all instances of noncompliance not reported otherwise, at the time monitoring reports are submitted; such reports shall contain the information listed in 4. above.
6. When The Wyoming Department of Transportation becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the administrator, it shall promptly submit such facts or information.
7. The Wyoming Department of Transportation shall retain all records concerning the nature and composition of injected fluids until 5 years after completion of any specified plugging and abandonment procedures. The administrator may require the owner/operator to deliver the records to the administrator at the conclusion of the retention period.
8. A subsurface discharge (injection) facility may not commence subsurface discharge (injection) until, following public notice and an opportunity for hearing, an underground injection control permit has been issued by the department for the proposed operation.
9. The annual report of operations for this facility shall be submitted on forms provided by the department and shall include the following information:
 - a. Any permit exceedances within the previous year.
 - b. The analytical results for sampling for the injected water and any ground water sampling results required under Section D or E of this permit.
 - c. Annual reports are due in the Cheyenne office of the Water Quality Division no later than December 1 of each year.
10. A comprehensive report for an aborted or curtailed operation authorized by this permit shall be submitted to the administrator within 30 days of complete termination of the injection (discharge) or associated activity, in lieu of an annual report.

5. GENERAL PERMIT CONDITIONS

1. After notice and opportunity for a hearing, a permit may be modified, suspended or revoked in whole or part during its term for cause which includes, but is not limited to, any of the following:
 - a. Violation of the permit;
 - b. Obtaining a permit by misrepresentation or failure of the discharge well or system.
2. Each permit is reviewed at least once every 5 years, and may be reviewed more frequently.
3. A permit may be modified at any time as may be required, including for conformity with changes in regulations or standards which occur after the permit is issued. A permit may be modified in whole or part in order to apply more, or less, stringent standards; or prohibitions for a toxic or other substance present in The Wyoming Department of Transportation's discharge, as may be ordered by the council. This permit can be terminated by authority of the administrator for one or more permit violations.
4. Public notice of the permit review and request for public comment will be made every 10 years by the administrator.
5. Any permit noncompliance constitutes a violation of the permit and is grounds for enforcement action, permit termination, revocation, or modification.
6. The filing of a request by The Wyoming Department of Transportation for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
7. The owner/operator of record (permittee) is always responsible for permit compliance. A permit holder cannot transfer his permit without approval of the department director, and no such transfer will be approved if the facility is not in compliance with the existing permit unless the proposed permittee agrees to bring the facility into compliance.
8. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve The Wyoming Department of Transportation from any responsibilities, liabilities or penalties established pursuant to any applicable state law or regulation.
9. The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.
10. The provisions of this permit are severable, and if any provision of the permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.
11. Pollution or waste which migrates into an aquifer containing a usable ground water of the state is a violation of the permit.

12. This permit is for a term of ten years. If The Wyoming Department of Transportation wishes to continue injection after the expiration date of this permit, they will be required to apply to the Administrator for, and obtain, a new permit.
13. Any modification which may result in a violation of a permit condition shall be reported to the administrator, and any modification that will result in a violation of a permit condition shall be reported to the administrator through the submission of a new or amended permit application.
14. The injection facility covered by this permit shall meet the construction requirements found in Section 10 of Chapter 16, and Part D of Chapter 11, Water Quality Rules and Regulations. The permittee shall submit notice of completion or construction to the administrator and allow for inspection of the facility upon completion of construction prior to commencing any injection activity.
15. the permittee shall notify the administrator seven (7) days prior to conversion of this facility to any other use, or final abandonment of the facility.
16. Injection shall not commence until all construction is complete.

H. DUTIES OF THE PERMITTEE

It is a duty of the permittee to:

1. Comply with all permit conditions;
2. Halt or reduce activity -- it shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce The Wyoming Department of Transportation activity in order to maintain compliance with the permit conditions;
3. Take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with this permit; and
4. Furnish to the administrator within a reasonable time, any information which the administrator may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit; and furnish to the administrator, upon request, copies of records required to be kept by this permit.
5. Operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding and operator staffing and training, and adequate laboratory and process controls including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.
6. Allow the administrator, or an authorized representative of the administrator, upon the presentation of credentials, during normal working hours, to enter the premises where a regulated facility is located, or where records are kept under conditions of this permit, and inspect the discharge and related facilities, review and copy reports and records required by the permit, collect fluid samples for analysis, measure and record water levels, and perform any other function authorized by law or regulation.

I. SPECIAL MEASURES THE DIRECTOR FINDS NECESSARY:

1. In the event that sewage is found to be surfacing from the leachfield covered by this permit, this is a violation of this permit and shall be reported immediately as required by Section F of this permit. The Wyoming Department of Transportation shall submit a modified application showing plans for a replacement leachfield (or other type of waste disposal method) within 90 days of determining that the primary leachfield has failed.

J. SIGNATORIES REQUIREMENT

1. All reports required by this permit and other requested information shall be signed as follows:

For a corporation -- by a principal executive officer of at least the level of vice-president;

For a partnership or sole proprietorship -- by a general partner or the proprietor, respectively;

For a municipality, state, federal or other public agency -- by either a principal executive officer or ranking elected official; or

By a duly authorized representative for any of the above. A person is a duly authorized representative only if:

1. The authorization is made in writing by one of the described principals;
2. The authorization specifies either an individual or position having responsibility for the overall operation of the regulated facility or activity; and
3. The written authorization is submitted to the administrator.

2. If an authorization is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to the administrator prior to or together with any reports or information, to be signed by an authorized representative.

3. Any person signing a report or other requested information shall make the following certification:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

STATEMENT OF BASIS FOR A UIC PERMIT

I. General information.

- A. Permit Number: 03-268
- B. Facilities Covered: The South Pass Rest Area Rest Area Wastewater System. Covers a new leachfield with a capacity of 3,600 gallons per day.
- C. Class of Facility: 5E3 (Under Chapter 16)

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

- | | | | |
|----------------|-----|----------------|-----|
| A. Chapter 8 | Yes | D. Chapter 12. | No |
| B. Chapter 9 | No | E. Chapter 13. | No |
| C. Chapter 11. | Yes | F. Chapter 16. | Yes |

III. Basis for issuing permit. (Indicate yes or no for each section.)

- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
Yes
- B. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

NOT Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3. Note that sediment ponds, public water supplies, sewerage systems, and small wastewater systems are exempt from the requirements of Section 17. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Applicable. This is an existing system which is being modified. The modification requires the owner to obtain an individual UIC permit to allow modifications to the system. A groundwater review has been completed in accordance with Section 17. This system will provide for a flow capacity to 3,600 gallons per day.

VI. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

VII. Applicant and Public Participation

- A. The applicant has been provided with a draft permit prior to the permit being issued.
- B. A Public Notice has been issued with a public notice period starting August 1, 2003 and ending on September 2, 2003 (30 day notice as required by Chapter 16.) This notice was published in the Wyoming State Journal in Lander and the Riverton Ranger on or before the start of the public comment period.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 5, Chapter 16, Wyoming Water Quality Rules and Regulations. This review was performed by Robert F. Lucht, P.E. and P.G., UIC Program Supervisor, and completed on July 11, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RFL/mad/3-0946-ltr



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

July 16, 2003

James E. Garrett
1501 Arabian
Laramie, Wyoming 82070

RE: Garrett Residential Septic System,
Location: SE 1/4, Section 7, T18N, R79W,

Application No. **03-269**
Carbon County

Dear Mr. Garrett:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific conditions also apply:

1. Leachfield Size and Layout - In the worksheets you choose a "Bed Type Chambered Leachfield" and calculated a minimum of 18 units needed. Your Site Plan indicates a bed with three rows of chambers, but you did not include a detail sheet of your bed layout and size. Therefore, your **leachfield bed shall be 3 units wide** (approximately 9 feet) **by at least 6 units long** (approximately 38 feet). Additionally, the effluent from the septic tank shall be **equally distributed to each of the three rows of chambers by a distribution box** (d-box) at the head of the leachfield. **Simple tees shall not be used** because you cannot divide the flow into three equal parts with just splitting tees. See the detail sheet for the leachfield bed size and layout included in the permit package.
2. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on July 15, 2005. Please reference Application Number 03-269 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,



Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bv/3-0776.ltr

cc: IPS, Cheyenne
Carbon County Planner

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 03-270
 SPECIAL CONDITIONS

DRIGGS WATER TANK PWS NO. #7410004 (IDAHO)

This permit hereby authorizes the applicant:

City of Driggs, Idaho
PO Box 48
Driggs, Idaho 83422

to construct and install a 1.0 million gallon concrete storage tank and improvements according to the procedures and conditions of the application number 03-270. The facility is located in the SE/4 of Section 20 T44N R118W in the county of Teton, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by September 30, 2004.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Casper WDEQ Field Office, 3030 Energy Lane, Casper, WY 82604, telephone (307) 473-3452; FAX (307) 473-3458.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral and/or written notice to the Northeast District Office in accordance with the provisions of Section 11, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.

- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



John V. Corra
Director
Department of Environmental Quality

9/3/03

Date of Issuance

JDL/9/2/03
bb/3-0943.ltr

Enclosures: Construction Notice Post Card, Certificate of Completion and Statement of Basis

STATEMENT OF BASIS

I. General information.

A. Permit Number: 03-270

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 11 No

B. Chapter 12 Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

N/A

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

- V. Application requires review to determine groundwater impacts in accordance with Section Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section v. from the Statement of Basis.)

N/A

- VI. If Section 17 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

- B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

- VII. Documentation of Statement of Basis.

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, NE District Water & Wastewater Supervisor, and completed on September 2, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

JDL/bb/3-0943.ltr



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

250 Lincoln Street • Lander, Wyoming 82520 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

September 5, 2003

Mayor LaVertha Gotier
City of Worland
P. O. Box 226
Worland, WY 82401

RE: Blocks 3, 4 & 5, Cloud Peak Addition Sewer, Permit Number 03-272
Washakie County

Dear Mayor Gotier:

The above application for coverage under General Permit to Construct 8 inch diameter PVC sewer in accordance with Chapter 3, Section 7 and Chapter 11, Part D of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section 0, of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Jeff Hermansky
Northwest District Engineering Supervisor
Water Quality Division

xc: IPS, Cheyenne



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

250 Lincoln Street • Lander, Wyoming 82520 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

September 8, 2003

Mayor LaVertha Gotier
City of Worland
P. O. Box 226
Worland, WY 82401

RE: Blocks 4 & 5, Cloud Peak Addition, Water Main Replacement, Permit Number 03-273
Washakie County, PWS #WY5600197

Dear Mayor Gotier:

The above application for coverage under General Permit to Construct an 8 inch, Class 150, PVC water main in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section 0, of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Jeff Hermansky
Northwest District Engineering Supervisor
Water Quality Division

xc: IPS, Cheyenne



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

July 30, 2003

Mr. Herman Noe, Manager of Engineering
Cheyenne Board of Public Utilities
P.O. Box 1469
Cheyenne, WY 82003-1469

RE: Cowboy Corral KIA Water and Sewer Line Extensions, Application No. 03-274, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as a sewer line extension and a water line loop, SE 1/4 Section 36 T14N R67W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 11, 2006.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 03-274 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/bv/3-0817.ltr

cc: IPS, Cheyenne
Samuel Sours, Kimley-Horn and Associates
Tower 1, Suite 500, 1515 Arapahoe St.
Denver, CO 80202

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
Herschler Building 4 West
Cheyenne, Wyoming 82002

PROJECT: Cowboy Corral KIA Water and Sewer Line Extension


ENGINEER: Kimley-Horn and Associates, Inc.

APPLICANT: Cheyenne Board of Public Utilities

WATER QUALITY DIVISION REFERENCE NUMBER: 03-274

REVIEWING ENGINEER: Louis B. Harmon

DATE OF REVIEW: July 14, 2003



Louis B. Harmon
15 July 2003

ACTION: **NOT AUTHORIZED FOR CONSTRUCTION**. In accordance with Section 14(a), Chapter 3, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with said Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. An engineering design report is required to accompany each application for a permit to construct by Chapter 12, Section 6 of the Wyoming Water Quality Division Rules and Regulations.
2. The engineering design report should provide information about the maximum fire flow required for the facility. A combination of flow testing of adjacent existing fire hydrants and modeling should establish that the required fire flow can be provided without reducing the residual pressure at any point in the distribution system below 20 psi.
3. The plans identify that backflow prevention will be installed on the building service line. The type of building use dictates that the service line should either be protected by a reduced pressure principle device or that a hazard classification survey is completed to justify the use of a double check assembly. The type of device to be installed should be identified.
4. The backflow prevention device for the fire line should be identified.

LBH/bb/3-0775.ltr

PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 03-275
SPECIAL CONDITIONS
REF/PERMIT NO. 93-131, 00-431

Rawlins Flying J Travel Plaza Wastewater System

This permit hereby authorizes the applicant:

Flying J, Inc.
1104 Country Hills Drive
Ogden, UT 84403

to construct, install or modify a one time land application of wastewater stored in wastewater lagoons, complete rebuild of wastewater collection and treatment system to include grease traps, settling tanks, septic tanks, a recirculation sand filter, repair of existing lagoons and a center pivot sprinkler system for land application of treated wastewater according to the procedures and conditions of the application number 03-275. The facility is located in Section 23 T21N R88W in the county of Carbon, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by August 11, 2008.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 6 The applicant will provide immediate oral or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 6 This permit includes the one time land application of the liquid contents the lagoons of the present system. The draw down shall be accomplished in such a fashion that untreated waste is not land applied. The liquid waste being land applied shall be tested for fecal coliforms. If the fecal coliform count is more than 1000 / 100 ml, the liquid waste shall be disinfected before land application. The land application area shall be clearly marked and isolated from public access for thirty days after the last land application. If it becomes necessary to remove solids from the lagoons, those solids shall be incorporated in the area to be farmed as part of the permanent land application area. Before the solids can be land applied, coverage must be obtained under the general permit that has been issued by Region 8, EPA.
- 3 of 6 This permit allows a Class C land application as allowed by Chapter 21 of the Wyoming Water Quality Rules and Regulations using a center pivot irrigation system with drop nozzles as described in the plans and specifications. Chapter 21, Section 13 requires monthly testing for listed parameters and annual reporting. If after the first full year of operation all test results meet Class B requirements, the testing frequency may be reduced to semi-annual testing at the beginning and end of the irrigation season. If at any time any of the parameters exceed Class B requirements, the testing frequency shall revert to monthly.
- 4 of 6 An operation and maintenance manual for the waste treatment system and the land application system shall be submitted by January 31, 2004. The operation and maintenance manual shall be approved before land application operations may begin.
- 5 of 6 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.

o of 6 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



John V. Corra
Director
Department of Environmental Quality

7/22/03

Date of Issuance

LBH/bv/3-0787.ltr

cc: Carbon County Planning Office

STATEMENT OF BASIS

- I. Permit Number: 03-275
- II. Application reviewed for compliance with the following regulations.
- A. Chapter 11. YES
- B. Chapter 12. NO
- III. Basis for issuing permit.
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- NO
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
- YES
- IV. Facilities not specifically covered by regulations
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
- Chapter 11, Section 5 allows for the permitting of facilities not specifically covered by Chapter 11 based on documentation of data obtained from a full scale comparable facility which demonstrates the acceptability of the design.
- B. Briefly state the basis for the deviation.
- The design report includes design information from a similar system operating in a similar climate, Billings, Montana.
- V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.
- YES
- VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected.
- A. Facility will not allow a discharge to groundwater. Briefly describe:
- The land application will be at agronomic rates. The sand filter is being constructed over an impermeable liner. The existing lagoons will no longer receive raw waste, but treated effluent from the sand filter. Geotechnical borings indicate that there is no naturally occurring unconfined aquifer at the site. The bedrock at a depth of 9 to 15 feet is an impervious claystone.

- B. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

Monitor wells will be installed along the down gradient side of the land application area. If groundwater is observed in the wells, it will be tested for Chapter 8 Class I parameters. If the nitrate level exceeds the primary drinking water standard of 10 ppm, immediate additional investigation and proposed remedy will be required. Failure to undertake appropriate remedial actions approved by DEQ will constitute a violation of this permit.

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on July 18, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

July 16, 2003

Dave Yacco
45 Main Drive
Wheatland, Wyoming 82201

RE: Yacco Residential Septic System,
Location: SW 1/4, Section 26, T24N, R68W,

Application No. 03-276
Platte County

Dear Mr. Yacco:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on July 15, 2003. Please reference Application Number 03-276 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bv/3-0778.ltr

cc: IPS, Cheyenne
Platte County Planner, Marlin Johnson, P.O. Box 728, Wheatland, Wyoming 82201

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 03-277R
SPECIAL CONDITIONS

Lincoln County - Trail Ridge Subdivision Water Distribution System
New System- No PWS Number

This permit hereby authorizes the applicant:

David Spurlock, Owner
Trail Ridge Subdivision
P.O. Box 3051
Alpine, Wyoming 83128

ARCHIVES

to construct a public water supply distribution system consisting of a well house with chlorinator and 611 LF (linear feet) of 2-inch, 8032 LF of 6-inch, and 6007 LF of 8-inch PVC water main, to serve 62 residential lots and one commercial lot according to the procedures and conditions of application number 03-277R. The facilities are located at Section 10 & 15, T36N, R119W in the county of Lincoln, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by September 3, 2005.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Southwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183, mbaron@state.wy.us.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations.

It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Southwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by letter, e-mail or telephone of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Southwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; mbaron@state.wy.us, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



John V. Corra
Director
Department of Environmental Quality



Date of Issuance

MDB/mdb

bb/3-0958.ltr

STATEMENT OF BASIS

I. General information.

Permit Number: 03-277R

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. No

B. Chapter 12. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable

B. Briefly state the basis for the deviation.

Not Applicable

C. Permit based on general or statewide deviation contained in approved policy statement

Not Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3¹.

Not Applicable

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.

VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

Not Applicable

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Barón, Environmental Senior Analyst, and completed on September 3, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/3-0958.ltr

ROAD APPLICATION PERMIT

New
Renewal
Modified

PERMIT NO. 03-278
REFERENCE PERMIT NO. 99-406
SPECIAL CONDITIONS 1 THROUGH 8

Centennial Oilfield

This permit hereby authorizes the applicant:

Centennial Energy
P.O. Box 469
Thermopolis, WY 82443

to road apply waste crude oil sludge from tank bottoms according to the procedures and conditions of application number 03-278. The application site is located in E ½ Section 16, T43N, R94W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective until September 30, 2004.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 8 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307) 332-3183.
- 2 of 8 The permittee will provide immediate oral and/or written notice to the Northwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183;

in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.

- 3 of 8 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the Northwest District, Office of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the attached Certification of Completion form, the following information:
- A. Date that the road application was completed; and
 - B. Certification the road application was done in accordance with the terms and conditions of the permit; or
 - C. Certification the road application was completed with changes or modifications. Submit the information necessary to clearly indicate the road application as actually performed. This information shall include a contour map depicting only those sections of road that actually received the waste crude oil sludge.
- 4 of 8 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 5 of 8 The waste crude oil sludge shall be applied uniformly and incorporated into the roadbed. Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. The waste crude oil sludge shall not be applied during the period from November 1 to April 10.
- 6 of 8 The application site slope shall not exceed eight percent (8%) for vehicular application.
- 7 of 8 The waste crude oil sludge application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
- 8 of 8 Only the roads designated in this permit are authorized for application of the waste crude oil sludge. Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.

AUTHORIZED BY:



John V. Corra
Director
Department of Environmental Quality

7/21/03

Date of Issuance

JH/lb/bv/3-0778.ltr

STATEMENT OF BASIS

General information.

Permit Number: 03-278

II. Application reviewed for compliance with the following regulations.

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are not numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed modified or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement.

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria

for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

- V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹.

Applicable

- VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

- A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying the waste crude oil sludge onto the roadbed. Repeated applications of the waste crude oil sludge on the same sections of road will be monitored by roadbed analyses that is required for future applications.

- B. Quality of waste is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

- C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

N/A

- D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

- E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

N/A

- F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

N/A

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

- G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

N/A

VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, Northwest District Engineering Supervisor, and completed on 7/18/03. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

August 15, 2003

Conoco Pipe Line
Attn. Dale Widrick, Facility Manager
206 Tank Farm Road
Guernsey, Wyoming 82214

RE: Conoco/Phillips Pump Station Septic System, Application No. **03-280**
Location: Section 15, Township 26N, Range 66W, Platte County

Dear Mr. Widrick:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific conditions also apply:


1. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.
2. Polyethylene Septic Tank Installation Requirements - To ensure structural integrity, the **manufacturer's instructions** regarding bedding the tank and filling the tank with water during burial **must be followed during installation**. Additionally, immediately after clean-outs, the tank must be refilled with water according to the manufacturer's instructions to maintain structural integrity.

Mr. Widrick
August 15, 2003
Page 2

The approval granted under this Notification Of Coverage and the General Permit shall expire on August 15, 2005. Please reference Application Number 03-280 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,



Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bb/3-0884.ltr

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Platte County Planner, Marlin Johnson, P.O. Box 728, Wheatland, Wyoming 82201



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

July 23, 2003

Richard Sass
P.O. Box 1106
Wheatland, Wyoming 82201

RE: Richard Sass Small Wastewater Treatment Facility, Application No. **03-281**
Location: S 1/2, Section 17, T24N, R67W, Platte County

Dear Mr. Sass:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on July 23, 2005. Please reference Application Number **03-281** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bv/3-0801.ltr

cc: IPS, Cheyenne
Platte County Planner, Marlin Johnson, P.O. Box 728, Wheatland, Wyoming 82201

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 03-282R

REFERENCE PERMIT NOS. 01-350R & 02-257

Saddle Butte Heights - Water System
New System No PWS # Assigned

This permit hereby authorizes the applicant:

WW Saddle Butte, 2001 LLC
Terry N. Worrell
6909 Vassar
Dallas, Texas 75205

to construct three booster pump stations in series to serve 45 residential lots according to the procedures and conditions of the application number 03-282R. The facility is located at Sections 28&29, T41N, R116W in the county of Teton, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by February 10, 2007.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:


- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Northwest District Engineer, 250 Lincoln Street, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

2/15/05
Date of Issuance
MDB/mb
bb/5-0237.ltr

STATEMENT OF BASIS

1. Permit Number: 03-282R
2. Application reviewed for compliance with the following regulations:
Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?
Yes.
4. If a Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Not Required.
5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Mark D. Baron, mbaron@state.wy.us, Environmental Senior Analyst and completed on February 10, 2005. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/5-0237.ltr

AS-BUILT PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 03-283

POWDER RIVER CAMPGROUND WATER SYSTEM FOR CONVENIENCE STORE & MOTEL

This permit hereby authorizes the applicant:

Ted Schumacher
P.O. Box 1064
Buffalo, WY, 82834

to have constructed, installed or modified a potable water well and water distribution system to serve a convenience store and 12 unit motel according to the procedures and conditions of the application numbers 03-283. The facility is located in the SW/4 of Section 17 of T49N R77W in the county of Johnson, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (DEQ/WQD), upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.


Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee has constructed and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

AUTHORIZED BY:


John F. Wagner, Administrator
Water Quality Division


John V. Corra, Director
Department of Environmental Quality

10/15/03
Date of Issuance

RJE/09/26/03

bb/3-1083.ltr

Enclosures: Statement of Basis

STATEMENT OF BASIS

- I. General information.
- A. Permit Number: 03-283
- II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)
- A. Chapter XI. No
- B. Chapter XII. Yes
- III. Basis for issuing permit. (Indicate yes or no for each section.)
- A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
Yes
- B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.
No
- C. Permit based on deviation from applicable regulations in accordance with approved policy statement.
No
- IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)
- A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
Section 9, (b) (i) - Total developed groundwater source and other water sources shall provide combined capacity equal to; twice the maximum daily demand w/one well and storage or maximum daily demand w/two wells.
- B. Briefly state the basis for the deviation.
Permittee is applying for WDEQ permit to construct additional well to meet Section 9, (b) (i). If the well does not meet the capacity requirements storage will be added to the system.
- C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).
N/A

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3¹. (Indicate either applicable or not applicable. If not applicable delete all of Section VI. from the Statement of Basis.)

N/A

VI. N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Rick J. Estes, PE, Northeast District DEQ/WQD-Senior Environmental Analyst, and completed on September 26, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RJE/bb/3-1083.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Dave Freudenthal, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

7-29-03
1/2

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

July 28, 2003

Mr. Randy Bomar, PE 6505
P.O. Box 1039
Sheridan, WY 82801

RE: Sheridan Slope Stabilization Water Line Relocation, Permit # 03-284

Dear Randy:

The above application for coverage under General Permit to Construct, Install, Modify or Operate an extension to the City of Sheridan Water Distribution System in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. All construction, installation, or modification allowed by this Notice of Coverage shall be completed by July 31, 2004.

Thank you.

Sincerely,

Rick J. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst

cc: IPS
Jackie Flowers-Public Works Director, City of Sheridan



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Dave Freudenthal, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

July 21, 2003

Roger Wilson
6050 Alpine Ct.
Rapid City, SD 57702

RE: Roger Wilson Sand Creek Cabin Septic System Permit # 03-285

Dear Roger:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of small wastewater septic in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. All construction, installation, or modification allowed by this permit shall be completed by July 31, 2004.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457. Thank you.

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQ NE District Senior Environmental Analyst

cc: IPS, Cheyenne



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

July 23, 2003

Mr. Art Genzler, Mayor
Town of Sinclair
P.O. Box 247
Sinclair WY 82334

RE: Sinclair Water Distribution and Sewer Collection System Improvements, Application No. 03-287,
Carbon County

Dear Mr. Genzler:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as replacement of water distribution line on Monroe Avenue, Sections 20 and 21 T21N R86W; Carbon County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 11, 2006.

Backflow prevention devices and abandoned water line procedures shall comply with the specifications of the plans associated with Permit to Construct 03-173.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 03-287 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/bv/3-0799.ltr

cc: IPS, Cheyenne
Gary Steele, PMPC, P.O. Box 370, Saratoga, WY 82331



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

July 24, 2003

Jamie Cordonier
1721 Newport
Casper, Wyoming 82609

RE: Cordonier Residential Septic System,
Location: NW 1/4, Section 10, T27N, R69W,

Application No. **03-288**
Platte County

Dear Mr. Cordonier:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific conditions also apply:

1. Minimum Leachfield Size - You made a slight error on your slowest percolation rate determination, and you also used 40.0 square feet equivalent area per unit when you should have used 35.4 sq. ft. per unit for a bed configuration minimum area calculation. Using these correct values to calculate your minimum leachfield size yields 18 Standard "Infiltrator" chamber units instead of the 16 units that you calculated. Therefore, **a minimum of 18 Standard Infiltrator chamber units shall be installed** in a bed configuration of two rows of 9 units each (57 feet long).
2. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on July 24, 2005. Please reference Application Number **03-288** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,



Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bv/3-0804.ltr

cc: IPS, Cheyenne
Platte County Planner, Marlin Johnson, P.O. Box 728, Wheatland, Wyoming 82201

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion



The State
of Wyoming



Department of Environmental Quality
1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Dave Freudenthal, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

September 17, 2003

Mr. Mark Hines, PE
Project Manager
P.O. Box 7010
Sheridan, WY 82801

RE: First Baptist Church Fire Main, Permit # 03-289

Dear Mark:

The above application for coverage under General Permit to Construct, Install, Modify or Operate an extension to the City of Sheridan Water Distribution System in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. All construction, installation, or modification allowed by this Notice of Coverage shall be completed by September 30, 2004.

Thank you.

Sincerely,

Rick J. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst

cc: IPS-Cheyenne
Jackie Flowers-Public Works Director, City of Sheridan



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Dave Freudenthal, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

August 4, 2003

Tonu & Karen Kiesel
258 Elk Grove Trail
Newcastle, WY 82701

RE: Kiesel Septic As-Built System, Permit # 03-290

Dear Tonu & Karen:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of small wastewater septic in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. Our review of the information and as-constructed plan submitted to this office indicates that the application meets DEQ/WQD regulations and the enclosed As-Built Permit To Construct is hereby issued. Please be advised that the system must be operated in accordance with the statements, representations and procedures presented in the application and all supporting documentation as well as the terms and conditions of the permit. You are urged to be familiar with all aspects of the permit application, permit and permit conditions.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457. Thank you.

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQ NE District Senior Environmental Analyst

cc: IPS, Cheyenne

PERMIT TO CONSTRUCT
PWS #WY 56000214

New
 Renewal

PERMIT NO. 03-291
SPECIAL CONDITIONS

Snake River Mobile Home Park Water System

This permit hereby authorizes the applicant:

SSDA, LLC
P.O. Box 3393
Jackson WY 83001

to construct, install or modify a connect a new well to existing water system, including a new chlorination system according to the procedures and conditions of the application number 03-291. The facility is located in SW 1/4 NE 1/4 Section 14 T39N R116W in the county of Teton, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by August 11, 2006.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Southeast District, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will provide immediate oral or written notice to the DEQ/WQD Southeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 4 The initial testing indicates that the well water does not comply with the standard of .010 ppm for arsenic that becomes effective on January 23, 2006. By January 23, 2005, Snake River Mobile Home Park must submit either plans for treatment to achieve compliance with the arsenic rule or evidence that the well is producing water that does not violate the rule.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



John Corra
Director
Department of Environmental Quality

9/18/03

Date of Issuance

LBH/bb/3-0966-ltr

cc: Jeff Hermansky

STATEMENT OF BASIS

- I. Permit Number: 03-291
- II. Application reviewed for compliance with the following regulations.
 - A. Chapter 11. NO
 - B. Chapter 12. YES
- III. Basis for issuing permit: Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.
- IV. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.
NO
- V. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on September 15, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LBH/bb/3-0966.ltr



The State
of Wyoming

Department of Environmental Quality



Dave Freudenthal, Governor

3030 Energy Lane • Suite 200 • Casper, Wyoming 82604

SOLID & HAZARDOUS WASTE DIVISION
(307) 473-3450
Fax: (307) 473-3458

AIR QUALITY DIVISION
(307) 473-3455
Fax: (307) 473-3458

WATER QUALITY DIVISION
(307) 473-3465
Fax: (307) 473-3458

ABANDONED MINES
(307) 473-3460
Fax: (307) 473-3458

NOTIFICATION OF COVERAGE

July 28, 2003

Curtis Williamson
Box 42
Sundance, WY 82729

RE: Williamson Small Wastewater Facility, Permit # 03-292 (95-201)

Dear Mr. Williamson:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3 and Chapter 11, Part D, of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit.

If you have any questions please contact Dennis Lamb at 3030 Energy Lane, Casper, WY, 82604, (307) 473-3452. Thank you.

Sincerely,

Dennis Lamb
NE District Supervisor
DEQ/WQD

cc: IPS, Cheyenne



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

July 23, 2003

Don Grenemyer
1201 Hightower Road
Wheatland, Wyoming 82201

RE: Grenemyer Residential Septic System,
Location: SW 1/4, Section 20, T26N, R68W,

Application No. **03-293**
Platte County

Dear Mr. Grenemyer:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on July 23, 2005. Please reference Application Number **03-293** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bv/3-0800.ltr

cc: IPS, Cheyenne
Platte County Planner, Marlin Johnson, P.O. Box 728, Wheatland, Wyoming 82201

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

August 29, 2003

Michael Roy, Planning Director
City of Douglas
101 North 4th Street
Douglas WY 82633

RE: City of Douglas, Wenzel Addition, Application No.03-294, Converse County

Dear Roy:


The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as 843 feet of 8" water main and 673 feet of 8" sewer main and related apputenances, NW 1/4 Section 15 T32 N R71W; Converse County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 11, 2006.

All service connections must have the appropriate type of backflow prevention device installed as required by Chapter 12, Section 14 of the Wyoming Water Quality Division Rules and Regulations.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 03-294 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,


Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/mad/3-0941-ltr
cc: IPS, Cheyenne

Michael Lewan, Worthington, Lenhart and Carpenter, Inc
200 Pronghorn
Casper WY 82601

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

Herschler Building 4 West
Cheyenne, Wyoming 82002

PROJECT: Wenzel Addition to the City Douglas, Wyoming


ENGINEER: Worthington, Lenhart, and Carpenter, Inc

APPLICANT: City of Douglas

WATER QUALITY DIVISION REFERENCE NUMBER: 03-294

REVIEWING ENGINEER: Louis B. Harmon

DATE OF REVIEW: August 12, 2003



ACTION: NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 14(a), Chapter 3, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with said Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. Both Chapter 11 and 12 of the Water Quality Division Rules and Regulations in Section 6 require an engineer's design report to accompany each application for a permit to construct.
2. Chapter 11 applies to wastewater collection. The design report should address the capacity of the sewer main in the highway to accept the additional flow from the proposed subdivision. The maximum anticipated sewage flow from the proposed subdivision should be quantified.
3. Chapter 12 applies to water distribution systems. The design report should address the peak daily flow, peak daily flow plus fire flow, and the corresponding residual pressures throughout the entire pressure zone supplying the subdivision. The plans do not show any fire hydrants. Are any planned?
4. Chapter 12, as revised in March 2003, requires back flow prevention devices at each service connection. The plans and specifications should include a commitment by the City of Douglas to ensure that each service connection is contained by the appropriate backflow prevention device.

LBH/bb/3-0878.ltr



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

September 16, 2003

F.E. Warren AFB
Attn. Rodney G. Trees, Chief of Design
300 Vesle Drive
Bldg. 320, Rm. 112
F.E. Warren AFB, Wyoming 82005

RE: Visitor Control Center & Entrance at Gate No. 1 - Replace & Upgrade Sewer Line,
Move Fire Hydrant, and Install Backflow Prevention, Application No. 03-295

Dear Mr. Trees:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and Existing Sewage Collection Systems in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permits, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits, which the Base already has copies of on file.

The approval granted under this Notification Of Coverage and the General Permit shall expire on September 16, 2006. Please reference Application Number 03-295 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bb/3-0996.ltr

Enclosures: Certificate of Completion form

cc: IPS, Cheyenne
George C. Walton, Balloffet-Entranco, 345 East Mountain Ave., Fort Collins, CO 80524

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

Herschler Building 4 West
Cheyenne, Wyoming 82002

PROJECT: River Run, An Apartment Community

ENGINEER: Coffey and Associates

APPLICANT: Community Development, Inc.

WATER QUALITY DIVISION REFERENCE NUMBER: 03-297

REVIEWING ENGINEER: Louis B. Harmon

DATE OF REVIEW: August 12, 2003



ACTION: NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 14(a), Chapter 3, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with said Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. The system as designed is a dead-end system because there is only one feed from the 6" diameter line in 17th Street. Two taps in 17th Street with a valve inserted in the 17th Street line between the two taps would be a looped system if the taps tie to the 8" loop in two places on opposite sides of a valve in the 8" line.
2. One additional valve is required in the 8" loop to comply with the maximum spacing requirement of 500 ft between valves.
3. The plans or specifications should specify the type of backflow prevention device to be installed in each building. A statement that all buildings will be equipped with the same device (probably a double check depending on the Engineer's determination) is acceptable.
4. Sewer service lines serving more than a single family home are considered to be collection lines subject to permitting requirements if the sewer line changes line or grade. Details need to be provided for all sewer service lines with changes of line or grade. An acceptable clean-out needs to be installed at all changes of direction of the service lines. If the grades, depths, and clean-out details are provided, plan and profile drawings will not be required for the service lines.

LBH/bb/3-0879.ltr

PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 03-296R
SPECIAL CONDITIONS

Solvay Minerals, Inc. - Cartridge Filtration
PWS # WY5600914

This permit hereby authorizes the applicant:

Ronald O. Hughes, Resident Manager
Solvay Minerals, Inc.
P.O. Box 1167
Green River, WY 82935

to construct a cartridge filtration system consisting of two sets of 5 and 1 micron filters and appurtenances, according to the procedures and conditions of application number 03-296R. The facility is located at NE 1/4 Section 3, T18N, R109W in the county of Sweetwater, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by October 7, 2005.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance, or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Mark Baron, Southwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, Wyoming 82520; (307) 332-3144; FAX (307) 332-3183, mbaron@state.wy.us.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will notify the Southwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; by letter, e-mail or telephone of the date construction will begin and the estimated completion date.
- 2 of 4 The applicant will provide immediate oral and/or written notice to the Southwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; (307)332-3144; FAX (307)332-3183; mbaron@state.wy.us, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southwest District, State of Wyoming, DEQ, Water Quality Division, 250 Lincoln Street, Lander, WY 82520; on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality

10-13-03

Date of Issuance

MDB/mdb

bb/3-1076.ltr

STATEMENT OF BASIS

I. General information.

Permit Number: 03 -296R

II. Application reviewed for compliance with the following regulations.

A. Chapter 11. No

B. Chapter 12. Yes

III. Basis for issuing permit.

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section 2.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter 11, or 12.

Yes

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

Yes

IV. Facilities not specifically covered by regulations.

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Chapter 12, Section 10 of the Wyoming Water Quality Rules and Regulation does not specifically address the use of cartridge filtration for water treatment.

B. Briefly state the basis for the deviation.

Chapter 12, Section 5 allows for new technology and equipment and provides a process for evaluating and permitting designs which deviate from these regulations. The use of 1 micron, absolute filters, meets the United State Environmental Protection Agencies' (USEPA) Long Term 1 Enhanced Surface Water Treatment Rule.

C. Permit based on general or statewide deviation contained in approved policy statement

Chapter 12, Section 10 (k)(ii)(C) requirements for contact time have been replaced by Wyoming Department of Environmental Quality/Water Quality Division (WDEQ /WQD) policy 14.10.1. Under Policy 14.10.1 the Wyoming DEQ has adopted the USEPA's Surface Water Treatment Rule.

- V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3¹.

N/A

- VI. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

N/A

- VII. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron, Environmental Senior Analyst, and completed on October 7, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/3-1076.ltr

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 17.



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

October 8, 2003

Mr. Gary Hall, Senior Development Manager
Community Development, INC
4100 Eaton Avenue, Suite A
Caldwell, ID 83607

RE: River Run, An Apartment Community in Laramie, Application No.03-297, Albany County

Dear Mr. Hall:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as 1392 ft of 8" dia. PVC water main with three fire hydrants and other appurtenances and 263 ft of 8" diameter PVC sewer main with manholes, Section 3 T15N R73W; Albany County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 11, 2006.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 03-297 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/mad/3-1072-ltr

cc: tPS, Cheyenne

Robert J. Coffey, Coffey & Associates, LLC, 903 Grand Avenue, Laramie WY 82070
City Engineer, City of Laramie, P.O. Box C, Laramie, WY 82073

**DEPARTMENT OF ENVIRONMENTAL QUALITY
STATE OF WYOMING
UNDERGROUND INJECTION CONTROL PERMIT
AUTHORIZATION TO DISCHARGE INTO UNDERGROUND RECEIVERS
ISSUED UNDER CHAPTER 16, WATER QUALITY RULES AND REGULATIONS**

() New
(X) Modified

Permit Number: UIC 03-298
Subclass Number: 5E3
Reference: UIC 99-367

In compliance with the Wyoming Environmental Quality Act (W.S. 35-11-101 through 1104, specifically 301(a)(i) through (iv), Laws 1973, Ch. 250, Section 1) and Water Quality Rules and Regulations, Chapter 3 (1988), and Chapter 16 (1998),

Applicant: Cowboy Hotel Corp.
P.O. Box 789
Ranchester, WY 82839
(307) 673-4456

is authorized to operate the Arrowhead Lodge Wastewater Facility in the NE $\frac{1}{4}$ SW $\frac{1}{4}$, Section 33, Township 56 North, Range 88 West, of the 6th Principal Meridian; according to the procedures and conditions of application # 03-298 and other conditions of this permit as contained on pages 1 through 9.


This permit shall become effective on date of issuance.



Administrator
Water Quality Division
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002
Phone: (307) 777-7781

9/4/03

Date



Director
Department of Environmental Quality
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002

9/8/03

Date

TABLE OF CONTENTS

A. DISCHARGE ZONE AND AREA OF REVIEW	3
Discharge Zone:	3
Area of Review:	3
B. GROUNDWATER CLASSIFICATION	3
C. AUTHORIZED OPERATIONS	4
D. ENVIRONMENTAL MONITORING PROGRAM FOR GROUNDWATERS OF THE STATE	4
Samples and measurements	4
records of all monitoring information	4
information shall include	4
groundwater in the receiving formation	4
waive further monitoring	4
E. REQUIREMENTS FOR MONITORING THE DISCHARGE	5
F. RECORDS AND REPORTS	5
retain copies of all reports	5
planned physical alterations or additions	5
submitted no later than 30 days	5
report any noncompliance	5
other information	5
noncompliance with a permit condition or malfunction	5
written submission shall be provided within 5 days	5
noncompliance not reported otherwise	6
failed to submit any relevant facts	6
retain all records concerning the nature and composition	6
public notice and an opportunity for hearing	6
annual report of operations	6
report for an aborted or curtailed operation	6
G. GENERAL PERMIT CONDITIONS	6
permit may be modified, suspended or revoked	6
reviewed at least once every 5 years	6
modified at any time as may be required	6
Public notice of the permit review	7
Any permit noncompliance constitutes a violation	7
filing of a request	7
(permittee) is always responsible for permit compliance	7
legal action	7
does not convey any property rights	7
provisions of this permit are severable	7

waste which migrates into an aquifer	7
permit is for a term of ten years	7
modification which may result in a violation	7
construction requirements	7
notify the administrator	7
construction is complete	7
H. DUTIES OF THE PERMITTEE	7
Comply with all permit conditions	8
Halt or reduce activity	8
Take all reasonable steps	8
Furnish to the administrator	8
Operate and maintain all facilities	8
enter the premises where a regulated facility	8
I. SPECIAL MEASURES THE DIRECTOR FINDS NECESSARY:	8
sewage is found to be surfacing	8
J. SIGNATORIES REQUIREMENT	8
For a corporation	8
For a partnership or sole proprietorship	8
By a duly authorized representative	8
authorization is no longer accurate	9
certification	9

A. DISCHARGE ZONE AND AREA OF REVIEW

1. Discharge Zone:

This injection facility (sanitary leachfield) is authorized to inject into the South Tongue River Terrace Deposit which is found at this location from zero to 20 feet below the ground surface.

2. Area of Review:

The facility authorized by this permit is located in:
Township 56 North, Range 88 West, 6th Principal Meridian
 Section 33: NE ¼ SW ¼

The Area of Review around this facility is legally described as:
Township 56 North, Range 88 West, 6th Principal Meridian
 Section 33: SW ¼

B. GROUNDWATER CLASSIFICATION

1. The groundwater in the South Tongue River Terrace Deposit is classified as class I (Domestic) under Chapter 8 of Wyoming Water Quality Rules and Regulations (March 11, 1993). This classification was made because:

- a. The groundwater in this formation meets all of the quality standards set forth in Chapter 8 for class I water;
- b. The groundwater in this formation is currently being used for domestic purposes at a point of withdrawal within the area of review; and

2. Groundwater of class I shall not be degraded so as to make it unusable as a source of water for this purpose. Any parameters which do not meet the class of use standard shall not be degraded whatsoever.

C. AUTHORIZED OPERATIONS

- 1. Cowboy Hotel Corp. is authorized to inject 143 barrels per day, (6,000 gallons per day) of wastewater as described: Sanitary waste only from a restaurant, bar, lodge, and motel. The operator is authorized to inject at a pressure of no more than atmospheric pressure as measured at the leachfield. This pressure is controlled by gravity drainage and is not required to be monitored.
- 2. **Hazardous Waste** This permit does not allow for the injection of any hazardous waste as defined by 40 CFR 261. Injection of any substance defined as hazardous waste, whether hazardous by listing or by characteristic is a violation of this permit.

D. ENVIRONMENTAL MONITORING PROGRAM FOR GROUNDWATERS OF THE STATE

- 1. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- 2. Cowboy Hotel Corp. shall prepare records of all monitoring information to be retained for a period of at least 3 years after closure of the facility.
- 3. Records of monitoring information shall include:
 - a. The date, exact place, and time of sampling or measurements;
 - b. The name(s) of individual(s) who performed the sampling or measurements;
 - c. The date(s) analyses were performed;
 - d. Names of individuals who performed the analyses;
 - e. The analytical techniques or methods used; and
 - f. The results of such analyses.
- 4. The groundwater in the receiving formation shall be sampled and the following parameters analyzed on the following schedule and from the following wells:

WELL NAME OR NUMBER	SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT (UCL)
---------------------	-------------------	-------------------	--------------------	--------------------

The Monitor Well east of the leachfield, as detailed on page 6 of the permit application	Twice a year in the spring and fall.	EPA Method 350.3	Ammonia as N	.500
		EPA Method 353.2	Nitrate as N	10.0

*All chemical concentrations in this permit are expressed in mg/l unless otherwise noted.

The above Upper Control Limit (UCL) is not to be exceeded in any sample. Exceedance of this value is a violation of this permit and shall require corrective action.

5. After the first two years of operation, the Water Quality Division may, without reissuing this permit, waive further monitoring of any parameter from the above list or may require additional monitoring based on new information about the nature of the waste. The Water Quality Division may also, after the first two years of operation, approve a more or less stringent monitoring schedule.

E. REQUIREMENTS FOR MONITORING THE DISCHARGE

Cowboy Hotel Corp. shall monitor the quality of the effluent being discharged to the leachfield from a sample point located upstream from the Vegetative Submerged Bed (VSB) and from a second sample point located down stream of the VSB on the following schedule. The following parameters shall be analyzed by the listed methods and reported semiannually:

SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT (UCL) *
Monthly	Meter Reading	Flow to the Leachfield	6,000 gallons per day
Annually in the fall	EPA Method 420.1	Total Phenols	.250
	EPA Method 350.3	Ammonia as N	100.0

*All chemical concentrations in this permit are expressed in mg/l unless otherwise noted. The above Upper Control Limit (UCL) is not to be exceeded in any sample. Exceedance of this value is a violation of this permit and shall require corrective action. In the event that any contaminant is found to exceed the above UCL's Cowboy Hotel Corp. shall undertake a study to determine and eliminate the source of that contaminant from the waste stream. Any parameter found to be exceeding the above UCL shall be sampled for in the downgradient well if not already sampled for. After the first two years of operation, the Water Quality Division may, without reissuing this permit, waive further monitoring of any parameter from the above list or may require additional monitoring based on new information about the nature of the waste. The Water Quality Division may also, after the first two years of operation, approve a more or less stringent monitoring schedule.

F. RECORDS AND REPORTS

1. Cowboy Hotel Corp. shall retain copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the report or application.
2. Cowboy Hotel Corp. shall give notice to the administrator as soon as possible of any planned physical alterations or additions, other than authorized operation and maintenance, to the permitted facility and receive authorization prior to implementing the proposed alteration or addition.
3. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 30 days following each schedule date.
4. Cowboy Hotel Corp. shall report any noncompliance which may endanger health or the environment, orally within 24 hours from the time The operator becomes aware of the circumstances. The report should include:
 - a. Any monitoring or other information which indicates that any contaminant may cause an endangerment to a usable groundwater of the state.
 - b. Any noncompliance with a permit condition or malfunction of the discharge (injection) system which may cause fluid migration into or between usable groundwaters of the state.
 - c. A written submission shall be provided within 5 days of the time The operator becomes aware of the circumstances. This written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected; the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
5. Cowboy Hotel Corp. shall report all instances of noncompliance not reported otherwise, at the time monitoring reports are submitted; such reports shall contain the information listed in 4. above.
6. When Cowboy Hotel Corp. becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the administrator, it shall promptly submit such facts or information.
7. Cowboy Hotel Corp. shall retain all records concerning the nature and composition of injected fluids until 5 years after completion of any specified plugging and abandonment procedures. The administrator may require the owner/operator to deliver the records to the administrator at the conclusion of the retention period.
8. A subsurface discharge (injection) facility may not commence subsurface discharge (injection) until, following public notice and an opportunity for hearing, an underground injection control permit has been issued by the department for the proposed operation.
9. The annual report of operations for this facility shall be submitted on forms provided by the department and shall include the following information:
 - a. Any permit exceedances within the previous year.

- b. The analytical results for sampling for the injected water and any groundwater sampling results required under Section D or E of this permit. Monthly volume readings for flow to the leachfield.
 - c. Annual reports are due in the Cheyenne office of the Water Quality Division no later than December 1 of each year.
10. A comprehensive report for an aborted or curtailed operation authorized by this permit shall be submitted to the administrator within 30 days of complete termination of the injection (discharge) or associated activity, in lieu of an annual report.

G. GENERAL PERMIT CONDITIONS

1. After notice and opportunity for a hearing, a permit may be modified, suspended or revoked in whole or part during its term for cause which includes, but is not limited to, any of the following:
 - a. Violation of the permit;
 - b. Obtaining a permit by misrepresentation or failure of the discharge well or system.
2. Each permit is reviewed at least once every 5 years, and may be reviewed more frequently.
3. A permit may be modified at any time as may be required, including for conformity with changes in regulations or standards which occur after the permit is issued. A permit may be modified in whole or part in order to apply more, or less, stringent standards; or prohibitions for a toxic or other substance present in Cowboy Hotel Corp.'s discharge, as may be ordered by the council. This permit can be terminated by authority of the administrator for one or more permit violations.
4. Public notice of the permit review and request for public comment will be made every 10 years by the administrator.
5. Any permit noncompliance constitutes a violation of the permit and is grounds for enforcement action, permit termination, revocation, or modification.
6. The filing of a request by Cowboy Hotel Corp. for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
7. The owner/operator of record (permittee) is always responsible for permit compliance. A permit holder cannot transfer his permit without approval of the department director, and no such transfer will be approved if the facility is not in compliance with the existing permit unless the proposed permittee agrees to bring the facility into compliance.
8. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve Cowboy Hotel Corp. from any responsibilities, liabilities or penalties established pursuant to any applicable state law or regulation.

9. The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.
10. The provisions of this permit are severable, and if any provision of the permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.
11. Pollution or waste which migrates into an aquifer containing a usable groundwater of the state is a violation of the permit.
12. This permit is for a term of ten years. If Cowboy Hotel Corp. wishes to continue injection after the expiration date of this permit, they will be required to apply to the Administrator for, and obtain, a new permit.
13. Any modification which may result in a violation of a permit condition shall be reported to the administrator, and any modification that will result in a violation of a permit condition shall be reported to the administrator through the submission of a new or amended permit application.
14. The injection facility covered by this permit shall meet the construction requirements found in Section 10 of Chapter 16, and Part D of Chapter 11, Water Quality Rules and Regulations. The permittee shall submit notice of completion or construction to the administrator and allow for inspection of the facility upon completion of construction prior to commencing any injection activity.
15. the permittee shall notify the administrator seven (7) days prior to conversion of this facility to any other use, or final abandonment of the facility.
16. Injection shall not commence until all construction is complete.

H. DUTIES OF THE PERMITTEE

It is a duty of the permittee to:

1. Comply with all permit conditions;
2. Halt or reduce activity -- it shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce Cowboy Hotel Corp. activity in order to maintain compliance with the permit conditions;
3. Take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with this permit; and
4. Furnish to the administrator within a reasonable time, any information which the administrator may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit; and furnish to the administrator, upon request, copies of records required to be kept by this permit.
5. Operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and

maintenance includes effective performance, adequate funding and operator staffing and training, and adequate laboratory and process controls including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

6. Allow the administrator, or an authorized representative of the administrator, upon the presentation of credentials, during normal working hours, to enter the premises where a regulated facility is located, or where records are kept under conditions of this permit, and inspect the discharge and related facilities, review and copy reports and records required by the permit, collect fluid samples for analysis, measure and record water levels, and perform any other function authorized by law or regulation.

I. SPECIAL MEASURES THE DIRECTOR FINDS NECESSARY:

1. In the event that sewage is found to be surfacing from the leachfield covered by this permit, this is a violation of this permit and shall be reported immediately as required by Section F of this permit. Cowboy Hotel Corp. shall submit a modified application showing plans for a replacement leachfield (or other type of waste disposal method) within 90 days of determining that the primary leachfield has failed.
2. The USFS Lease includes provision for 45 spaces for short term recreational vehicles. No sewage flow has been provided for these spaces, either for hookup to the septic system or for any kind of a service building. The USFS has also required that existing long-term leased trailers be removed within two years. Prior to the conversion of any of these spaces to their final configuration as recreational vehicle spaces, the permittee shall apply for and obtain a modified permit to cover the disposal of waste from these spaces. In the interim, wastewater from the shower building must be disposed of off site.

J. SIGNATORIES REQUIREMENT

1. All reports required by this permit and other requested information shall be signed as follows:
 - a. For a corporation -- by a principal executive officer of at least the level of vice-president;
 - b. For a partnership or sole proprietorship -- by a general partner or the proprietor, respectively;
 - c. By a duly authorized representative for any of the above. A person is a duly authorized representative only if:
 1. The authorization is made in writing by one of the described principals;
 2. The authorization specifies either an individual or position having responsibility for the overall operation of the regulated facility or activity; and
 3. The written authorization is submitted to the administrator.
2. If an authorization is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to the administrator prior to or together with any reports or information, to be signed by an authorized representative.

3. Any person signing a report or other requested information shall make the following certification:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

STATEMENT OF BASIS FOR A UIC PERMIT

I. General information.

A. Permit Number: UIC 03-298

B. Facilities Covered: The Arrowhead Lodge Septic System. Covers an new septic system to replace all existing septic systems which have failed. This large scale sanitary septic system will have a capacity of 6,000 gallons per day.

C. Class of Facility: 5E3 (Under Chapter 16)

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter 8 Yes

D. Chapter 12. No

B. Chapter 9 No

E. Chapter 13. No

C. Chapter 11. Yes

F. Chapter 16. Yes

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

NOT Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3. Note that sediment ponds, public water supplies, sewerage systems, and small wastewater systems are exempt from the requirements of Section 17. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Applicable. This is a new system which was required to obtain an individual UIC permit. A groundwater review has been completed in accordance with Section 17.

VI. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

VII. Applicant and Public Participation

- A. The applicant has been provided with a draft permit prior to the permit being issued.
- B. A Public Notice has been issued with a public notice period starting August 1, 2003 and ending on September 1, 2003 (30 day notice as required by Chapter 16.) This notice was published in the Sheridan Press on or before the start of the public comment period.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 5, Chapter 16, Wyoming Water Quality Rules and Regulations. This review was performed by Robert F. Lucht, P.E. and P.G., UIC Program Supervisor, and completed on July 28, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RFL/mad/3-0947-ltr

AS-BUILT PERMIT TO CONSTRUCT

New
Renewal
Modified

PERMIT NO. 03-299

DOUGLAS AND ALINEA COY SMALL WASTEWATER SYSTEM

This permit hereby authorizes the applicant:

Douglas and Alinea Coy
2222 Highway 116 N Box 714
Upton, WY 82730

to have constructed, installed or modified a septic system according to the procedures and conditions of the application numbers 03-299. The facility is located in the NE/4 of NE/4 & W/2 of Section 8 of T48N R64W in the county of Weston, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (DEQ/WQD), upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee has constructed and shall operate the permitted facility in accordance with the statements, presentations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

AUTHORIZED BY:



John V. Corra, Director
Department of Environmental Quality

7/31/03

Date of Issuance

JDL/07/28/03/bv/3-0813.ltr

Enclosures: Statement of Basis

STATEMENT OF BASIS

General information.

A. Permit Number: 03-299

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. Yes

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

Yes

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

Not Applicable (N/A)

B. Briefly state the basis for the deviation.

N/A

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

N/A

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of Section VI. from the Statement of Basis.)

N/A

VI. N/A

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, Northeast District DEQ/WQD-Senior Environmental Analyst, and completed on July 28, 2003. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.



The State
of Wyoming

Department of Environmental Quality

Dave Freudenthal, Governor

3030 Energy Lane • Suite 200 • Casper, Wyoming 82604



SOLID & HAZARDOUS WASTE DIVISION
(307) 473-3450
Fax: (307) 473-3458

AIR QUALITY DIVISION
(307) 473-3455
Fax: (307) 473-3458

WATER QUALITY DIVISION
(307) 473-3465
Fax: (307) 473-3458

ABANDONED MINES
(307) 473-3460
Fax: (307) 473-3458

NOTIFICATION OF COVERAGE

April 12, 2004

W. N. McMurry
816 Circle Drive
Casper, WY 82601

RE: McMurry Waterline Extension, Permit # 03-300

Dear Mr. McMurry:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a water distribution system in accordance with Chapter 3 and Chapter 12 Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit.

If you have any questions please contact Dennis Lamb at 3030 Energy Lane, Casper, WY, 82604, (307) 473-3452. Thank you.

Sincerely,

Dennis Lamb
NE District Supervisor
DEQ/WQD

cc: IPS, Cheyenne