


Memorandum from Lou Harmon

Southeast District Engineer, Wyoming Department of Environmental Quality/Water Quality Division
Phone (307) 777-7088, Fax (307) 777-5973, email: lharmo@missc.state.wy.us

TO: Permit File

SUBJECT: Permitting Action 04-152, Notice of Intent of Hydrostatic Test Water Discharge as allowed by Statewide Permit 97-201

1. On May 14, 2004, a copy of the signed Landowner's Consent for land application was received by the Water Quality Division. This satisfied the requirements of a review sent to Kinder Morgan on April 14, 2004.
2. On May 14, 2004 a verbal approval was given to Kinder Morgan to proceed with the land application of hydrostatic test water to lands owned by Elmer Peterson in accordance with the Notice of Intent as per Statewide Permit 97-201 dated 14 April 2004.





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

250 Lincoln Street • Lander, Wyoming 82520 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

May 19, 2004

Mr. Alan Bybee
Teton Valley Development Company, LLC
P. O. Box 3393
Jackson, WY 83001

RE: TVDC Townhomes PUD, Permit Number 04-153
Teton County

Dear Mr. Bybee:

The above application for coverage under General Permit to Construct sanitary sewer collector lines and manholes, and a short section of water main in accordance with Chapter 3, Section 7, Chapter 11, Part D and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Jeff Hermansky
Northwest District Supervising Engineer
Water Quality Division

xc: IPS, Cheyenne

RECEIVED

MAY 21 2004

WATER QUALITY DIVISION
WYOMING



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

250 Lincoln Street • Lander, Wyoming 82520 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

June 3, 2004

Bryan Parham, President
Royal Construction, Inc.
1311 Lane 13
Powell, WY 82435

RE: Whispering Pines Subdivision, Permit Number 04-154
Park County

Dear Mr. Parham:

The above application for coverage under General Permit to Construct 8-inch Class 52 ductile iron pipe water mains and to construct 15 and 8-inch SDR 35 PVC sewer mains in accordance with Chapter 3, Section 7, Chapter 11, Section 9, and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark D. Baron
Environmental Senior Analyst
Water Quality Division

xc: IPS, Cheyenne

encl: General Permits for Public Water Distribution System and Sewage Collection System



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

April 20, 2004

Mr. Herman Noe, Manager of Engineering
Cheyenne Board of Public Utilities
P.O. Box 1469
Cheyenne WY 82003-1469

RE: The Victorians, Application No.04-156, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as, SE 1/4 Section 22 T14N R66W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All service connections will be protected by the appropriate backflow device as required by Chapter 12, Section 14(i) of the Water Quality Division Rules and Regulations. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 11, 2006.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 04-156 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/bb/4-0410.ltr

cc: IPS, Cheyenne
Lawrence R. Gallagher, Summit Engineering, LLC
5907 Townsend Place
Cheyenne WY 82009



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Dave Freudenthal, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

April 19, 2004

Mr. & Mrs. Ed & Dian Blais
P.O. Box 1275
12 Moon Ct
Sundance, WY 82729

RE: Small WW Facility For Ed & Dian Blais, Permit # 04-157

Dear Ed & Dian:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of a small wastewater septic system in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. All construction, installation, or modification allowed by this permit shall be completed by April 1, 2005.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457.

Thank you.

Sincerely,


Rick J. Estes, P.E.

WDEQ/WQ NE District Senior Environmental Analyst

cc: IPS, Cheyenne

LA Helms, Lone Wolf Contracting, 114 N. Summner Ave, Newcastle, WY 82701



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Steve Freudenthal, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

May 24, 2004

Mr. Leon Brady
c/o Jim's Water Service-Pipeline Division
3421 Garman Rd.
Gillette, WY 82716

RE: 3548 Coulter Lane Shop Septic System, Permit # 04-158

Dear Leon:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of small wastewater septic in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. Our review of the information and as-constructed plan submitted to this office indicates that the application meets DEQ/WQD regulations and the enclosed As-Built Permit To Construct is hereby issued. Please be advised that the system must be operated in accordance with the statements, representations and procedures presented in the application and all supporting documentation as well as the terms and conditions of the permit. You are urged to be familiar with all aspects of the permit application, permit and permit conditions.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457. Thank you.

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQ NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Larry Baccari, PE, 1949 Sugarland Dr, Ste 134, Sheridan, WY 82801
Keith Bowar, Campbell County Inspector w/permit application



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

August 25, 2004

Mr. Michael David Stroud
Branch Manager-SGS
2804 Hackthorne Lane
Gillette, WY 82716

RE: SGS Leachfield Improvements, Permit # 04-159

Dear Michael:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of small wastewater septic in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. Our review of the information and **as-constructed plan** submitted to this office indicates that the application meets DEQ/WQD regulations and the enclosed As-Built Permit To Construct is hereby issued. Please be advised that the system must be operated in accordance with the statements, representations and procedures presented in the application and all supporting documentation as well as the terms and conditions of the permit. You are urged to be familiar with all aspects of the permit application, permit and permit conditions.

If you have any questions please contact me at 1866 S. Sheridan Avenue, Sheridan, WY, 82801, (307) 673-9337. Thank you.

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQ NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Steve Bruce, Bruce Engineering, 118 S. Gillette Ave., Gillette, WY 82716

Page 1 of 1





The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Dave Freudenthal, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

May 4, 2004

Mr. Mitch Aars
108 E. Warlow Dr. #96
Gillette, WY 82716

RE: Mitch & Shellie Aars Single Family WW System, Permit # 04-160

Dear Mitch:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of a small wastewater septic system in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. **A minimum of two (2) photos of the system installation shall accompany the Certificate of Completion submitted to this office.** All construction, installation, or modification allowed by this permit shall be completed by May 1, 2005.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457. Thank you.

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQ NE District Senior Environmental Analyst

cc: ²IPS, Cheyenne
Vince Waters, NEWSCO, 647 McKean Rd, Moorcroft, WY 82721
Town of Pine Haven, 24 Waters Drive, Pine Haven, WY 82721



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Dave Freudenthal, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

May 25, 2004

Mr. James A. Miller
Mayor
City of Sundance.
P.O. Box 541
Sundance, WY 82729

RE: City of Sundance Hwy 585 Waterline Extension, PWS# 5600055 Permit # 04-161

Dear Jim:

The above application for coverage under General Permit to Construct, Install, Modify or Operate an extension to the City of Sundance water distribution system in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. All construction, installation, or modification allowed by this Notice of Coverage shall be completed by June 1, 2005.

If you have any questions please contact me.

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQD NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Kenneth Rathbun, PE, Bearlodge LTD, Inc, Box 130, Sundance, WY 82729



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 28, 2004

Mayor Dan Blakeman
Town of Pine Haven
24 Waters Drive
Pine Haven, WY 82721

RE: Aspen Lane & Elm Street Waterline Extension, PWS# 5600191 Permit # 04-162

Dear Dan:

The above application for coverage under General Permit to Construct, Install, Modify or Operate an extension to the Town of Pine Haven water distribution system in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. All construction, installation, or modification allowed by this Notice of Coverage shall be completed by August 31, 2005.

If you have any questions please contact me.

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQD NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Corky Stetson, PE, Stetson Engineering, Inc, P. O. Box 457, Gillette, WY 82717





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

250 Lincoln Street • Lander, Wyoming 82520 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

April 23, 2004

Glen Michial Richert
259 Hwy.20 South
Thermopolis, WY 82443

RE: Richert Septic Tank / Leach Field, Permit Number #04-163
Hot Springs County

Dear Mr. Richert:

The above application for coverage under General Permit to Construct, a septic tank /leach field to serve a three (3) bedroom mobile home in accordance with Chapter 3, Section 7 and Chapter 11, Part D of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Jeff Hermansky
Northwest District Supervising Engineer
Water Quality Division

cc: IPS, Cheyenne
Hot Springs County

encl: General Permit to Construct, etc.



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

April 27, 2004

Tom McIntosh
2043 Chestnut
Casper, Wyoming 82601

RE: McIntosh Residential Septic System,
Location: SW 1/4, Section 10, T27N, R69W,

Application No. **04-164**
Platte County

Dear Mr. McIntosh:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific conditions also apply:

1. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.
2. Polyethylene Septic Tank Installation Requirements - To ensure structural integrity, the **manufacturer's instructions** regarding bedding the tank and filling the tank with water during burial **must be followed during installation**. Additionally, immediately after clean-outs, the tank must be refilled with water according to the manufacturer's instructions to maintain structural integrity.
3. Minimum Leachfield Size - The minimum leachfield size shall be **at least 19 "Infiltrator" Units**. Your calculation of 18 units was slightly under sized.

4. Leachfield Bed Layout - The header pipe arrangement at the head of the leachfield is very important to ensure relatively equal flow distribution to each of the legs of the leach bed. The header pipe arrangement shown on your site plan is one which will not provide equal distribution to each leg of your leach bed (see the attachment provided). Therefore it is recommended that you either use a distribution box for a three(3) legged bed, or a multiple tee arrangement as shown for a four(4) legged bed at the bottom of the attachment. A four legged bed would be 20 units in four legs, each 5 units long; which would meet the requirements of item #3 above.

The approval granted under this Notification Of Coverage and the General Permit shall expire on April 30, 2006. Please reference Application Number 04-164 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,



Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/pf/4-0449-ltr

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion
Equal Flow Distribution Header Pipe Examples

cc: IPS, Cheyenne
Platte County Planner, Marlin Johnson, P.O. Box 728, Wheatland, Wyoming 82201



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

April 22, 2004

Mr. Daniel Overzet, PE, NPS Intermountain Support Office - Denver
Post Office 25287
Denver CO 80225-0287

RE: Fort Laramie National Historic Site Maintenance Bldg SMWW
Location: NE 1/4, SE 1/4, Section 29 T26N R64W

Application No. 04-165
County Goshen

Dear Daniel:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

The approval granted under this Notification Of Coverage and the General Permit shall expire on April 22, 2009. Please reference Application Number 04-165 in any future correspondence.

If you have any questions, please contact me at (307) 777-7088

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/pf/4-0421-ltr

cc: IPS, Cheyenne
Goshen County Planner, 1833 East D, Torrington, WY 82240

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion



The State
of Wyoming

Department of Environmental Quality



Dave Freudenthal, Governor

3030 Energy Lane • Suite 200 • Casper, Wyoming 82604

SOLID & HAZARDOUS WASTE DIVISION
(307) 473-3450
Fax: (307) 473-3458

AIR QUALITY DIVISION
(307) 473-3455
Fax: (307) 473-3458

WATER QUALITY DIVISION
(307) 473-3465
Fax: (307) 473-3458

ABANDONED MINES
(307) 473-3460
Fax: (307) 473-3458

NOTIFICATION OF COVERAGE

April 22, 2004

Hal H. Hutchinson, PE
City Engineer
City of Casper
200 N. David
Casper, WY 82601

RE: 2004 Miscellaneous Street Repair and Water Main Replacement Project, Application No. 04-166

Dear Mr. Hutchinson:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V. Section O. of the general permit.

The following additional requirements are conditions of this coverage:

1. All commercial and industrial customers located within water main replacement areas which are not already in compliance with cross connection requirements will be inspected. An appropriate compliance schedule, not to exceed 30 months, will be established dependent upon the degree of hazard and the cost of the retrofit installation. The City of Casper will be responsible to insure compliance.
2. Residential customers within water main replacement areas will be on an appropriate schedule to install dual check valves, expansion tanks, and pressure relief valves. This time frame shall not exceed 30 months, and follow up will take place to insure compliance.

Hal H. Hutchinson

April 22, 2004


Page 2 of 2

3. The City of Casper Uniform Plumbing Code will be amended to require dual check valves and accompanying expansion tanks/pressure relief valves for new construction.

4. Within six months, the City of Casper will revise its Cross Connection Control Ordinance to require dual check valves for all residential services.

If you have any questions, please contact Dennis Lamb or myself at 307-473-3465.

Sincerely,



Dennis Lamb

Northeast District Supervisor

Water Quality Division

cc: IPS, Cheyenne



The State
of Wyoming

Department of Environmental Quality

Dave Freudenthal, Governor

3030 Energy Lane • Suite 200 • Casper, Wyoming 82604



SOLID & HAZARDOUS WASTE DIVISION
(307) 473-3450
Fax: (307) 473-3458

AIR QUALITY DIVISION
(307) 473-3455
Fax: (307) 473-3458

WATER QUALITY DIVISION
(307) 473-3465
Fax: (307) 473-3458

ABANDONED MINES
(307) 473-3460
Fax: (307) 473-3458

NOTIFICATION OF COVERAGE

April 22, 2004

Lisa Norton
Yates Petroleum
105 South 4th Street
Artesia, NM 88210

RE: Yates Petroleum Burger Draw CBM Water Treatment Pilot Project, Permit # 04-167

Dear Ms. Norton:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Pilot Plant in accordance with Section 5, Chapter 11, of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit.

If you have any questions please contact Dennis Lamb at 3030 Energy Lane, Casper, WY, 82604, (307) 473-3452. Thank you.

Sincerely,

Dennis Lamb
NE District Supervisor
DEQ/WQD

cc: IPS, Cheyenne

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
"AS-BUILT" PERMIT TO CONSTRUCT

PERMIT NO. 04-168RR

Salt River Cove Subdivision - Lincoln County
New Water System No Public Water System Number Assigned

This permit hereby authorizes the applicant:

Robert Meikle, Owner
1462 Bluejay Place
Eagle, ID 83615

to construct a public water supply distribution system to be connected to the existing Trial Ridge Subdivision water system consisting of 16 water service connections, 4100 linear feet (LF) of 6-inch PVC water and 1440 LF of 8-inch PVC water main according to the procedures and conditions of the application number 04-168RR. The facility is located in SW 1/4 Section 10, T36N, R119W in the county of Lincoln, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by July 27, 2007.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadow View Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
- a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 4 A copy of the written agreement between David Spurlock owner of the Trail Ridge water system (WDEQ/WQD Permit 03-172) and Robert Meikle owner of the Salt River water system must be submitted before connecting the systems together. The agreement must indicate that the Trail Ridge Subdivision water system will supply water to the Salt River Cove Subdivision water system.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John M. Corra
Director
Department of Environmental Quality

7/21/05
Date of Issuance

MDB/mdb/bb/5-0838.ltr

STATEMENT OF BASIS

1. Permit Number: 04-168RR
2. Application reviewed for compliance with the following regulations:
Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?
Yes
4. If a Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Not Required
5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Mark D. Baron, mbaron@state.wy.us, Environmental Senior Analyst and completed on July 27, 2005. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/5-0838.ltr



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Dave Freudenthal, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

May 4, 2004

Mr. Timothy W. Crozier
17145 US Hwy 14
Moorcroft, WY 82721

RE: Cozier Home Septic System, Permit # 04-169

Dear Timothy:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of a small wastewater septic system in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. **A minimum of two (2) photos of the system installation shall accompany the Certificate of Completion submitted to this office.** All construction, installation, or modification allowed by this permit shall be completed by May 1, 2005.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457. Thank you.

Sincerely,

Rick J. Estes, P.E.

WDEQ/WQ NE District Senior Environmental Analyst

cc: *IPS, Cheyenne

Randy Gantz, Gantz Backhoe Service, Inc., Box 280, Hulett, WY 82720



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 11, 2004

Mr. Donald Phillips, Mayor
Town of Burns
102 East Main Street
Burns, WY 82053

RE: Town of Burns - Main Street Reconstruction, Application No.04-170, Laramie County

Dear Mr. Phillips:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as 750 ft of water main replacement, 1 new fire hydrant, 4 relocated fire hydrants and 2285 of sewer main replacement, SE 1/4 Section 7 T14N R62W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All service connections will be protected by the appropriate backflow device as required by Chapter 12, Section 14(i) of the Water Quality Division Rules and Regulations. The existing cross between the water main in 1st Street that is to be abandoned and the existing water main in Main Street shall be removed and the abandoned water lines plugged or removed from the ground. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 11, 2006.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 04-170 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division


LBH/bb/4-0484.ltr

cc: IPS, Cheyenne
Scott D. Larson, Benchmark Engineers, P.C.
1920 Thomes Ave., Suite 620
Cheyenne WY 82001





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 14, 2004

Mr. Herman Noe, Manager of Engineering
Cheyenne Board of Public Utilities
P.O. Box 1469
Cheyenne WY 82003-1469

RE: Cheyenne South Park 2nd Filing Water and Sewer Extensions, Application No.04-171, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as water and sewer line extensions to serve 127 residential units, SE 1/4 Section 6 T13N R66W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All service connections will be protected by the appropriate backflow device as required by Chapter 12, Section 14(i) of the Water Quality Division Rules and Regulations. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 11, 2006.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 04-171 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/bb/4-0489.ltr

cc: IPS, Cheyenne
Lawrence R. Gallagher, Summit Engineering, LLC
5907 Townsend Place
Cheyenne WY 82009





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

May 3, 2004

Bruce Hepp
City of Buffalo-Mayor
46 N. Main
Buffalo, WY 82834

RE: Buffalo Water Treatment Plant-Pilot Plant, Permit # 04-172

Dear Bruce:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Pilot Plant to the Buffalo Water Treatment Plant in accordance with Section 5, Chapter 12, of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. All construction, installation, or modification allowed by this Notice of Coverage shall be completed by June 15, 2004.

If you have any questions please contact me at 674-6427.

Thank you.

Sincerely,

Rick J. Estes, PE
DEQ/WQD NE District Senior Environmental Analyst

cc: ~~IPS~~; Cheyenne

Darwin Dyck, PE, RTW Inc., 1576 Sherman St. Suite 100, Denver, CO 80203



The State
of Wyoming

Department of Environmental Quality



Dave Freudenthal, Governor

3030 Energy Lane • Suite 200 • Casper, Wyoming 82604

SOLID & HAZARDOUS WASTE DIVISION
(307) 473-3450
Fax: (307) 473-3458

AIR QUALITY DIVISION
(307) 473-3455
Fax: (307) 473-3458

WATER QUALITY DIVISION
(307) 473-3465
Fax: (307) 473-3458

ABANDONED MINES
(307) 473-3460
Fax: (307) 473-3458

NOTIFICATION OF COVERAGE

April 29, 2004

Phil Johnson
7600 Poison Spider
Casper, WY 82604

RE: Phil Johnson Water Line Project, Permit # 04-173

Dear Mr. Johnson:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a water distribution system in accordance with Chapter 3 and Chapter 12 Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit.

If you have any questions please contact Dennis Lamb at 3030 Energy Lane, Casper, WY, 82604, (307) 473-3452. Thank you.

Sincerely,

Dennis Lamb
NE District Supervisor
DEQ/WQD

cc: IPS, Cheyenne

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 04-174

Riverton - Solid Waste District Baler Facility - Water and Sewer Extensions
PWS # WY5600047

This permit hereby authorizes the applicant:

Don Connell, Superintendent of Operations
Fremont County Solid Waste Disposal District
P.O. Box 1400
Lander, WY 82520

to construct water and sewer main extensions consisting of 1747 linear feet (LF) of 8-inch water main and 1337 LF of 2-inch force main, according to the procedures and conditions of the application number 04-174. The facility is located at SW1/4 Section 25, T1N, R4E in the county of Fremont, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by July 20, 2006.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Northwest District Engineer, 250 Lincoln Street, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
- a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division

7/26/04
Date of Issuance


John V. Corra
Director
Department of Environmental Quality

MDB/pf/4-0755-ltr

STATEMENT OF BASIS

1. Permit Number: 04-174R
2. Application reviewed for compliance with the following regulations:
Chapters 3, 11 and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?
Yes.
3. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Not Required.
4. Documentation of Statement of Basis: The archives file for this permit include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Mark D. Baron, mbaron@state.wy.us, Environmental Senior Analyst and completed on July 20, 2004. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

MDB

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 04-175

Bridger Valley Water Treatment Plant Storage Tank
PWS: 5600757

This permit hereby authorizes the applicant:

Bridger Valley Joint Powers Board
P.O. Box 615
Mountain View, WY 82939

to construct, install or modify a new 500,000 gallon metal water storage tank according to the procedures and conditions of the application number 04-175. The facility is located in SE1/4 Section 27, T15N, R115W in the county of Uinta, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by September 30, 2006.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality/ Water Quality Division, SW District, 250 Lincoln Street, Lander, WY 82520, 307-332-3144, fax 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

8/12/04
Date of Issuance

DHC/pf/4-0832.ltr

STATEMENT OF BASIS

1. Permit Number: 04-175
2. Application reviewed for compliance with the following regulations:
Chapter 12 of the Wyoming Water Quality Rules and Regulations
3. Does the permit comply with all applicable regulations identified above?

Yes

Select appropriate reason; delete others, if not used, delete all

Public water supplies are exempted from review by Chapter 3, Section 17.

4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3.

Not Required

5. Documentation of Statement of Basis: The archives file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle H. Conklin, dconkl@state.wy.us, SW District Engineering Supervisor and completed on July 7, 2004. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

April 30, 2004

Guy N. Kibbe
P.O. Box 1344
Saratoga, Wyoming 82331

RE: Guy Kibbe Residential Septic System,
Location: NE1/4 NW1/4, Section 23, T17N, R84W,

Application No. **04-176**
Carbon County

Dear Mr. Kibbe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from each compartment of the tank must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on April 30, 2006. Please reference Application Number **04-176** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/PF/4-0460-LTR

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Carbon County Planner



The State of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002

ADMIN/OUTREACH (307)777-7758 FAX 777-3610	ABANDONED MINES (307)777-6145 FAX 777-6462	AIR QUALITY (307)777-7391 FAX 777-5616	INDUSTRIAL SITING (307)777-7369 FAX 777-6937	LAND QUALITY (307)777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307)777-7752 FAX 777-5973	WATER QUALITY (307)777-7781 FAX 777-5973
---	--	--	--	---	---	--

NOTIFICATION OF COVERAGE

April 30, 2004

Robert Weber
P.O. Box 213
Sinclair, Wyoming 82334

RE: Robert Weber Septic System, Application No. **04-177**
Location: NW1/4 NW1/4, Section 13, T21N, R88W, Carbon County

Dear Mr. Weber:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific conditions also apply:

1. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.
2. Septic Tank / Leachfield Separation - There shall be at least ten(10) feet of solid pipe between the septic tank outlet and the beginning of the leachfield chambers.

The approval granted under this Notification Of Coverage and the General Permit shall expire on April 30, 2006. Please reference Application Number 04-177 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,



Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/pf/4-0461-ltr

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Carbon County Planner



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

September 28, 2007

Alan Bybee
SSDA, LLC
P.O. Box 3393
Jackson, WY 83001

RE: Snake River Mobile Home Park Water Treatment System, Permit Number: 04-179
Withdrawn, Teton County

Dear Mr. Bybee:

Our database indicated that a permit to construct was never issued for the Snake River Mobile Home Park water treatment system project. On September 25, 2007, I met with you for a site visit of your well and well house that serves the mobile home park. The well is chlorinated with a Sentry pellet chlorinator. You reported that the well is 450 feet deep and a 7-1/2 horsepower submersible pump is set at the 300-foot depth. The pump is equipped with a variable frequency drive.

The water treatment system granular activated carbon (GAC) system was never installed and DEQ understands that there are no plans to install the GAC system. Thus, permit application 04-179 is being withdrawn. As a reminder, the construction, installation, or modification of a public water supply system without a 'Permit to Construct' is a violation of Wyoming State Statute 35-11-301 and may lead to the imposition of penalties.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

James Brough, P.E.
Northwest District Engineer
Water Quality Division

xc: Steve Wonacott, Advanced Engineering, 2085 South Park Ranch Road, Jackson, WY 83001
IPS

F:\DIVISION\WQD\W&WW Section\2004 Permits & Reviews\04-179.withdrawn.jsb.doc



**DEPARTMENT OF ENVIRONMENTAL QUALITY
STATE OF WYOMING
UNDERGROUND INJECTION CONTROL PERMIT
AUTHORIZATION TO DISCHARGE INTO UNDERGROUND RECEIVERS
ISSUED UNDER CHAPTER 16, WATER QUALITY RULES AND REGULATIONS**

(X) New
() Modified


Permit Number: UIC 04-180RR
Subclass Number: 5E3

In compliance with the Wyoming Environmental Quality Act (W.S. 35-11-101 through 1104, specifically 301(a)(i) through (iv), Laws 1973, Ch. 250, Section 1) and Water Quality Rules and Regulations, Chapter 3 (2000), and Chapter 16 (1998),

Applicant: Attn: Michael J. Brennan
Granite Creek Partnership, LLC
P.O. Box 68
Jackson, WY 83001

is authorized to operate the Granite Ranch Wastewater Facility in the NE1/4, Section 19, Township 42 North, Range 116 West, of the 6th Principal Meridian; according to the procedures and conditions of application # 04-180RR and other conditions of this permit.


This permit shall become effective on date of issuance.



John Wagner, Administrator
Water Quality Division
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002
Phone: (307) 777-7781

5/2/05

Date



John V. Corra, Director
Department of Environmental Quality
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002

5/2/05

Date

TABLE OF CONTENTS

A. DISCHARGE ZONE AND AREA OF REVIEW2

B. GROUNDWATER CLASSIFICATION2

C. AUTHORIZED OPERATIONS2

D. ENVIRONMENTAL MONITORING PROGRAM FOR GROUND WATERS OF THE STATE3

E. REQUIREMENTS FOR MONITORING THE DISCHARGE4

F. RECORDS AND REPORTS4

G. GENERAL PERMIT CONDITIONS5

H. DUTIES OF THE PERMITTEE6

I. SPECIAL MEASURES THE DIRECTOR FINDS NECESSARY:7

J. SIGNATORIES REQUIREMENT:7

A. DISCHARGE ZONE AND AREA OF REVIEW

1. Discharge Zone: This injection facility (sanitary leachfield) is not authorized to inject into any aquifer which may be found during the well monitoring development.

2. Area of Review

The facility authorized by this permit is located in:

Township 42 North, Range 116 West, 6th Principal Meridian
Section 19: NE ¼

The Area of Review around this facility is legally described as:

Township 42 North, Range 116 West, 6th Principal Meridian
Section 19: NE ¼

B. GROUNDWATER CLASSIFICATION

1. The groundwater in the alluvial aquifer along the Snake River is classified as class I (Domestic) under Chapter 8 of Wyoming Water Quality Rules and Regulations (March 11, 1993). This classification was made because: The groundwater in this formation is currently being used for domestic purposes at several points of withdrawal.
2. Ground water of class I shall not be degraded so as to make it unusable as a source of water for this purpose. Any parameters, which do not meet the class of use standard, shall not be degraded whatsoever.

C. AUTHORIZED OPERATIONS

The Granite Creek Ranch is authorized to inject 89 barrels per day, (3,750 gallons per day) of wastewater through a septic system. The wastewater is described as domestic sewage effluent from a single-family residential compound consisting of

22 buildings. The liquid shall flow from the septic tank to a pump tank and then distributed through pressure to a chamber leach field. A flow distribution valve will distribute the liquid waste on an alternating basis through the leach chamber laterals.

2. This permit does not allow for the injection of any hazardous waste as defined by 40 CFR 261. Injection of any substance defined as **hazardous waste**, whether hazardous by listing or by characteristic is a violation of this permit.
3. In the event that any septic system covered by this permit is converted at any time to any other use, additional capacity may be required for the septic system. Any such conversion shall be reported to the DEQ in the form of a modified permit application showing that all required capacity exists for the newly converted system.

D. ENVIRONMENTAL MONITORING PROGRAM FOR GROUNDWATERS OF THE STATE

1. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
2. The Granite Creek Ranch shall prepare records of all monitoring information to be retained for a period of at least 3 years after closure of the facility.
3. Records of monitoring information shall include:
 - a. The date, exact place, and time of sampling or measurements;
 - b. The name(s) of individual(s) who performed the sampling or measurements;
 - c. The date(s) analyses were performed;
 - d. Names of individuals who performed the analyses;
 - e. The analytical techniques or methods used; and
 - f. The results of such analyses.
4. The groundwater in the receiving formation shall be sampled and the following parameters analyzed according to the following schedule and reported annually by December 31 of each year. **In addition, fecal coliforms must be reported for the water supply; fecal coliform must be absent from drinking water.**

WELL NAME OR NUMBER	SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT (UCL)*
One up gradient monitoring well (north) and two down gradient monitor wells (southwest and southeast)	Twice per year during the second and third quarters (e.g., June and August)	EPA Method 300.0	Chloride	250
		EPA Method 350.3	Ammonia as N	.500
		EPA Method 353.2	Nitrate as N	10.0
		Any method	Water Elevation	No limit

*All chemical concentrations in this permit are expressed in mg/l unless otherwise noted.

5. After the first two years of operation, the Water Quality Division may, without reissuing this permit, waive further monitoring of any parameter from the above list or may require additional monitoring based on new information about the nature of the waste. The Water Quality Division may also, after the first two years of operation, approve a more or less stringent monitoring schedule.

E. REQUIREMENTS FOR MONITORING THE DISCHARGE

Granite Creek Ranch shall monitor the quality of the effluent from the dosing tank at the point where the flow leaves the tank on the following schedule. The following parameters shall be analyzed by the listed methods and reported annually:

SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT (UCL) *
Annually in the third quarter	EPA Method 325.2	Chlorides	No Limit
	EPA Method 353.2	Nitrate as N	No Limit
	EPA Method 350.3	Ammonia as N	No Limit

*All chemical concentrations in this permit are expressed in mg/l unless otherwise noted.

After the first two years of operation, the Water Quality Division may, without reissuing this permit, waive further monitoring of any parameter from the above list or may require additional monitoring based on new information about the nature of the waste. The Water Quality Division may also, after the first two years of operation, approve a more or less stringent monitoring schedule.

F. RECORDS AND REPORTS

1. Granite Creek Ranch shall retain copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the report or application.
2. Granite Creek Ranch shall give notice to the administrator as soon as possible of any planned physical alterations or additions, other than authorized operation and maintenance, to the permitted facility and receive authorization prior to implementing the proposed alteration or addition.
3. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 30 days following each schedule date.
4. Granite Creek Ranch shall report any noncompliance which may endanger health or the environment, orally within 24 hours from the time the operator becomes aware of the circumstances. The report should include:
 - a. Any monitoring or other information which indicates that any contaminant may cause an endangerment to a usable groundwater of the state.
 - b. Any noncompliance with a permit condition or malfunction of the discharge (injection) system which may cause fluid migration into or between usable groundwaters of the state.
 - c. A written submission shall be provided within 5 days of the time the operator becomes aware of the circumstances. This written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected; the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
5. Granite Creek Ranch shall report all instances of noncompliance not reported otherwise, at the time monitoring reports are submitted; such reports shall contain the information listed in item 4 above.
6. When Granite Creek Ranch becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the administrator, it shall promptly submit such facts or information.

7. Granite Creek Ranch shall retain all records concerning the nature and composition of injected fluids until 5 years after completion of any specified plugging and abandonment procedures. The administrator may require the owner/operator to deliver the records to the administrator at the conclusion of the retention period.
8. A subsurface discharge (injection) facility may not commence subsurface discharge (injection) until, following public notice and an opportunity for hearing, an underground injection control permit has been issued by the department for the proposed operation.
9. The annual report of operations for this facility shall be submitted on forms provided by the department and shall include the following information:
 - a. Any permit exceedances within the previous year.
 - b. The analytical results for sampling for the injected water and any ground water sampling results required under Section D or E of this permit.
 - c. Annual reports are due in the Lander office of the Water Quality Division no later than December 31 of each year.
10. A comprehensive report for an aborted or curtailed operation authorized by this permit shall be submitted to the administrator within 30 days of complete termination of the injection (discharge) or associated activity, in lieu of an annual report.

G. GENERAL PERMIT CONDITIONS

1. After notice and opportunity for a hearing, a permit may be modified, suspended or revoked in whole or part during its term for cause which includes, but is not limited to, any of the following:
 - a. Violation of the permit;
 - b. Obtaining a permit by misrepresentation or failure of the discharge well or system.
2. Each permit is reviewed at least once every 5 years, and may be reviewed more frequently.
3. A permit may be modified at any time as may be required, including for conformity with changes in regulations or standards which occur after the permit is issued. A permit may be modified in whole or part in order to apply more, or less, stringent standards; or prohibitions for a toxic or other substance present in Granite Creek Ranch's discharge, as may be ordered by the council. This permit can be terminated by authority of the administrator for one or more permit violations.
4. Public notice of the permit review and request for public comment will be made every 10 years by the administrator.
5. Any permit noncompliance constitutes a violation of the permit and is grounds for enforcement action, permit termination, revocation, or modification.
6. The filing of a request by Granite Creek Ranch for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
7. The owner/operator of record (permittee) is always responsible for permit compliance. A permit holder cannot transfer his permit without approval of the department director, and no such transfer will be approved if the facility is not in compliance with the existing permit unless the proposed permittee agrees to bring the facility into compliance.
8. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve Granite Creek Ranch from any responsibilities, liabilities or penalties established pursuant to any applicable state law or regulation.
9. The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

10. The provisions of this permit are severable, and if any provision of the permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.
11. Pollution or waste, which migrates into an aquifer containing a usable ground water of the state is a violation of the permit.
12. This permit is for a term of ten years. If Granite Creek Ranch wishes to continue injection after the expiration date of this permit, they will be required to apply to the Administrator for, and obtain, a new permit.
13. Any modification which may result in a violation of a permit condition shall be reported to the administrator, and any modification that will result in a violation of a permit condition shall be reported to the administrator through the submission of a new or amended permit application.
14. The injection facility covered by this permit shall meet the construction requirements found in Section 10 of Chapter 16, and Part D of Chapter 11, Water Quality Rules and Regulations. The permittee shall submit notice of completion or construction to the administrator and allow for inspection of the facility upon completion of construction prior to commencing any injection activity.
15. The permittee shall notify the administrator seven (7) days prior to conversion of this facility to any other use, or final abandonment of the facility.
16. Injection shall not commence until all construction is complete.

H. DUTIES OF THE PERMITTEE

It is a duty of the permittee to:

1. Comply with all permit conditions;
2. Halt or reduce activity -- it shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce Granite Creek Ranch activity in order to maintain compliance with the permit conditions;
3. Take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with this permit; and
4. Furnish to the administrator within a reasonable time, any information which the administrator may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit; and furnish to the administrator, upon request, copies of records required to be kept by this permit.
5. Operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding and operator staffing and training, and adequate laboratory and process controls including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.
6. Allow the administrator, or an authorized representative of the administrator, upon the presentation of credentials, during normal working hours, to enter the premises where a regulated facility is located, or where records are kept under conditions of this permit, and inspect the discharge and related facilities, review and copy reports and records required by the permit, collect fluid samples for analysis, measure and record water levels, and perform any other function authorized by law or regulation.

I. SPECIAL MEASURES THE DIRECTOR FINDS NECESSARY:

In the event that sewage is found to be surfacing from the leachfield covered by this permit, this is a violation of this permit and shall be reported immediately as required by Section F of this permit. Granite Creek Ranch shall submit a modified application showing plans for a replacement leachfield (or other type of waste disposal method) within 90 days of determining that the primary leachfield has failed.

J. SIGNATORIES REQUIREMENT

1. All reports required by this permit and other requested information shall be signed as follows:
 - a. For a corporation -- by a principal executive officer of at least the level of vice-president;
 - b. For a partnership or sole proprietorship -- by a general partner or the proprietor, respectively;
 - c. For a municipality, state, federal or other public agency-- by either a principal executive officer or ranking elected official; or
 - d. By a duly authorized representative for any of the above, a person is a duly authorized representative only if:
 1. The authorization is made in writing by one of the described principals;
 2. The authorization specifies either an individual or position having responsibility for the overall operation of the regulated facility or activity; and
 3. The written authorization is submitted to the administrator.
2. If an authorization is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to the administrator prior to or together with any reports or information, to be signed by an authorized representative.
3. Any person signing a report or other requested information shall make the following certification:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

JSB/jd/5-0526

STATEMENT OF BASIS FOR A UIC PERMIT

I. General Information.

A. Permit Number: UIC #04-180RR

B. Facilities Covered: This permit covers a new septic system to serve the Granite Ranch single family residential compound consisting of 22 buildings. This system is located about one mile from Teton Village east of State Road 390. Maximum flow to the system is expected to be 3,750 gallons per day.

C. Class of Facility: 5E3 (under Chapter 16)

II. Application reviewed for compliance with the following regulations.
(Indicate yes or no for each section.)

A. Chapter 8 Yes

D. Chapter 12 No

B. Chapter 9 No

E. Chapter 13 No

C. Chapter 11 Yes

F. Chapter 16 Yes

III. Basis for issuing permit. (Indicate yes or no for each section)

A. Review of application package indicates proposed facility will be in compliance with applicable regulation identified in Section II.

YES

B. Permit based on deviation from applicable regulations in accordance with approved policy statement.

C.

YES: System uses "Infiltrators" and is designed in accordance with Policy 13.41.2

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.) NOT Applicable

V. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3. Note that sediment ponds, public water supplies, sewerage systems, and small wastewater systems are exempt from the requirements of Section 15. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

Applicable; The wastewater, 3,750 gallons per day, is generated by a single family residential compound. A groundwater review has been done in accordance with Chapter 3, Section 17. Groundwater monitoring and effluent monitoring is required by the permit.



VI. Documentation of Statement of Basis.

- A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.**

VII. Applicant and Public Participation

- A. The applicant has been provided with a draft permit prior to the permit being issued.**
- B. Public Notice has been issued with a public notice period starting March 21, 2005 and ending on April 20, 2005 (30 day notice as required by Chapter 16). This notice was published in the Jackson Hole News on or before the start of the public comment period.**

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 5, Chapter 16, Wyoming Water Quality Rules and Regulations. This review was performed by Jeff Hermansky, P.E., and completed on March 21, 2005. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

250 Lincoln Street • Lander, Wyoming 82520 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

October 13, 2004

Mr. Louis Koritnik, President
Pine Mountain Evaporation & Reclamation
1212 Eagle Way Rock Springs, WY 82901

RE: **Pine Mountain Evaporation and Reclamation WWF Pilot Plant, Permit Number 04-181R; SE 1/4 Section 33; T15N, R102W, Sweetwater County**

Dear Mr. Koritnik:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Pilot Plant for evaluating a process for treating produced water and coalbed methane produced water in accordance with Chapter 3, Section 7, Chapter 11, Section 5 and other applicable sections of Chapter 11 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

In carrying out the activities authorized by this permit, the permittee, owner and operator shall also comply with all of the following permit conditions:

- 1 of 6 This pilot plant is permitted to receive Resource Conservation and Recovery Act (RCRA) exempt oil and gas exploration and production produced water and coalbed methane produced water only. The maximum quantity of produced water to be received shall be limited to that required to achieve the maximum production of treated water from the permitted pilot plant.
- 2 of 6 All open-topped tanks shall be covered with netting or screen to prevent the entry of birds and/or

other wildlife. The netting or screen shall be constructed so it remains in place, intact and above the surface of the liquid in the tank during winds up to 100 mph and/or when weighted with snow, ice or rain.

3 of 6 No treated water from this pilot plant may be discharged to the surface, land applied or used for irrigation without first obtaining an NPDES permit, a separate permit for the land application, or a modification of this permit to allow land application of the treated water.

4 of 6 All wastes generated as a result of the operation of this pilot plant, including salts removed by the process, used filters, scale from the tubes, hydrocarbons, etc. must be contained and disposed of at a landfill or other approved disposal facility.

Any spills or releases of produced water, hydrocarbons, or chemicals must immediately be contained, reported and cleaned up as required by Chapter 4 of the Wyoming Water Quality Rules and Regulations.


5 of 6 Records must be kept continually and submitted to this Department annually, to allow the DEQ to evaluate the effectiveness of the permitted pilot plant. Required records shall include the following:

- a) A daily record of the loads of produced water received at the pilot plant, showing the load number, the source, the hauler, the driver's name, the date and time of delivery, the quantity of produced water received, and the name of the person logging in the information.
- b) Laboratory analyses of the levels of Total Dissolved Solids (TDS), Total Petroleum Hydrocarbons (TPH), Sodium, Chlorides and Sulfates for the first load of produced water from each source, and for each 5th load from each source thereafter. The load number from the daily load record shall be included in the sample name or number for each particular load.
- c) Laboratory analyses of the levels of TDS, TPH, and the Sodium Adsorption Ratio (SAR) of the treated water from the pilot plant. The water produced from the pilot plant shall be sampled and analyzed at least weekly for the first month of operation, and monthly thereafter to determine the suitability of the treated water for irrigation, discharge to the surface, land application or other uses.
- d) A daily record of the quantity of water produced by the pilot plant, measured in gallons, thousands of gallons or barrels.

6 of 6 Copies of all of the records as required in a) through d) above shall be submitted to this office annually, following the end of each calendar year. The copies must be submitted to the Department of Environmental Quality, SW District Engineering Supervisor, Water Quality Division, 250 Lincoln Street, Lander, WY 82520 within 60 days of the end of the calendar year that they represent.

If you have any questions regarding this permit or the conditions listed above, please contact me at 307-332-3144 or by e-mail at dconkl@state.wy.us.

Sincerely,

A handwritten signature in black ink, appearing to read "Doyle Conklin". The signature is written in a cursive style with a large initial "D".

Doyle Conklin
SW District Engineering Supv.
Water Quality Division

xc: IPS, Cheyenne
Sweetwater County Planning; 80 W. Flaming Gorge Way; Green River, WY 82935
encl: General Permit to Construct, Install, Modify or Operate a Pilot Plant



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Dave Freudenthal, Governor

AIR QUALITY (307) 672-6457 Fax (307) 674-6050	LAND QUALITY (307) 672-6488 Fax (307) 672-2213	WATER QUALITY (307) 672-6457 Fax (307) 674-6050
---	--	---

NOTIFICATION OF COVERAGE

May 7, 2004

Mr. Bruce Yates, PE
SAWS Manager
224 South Main
Sheridan, WY 82801

RECEIVED

MAY 11 2004

WATER QUALITY DIVISION
WYOMING

RE: Cornerstone Church Waterline, Permit # 04-182

Dear Bruce:

The above application for coverage under General Permit to Construct, Install, Modify or Operate an extension to the Sheridan Area Water System Distribution System in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. All construction, installation, or modification allowed by this Notice of Coverage shall be completed by December 31, 2005.

Thank you.

Sincerely,

Rick V. Estes, P.E.
DEQ/WQD NE District Senior Environmental Analyst

cc: IPS-Cheyenne
Jackie Flowers-Public Works Director, City of Sheridan
Moses Jacobs, PE, MJAE, 237 N. Main St. No. 2, Sheridan, WY 82801



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

July 1, 2004

Mr. Dale Holcomb
Box 506
Moorcroft, WY 82721

RE: Holcomb Residential **As-Built** Septic System, Permit # 04-183

Dear Dale:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of small wastewater septic in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. Our review of the information and as-constructed plan submitted to this office indicates that the application meets WDEQ/WQD regulations and this As-Built Notice of Coverage is hereby issued. Please be advised that the system must be operated in accordance with the statements, representations and procedures presented in the application and all supporting documentation as well as the terms and conditions of the permit. You are urged to be familiar with all aspects of the permit application, permit and permit conditions.

If you have any questions please contact me at 1866 S. Sheridan Avenue, Sheridan, WY, 82801, (307) 673-9337. Thank you.

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQ NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Dan Swaney, Heritage Homes, 518 N. US Hwy 14-16 Suite D, Gillette, WY 82716





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

May 7, 2004

Mr. Greg S. Lucas
P.O. Box 3227
Gillette, WY 82717

RE: Paramount Construction Office & Shop Septic System, Permit # 04-184

Dear Greg:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of a small commercial wastewater septic system in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. **A minimum of two (2) photos of the system installation shall accompany the Certificate of Completion submitted to this office.** All construction, installation, or modification allowed by this permit shall be completed by May 1, 2005.

If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457. Thank you.

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQ NE District Senior Environmental Analyst

cc: ~~IPS~~ Cheyenne

Steven P. Goodrich, PE, Stetson Engineering Inc., PO Box 457, Gillette, WY 82717
Keith Bowar, Campbell County Inspector

**DEPARTMENT OF ENVIRONMENTAL QUALITY
STATE OF WYOMING
UNDERGROUND INJECTION CONTROL PERMIT
AUTHORIZATION TO DISCHARGE INTO UNDERGROUND RECEIVERS
ISSUED UNDER CHAPTER 16, WATER QUALITY RULES AND REGULATIONS**

(X) New
() Modified

Permit Number: UIC 04-185
Subclass Number: 5E3

In compliance with the Wyoming Environmental Quality Act (W.S. 35-11-101 through 1104, specifically 301(a)(i) through (iv), Laws 1973, Ch. 250, Section 1) and Water Quality Rules and Regulations, Chapter 3 (1988), and Chapter 16 (1998),

Applicant: Wyoming Department of Transportation
P.O. Box 668
Sheridan, WY 82801
ATTN: Mark Gillett
(307) 674-2300

is authorized to operate the Dietz Interchange Port of Entry Wastewater Facility in the W½, Section 28, Township 57 North, Range 84 West, of the 6th Principal Meridian; according to the procedures and conditions of application # 04-185 and other conditions of this permit.


This permit shall become effective on date of issuance.



John Wagner, Administrator
Water Quality Division
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002
Phone: (307) 777-7781

8/2/04

Date



John V. Corra, Director
Department of Environmental Quality
Herschler Building, 122 West 25th Street
Cheyenne, WY 82002

8/12/04

Date

TABLE OF CONTENTS

A. DISCHARGE ZONE AND AREA OF REVIEW	3
Discharge Zone:	3
Area of Review	3
B. GROUND WATER CLASSIFICATION	3
C. AUTHORIZED OPERATIONS	3
D. ENVIRONMENTAL MONITORING PROGRAM FOR GROUND WATERS OF THE STATE	4
Samples and measurements	4
records of all monitoring information	4
information shall include	4
ground water in the receiving formation	4
waive further monitoring	4
E. REQUIREMENTS FOR MONITORING THE DISCHARGE	4
F. RECORDS AND REPORTS	5
retain copies of all reports	5
planned physical alterations or additions	5
submitted no later than 30 days	5
report any noncompliance	5
other information	5
noncompliance with a permit condition or malfunction	5
written submission shall be provided within 5 days	5
noncompliance not reported otherwise	5
failed to submit any relevant facts	5
retain all records concerning the nature and composition	5
public notice and an opportunity for hearing	6
annual report of operations	6
report for an aborted or curtailed operation	6
G. GENERAL PERMIT CONDITIONS	6
permit may be modified, suspended, or revoked	6
reviewed at least once every 5 years	6
modified at any time as may be required	6
Public notice of the permit review	6
Any permit noncompliance constitutes a violation	6
filing of a request	6
(permittee) is always responsible for permit compliance	6
legal action	7
does not convey any property rights	7
provisions of this permit are severable	7
waste which migrates into an aquifer	7
permit is for a term of ten years	7
modification which may result in a violation	7
construction requirements	7
notify the administrator	7
construction is complete	7
H. DUTIES OF THE PERMITTEE	7
Comply with all permit conditions	7
Halt or reduce activity	7
Take all reasonable steps	7

Furnish to the administrator	7
Operate and maintain all facilities	7
enter the premises where a regulated facility	8
.. SPECIAL MEASURES THE DIRECTOR FINDS NECESSARY:	
sewage is found to be surfacing	8

A. DISCHARGE ZONE AND AREA OF REVIEW

1. Discharge Zone:

This injection facility (sanitary leachfield) is not authorized to inject into an any aquifer which may be found during the monitoring well development.

2. Area of Review

The facility authorized by this permit is located in:

Township 57 North, Range 84 West, 6th Principal Meridian
Section 28: W $\frac{1}{2}$

The Area of Review around this facility is legally described as:

Township 57 North, Range 84 West, 6th Principal Meridian
Section 28: NW $\frac{1}{4}$, N $\frac{1}{2}$ SW $\frac{1}{4}$

B. GROUND WATER CLASSIFICATION

The ground water will be classified as following the construction of the facility under Chapter 8 of Wyoming Water Quality Rules and Regulations (March 11, 1993). This classification will be made because:

- a. Ground water was encountered in the drinking water well constructed for the Port of Entry at approximately 60'. Groundwater at this depth is not being used for drinking water in the area of interest. The Port of Entry drinking water well casing is not perforated until the depth of 900'.
2. Ground water of the class determined shall not be degraded so as to make it unusable as a source of water for its purpose. Any parameters which do not meet the class of use standard shall not be degraded whatsoever.

C. AUTHORIZED OPERATIONS

1. The Wyoming Department of Transportation is authorized to inject 137 barrels per day, (5,733 gallons per day) of wastewater as described: Sanitary waste only from a Wyoming Department of Transportation Port of Entry Scale House and Inspection Building (two systems). The waste in each system to be disposed of is to be treated first in a septic tank. The liquid shall flow from the septic tank to a pump tank and then distributed through pressure to a chamber leach field. A flow distribution valve will distribute the liquid waste on a alternating basis through the leach chamber laterals.
2. **Hazardous Waste** This permit does not allow for the injection of any hazardous waste as defined by 40 CFR 261. Injection of any substance defined as hazardous waste, whether hazardous by listing or by characteristic is a violation of this permit. An oil/water separator is authorized to be connected to the inspection building septic system. No mechanical work bays are authorized to discharge to this wastewater system under this permit. The oil/water separator is required to collect wastes from truck washes that may be required to allow inspection of trucks.

D. ENVIRONMENTAL MONITORING PROGRAM FOR GROUND WATERS OF THE STATE

1. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
2. The Wyoming Department of Transportation shall prepare records of all monitoring information to be retained for a period of at least 3 years after closure of the facility.
3. Records of monitoring information shall include:
 - a. The date, exact place, and time of sampling or measurements;
 - b. The name(s) of individual(s) who performed the sampling or measurements;
 - c. The date(s) analyses were performed;
 - d. Names of individuals who performed the analyses;
 - e. The analytical techniques or methods used; and
 - f. The results of such analyses.
4. The ground water in the receiving formation shall be sampled and the following parameters analyzed on the following schedule and from the following wells.

WELL NAME OR NUMBER	SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT (UCL)*
Monitor Well Dietz Port of Entry #1	Quarterly	EPA Method 350.3	Ammonia as N	.500
		EPA Method 604	Phenol	.001
Sheridan POE #1 Domestic Water Supply Well P146701W		EPA Method 353.2	Nitrate as N	10.0
		Microbiological Methods for Monitoring the Environment p. 108	Total Coliform	1 colony/100ml

*All chemical concentrations in this permit are expressed in mg/l unless otherwise noted. Prior to taking the above samples, the Wyoming Department of Transportation shall monitor the static water level in monitor wells Dietz POE -1, Dietz POE -2, and Dietz POE -3. The results of those measurements shall be reported along with the sampling results.

5. After the first two years of operation, the Water Quality Division may, without reissuing this permit, waive further monitoring of any parameter from the above list or may require additional monitoring based on new information about the nature of the waste. The Water Quality Division may also, after the first two years of operation, approve a more or less stringent monitoring schedule.

E. REQUIREMENTS FOR MONITORING THE DISCHARGE

The Wyoming Department of Transportation shall monitor the quality of the effluent from the septic tank at the point where the flow leaves the tank on the following schedule. The following parameters shall be analyzed by the listed methods and reported annually:

SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT (UCL)*
Quarterly	EPA Method 420.1	Total Phenols	.500
	EPA Method 353.2	Nitrate as N	No Limit

SAMPLING SCHEDULE	ANALYTICAL METHOD	PARAMETER ANALYZED	PERMIT LIMIT (UCL) *
	EPA Method 350.3	Ammonia as N	No Limit

*All chemical concentrations in this permit are expressed in mg/l unless otherwise noted. The above Upper Control Limit (UCL) is not to be exceeded in any sample. Exceedance of this value is a violation of this permit and shall require corrective action. In the event that any contaminant is found to exceed the above UCL's The Wyoming Department of Transportation shall undertake a study to determine and eliminate the source of that contaminant from the waste stream. Any parameter found to be exceeding the above UCL shall be sampled for in the downgradient wells if not already sampled for. After the first two years of operation, the Water Quality Division may, without reissuing this permit, waive further monitoring of any parameter from the above list or may require additional monitoring based on new information about the nature of the waste. The Water Quality Division may also, after the first two years of operation, approve a more or less stringent monitoring schedule.

F. RECORDS AND REPORTS

1. The Wyoming Department of Transportation shall retain copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the report or application.
2. The Wyoming Department of Transportation shall give notice to the administrator as soon as possible of any planned physical alterations or additions, other than authorized operation and maintenance, to the permitted facility and receive authorization prior to implementing the proposed alteration or addition.
3. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 30 days following each schedule date.
4. The Wyoming Department of Transportation shall report any noncompliance which may endanger health or the environment, orally within 24 hours from the time the operator becomes aware of the circumstances. The report should include:
 - a. Any monitoring or other information which indicates that any contaminant may cause an endangerment to a usable ground water of the state.
 - b. Any noncompliance with a permit condition or malfunction of the discharge (injection) system which may cause fluid migration into or between usable ground waters of the state.
 - c. A written submission shall be provided within 5 days of the time the operator becomes aware of the circumstances. This written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected; the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
5. The Wyoming Department of Transportation shall report all instances of noncompliance not reported otherwise, at the time monitoring reports are submitted; such reports shall contain the information listed in 4. above.
6. When the Wyoming Department of Transportation becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the administrator, it shall promptly submit such facts or information.

The Wyoming Department of Transportation shall retain all records concerning the nature and composition of injected fluids until 5 years after completion of any specified plugging and abandonment procedures.

The administrator may require the owner/operator to deliver the records to the administrator at the conclusion of the retention period.

8. A subsurface discharge (injection) facility may not commence subsurface discharge (injection) until, following public notice and an opportunity for hearing, an underground injection control permit has been issued by the department for the proposed operation.
9. The annual report of operations for this facility shall be submitted on forms provided by the department and shall include the following information:
 - a. Any permit exceedances within the previous year.
 - b. The analytical results for sampling for the injected water and any ground water sampling results required under Section D or E of this permit.
 - c. Annual reports are due in the Sheridan office of the Water Quality Division no later than December 1 of each year.
10. A comprehensive report for an aborted or curtailed operation authorized by this permit shall be submitted to the administrator within 30 days of complete termination of the injection (discharge) or associated activity, in lieu of an annual report.

G. GENERAL PERMIT CONDITIONS

1. After notice and opportunity for a hearing, a permit may be modified, suspended, or revoked in whole or part during its term for cause which includes, but is not limited to, any of the following:
 - a. Violation of the permit;
 - b. Obtaining a permit by misrepresentation or failure of the discharge well or system.
2. Each permit is reviewed at least once every 5 years, and may be reviewed more frequently.
3. A permit may be modified at any time as may be required, including for conformity with changes in regulations or standards which occur after the permit is issued. A permit may be modified in whole or part in order to apply more, or less, stringent standards; or prohibitions for a toxic or other substance present in the Wyoming Department of Transportation's discharge, as may be ordered by the council. This permit can be terminated by authority of the administrator for one or more permit violations.
4. Public notice of the permit review and request for public comment will be made every 10 years by the administrator.
5. Any permit noncompliance constitutes a violation of the permit and is grounds for enforcement action, permit termination, revocation, or modification.
6. The filing of a request by the Wyoming Department of Transportation for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
7. The owner/operator of record (permittee) is always responsible for permit compliance. A permit holder cannot transfer his permit without approval of the department director, and no such transfer will be approved if the facility is not in compliance with the existing permit unless the proposed permittee agrees to bring the facility into compliance.

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the Wyoming Department of Transportation from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation.

9. The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.
10. The provisions of this permit are severable, and if any provision of the permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.
11. Pollution or waste which migrates into an aquifer containing a usable ground water of the state is a violation of the permit.
12. This permit is for a term of ten years. If the Wyoming Department of Transportation wishes to continue injection after the expiration date of this permit, they will be required to apply to the Administrator for, and obtain, a new permit.
13. Any modification which may result in a violation of a permit condition shall be reported to the administrator, and any modification that will result in a violation of a permit condition shall be reported to the administrator through the submission of a new or amended permit application.
14. The injection facility covered by this permit shall meet the construction requirements found in Section 10 of Chapter 16, and Part D of Chapter 11, Water Quality Rules and Regulations. The permittee shall submit notice of completion or construction to the administrator and allow for inspection of the facility upon completion of construction prior to commencing any injection activity.
15. The permittee shall notify the administrator seven (7) days prior to conversion of this facility to any other use, or final abandonment of the facility.
16. Injection shall not commence until all construction is complete.

H. DUTIES OF THE PERMITTEE

It is a duty of the permittee to:

1. Comply with all permit conditions;
2. Halt or reduce activity -- it shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the Wyoming Department of Transportation activity in order to maintain compliance with the permit conditions;
3. Take all reasonable steps to minimize or correct any adverse impact on the environment resulting from noncompliance with this permit; and
4. Furnish to the administrator within a reasonable time, any information which the administrator may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit; and furnish to the administrator, upon request, copies of records required to be kept by this permit.
5. Operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance includes effective performance, adequate funding and operator staffing and training, and adequate laboratory and process controls including appropriate quality assurance procedures. This provision

requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

6. Allow the administrator, or an authorized representative of the administrator, upon the presentation of credentials, during normal working hours, to enter the premises where a regulated facility is located, or where records are kept under conditions of this permit, and inspect the discharge and related facilities, review and copy reports and records required by the permit, collect fluid samples for analysis, measure and record water levels, and perform any other function authorized by law or regulation.

I. SPECIAL MEASURES THE DIRECTOR FINDS NECESSARY:

1. In the event that sewage is found to be surfacing from the leachfield covered by this permit, this is a violation of this permit and shall be reported immediately as required by Section F of this permit. The Wyoming Department of Transportation shall submit a modified application showing plans for a replacement leachfield (or other type of waste disposal method) within 90 days of determining that the primary leachfield has failed.

J. SIGNATORIES REQUIREMENT

1. All reports required by this permit and other requested information shall be signed as follows:

For a corporation -- by a principal executive officer of at least the level of vice-president;

For a partnership or sole proprietorship -- by a general partner or the proprietor, respectively;

For a municipality, state, federal, or other public agency -- by either a principal executive officer or ranking elected official; or

By a duly authorized representative for any of the above. A person is a duly authorized representative only if:

1. The authorization is made in writing by one of the described principals;
 2. The authorization specifies either an individual or position having responsibility for the overall operation of the regulated facility or activity; and
 3. The written authorization is submitted to the administrator.
2. If an authorization is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to the administrator prior to or together with any reports or information, to be signed by an authorized representative.
 3. Any person signing a report or other requested information shall make the following certification:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment."

RJE/bb/4-0787.ltr



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

250 Lincoln Street • Lander, Wyoming 82520 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

May 4, 2004

Mr. Joe Arnold
P. O. Box 95
Thermopolis, WY 82443

RE: Arnold Replacement Leach Field, Permit Number 04-186
Hot Springs County

Dear Mr. Arnold:

The above application for coverage under General Permit to Construct a replacement leach field in accordance with Chapter 3, Section 7 and Chapter 11, Part D of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section 0, of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

A handwritten signature in black ink that reads "Jeff Hermansky".

Jeff Hermansky
Northwest District Engineering Supervisor
Water Quality Division

xc: IPS, Cheyenne



Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 20, 2004

Mayor Mike Varney
City of Torrington
P.O. Box 250
Torrington, WY 82240-0250

RE: Torrington G Street Sewer Extension, Application No. 04-187, Goshen County

Dear Mayor Varney:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Sewage Collection Systems described as a 298 foot 8" diameter sewer line extension with one manhole, NE 1/4 Section 10 T24N R61 W, Goshen County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, the general permit, and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 11, 2006.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 04-187 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/bb/4-0510.ltr

cc: IPS, Cheyenne

Marc Rosso, Baker and Associates
1925 East A Street
Torrington WY 82240



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 04-188

Lingle Sewer Lagoon Rehabilitation

This permit hereby authorizes the applicant:

Town of Lingle
220 Main Street
Lingle, Wyoming, 82223

to construct, install or modify Cell No.1 with deepening, a synthetic liner and new outlet structure according to the procedures and conditions of the application number 04-188. The facility is located in NE 1/4 Section 29 T25N R62W in the county of Goshen, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by September 30, 2007.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088, FAX 307-777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 4 The 4" drain line from Cell No. 1 shall be upgraded to a 6" diameter or larger SDR 35 PVC pipe.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".


AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division

6/7/04

John V. Corra
Director
Department of Environmental Quality



Date of Issuance

JVC/JFW/LBH/pf/4-0551-ltr

STATEMENT OF BASIS


1. Permit Number: 04-188
2. Application reviewed for compliance with the following applicable regulations :
Chapter(s) 3 and 11 of the Wyoming Water Quality Rules and Regulations
3. Does the permit comply with all applicable regulations identified above?
YES
4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was required.
5. If Section 17 of Chapter 3 review is required, indicate the basis for determining how groundwater will be protected.
 - a. The facility will not allow a discharge to groundwater. The lagoon will be lined with a synthetic liner.
6. Documentation of Statement of Basis: The archives file for this permit include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon PE-PG, Southeast District Engineer, lharmo@state.wy.us, and completed on June 3, 2004. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 21, 2004

Mr. Herman Noe, Manager of Engineering
Cheyenne Board of Public Utilities
P.O. Box 1469
Cheyenne WY 82003-1469

RE: Cheyenne Industrial Park Jeld-Wen Extensions, Application No.04-189, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as 1720 ft of 8" diameter water line, 8 fire hydrants, and a 6" diameter sewer service, Section 36 T14N R66W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All service connections will be protected by the appropriate backflow device as required by Chapter 12, Section 14(i) of the Water Quality Division Rules and Regulations. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 11, 2006.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 04-189 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division


cc: IPS, Cheyenne
Ryan S. Rigg, A.V.I. p.c.
2035 Westland Road
Cheyenne WY 82001

LBH/pf/4-0514-itr





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 10, 2004

Mr. Dennis Auker,
Laramie County School District No. 1
2801 House Avenue
Cheyenne, Wyoming 82001

RE: Cheyenne Central High Gymnasium Renovation, Application No.04-190,Laramie County

Dear Mr. Auker:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems described as 90 feet of 6" diameter ductile iron pipe fire service line, NE 1/4 Section 24 T14N R67W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All service connections will be protected by the appropriate backflow device as required by Chapter 12, Section 14(i) of the Water Quality Division Rules and Regulations. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 11, 2006.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 04-190 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/pf/4-0516-ltr

cc: Scott Larson, Benchmark Engineers, P.C., 1920 Thomes Ave. Cheyenne, WY. 82001

Cheyenne BOPU, 2406 Snyder Avenue, Cheyenne, WY 82001

IPS, Cheyenne





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

250 Lincoln Street • Lander, Wyoming 82520 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

August 18, 2004

Mr. William Urbigit
City of Riverton
816 North Federal Boulevard
Riverton, WY 82501

RE: Brunton Site, Permit Number 04-192R
Fremont County

Dear Mr. Urbigit:

The above application for coverage under General Permit to Construct 8-inch diameter PVC water and sewer mains in accordance with Chapter 3, Section 7 and Chapter 11, Part D and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

The City of Riverton must verify that the reduced pressure principle backflow prevention devices are installed within the Brunton building(s) so that the city main and the internal domestic piping is protected.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Jeff Hermansky
Northwest District Engineering Supervisor
Water Quality Division

xc: IPS, Cheyenne



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

250 Lincoln Street • Lander, Wyoming 82520 • Fax (307) 332-7726

ABANDONED MINES
(307) 332-5085

AIR QUALITY
(307) 332-6755

LAND QUALITY
(307) 332-3047

SOLID & HAZARDOUS WASTE
(307) 332-6924

WATER QUALITY
(307) 332-3144

NOTIFICATION OF COVERAGE

May 6, 2004

Nathan Sponsel, Town Manager
Town of Cowley
P.O. Box 635
Cowley, Wyoming 82420

RE: Cowley - Rocky Mountain Elementary School Sanitary Sewer Line Connection - Permit
Number: 04-194, Lot 54, T57N, R96W, Big Horn County

Dear Mr. Sponsel:

The above application for coverage under General Permit to Construct the extension of a sewage collection system consisting of 114 linear feet of 6-inch PVC sewer main and appurtenances in accordance with Chapter 3, Section 7 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.
Environmental Senior Analyst
Water Quality Division

cc: IPS, Cheyenne
encl: General Permit For a Sewage Collection System



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Steve Freudenthal, Governor

AIR QUALITY
(307) 672-6457
x (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

June 9, 2004

Mr. Drew Redinger
10 Grandview Drive
Sheridan, WY 82801

RE: Stonebrook Meadows Development, Permit # 04-195 - PWS# 5600044

Dear Mr. Redinger:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a extension to the Town of Ranchester Wastewater Collection and Water Distribution system in accordance with Chapter 3 and Chapter 11 of the WWQRR has been reviewed and is hereby approved. You are now authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this permit shall be completed by May 1, 2005.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits. Following completion of construction of this facility please return the attached WDEQ Certificate of Completion and Transfer of Ownership when the utilities are accepted by the Town of Ranchester. If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457. Thank you.

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQD NE District Senior Environmental Analyst

cc: 4PS, Cheyenne
Bill Trapp, W & WW Operator, P.O. Box 695, Ranchester, WY 82839
Jeff Rosenlund, PE HKM Engineering Inc., 16 W. 8th Street (P.O. Box 7010), Sheridan,
WY 82801



The State
of Wyoming



Department of Environmental Quality

1043 Coffeen Avenue, Suite D • Sheridan, Wyoming 82801

Dave Freudenthal, Governor

AIR QUALITY
(307) 672-6457
Fax (307) 674-6050

LAND QUALITY
(307) 672-6488
Fax (307) 672-2213

WATER QUALITY
(307) 672-6457
Fax (307) 674-6050

NOTIFICATION OF COVERAGE

May 6, 2004

Mr. Ken Johnson
Evergreen Inn
480 E. 5th Street
Sheridan, WY 82801

RE: New Fire Hydrant-Evergreen Inn, Permit # 04-196
PWS# 5600052

Dear Ken:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a extension to the City of Sheridan Water Distribution system in accordance with Chapter 3 and Chapter 11 of the WWQRR has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits. All construction, installation, or modification allowed by this permit shall be completed by April 1, 2005.

A transfer of ownership must be filed with WDEQ if the City of Sheridan assumes ownership of the fire line. If you have any questions please contact me at 1043 Coffeen Avenue, Suite D, Sheridan, WY, 82801, (307) 672-6457. Thank you.

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQ NE District Senior Environmental Analyst

cc: IPS; Cheyenne
Moses Jacobs, PE, 237 N. Main St.No. 2B, Sheridan, WY 82801
Mike Cole, PE, City of Sheridan Asst. Public Works Director



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 8, 2004

Jessica Gurich
316 Gibbon Street
Laramie, WY 82072

RE: Polk Street Improvements - Water Main Extension, Application No. 04-197

Dear Ms. Gurich:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit, and the materials submitted in your application package. All water service connections will be protected by the appropriate backflow device as required by Chapter 12, Section 14(i) of the Water Quality Division Rules and Regulations. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

The approval granted under this Notification Of Coverage and the General Permit shall expire on June 7, 2006. Please reference Application Number 04-197 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bb/4-0578.ltr

Enclosures: GENERAL PERMIT - Extensions/Modifications of Existing Public Water Supply Distribution Systems
Certificate of Completion Form

cc: IPS, Cheyenne
James W. Johnson, Johnson Engineering Assoc., 110 Superior Ct., Laramie, Wyoming 82072

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH
(307) 777-7758
FAX 777-3610

ABANDONED MINES
(307) 777-6145
FAX 777-6462

AIR QUALITY
(307) 777-7391
FAX 777-5616

INDUSTRIAL SITING
(307) 777-7369
FAX 777-6937

LAND QUALITY
(307) 777-7756
FAX 777-5864

SOLID & HAZ. WASTE
(307) 777-7752
FAX 777-5973

WATER QUALITY
(307) 777-7781
FAX 777-5973



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 04-198

Curt Gowdy Headquarters Water Cistern
PWS # WY5600866N

This permit hereby authorizes the applicant:

Wyoming State Parks & Historic Sites
Attn. John W. Brunner, Consultant Engineer
2301 Central Avenue
4th Floor Barrett Bldg.
Cheyenne, Wyoming 82002

to construct, install, and modify a public water supply system water storage cistern facility and chlorination and distribution control system according to the procedures and conditions of the application number 04-198. The facility is located in the SE ¼ of Section 08, T14N, R70W, in the county of Laramie, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by December 6, 2007.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3. The applicant will provide immediate oral or written notice to the DEQ/WQD Southeast District Office at 122 West 25th Street, Herschler Building - 4W, Cheyenne, Wyoming 82002, (307) 777-7781, or FAX (307) 777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3. Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Southeast District office a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

12/6/04
Date of Issuance

RLE/bb/4-1221.ltr

cc: Laramie County Health Dept. / Environmental Health Division

STATEMENT OF BASIS

1. Permit Number: 04-198
2. Application reviewed for compliance with the following regulations:
Chapter 12 of the Wyoming Water Quality Rules and Regulations
3. Does the permit comply with all applicable regulations identified above?
YES
4. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3 NOT Required
5. Documentation of Statement of Basis: The archives file for this permit include adequate documentation of all sections of this Statement of Basis


CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, rewald@state.wy.us, Environmental Senior Analyst, and completed on December 6, 2004. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

RLE/bb/4-1221.ltr



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

June 17, 2004

Wyoming State Parks & Historic Sites
Attn. John W. Bruner, Project Engineer
2301 Central Ave., 4th Fl Barrett Bldg.
Cheyenne, Wyoming 82002

RE: **Withdrawal of Permit Application:** **Number 04-199**

Dear Mr. Bruner:

At your request, your application for a new public water supply system, number 04-199, is being returned without having been permitted.

This project has not been permitted as a Public Water Supply(PWS) system. If you wish to reconsider classification or conversion of this facility to a PWS system, then application procedures pursuant to Chapter 3 of the Wyoming Water Quality Rules and Regulations must be followed.

Sincerely;

Ronald L. Ewald
Senior Analyst
SE District, Water Quality Division

RLE/pf/4-0606-ltr

cc: IPS



WYOMING

DEPARTMENT OF STATE PARKS & CULTURAL RESOURCES
DIVISION OF STATE PARKS & HISTORIC SITES

Pat Green
Division Director
State Parks & Historic Sites
2301 Central
Barrett Building 4th Floor
Cheyenne, WY 82002

(307) 777-6323
FAX (307) 777-6005


Mr. Ronald L. Ewald
Wyoming Department of Environmental Quality
Water Quality Division
Herschler Bldg., 4 West
Cheyenne, WY 82002

June 10, 2004

Dear Ron,

Thank you for the review of the Twin Lakes Group Shelter Water System at Curt Gowdy State Park. After further consideration, we have determined that according to definition, our project does not meet the requirements for a public water system. Our well will supply one outlet for a reservable group shelter on Crystal Reservoir. Judging by usage patterns at other group shelters within the park, it is most likely to be used by groups only two days per week during the three summer months between Memorial Day and Labor Day. The system will be winterized the rest of the year. Therefore, Wyoming State Parks & Historic Sites would like to withdraw the application. Your comments will be useful as a reference for the next applicable project.

Sincerely,


John W. Bruner
Project Engineer

Dave Freudenthal, *Governor*




Phil Noble, *Director*

RECEIVED
JUN 15 2004
WATER QUALITY DIVISION
WYOMING



Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



John Corra, Director

Dave Freudenthal, Governor

NOTIFICATION OF COVERAGE

July 7, 2004

Mr. Robert Blake, Vice President
B-Hive, Inc.
101 McConnel Street
Laramie, WY 82072

RE: City of Laramie Snowy Range Addition, Application No.04-200, Albany County

Dear Mr. Blake:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as 750 feet of 8" diameter PVC water main plus fittings, valves and one fire hydrant, 530 feet of 8" diameter PVC sewer main and one manhole, NE 1/4 Section 6 T15N R73W; Albany County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All service connections will be protected by the appropriate backflow device as required by Chapter 12, Section 14(i) of the Water Quality Division Rules and Regulations. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 11, 2006.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 04-200 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

cc: IPS, Cheyenne
Robert J. Coffey, Coffey and Associates, Inc., 903 Grand Avenue, Laramie WY 82070
Bob Juve, City of Laramie, P.O. Box C, Laramie, WY 82073

LBH/pf/4-0664-ltr



