




Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 24, 2005

G. Barr McCutcheon, Owner
Barr-More, LLC
P.O. Box 1662
Afton, WY 83110

RE: Air Park Subdivision - Water and Sewer Main Extensions - Permit Number 05-251, E 1/2, Section 36, T32N, R119W, Lincoln County, PWS# 5600002

Dear Mr. McCutcheon:

The above application for coverage under General Permits to Construct public water supply and sewage collection system extensions to serve 54 residential lots in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.
Environmental Senior Analyst
Water Quality Division

xc: IPS, Cheyenne


encl: General Permit for Public Water Supply Distribution System,
General Permit for a Sewage Collection System

Page 1 of 1





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

October 27, 2005

TOG Development
Attn: W.P. Greaser, Secretary/Treasurer
1267 N. 15th Street, Suite 101
Laramie, Wyoming 82072

RE: Permit To Construct Application: **No. 05-252**
Project: Coughlin-Pole Mountain 2nd Addition: Water & Sewer Extensions
Action: **DENIED** Reason: Does Not Meet Chapter 12 Minimum Requirements

Dear Mr. Greaser:

The above referenced application was first submitted to the Wyoming Department of Environmental Quality(DEQ) / Water Quality Division(WQD) on May 12, 2005 on your behalf by the Aspen-Banner Engineering firm. An initial set of review comments were issued by the WQD on July 15, 2005. These comments indicated that the water system pressure model needed to be rerun with some adjustments made. However, the primary problem was that the water line extension was a 550 foot long 8" diameter dead-end extension with two fire hydrants added on to an existing 258 foot long 6" diameter dead-end extension. This was a clear violation of Chapter 12, Section 14(b)(ii) which stipulates that the maximum length of 6" diameter water main serving fire hydrants from only one direction(dead-end) is 250 feet. The review comments indicated that the existing 6" pipe should be removed back to the junction at the corner of Nighthawk Drive and 23rd Street and be replaced with 8" pipe the full length of the 23rd Street extension.

Subsequent submittals indicated that it was the desire of the applicant to leave the existing 6" water main in place and a variance from the above referenced requirement was requested by the engineer. The WQD reviewing personnel indicated that such a variance could only be granted if two specific conditions were met. These conditions were that:

1. The City of Laramie provide written documentation that the City agrees to leaving the existing 6" water main in place, and
2. Sufficient documentation be provided to demonstrate that the required minimum pressure(20 psi) could be maintained at all points along the water main extension during fire flow conditions.

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH
(307) 777-7758
FAX 777-3610

ABANDONED MINES
(307) 777-6145
FAX 777-6462

AIR QUALITY
(307) 777-7391
FAX 777-5616

INDUSTRIAL SITING
(307) 777-7369
FAX 777-6937

LAND QUALITY
(307) 777-7756
FAX 777-5864

SOLID & HAZ. WASTE
(307) 777-7752
FAX 777-5973

WATER QUALITY
(307) 777-7781
FAX 777-5973




Several submittals were made to the WQD to try to satisfy these two conditions. The first condition was satisfied, but the second condition has not been satisfied. In fact, the last submittal which was received by the WQD on October 3, 2005, indicated that the maximum available fire flow at the first fire hydrant (located approximately at the midpoint of the proposed water main extension) was only 1186gpm with a residual pressure of 20.00 psi at the end of the water main extension. The required minimum fire flow in Laramie R1 zoning is 1500gpm.

The application and subsequent submittals do not comply with the requirements of Chapter 12, Section 14. Therefore the permit is denied in accordance with Chapter 3 of the Water Quality Rules and Regulations, Section 14(a)(i).

If you should have any questions concerning this matter, please call either myself or Louis Harmon at (307) 777-7781.

Sincerely,



John V. Corra
Director

Wyoming Department of Environmental Quality

JVC/RLE/5-1176

cc: John F. Wagner, Administrator, WQD
Louis Harmon, SE District Supervisor
Jim I. Cavalli, P.E., Aspen-Banner Engineering, 1575 North 4th St., Suite 105,
Laramie, Wyoming 82072
Permit file No. 05-252



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

October 27, 2005

TOG Development
Attn: W.P. Greaser, Secretary/Treasurer
1267 N. 15th Street, Suite 101
Laramie, Wyoming 82072

RE: Permit To Construct Application: **No. 05-252**
Project: Coughlin-Pole Mountain 2nd Addition: Water & Sewer Extensions
Action: **DENIED** Reason: Does Not Meet Chapter 12 Minimum Requirements

Dear Mr. Greaser:

The above referenced application was first submitted to the Wyoming Department of Environmental Quality(DEQ) / Water Quality Division(WQD) on May 12, 2005 on your behalf by the Aspen-Banner Engineering firm. An initial set of review comments were issued by the WQD on July 15, 2005. These comments indicated that the water system pressure model needed to be rerun with some adjustments made. However, the primary problem was that the water line extension was a 550 foot long 8" diameter dead-end extension with two fire hydrants added on to an existing 258 foot long 6" diameter dead-end extension. This was a clear violation of Chapter 12, Section 14(b)(ii) which stipulates that the maximum length of 6" diameter water main serving fire hydrants from only one direction(dead-end) is 250 feet. The review comments indicated that the existing 6" pipe should be removed back to the junction at the corner of Nighthawk Drive and 23rd Street and be replaced with 8" pipe the full length of the 23rd Street extension.

Subsequent submittals indicated that it was the desire of the applicant to leave the existing 6" water main in place and a variance from the above referenced requirement was requested by the engineer. The WQD reviewing personnel indicated that such a variance could only be granted if two specific conditions were met. These conditions were that:

1. The City of Laramie provide written documentation that the City agrees to leaving the existing 6" water main in place, and
2. Sufficient documentation be provided to demonstrate that the required minimum pressure(20 psi) could be maintained at all points along the water main extension during fire flow conditions.

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH
(307) 777-7758
FAX 777-3610

ABANDONED MINES
(307) 777-6145
FAX 777-6462

AIR QUALITY
(307) 777-7391
FAX 777-5616

INDUSTRIAL SITING
(307) 777-7369
FAX 777-6937

LAND QUALITY
(307) 777-7756
FAX 777-5864

SOLID & HAZ. WASTE
(307) 777-7752
FAX 777-5973

WATER QUALITY
(307) 777-7781
FAX 777-5973




Several submittals were made to the WQD to try to satisfy these two conditions. The first condition was satisfied, but the second condition has not been satisfied. In fact, the last submittal which was received by the WQD on October 3, 2005, indicated that the maximum available fire flow at the first fire hydrant (located approximately at the midpoint of the proposed water main extension) was only 1186gpm with a residual pressure of 20.00 psi at the end of the water main extension. The required minimum fire flow in Laramie R1 zoning is 1500gpm.

The application and subsequent submittals do not comply with the requirements of Chapter 12, Section 14. Therefore the permit is denied in accordance with Chapter 3 of the Water Quality Rules and Regulations, Section 14(a)(i).

If you should have any questions concerning this matter, please call either myself or Louis Harmon at (307) 777-7781.

Sincerely,



John V. Corra
Director

Wyoming Department of Environmental Quality

JVC/RLE/5-1176

cc: John F. Wagner, Administrator, WQD
Louis Harmon, SE District Supervisor
Jim I. Cavalli, P.E., Aspen-Banner Engineering, 1575 North 4th St., Suite 105,
Laramie, Wyoming 82072
Permit file No. 05-252

MEMO

To: John Corra, Director DEO *JC*

Through: John Wagner, Administrator, WQD *JW*
Larry Robinson, Manager, Water and Wastewater Program *LR*
Louis Harmon, SE District Supervisor *LH*

From: Ron Ewald, SE District Engineer, Primary Application Reviewer *RLE (8'?)*

Date: October 27, 2005

Subject: **DENIAL** of Permit To Construct Application No. 05-252
Project: Coughlin-Pole Mountain 2nd Addition: Water & Sewer Extensions
Summary of application review process.

05-12-05: Application received - Submitted by Aspen-Banner Engineering firm on behalf of the owners, TOG Development. The application is for water and sewer main extensions up a continuance of 23rd Street in Laramie. Both utilities are to be dead-end extensions.

07-15-05: 1st WQD Review Completed and Issued - The sewer main extension is OK and not an issue. However, concerning the water system extension, several lesser concerns were noted including the need to rerun the pressure model with some adjustments. The primary problem identified was that the water line extension was a continuance of an existing 258-foot long 6" diameter dead-end line. The proposed extension was for an additional 550 feet of 8" main with two new fire hydrants on the line. The review identified this as a violation of Chapter 12, Section 14(b)(ii) which stipulates that the maximum length of 6 inch diameter water main serving fire hydrants from only one direction (dead-end) is 250 feet. The review requested that the existing 6" pipe be removed back to the junction at the corner of Nighthawk Drive and 23rd Street where the dead-end line started and be replaced with 8" pipe the full length of the 23rd Street extension.

07-25-05: Response to 1st Review Comments Received - Applicant does not want to remove the existing 6" pipe and replace it with 8" pipe. The engineer had two justifications for leaving the existing 6" pipe in place. They were:

- the dead-end will be eliminated sometime "soon" in the future when the next phase of the subdivision is built out and the water line is completed and looped, and
- even as a dead-end line there is adequate pressure to meet the minimum requirements of Chapter 12.

08-02-05: 2nd WQD Review Completed and Issued - The request for a variance from the requirement that dead-end water mains serving fire hydrants longer than 250 feet must be a minimum of 8" in diameter, was not accepted. It was not adequately demonstrated that the minimum residual pressure at all locations in the extension would remain above 20 psi under fire flow conditions. Other more specific details were discussed in the review, but they related to afore mentioned condition.

09-12-05: Meeting - Present: Lou Harmon and Ron Ewald, WQD, and Jim Cavalli of Aspen-Banner Engineering. The purpose of the meeting was to discuss and try to clear up any confusion, questions, or concerns about requirements. The goal of the meeting was for the engineer to understand exactly what was required to obtain the variance that the applicant desired to be able to leave the existing 6" water main in place and not have to replace it with new 8" pipe. Mr. Cavalli seemed to understand what was needed when he left.


10-03-05: Response to 2nd Review Comments & Meeting Received - The information submitted demonstrated that:

- The required minimum fire flow in this area of Laramie, R1 zoning, is 1500gpm by City ordinance.
- The maximum fire flow at the midpoint of the extension which results in a residual pressure of 20.00 psi at the far end of the water main extension is 1186gpm.
- If the required 1500gpm minimum fire flow were withdrawn from either hydrant on the proposed extension, or through a combination of the two hydrants, the residual pressure at the far end of the water line extension would fall well below 20 psi.

10-27-05: RECOMMENDATION - Application for Permit to Construct No. 05-252 Should be DENIED



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 2, 2005

Mr. Herman Noe, Manager of Engineering
Cheyenne Board of Public Utilities
P.O. Box 1469
Cheyenne, WY 82003-1469

RE: The Pointe Subdivision, Phase II, Application No.05-253, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as 11, 560 feet of 8" diameter water main with appurtenances and 7460 feet of 8" diameter sewer line with manholes, N 1/2 Section 18 T14N.R66W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by July 24, 2007.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 05-253 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

cc: IPS, Cheyenne
Scott Larson, BenchMark Engineers, P.C.
1920 Thomes Avenue, Suite 620
Cheyenne, WY 82001

.LBH/jc/5-0624

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH
(307) 777-7758
FAX 777-3610

ABANDONED MINES
(307) 777-6145
FAX 777-6462

AIR QUALITY
(307) 777-7391
FAX 777-5616

INDUSTRIAL SITING
(307) 777-7369
FAX 777-6937

LAND QUALITY
(307) 777-7756
FAX 777-5864

SOLID & HAZ. WASTE
(307) 777-7752
FAX 777-5973

WATER QUALITY
(307) 777-7781
FAX 777-5973





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 27, 2005

Diana Waycott
The Trapper Inn
P.O. Box 1712
Jackson, WY 83001

RE: Trapper Inn Water Line Replacement and New Sewer Laterals, Permit Number: 05-254, Section 28, T41N, R116W, Teton County

Dear Mr. Waycott:

The above application for coverage under General Permit to replace an existing 4-inch water line with a new 8-inch water line, and to install new water laterals and new sewer laterals in accordance with Chapter 3, Section 7; Chapter 11, Section 9; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved provided:

The reduced principle backflow prevention (RP) assembly shall not be installed in a pit or below grade. The RP must be installed with a minimum of 12 inches clearance between grade and opening of discharge port of relief valve.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.
Environmental Engineer
Water Quality Division

xc: IPS, Cheyenne
Shawn O'Malley, P.E., Town of Jackson, P.O. Box 1687, Jackson, WY 83001
James Ramage, P.E., Valley West Engineering, P.O. Box 4852, Jackson, WY 83001

encl: General Permit For a Public Water Supply Distribution System

Lander Field Office • 250 Lincoln Street • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 05-255

Town of Buffalo Water Storage Project
PWS NO: WY-5600005

This permit hereby authorizes the applicant:

Town of Buffalo
46 North Main Street
Buffalo, Wyoming 82834

to construct, install or modify a 16" water transmission mains and 2.5 million-gallon water storage tank according to the procedures and conditions of the application number 05-255. The facility is located in Sections 27, 28 and 33, Township 51 North, Range 82 West in the county of Johnson, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by December 31, 2007.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and

permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will provide immediate oral or written notice to the DEQ/WQD Northeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations (WWQRR) of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 4 of 4 The applicant shall submit copies of the contractor provided tank design drawings and calculations for the 2.5 million gallon storage tank before construction starts, but only after applicant has a version applicant finds acceptable. Drawings and calculations shall be Wyoming PE stamped.

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

8/4/05
Date of Issuance

KJF/jc/5-0860

STATEMENT OF BASIS

1. Permit Number: 05-255
2. Application reviewed for compliance with the following applicable regulations:
 - a. Chapter 12.
3. Does the permit comply with all applicable regulations identified above?
 - a. Yes
4. Facilities not specifically covered by regulations
 - a. Not applicable
5. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.

not required
6. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Kevin Frank, PE, SRF Program Senior Analyst, and Rick Estes, PE, NE District Senior Analyst, and completed on August 3, 2005. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 31, 2005

Carol Dewey
Secretary of the Board
Pine Ridge Community Church
17033 US Hwy 14
Carlile, WY 82721

RE: Pine Ridge Community Church Septic System, Permit # 05-256

Dear Carol:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of a small wastewater septic system in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. **You are required to submit a minimum of two (2) photos of the system installation and the Certificate of Completion to this office no later than 60 days following the installation.** All construction, installation, or modification allowed by this permit shall be completed by June 1, 2006.

On August 4, 2004, the Crook County Commissioners enacted Resolution NO. 9-2004. This resolution requires that ALL small wastewater treatment facilities permitted by the Wyoming Department of Environmental Quality (WDEQ) and installed in Crook County after September 1, 2004, MUST BE INSPECTED BY AN INSPECTOR DESIGNATED BY CROOK COUNTY.

Please contact the Crook County Clerks Office for requirements of this resolution.

If you have any questions please contact me at 1866 S. Sheridan Avenue 673-9337, 673-2213 (fax).

Thank you

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQ NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Crook County Clerk, P.O. Box 37, Sundance, WY 82729
Tri City Excavation, 169 Thorn Divide Rd., Carlile, WY 82721

Page 1 of 1





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

August 9, 2005

Mr. John McPartland
Mayor-Town of Hulett
P.O. Box 278
Hulett, WY 82720

RE: Black Hills Golf Community Water & Sewer Extension 05-257
-PWS# 5600026

Dear John:

The above application for coverage under General Permit to Construct, Install, Modify or Operate an extension to the Town of Hulett Wastewater Collection and Water Distribution system in accordance with Chapter 3 and Chapters 11 and 12 of the WWQRR has been reviewed and is hereby approved. You are now authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this permit shall be completed by September 1, 2006.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits. Following completion of construction of this facility please return the attached WDEQ Certificate of Completion to this office.

If you have any questions please contact me at 1866 S. Sheridan Avenue, Sheridan, WY, 82801, (307) 673-9337.

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQD NE District Senior Environmental Analyst


cc: IPS, Cheyenne
Kenneth Rathbun, P.E., Bearlodge Ltd. Inc., PO Box 130, Sundance, WY 82729

Page 1 of 1





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 27, 2005

Robert D. Merrill
Box 717
Encampment, Wyoming 82325

RE: Merrill Guest Cabins Septic System,
Location: NW 1/4, Section 30, T15N, R83W,

Application No. **05-258**
Carbon County

Dear Mr. Merrill:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific conditions also apply:

1. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.
2. Polyethylene Septic Tank Installation Requirements - To ensure structural integrity, the **manufacturer's instructions** regarding bedding the tank and filling the tank with water during burial **must be followed during installation**. Additionally, immediately after clean-outs, the tank must be refilled with water according to the manufacturer's instructions to maintain structural integrity.

The approval granted under this Notification Of Coverage and the General Permit shall expire on June 30, 2007. Please reference Application Number **05-258** in any future correspondence.

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH
(307) 777-7758
FAX 777-3610

ABANDONED MINES
(307) 777-6145
FAX 777-6462

AIR QUALITY
(307) 777-7391
FAX 777-5616

INDUSTRIAL SITING
(307) 777-7369
FAX 777-6937

LAND QUALITY
(307) 777-7756
FAX 777-5864

SOLID & HAZ. WASTE
(307) 777-7752
FAX 777-5973

WATER QUALITY
(307) 777-7781
FAX 777-5973



If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald J. Ewald

Ronald L. Ewald, P.E.
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/jc/5-0722

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Ken Campbell, Campbell Excavating & Construction, P.O. Box 414,
Encampment, Wyoming 82325
Carbon County Planning Director, Jonathan Schnal, 215 W. Buffalo
Street, #304, P.O. Box 487, Rawlins, Wyoming 82301



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

July 19, 2005

David & Sydney Gourlay
Box 425
Baggs, Wyoming 82321

RE: Gourlay Residential Septic System, Application No. **05-259**
Location: NE ¼ SE ¼, Section 7, T12N, R91W, Carbon County

Dear Mr. & Mrs. Gourlay:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on July 19, 2007. Please reference Application Number **05-259** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald, P.E.
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/jc/5-0807

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Carbon County Planning Director, Jonathan Schnal, 215 W. Buffalo Street, #304,
P.O. Box 487, Rawlins, Wyoming 82301

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

July 1, 2005

Cheyenne Board of Public Utilities
Attn. Herman Noe, Engineering Manager
P.O. Box 1469
Cheyenne, Wyoming 82003

RE: Cheyenne Ranch Business Center – Fire Service Lines & Fire Hydrant,
Application No. **05-260**

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit, and the materials submitted in your application package. All water service connections will be protected by the appropriate backflow device as required by Chapter 12, Section 14(i) of the Water Quality Division Rules and Regulations. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit, which the BOPU already has a copy of.

The approval granted under this Notification Of Coverage and the General Permit shall expire on July 1, 2007. Please reference Application Number 05-260 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald, P.E.
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bb/5-0750.ltr

Enclosures: Certificate of Completion Form

cc: IPS, Cheyenne

Lawrence R. Gallagher, Summit Engineering, LLC, 5907 Townsend Place,
Cheyenne, Wyoming 82009

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH
(307) 777-7758
FAX 777-3610

ABANDONED MINES
(307) 777-6145
FAX 777-6462

AIR QUALITY
(307) 777-7391
FAX 777-5616

INDUSTRIAL SITING
(307) 777-7369
FAX 777-6937

LAND QUALITY
(307) 777-7756
FAX 777-5864

SOLID & HAZ. WASTE
(307) 777-7752
FAX 777-5973

WATER QUALITY
(307) 777-7781
FAX 777-5973






Dave Freudenthal, Governor

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



John Corra, Director

NOTIFICATION OF COVERAGE

June 2, 2005

Carl & Carol Pengra
22745 151st Avenue
Boxelder, SD 57719

RE: Pengra Residential Septic System, Permit # 05-261

Dear Carl and Carol:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of a small wastewater septic system in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. **You are required to submit a minimum of two (2) photos of the system installation and the Certificate of Completion to this office no later than 60 days following the installation.** All construction, installation, or modification allowed by this permit shall be completed by June 1, 2006.

On August 4, 2004, the Crook County Commissioners enacted Resolution NO. 9-2004. This resolution requires that ALL small wastewater treatment facilities permitted by the Wyoming Department of Environmental Quality (WDEQ) and installed in Crook County after September 1, 2004, MUST BE INSPECTED BY AN INSPECTOR DESIGNATED BY CROOK COUNTY.

Please contact the Crook County Clerks Office for requirements of this resolution.

If you have any questions please contact me at 1866 S. Sheridan Avenue 673-9337, 673-2213 (fax).

Thank you

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQ NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Crook County Clerk, P.O. Box 37, Sundance, WY 82729
Shoun's Plumbing & Heating, Box 994, Sundance, WY 82729

Page 1 of 1



AS-BUILT
PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 05-262

Jim Licking AS-BUILT Residential Septic System

This permit hereby authorizes the applicant:

Jim Licking
P.O. Box 62
Guernsey, Wyoming 82214

to have constructed and installed a 3 bedroom residential septic system with septic tank and perforated pipe and rock leachfield (in 1997) according to the procedures and conditions of the application number 05-262. The facility is located in the SE 1/4 of Section 5, Township 26N, Range 66W, in the county of Platte, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, meets applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.


The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee has constructed and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality

7/21/05

Date of Issuance


RLE/jc/5-0810

cc: Platte County Planner, Marlin Johnson, P.O. Box 728, Wheatland, Wyoming 82201
Jerry Barnes, 8528 South Jay Lane, Morrison, Colorado 80465

P:50007.DOC



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

CERTIFIED MAIL

November 1, 2005

Jim Licking
P.O. Box 62
Guernsey, WY 82214

RE: As-Built Septic System **Permit No. 05-262: INVALID**

Dear Mr. Licking:

On August 26, 2005 Ronald Ewald of the Wyoming Department of Environmental Quality / Water Quality Division (WQD) was on-site to inspect the septic system approved by this as-built permit at the request of the purchaser of the property. A summary of the findings and conclusions follow.

The applicable standards of Chapter 11 of the Water Quality Rules and Regulations(WQR&R) concerning septic systems which were inspected/examined included the following:

- A. Minimum soil absorption system sizing as required by Section 38(a), calculated to be 978 sq. ft. based on 3 bedrooms and a soil percolation rate of 20 minutes per inch, and
- B. Required minimum separation distance between water supply well and leachfield as required by Section 35(a)(i) equal to 100 feet.

The as-built application represented the following:

- 1. The leachfield contained 990 sq. ft. of infiltrative surface area configured in two 165-foot long, 2 foot wide trenches, with 6 inches of rock beneath the perforated leach pipe.
- 2. The nearest point of the leachfield to the water supply well was 150 feet.

The inspection found the following:

- a. The trench nearest to the well (first trench) cannot be 150 feet from the well. That would put it directly in front of the dog kennel area on the east side of the barn. There is only a maximum of about 40 feet of trench run available in front of the kennel, not 165 feet as shown on the plans, let alone a second trench beyond that.
- b. If the first trench is directly in front of the barn as shown on the submitted plans, it still cannot be 165 feet long because there is only about a maximum of 80 feet of trench run available in this location.

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH
(307) 777-7758
FAX 777-3610

ABANDONED MINES
(307) 777-6145
FAX 777-6462

AIR QUALITY
(307) 777-7391
FAX 777-5616

INDUSTRIAL SITING
(307) 777-7369
FAX 777-6937

LAND QUALITY
(307) 777-7756
FAX 777-5864

SOLID & HAZ. WASTE
(307) 777-7752
FAX 777-5973

WATER QUALITY
(307) 777-7781
FAX 777-5973



- c. There is a relatively level, but narrow, "finger" of land, which extends out from the main flat working plateau area where leachfield trenches could possibly be extended. However, if the trenches shown on the plan do line up with this finger of land, then they are probably about 100 feet, to maybe a maximum, of 120 feet long.
- d. Additionally, if the first trench does line up with this finger of land, then it is only about 88 feet from the well, not the 150 feet reported in the application. In addition, this would place it in the middle of the driveway, which was not indicated on the application submittal, and is a very bad location for a leachfield trench.

Based on the above inspection findings, the WQD comes to the following conclusions:

- I. Using the 20 minute per inch percolation rate, 2 foot wide trench with 6" of rock under the pipe, and 3 bedrooms, as indicated in the application; two trenches at a maximum of 120 feet long (from the on-site inspection) would provide only 74% of the required minimum infiltrative surface area. Therefore, at the most generous, the leachfield is at least 26% too small, and probably more like 40% or even 50% too small.
- II. The nearest point of the as-built leachfield may or may not be less than 100 feet from the water supply well in violation of Section 35(a)(i). It is impossible to know since so many of the submitted application dimensions are inconsistent with the actual measurements found during the on-site inspection.
- III. The information and measurements submitted in the as-built application are not accurate. Furthermore, when realistic measurements and dimensions are used to do compliance calculations, the leachfield is at least 26% too small, and probably even more than that.

Therefore, based on the findings and conclusions listed above;

As-Built Permit No. 05-262 is Found to be: INVALID and NULL & VOID,

because it was issued based on inaccurate information, which if it were accurate would result in a system shown to be in non-conformance with the applicable standards of the WQR&R.

If you should have any questions please call me at (307) 777-6183.

Sincerely;




Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division
RLE/jc/5-1192

cc: Jerry Barnes, P.O. Box 332, Guernsey, Wyoming 80221
Permit No. 05-262 file



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 2, 2005

Mr. Herman Noe, Manager of Engineering
Cheyenne Board of Public Utilities
P.O. Box 1469
Cheyenne, WY 82003-1469

RE: WAFB / Snyder Avenue Relief Sewer Main Project, Application No.05-263, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Sewage Collection Systems described as 3411 ft of 18" diameter replacement sewer, 895 ft of 15" diameter sewer replacement and 3116 ft of pipe bursting upgrade to 15" diameter sewer line, NW 1/4 Section 31 T14N R66N; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by July 24, 2007.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 05-263 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon, PE-PG
Southeast District Engineer
Water Quality Division

cc: IPS Cheyenne

Jeff Pecenka, Cheyenne BOPU
2406 Snyder Avenue
Cheyenne WY 82001

LBH/jc/5-0634

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

PERMIT TO CONSTRUCT

PERMIT NO. 05-264

Daniel Junction Food Mart
PWS: WY5601517N

This permit hereby authorizes the applicant:

Gene Lippincott
P.O. Box 383
Daniel, WY 83115

to construct a chlorinator at the well head of the existing water system, a water distribution system extension, sewage collection system and septic system for a new RV park, and an RV dump station with a 2,000 gallon holding tank according to the procedures and conditions of the application number 05-264. The facility is located in the NW1/4 Section 29, T34N, R111W in the county of Sublette, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by September 30, 2007.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality/ Water Quality Division, Southwest District, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, fax 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division

7/15/05
Date of Issuance


John V. Corra
Director
Department of Environmental Quality

DHC/dc/jc/5-0790

cc: Sublette County Sanitarian; P.O. Box 722; Pinedale, WY 82941
Sublette County Planning; P.O. Box 506; Pinedale, WY 82941

File: Daniel Junction Food Mart, Sublette County
Chron

STATEMENT OF BASIS


1. Permit Number: 05-264
2. Application reviewed for compliance with the following regulations :
Chapters 3, 11 and 12 of the Wyoming Water Quality Rules and Regulations
3. Does the permit comply with all applicable regulations identified above?
Yes
4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3.
Not Required
5. Documentation of Statement of Basis: The archives file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle H. Conklin, Southwest District Engineering Supervisor, and completed on July 12, 2005. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 7, 2005

RaJean Strube-Fossen
Strube Construction, LLC
P.O. Box 1654
Lander, WY 82520

RE: Water Line and Sewer Line for Indian Lookout 5th Addition; Permit Number: 05-265, Section 13, T33N, R100W, Fremont County, PWS #WY5600176C

Dear Mrs. Strube-Fossen:

The above application for coverage under General Permit to install about 1,100 linear feet of 8-inch waterline, extension of a public water supply distribution system, and about 1,000 linear feet of 8-inch sewer line, extension of an existing sewer collection in accordance with Chapter 3, Section 7; Chapter 11, Section 9; and Chapter 12, Section 14; of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved with the following condition:

In accordance with Chapter 12, Section 14(i), the appropriate backflow prevention device shall be required for each water service connection (i.e., dual check valves are restricted to residential and domestic services).

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.
Environmental Engineer
Water Quality Division

cc: IPS, Cheyenne
Roger Strube, P.E., Strube-Banner Engineering, 1575 North 4th St. Suite 105, Laramie, WY 82072
Mickey Simmons, City of Lander, 125 Buena Vista Drive, Lander, WY 82520

encl: General Permits For a Public Water Supply Distribution System and Sewage Collection System

Lander Field Office • 250 Lincoln Street • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 24, 2005

Roy Runia, Owner
690 E. Sunnyside Lane
Thermopolis, WY 82443

RE: Runia's Small Wastewater Treatment Facility, Permit Number: 05-266, Section 4, T43N, R94W, Hot Springs County

Dear Mr. Runia:

The above application for coverage under General Permit to construct a gravity flow septic tank and leachfield in accordance with Chapter 3, Section 7; and Chapter 11, Part D of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.
Environmental Engineer
Water Quality Division

xc: IPS, Cheyenne
Lee Campbell, Hot Springs County, 415 Arapahoe, Thermopolis, WY 82443

encl: General Permit For a Small Wastewater Facility

Lander Field Office • 250 Lincoln Street • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726


WATER QUALITY
(307) 332-3144
FAX 332-3183





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

September 7, 2005

Ben Doud
Doud BTS
780 Simms Street, Suite 104
Golden, CO 80401

RE: Rock Springs -Schlumberger Water and Sewer Main Extensions -Permit Number 05-267R, NW1/4 Section 15, T19N, R105W, Sweetwater County, PWS # WY5601182

Dear Mr. Doud:

The above application for coverage under General Permits to Construct a public water supply distribution system extension consisting of 1498 linear feet (LF) of 8 - inch and 573 LF of 6-inch PVC water main and a sewage collection system extension consisting of 961 LF of 6-inch and 339 LF of 4-inch PVC sewer main in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.
Environmental Senior Analyst
Water Quality Division

xc: ✓IPS, Cheyenne

encl: General Permit for Public Water Supply Distribution System,
General Permit for a Sewage Collection System

Page 1 of 1

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726


SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

September 29, 2005

Mr. Mark Hettinger
Hettinger Real Estate, LLC
P.O. Box 1564
Gillette, WY 82901

RE: **Hettinger Realty Development –Water Distribution System, Permit No. 05-268RR;**
S 1/2 Section 11 and NW1/4 SW1/4 Section 12, T18N, R106W, Sweetwater County;
PWS #WY5601182

Dear Mr. Hettinger:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to Existing Public Water Supply Distribution Systems in accordance with Chapter 3, Section 7 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved.

You are authorized to construct, install or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Doyle H. Conklin, P.E.
SW District Engineering Supervisor
Water Quality Division

cc: IPS, Cheyenne
Sweetwater County Planner; 80 West Flaming Gorge Way; Green River, WY 82935
Joint Powers Water Board; Attn: Bryan Seppie, P.E.; P.O. Box 1299, Green River, WY 82935
encl.: General Permit for Extensions to Existing Public Water Distribution Systems

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726


SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 27, 2005

Scope Properties LLC
Attn: Bryce Hunter, Member
1319 Pinecrest
Riverton, Wyoming 82501

RE: #27 Reservoir Drive, Lake Shore Tracts: Septic System,
Location: NW ¼, Section 14, T29N, R68W,

Application No. **05-269**
Platte County

Dear Mr. Hunter:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a **1 bedroom modular cabin** in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on June 30, 2007. Please reference Application Number 05-269 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald, P.E.
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/jc/5-0720

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Ron Millikin, Millikin Drilling, P.O. Box 217, Glendo, Wyoming 82213
Platte County Planner, Marlin Johnson, P.O. Box 728, Wheatland, Wyoming 82201

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

August 5, 2005

Wayne Johnson
Mesa Investments
P.O. Box 1664
Rock Springs, WY 82902

RE: Fairway Estates Phase 3 Subdivision, Water and Sewer Main Extensions -Permit Number 05-270R, NE1/4 Section 9, T19N, R105W, Sweetwater County

Dear Mr. Johnson:

The above application for coverage under General Permits to Construct a public water supply system extension consisting of 1265 linear feet (LF) of 8 - inch PVC water main and a sewage collection system extension consisting of 773 LF of 8-inch PVC sewer main to serve 16 lots in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.
Environmental Senior Analyst
Water Quality Division

xc: ✓ IPS, Cheyenne

encl: General Permit for Public Water Supply Distribution System,
General Permit for a Sewage Collection System

Page 1 of 1






Dave Freudenthal, Governor

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



John Corra, Director

NOTIFICATION OF COVERAGE

June 2, 2005

Mr. Jimmy G. Long
P.O. Box 156
Newcastle, WY 82701

RE: James Long Small Wastewater System, Permit # 05-272

Dear James:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of a small wastewater septic system in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You were authorized to construct, install, or modify the facility at **which lies in the NE1/4 of Section 33 in Township 46 North, Range 61 West** in accordance with general permit and the materials submitted in your application package.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. **A minimum of two (2) photos of the system installation, gravel and pipe or set infiltrators shall accompany the Certificate of Completion submitted to this office.** All construction, installation, or modification allowed by this permit shall be completed by June 1, 2006.

If you have any questions please contact me at 1866 S. Sheridan Avenue 673-9330, 673-2213 (fax).

Thank you

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQ NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Kurt Kremke, Weston County Assessor
LA Helms, P.O. Box 572, Newcastle, WY 82701

Page 1 of 1



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 05-274

Land Application of Produced CBM Water, County Line CBM Project-Pivot 10

This permit hereby authorizes the applicant:

Anadarko Petroleum Corporation
PO Box 1689
Gillette, WY 82717

to construct, install, or modify a land application water system for produced CBM discharge water according to the procedures and conditions of the application number 05-274. The facility is located in Section 21, Township 48 North, Range 77 West in the county of Johnson, in the State of Wyoming. This permit shall be effective until July 1, 2008.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the land application described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the land application is located for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor: any infringement of federal, state or local laws or regulations.

The permittee shall conduct permitted land application in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will provide immediate oral or written notice to the DEQ/WQD Northeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 4 The applicant shall submit an annual report to the department providing relevant details of the land application, including quantity of water applied, quality of water applied, type and quantity of soil amendments applied, any violations of DEQ regulations (NPDES or groundwater), soil sampling data from the land receiving the water, photographs and any other information deemed applicable by the department.
- 3 of 4 Within sixty days of completion of the land application, the applicant will submit to the DEQ/WQD Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Dates that the land application was initiated and terminated for the irrigation season; and
 - b. Certification the land application was performed in accordance with the terms and conditions of the permit; or
 - c. Certification the land application was completed with changes or modifications. Submittal of documentation of the land application sites where the changes or modifications were performed if appropriate. All modifications or deviations from the authorized plans must be highlighted; and
 - d. Landowner certification and applicable documentation that the site has been properly reclaimed.

4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

6/27/05
Date of Issuance

PEWbb/5-0710.ltr
cc: WDEQ Sheridan Field Office, Casper Field Office

STATEMENT OF BASIS

1. Permit Number: 05-274
2. Application reviewed for compliance with the following applicable regulations :
 - a. Chapter 11.
3. Does the permit comply with all applicable regulations identified above?
 - a. Yes
4. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.

The water is being applied at an agronomic rate determined by soil testing to prevent groundwater impacts.

5. Documentation of Statement of Basis.

The archive file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Paul Wollenzien, Northeast District Senior Analyst and Dennis Lamb, Northeast District Supervisor, and completed on June 16, 2005. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."

PW/bb/5-0710.ltr



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

June 26, 2008

Mr. Tim Kalus
Anadarko Petroleum
1400 East Lincoln Avenue
Gillette, WY 82716

RE: Anadarko County Line Project, Skewed Land Application
Permit Nos. 05-274

Dear Mr. Kalus:

On June 27, 2008, the Wyoming Department of Environmental Quality, Water Quality Division (WDEQ/WQD) issued the above referenced Permit to Construct. The construction, installation and operation of the land application expired on July 1, 2008. Please notify this office within 30 days of the date of this letter if you wish to renew the Permit to Construct and continue to operate the land application facility referenced above. After 30 days, the permit will be considered expired and any land application after that date will be considered a violation of Wyoming Water Quality Rules and Regulations.

If there are any questions concerning this matter, please call Kim Medina at (307) 473-3476, or contact her at kmedin@state.wy.us, or 152 North Durbin, Suite 100, Casper, Wyoming 82601.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
Wyoming Department of Environmental Quality

Enclosures

cc: IPS, Cheyenne
WDEQ file



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 05-275

Land Application of Produced CBM Water, Big George CBM Facility

This permit hereby authorizes the applicant:

Petrox Resources, Inc.
39868 Hwy 13
Meeker, CO 81641

to construct, install or modify a land application water system for produced CBM discharge water procedures and conditions of the application number 05-275. The facility is located in SE/4 of Section 22 and NE/4 of Section 27, Township 48 North, Range 77 West in the county of Johnson, in the State of Wyoming. This permit shall be effective until June 1, 2008.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the land application described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the land application is located for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor: any infringement of federal, state or local laws or regulations.

The permittee shall conduct permitted land application in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1 of 4 The applicant will provide immediate oral or written notice to the DEQ/WQD Northeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.


2 of 4 The applicant shall submit an annual report to the department providing relevant details of the land application, including quantity of water applied, quality of water applied, type and quantity of soil amendments applied, any violations of DEQ regulations (NPDES or groundwater), soil sampling data from the land receiving the water, photographs and any other information deemed applicable by the department.


3 of 4 Within sixty days of completion of the land application, the applicant will submit to the DEQ/WQD Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:

- a. Dates that the land application was initiated and terminated for the irrigation season; and
- b. Certification the land application was performed in accordance with the terms and conditions of the permit; or
- c. Certification the land application was completed with changes or modifications. Submittal of documentation of the land application sites where the changes or modifications were performed if appropriate. All modifications or deviations from the authorized plans must be highlighted; and
- d. Landowner certification and applicable documentation that the site has been properly reclaimed.

4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

6/8/05
Date of Issuance

PEW/jc/5-0652

cc: WDEQ Sheridan Field Office, Casper Field Office

STATEMENT OF BASIS

1. Permit Number: 05-275
2. Application reviewed for compliance with the following applicable regulations :
 - a. Chapter 12.
3. Does the permit comply with all applicable regulations identified above?
 - a. Yes
4. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.

The water is being applied at an agronomic rate determined by soil testing to prevent groundwater impacts.

5. Documentation of Statement of Basis.


The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Paul Wollenzien, Northeast District Senior Analyst and Dennis Lamb, Northeast District Supervisor, and completed on June 6, 2005. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

July 7, 2008

Mr. Michael J. Clark
Petrox Resources, Inc.
39868 Highway 13
Meeker, Colorado 81641

RE: Petrox Resources, Big George CBM Facility, Land Application Project
Permit #05-275

Dear Mr. Clark:

On July 8, 2005, the Wyoming Department of Environmental Quality, Water Quality Division (WDEQ/WQD) issued the above referenced Permit to Construct. The construction, installation and operation of the land application expired on June 1, 2008. Please notify this office within 30 days of the date of this letter if you wish to renew the Permit to Construct and continue to operate the land application facility referenced above. After 30 days, the permit will be considered expired and any land application after that date will be considered a violation of Wyoming Water Quality Rules and Regulations.

If there are any questions concerning this matter, please call Kim Medina at (307) 473-3476, or contact her at kmedin@state.wy.us, or 152 North Durbin, Suite 100, Casper, Wyoming 82601.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
Wyoming Department of Environmental Quality

cc: IPS, Cheyenne
WDEQ file





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

July 7, 2008

John Bettridge
Southwestern Production Corporation
1675 Larimer Street, #820
Denver, CO 80202

RE: Duck Creek POD Land Application Project
Permit #05-276

Dear Mr. Bettridge:

On June 8, 2005, the Wyoming Department of Environmental Quality, Water Quality Division (WDEQ/WQD) issued the above referenced Permit to Construct to Comet Oil. The construction, installation and operation of the land application expired on June 1, 2008. We understand that Southwestern Production Corporation acquired the operation of this facility. Please notify this office within 30 days of the date of this letter if you wish to renew the Permit to Construct and continue to operate the land application facility referenced above. After 30 days, the permit will be considered expired and any land application after that date will be considered a violation of Wyoming Water Quality Rules and Regulations. If you wish to renew your permit, compliance with all permit conditions must be achieved prior to issuance of a permit renewal. Further a transfer of ownership, transferring the permit to Southwestern Production Company, will also need to be completed.

If there are any questions concerning this matter, please call Kim Medina at (307) 473-3476, or contact her at kmedin@state.wy.us, or 152 North Durbin, Suite 100, Casper, Wyoming 82601.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
Wyoming Department of Environmental Quality

Enclosures: Transfer of Ownership

cc: IPS, Cheyenne
WDEQ file



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 05-278

Land Application of Produced CBM Water, County Line CBM Project-Pivot 1

This permit hereby authorizes the applicant:

Anadarko Petroleum Corporation
PO Box 1689
Gillette, WY 82717

to construct, install or modify a land application water system for produced CBM discharge water according to the procedures and conditions of the application number 05-278. The facility is located in SE/NE/4Section 32, Township 48 North, Range 77 West in the county of Johnson, in the State of Wyoming. This permit shall be effective until July 1, 2008.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the land application described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the land application is located for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor: any infringement of federal, state or local laws or regulations.


The permittee shall conduct permitted land application in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:


- 1 of 4 The applicant will provide immediate oral or written notice to the DEQ/WQD Northeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 4 The applicant shall submit an annual report to the department providing relevant details of the land application, including quantity of water applied, quality of water applied, type and quantity of soil amendments applied, any violations of DEQ regulations (NPDES or groundwater), soil sampling data from the land receiving the water, photographs and any other information deemed applicable by the department.
- 3 of 4 Within sixty days of completion of the land application, the applicant will submit to the DEQ/WQD Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Dates that the land application was initiated and terminated for the irrigation season; and
 - b. Certification the land application was performed in accordance with the terms and conditions of the permit; or
 - c. Certification the land application was completed with changes or modifications. Submittal of documentation of the land application sites where the changes or modifications were performed if appropriate. All modifications or deviations from the authorized plans must be highlighted; and
 - d. Landowner certification and applicable documentation that the site has been properly reclaimed.

4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality

7-1-05

Date of Issuance

PEW/bb/5-0749.ltr
cc: WDEQ Sheridan Field Office, Casper Field Office

STATEMENT OF BASIS

1. Permit Number: 05-278
2. Application reviewed for compliance with the following applicable regulations :
 - a. Chapter 11.
3. Does the permit comply with all applicable regulations identified above?
 - a. Yes
4. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.

The water is being applied at an agronomic rate determined by soil testing to prevent groundwater impacts.

5. Documentation of Statement of Basis.

The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Paul Wollenzien, Northeast District Senior Analyst and Dennis Lamb, Northeast District Supervisor, and completed on June 16, 2005. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."

PEW/bb/5-0749.ltr



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

July 7, 2008

Mr. Tim Kalus
Anadarko Petroleum
1400 East Lincoln Avenue
Gillette, WY 82716

RE: Anadarko County Line Project, Oxbow Pivot 1
Permit Nos. 05-278

Dear Mr. Kalus:

On July 1, 2005, the Wyoming Department of Environmental Quality, Water Quality Division (WDEQ/WQD) issued the above referenced Permit to Construct. The construction, installation and operation of the land application expired on July 1, 2008. Please notify this office within 30 days of the date of this letter if you wish to renew the Permit to Construct and continue to operate the land application facility referenced above. After 30 days, the permit will be considered expired and any land application after that date will be considered a violation of Wyoming Water Quality Rules and Regulations.

If there are any questions concerning this matter, please call Kim Medina at (307) 473-3476, or contact her at kmedin@state.wy.us, or 152 North Durbin, Suite 100, Casper, Wyoming 82601.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
Wyoming Department of Environmental Quality

cc: IPS, Cheyenne
WDEQ file





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 17, 2005

Manuel Lopez, President
Snow King Resort, Inc.
P.O. Box SKI
Jackson, WY 83001

RE: Cache Creek I & II Condominiums Water Lines and Sewer Line, Permit Number: 05-279,
Section 34, T41N, R116W, Teton County

Dear Mr. Lopez:

The above application for coverage under General Permit to install 8 and 6-inch water lines, extensions of a public water supply distribution system, and 8-inch sewer line, extension of an existing sewer collection, in accordance with Chapter 3, Section 7; Chapter 11, Section 9; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved provided:

In accordance with Chapter 12, Section 14(i), the appropriate backflow prevention device shall be required for each water service connection (i.e., dual check valves are restricted to residential and domestic services).

You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.
Environmental Engineer
Water Quality Division

xc: IPS, Cheyenne
Shawn O'Malley, P.E., Town of Jackson, P.O. Box 1687, Jackson, WY 83001
Matt Bowers, P.E., Nelson Engineering, P.O. Box 1599, Jackson, WY 83001

encl: General Permits For a Public Water Supply Distribution System and Sewage Collection System

Lander Field Office • 250 Lincoln Street • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

July 21, 2005

John Bragg
1409 Bridger Street
Laramie, Wyoming 82070

RE: John Bragg Residential Septic System,
Location: NW ¼, Section 10, T19N, R81W,

Application No. **05-280**
Carbon County

Dear Mr. Bragg:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on July 21, 2007. Please reference Application Number **05-280** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald, P.E.
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/bb/5-0819.ltr

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne

Ben Jordan, P.G., Weston Engineering, 1050 N. 3rd St., Ste. E, Laramie, WY 82072
Carbon County Planning Director, Jonathan Schnal, 215 W. Buffalo Street, #304,
P.O. Box 487, Rawlins, Wyoming 82301

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH
(307) 777-7758
FAX 777-3610

ABANDONED MINES
(307) 777-6145
FAX 777-6462

AIR QUALITY
(307) 777-7391
FAX 777-5616

INDUSTRIAL SITING
(307) 777-7369
FAX 777-6937

LAND QUALITY
(307) 777-7756
FAX 777-5864

SOLID & HAZ. WASTE
(307) 777-7752
FAX 777-5973

WATER QUALITY
(307) 777-7781
FAX 777-5973



PERMIT TO CONSTRUCT

New
 Renewal
 Modified

PERMIT NO. 05-281
SPECIAL CONDITIONS: (8)
REF/PERMIT NO.

Dinklage Feed Yard, Torrington, Wyoming

This permit hereby authorizes the applicant:

Dinklage Feed Yard
5596 US Highway 26
Torrington WY 82240

to construct, install or modify monitoring wells according to the procedures and conditions of the application number 05-281. The facility is located in S 19; T24N; R60W in the county of Goshen, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by 15 June 2010.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

The permittee shall notify representatives from the DEQ, Water Quality Division the day construction commences and give an estimate of completion of the project. The authorized representative in your area can be contacted at the following address: Groundwater Pollution Control Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002; telephone (307) 777-7781; FAX (307) 777-5973.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 8 The applicant will provide immediate oral or written notice to the DEQ/WQD Groundwater Pollution Control Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 8 No monitoring well/piezometer shall be abandoned without prior approval from the Water Quality Division. After the monitoring well(s)/piezometer(s) have fulfilled their purpose, they shall be abandoned according to procedures specified in Chapter XI, Part G, Section 70 of Wyoming Water Quality Rules and Regulations. In addition, borings in public use areas, particularly paved streets and alleys, shall be abandoned in accordance with City and/or Highway Department requirements.
- 3 of 8 WDEQ/WQD personnel shall be given at least two (2) weeks notice prior to the installation of monitor well(s)/piezometer(s) and sample collection so that they may be on site if deemed necessary.
- 4 of 8 The applicant is responsible for obtaining any Permits required by the State Engineer's Office (777-7354).
- 5 of 8 The results of any other analyses conducted on soil or water removed from these wells/piezometers or boreholes shall be provided to the department as soon as they are available.
- 6 of 8 Environmental Monitoring Program for Groundwater of the State:
 - a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity and performed in accordance with WDEQ or EPA approved Standard Procedures or Quality Assurance/Quality Control (QA/QC) Plan.
 - b. The permittee shall maintain records of all monitoring information for a period of at least 3 years.
 - c. Records of monitoring information shall include:
 - i. The date, exact place, and time of sampling or measurements;
 - ii. The name(s) of individual(s) who performed the sampling or measurements;
 - iii. The Mean Sea Level elevation of the water table to the closest .01 ft., and the depth to water (to the closest .01 ft.) from a marked measuring point at the top of casing;
 - iv. Sampling procedures and sample preservation accomplished;
 - v. The date(s) analyses were performed;
 - vi. Names of individuals who performed the analyses;
 - vii. The analytical techniques or methods used;
 - viii. The results of such analyses,
 - ix. The latitude and longitude of each well (obtained with GPS), and;
 - x. Monitor wells shall be sampled and the groundwater analyzed as indicated on the following table:


WELL NAME OR NUMBER	SAMPLING FREQUENCY	ANALYTICAL METHOD(S)	PARAMETER(S) ANALYZED	PERMIT LIMIT*
MW-2, MW-7 MW-8 MW-14 MW-15	See condition #7	EPA 350.1 EPA 353.2 Standard 2540C TDS Meter	ammonia as N; nitrate +nitrite as N; total dissolved solids; water levels	0.5 10.0 None

*Permit Limits (i.e. Groundwater Protection Standards) are only required for compliance monitoring wells. All chemical concentrations in this permit are expressed in mg/l unless otherwise noted.


7 of 8 These five (5) new monitoring wells shall be added to the existing sampling program. Initial water quality samples shall be reported to the WDEQ/WQD within 30 days of well completion.

8 of 8 The results of these analyses shall be submitted to the Cheyenne office at the following address: Groundwater Pollution Control Office, State of Wyoming, DEQ, Water Quality Division, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002 by the last day of the month following the end of each reporting period. The first set of results are due no later than January 1, 2006.

AUTHORIZED BY:



John Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality


6/5/05
Date of Issuance

JAP/jc/5-0629

cc: Kevin Frederick, John Passehl



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

June 6, 2005

Mr. Rex Trumbull
Dinklage Feed Yard, Inc.
5596 US Highway 26
Torrington, WY 82240

RE: Approval of proposed monitoring wells for Dinklage Feed Yard, Inc., Torrington, WY

Dear Mr. Trumbull:

The Wyoming Department of Environmental Quality (WDEQ) has reviewed the proposed monitoring wells for this facility. The purpose of this letter is to approve the proposed wells via permit (**Permit No. 05-281**) in accordance with WDEQ Water Quality Rules and Regulations, Chapter III.

Please contact me at 307-777-5623, or Kevin Frederick at 307-777-5985 if you have any questions about this letter or our expectations for this site.

Sincerely,

John A. Passehl, P.G.
Program Principal
Water Quality Division

JAP/jc/5-0632

Attachment: WDEQ Permit No. 05-281

cc: Steven B. Hoffman, P.G., Lidstone and Associates, Inc., 4025 Automation Way, Building E,
Fort Collins, CO 80525-3448
Kevin Frederick, WDEQ Program Supervisor
Lou Harmon, WDEQ WW District Engineer



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 05-282

Grand Teton National Park Visitor Center, Moose, Wyoming
PWS #5680093

This permit hereby authorizes the applicant:

Thayne O'Brien, Contracting Officer
National Park Service - Grand Teton National Park
Post Office Drawer 170
Moose, WY 83012

to install a 10-inch, 8-inch and 2-inch water lines, extensions of a public drinking water system; and to install a lift station, a 4-inch force main, cleanouts, and a connection to the existing sewer plant; according to the procedures and conditions of the application number 05-282. The new utilities will serve a new visitors center that will replace an existing one. The facility is located within Section 36, Township 43 North and Range 116 West in the county of Teton, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by June 24, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not


relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Northwest District Engineer, 250 Lincoln Street, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
- a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Cojra
Director
Department of Environmental Quality

6/27/05
Date of Issuance

JSB/jsb/jc/5-0716

STATEMENT OF BASIS

1. Permit Number: 05-282
2. Application reviewed for compliance with the following regulations:
Chapters 3, 11, and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?[COMMENT2] Yes
4. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.
No
5. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected. [COMMENT3]
Public water supplies and sewerage systems are exempted from review by Chapter 3, Section 17.
6. Documentation of Statement of Basis: The archives file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by James S. Brough, jbroug@state.wy.us, Environmental Engineer and completed on June 24, 2005. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

Xc: Dave Dufault, P.E., Nelson Engineering, P.O. Box 1599, Jackson, WY 83001



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 8, 2005

Mr. Gary Gerhard, Facilities Manager
City of Torrington
2042 East A
Torrington, WY 82240

RE: Torrington Olive Acres Sewer Improvement, Application No.05-283,Goshen County

Dear Mr. Gerhard:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Sewage Collection Systems described as 780 ft of replacement 8" diameter sewer and 5 manholes, SW 1/4 Section 10 T24N R61W; Goshen County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by July 24, 2007.

The sewer line shall be installed a minimum grade of 0.002 ft/ft or 0.2ft of fall per 100 ft as per the DEQ/WQD flat grade policy.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 05-283 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

cc: IPS, Cheyenne

Anthony Niederhauser, Baker & Assoc.
120 East 16th Street Suite A
Scottsbluff, NE 69361

LBH/jc/5-0660

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH
(307) 777-7758
FAX 777-3610

ABANDONED MINES
(307) 777-6145
FAX 777-6462

AIR QUALITY
(307) 777-7391
FAX 777-5616

INDUSTRIAL SITING
(307) 777-7369
FAX 777-6937

LAND QUALITY
(307) 777-7756
FAX 777-5864

SOLID & HAZ. WASTE
(307) 777-7752
FAX 777-5973

WATER QUALITY
(307) 777-7781
FAX 777-5973



LAND APPLICATION PERMIT

X New

PERMIT NO. 05-284
SPECIAL CONDITIONS

This permit hereby authorizes the applicant:

Daniel Wilson
P.O. Box 21094
Cheyenne, WY 82003

to land apply truck wash water according to the procedures and conditions of the application number 05-284. The application site is located in the NE 1/4 Section 28 T14N R65W in the county of Laramie, in the State of Wyoming. This permit shall be effective until June 7, 2010.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the land application described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the land application. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 3 The permittee shall provide immediate oral or written notice to Southeast District Engineer/Water Quality Division, 122 West 25th Street, Cheyenne, WY 82202, 307-777-7088 in accordance with the provisions of Section 9, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
- 2 of 3 The review and approval of this permit is based upon the items identified in the attached Statement of Basis.

3 of 3 Application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.

AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality

6/19/05

Date of Issuance

LBH/jc/5-0654

cc: Gary Hickman, Laramie County Environmental Health Department

STATEMENT OF BASIS

1. Permit Number: 05-284
2. Application reviewed for compliance with the following applicable regulations :
Chapters 3 and 11 of the Wyoming Water Quality Rules and Regulations
3. Does the permit comply with all applicable regulations identified above?

YES

Land application limited by the requirements of this permit does not allow infiltration to the vadose zone or groundwater.

4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.
5. Documentation of Statement of Basis: The archives file for this permit include adequate documentation of all sections of this Statement of Basis.


CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon PE-PG, Southeast District Engineer, lharmon@state.wy.us, and completed on June 8, 2005. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 2, 2005

Mr. Mike Cole
Assistant Public Works Director
City of Sheridan
P.O. Box 848
Sheridan, WY 82801

RE: Cloud Peak Ranch-First Filing, Transfer of Ownership of #04-034, New Permit # 05-285
PWS# 5600052

Dear Mike:

The above application for coverage has been transferred to the City of Sheridan Ownership. Don Roberts or his associates have completed all construction, installation, or modification allowed by WDEQ Permit #04-034. All conditions or requirements from the original permit have now been transferred to the City of Sheridan.

If you have any questions please contact me at 673-9337.

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQ NE District Senior Environmental Analyst


cc: IPS, Cheyenne
Jeff Feck, PE, TSP Two, Inc., One S. Scott St., Sheridan, WY 82801
Don Roberts, System Land Ranch LLC, 2 Soldier Creek Rd., Sheridan, WY 82801

Page 1 of 1





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 2, 2005

Mr. Mike Cole
Assistant Public Works Director
City of Sheridan
P.O. Box 848
Sheridan, WY 82801

RE: Sheridan Wesleyan Church Building Addition, Transfer of Ownership of #04-019, New Permit # 05-286
PWS# 5600052

Dear Mike:

The above application for coverage has been transferred to the City of Sheridan Ownership. The Sheridan Wesleyan Church or their associates have completed all construction, installation, or modification allowed by WDEQ Permit #04-019. All conditions or requirements from the original permit have now been transferred to the City of Sheridan.

If you have any questions please contact me at 673-9337.

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQ NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Moses Jacobs, PE, 237 N. Main St., No. 2B, Sheridan, WY 82801
Chuck Lucas, Sheridan Wesleyan Church, 404 E. Brundage Ln., Sheridan, WY 82801



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 05-287R

Reference Permit No. 01-132RR & 03-157R

Jensen Evaporation Facility Project - Pit D - Sublette County

This permit hereby authorizes the applicant:

Bill Fiant, Owner
Anticline Disposal, LLC
12994 Hwy 189
Daniel, WY 83115

to construct a commercial, subtitle C resource conservation and recovery act (RCRA) exempt, oil and gas exploration, 1.4 million barrel wastewater disposal pond (Pit D) permitted to receive produced water only, according to the procedures and conditions of the application number 05-287R. The facility is located at SW1/4 Section 18, T31N, R108W in the county of Sublette, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by August 2, 2007.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 14 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadow View Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

- 2 of 14 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

- 3 of 14 This facility is permitted to treat oil and gas field exploration and production produced water only.

- 4 of 14 A completed operation and maintenance manual for this facility must be submitted to the Southwest District Engineer, State of Wyoming, DEQ, Water Quality Division, 510 Meadow View Drive, Lander, WY 82520. This manual must meet the applicable requirements of Chapter 11, Section 24 of the Wyoming Water Quality Rules and Regulations, and be approved by the DEQ/WQD prior to placing this facility in operation.

- 5 of 14 Validity of this permit is subject to the owner maintaining a bond acceptable to the State of Wyoming DEQ/WQD for the amount of the estimated treatment facility closure and post-closure costs. US Bank National Association, Minneapolis, letter of credit No. SLCMMSP03252 in the amount of One Million Seven Hundred Seventy One Thousand One Hundred and Eight Dollars (\$1,771,108) has been accepted as the reclamation performance bond covering this site. Bonding is subject to review on an annual basis. The closure of this facility shall be in compliance with the submitted plan and Chapter 14 of the Wyoming Water Quality Rules and Regulations, unless the DEQ/WQD determines additional remediation of the site and/or waters of the state are required.

6 of 14 The leak detection system inspection pipes are to be checked weekly for the first month and monthly thereafter with a log kept of the inspection results. If fluid is found, the DEQ/WQD Southwest District is to be notified immediately, and samples are to be pulled from the inspection pipes and the evaporation cell(s) and tested for total petroleum hydrocarbons (TPH) by EPA method 8015 (modified for gasoline and diesel range hydrocarbons), chlorides, total dissolved solids (TDS), and sulfates. Results are to be reported to the DEQ/WQD as soon as they are available.

7 of 14 If fluid is found in the leak detection system, and a leak is verified by observation or sampling and testing, the fluid recirculating system shall be activated to minimize the fluid level under the pond liner and the chance for migration of the fluid to groundwater, until repairs and/or corrective action can be taken.

8 of 14 If a leak in the primary liner of a cell is confirmed, the following monitoring, reporting and repair actions are required:

1. High level alarms on the recirculating leak detection system sumps shall be continuously monitored.
2. The totalizing hour meters shall be read at least weekly.
3. If the recovery rate exceeds 400 gallons per day per acre (gpd/acre) for any sub-cell as delineated by the recovery system, the permittee shall notify the DEQ/WQD within seven (7) days. Repair of the primary liner must be scheduled within 12 months.
4. If the recovery rate exceeds 800 gpd/acre for any sub-cell as delineated by the recovery system, the DEQ/WQD shall be notified within 48 hours. Repair of the primary liner must be scheduled within 60 days.
5. If the high level alarm level is reached, the DEQ/WQD shall be notified immediately. Repair of the primary liner must be initiated immediately.

If fluids are detected in the leak detection system and there is a threat of contamination to groundwater, the DEQ/WQD may require periodic sampling and testing of the groundwater monitoring wells. Required sampling and testing parameters and frequency will be determined by the DEQ/WQD.

9 of 14 Fluids in the evaporation cells are to be sampled and analyzed annually during the fall to determine levels of total petroleum hydrocarbons (TPH) by EPA method 8015 (modified for gasoline and diesel range hydrocarbons), chlorides, total dissolved solids (TDS), and sulfates.


10 of 14 All open-topped tanks shall be covered with netting or screen to prevent the entry of birds and/or other wildlife. The netting or screen shall be constructed so it remains intact and above the surface of the liquid in the tank even during winds up to 80 mph and/or when weighted with snow, ice or rain.

To protect birds and other wildlife, evaporation cells shall be kept virtually oil free at all times, or shall be completely netted or screened to the standards required for open-topped tanks. All produced water received by this facility shall be treated in the receiving and pretreatment facilities to remove hydrocarbons from the produced water before it is discharged to the evaporation cells. If a sheen develops on any part of an evaporation cell, it shall be removed immediately by skimming, use of sorptive materials and/or by the introduction to the evaporation cell(s) of biological cultures that digest hydrocarbons.

- 11 of 14 a) A 1 foot thick compacted clay liner with a max permeability of 1×10^{-5} cm/sec under the second high-density polyethylene liner is required.
- b) The compacted clay liner shall meet the following criteria: The tests for water content and density shall be taken during the placement of each lift of the liner. A total minimum liner thickness of one (1) foot shall be provided and shall be constructed with maximum lifts of one-half (0.5) foot. Either permeability testing of undisturbed core samples from the in-place seal, or detailed tests such as particle size distribution and Atterburg limits shall be conducted. Detailed tests should confirm that the soil specified was used for liner construction. One (1) test shall be conducted per acre per lift. For core sampling of the in-place liner, one (1) core of the completed liner shall be tested per acre. The permittee shall provide the division written certification by a Wyoming registered professional engineer that the soil liner was constructed according to the permit and that final testing indicated results within the allowable limits established by the permit.
- 12 of 14 A security fence shall be maintained around the perimeter of all four disposal pits to prevent domestic life stock; wildlife and non- authorized humans from entering.
- 13 of 14 All exterior dikes and non-gravel/paved areas are to be seeded by the spring of 2006.
- 14 of 14 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

8/17/05
Date of Issuance

MDB/mdb/jc/5-0857

STATEMENT OF BASIS

1. Permit Number: 05 - 287R
2. Application reviewed for compliance with the following regulations:
Chapters 3 and 11 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?
The approval is based upon following the Chapter 20, Section 35 regulations in accordance with Section 5 of Chapter 11.
4. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
This disposal pond is to be lined with a primary 60-mil high-density polyethylene liner along with a secondary containment system consisting of a leak detection system back by a 40-mil high-density polyethylene liner over a 1-foot compacted clay liner. If a leak is detected, there is a recirculation system to return leaking fluids to the pond, thus reducing the hydrostatic head beneath the primary liner, and minimizing migration of the fluids to groundwater. There are also four monitoring wells that monitor groundwater impacts.
5. Documentation of Statement of Basis: The archives file for this permit include adequate documentation of all sections of this Statement of Basis.


CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Mark D. Baron, mbaron@state.wy.us, Environmental Senior Analyst and completed on August 2, 2005. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

cc: Planning and Zoning Administrator, Sublette County Planning and Zoning Office,
P.O. Box 506, Pinedale, WY 82941



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

January 23, 2006

Mr. Robert D. Blake
B Hive, Inc
101 McConnell Street
Laramie WY 82072

Subject: Application Returned Without Action
Application for Permit to Construct 05-288 Snowy Range Addition

Dear Mr. Blake:

The application for permit to construct 05-288 for the Snowy Range Addition Water and Sewer Extensions along with all supporting information is being returned without action. There has not been a response to the application denial and request for additional information mailed to you and your engineer on June 8, 2005. It is the Wyoming Water Quality Division policy to return any application that is inactive for more than six months without any action taken.

If you wish to continue with this project please submit an application for a permit to construct as required by Chapter 3 of the Wyoming Water Quality Division Rules and Regulations (WQD R&R). The application should be accompanied by a design report, plans, and specifications as required by Chapters 11 and 12 of the WQD R&R.

Sincerely:

Louis B. Harmon PE-PG
Southeast District Supervisor
Water and Wastewater Program, Wyoming Water Quality Division

LBH/bb/6-0055.LTR

Enclosures

cc: Coffey and Associates LLC
903 Grand Avenue
Laramie WY 82070



COFFEY ENGINEERING & SURVEYING, L.L.C.

3 E. Grand Avenue, Laramie, Wyoming 82070 • admin@wyocoffey.com • 307.742.7425 • Fax: 307.742.7403



1018.01

RECEIVED

05-288
JUN 17 2005

PLANNING DIVISION
WYOMING

June 15, 2005

Wyoming Department of Environmental Quality
Louis Harmon and Ron Ewald
Herschler Building, 4th Floor West
Cheyenne, Wyoming 82002

Re: Response to review for Snowy Range Addition, Phase 1

Gentlemen:

The purpose of this letter is to address issues cited in your review of the plans and engineering design report for Snowy Range Addition, Phase 1.

Comment 1:

We anticipate a letter will follow from the City of Laramie, stating that the City of Laramie has the capacity to provide water and sewage services for this project.

Comment 2:

We understand that the Notification of Coverage issued will only be applicable to Phase 1.

Comment 3:

It is also understood that when Phase 2 construction is initiated, the water line must be extended to the tie-in at Colorado Avenue.

Comment 4:

Please note that we acknowledge the error on page 3 of 9 of the engineering design report; this letter is intended to reflect the revision to 350 gpd per residential lot.

Please do not hesitate to contact us with any questions or comments regarding this project.

Sincerely,

COFFEY ENGINEERING & SURVEYING

Laura Vandervort, E.I.T.


Reviewed by:

David R. Coffey, P.E., L.S.I.T.

cc: Bob Juve
Bob Blake



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 9, 2005

Brian Sweeney, Public Works Director
City of Douglas
P.O. Box 1030
Douglas, WY 82633

RE: Douglas Springline I-25 Boring Project, Application No.05-289,Converse County

Dear Mr. Sweeney:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems described as lowering, boring and casing Little Box Elder Spring transmission line under I-25, SW 1/4 Section 29 T33N R73W; Converse County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by July 24, 2007.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 05-289 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

cc: IPS, Cheyenne

Thomas Brauer, CEPI
355 North Lincoln Street
Casper, WY 82601

LBH/jc/5-0662

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH
(307) 777-7758
FAX 777-3610

ABANDONED MINES
(307) 777-6145
FAX 777-6462

AIR QUALITY
(307) 777-7391
FAX 777-5616

INDUSTRIAL SITING
(307) 777-7369
FAX 777-6937

LAND QUALITY
(307) 777-7756
FAX 777-5864

SOLID & HAZ. WASTE
(307) 777-7752
FAX 777-5973

WATER QUALITY
(307) 777-7781
FAX 777-5973



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
"AS-BUILT" PERMIT TO CONSTRUCT

PERMIT NO. 05-290

Twenty Mile Plan of Development (POD)

This permit hereby authorizes the applicant:

Windsor Energy Group, LLC.
405 West Boxelder Rd., Suite A
Gillette, Wyoming 82718

to have installed compliance monitoring wells according to the procedures and conditions of the application number 05-290. The facilities are proximal to the on channel coalbed methane produced water impoundments located in Township 54N, Range 72W, Section 18; and Township 55 N, Range 72W, Sections 30, 31, 32 and in the county of Campbell, in the State of Wyoming. All construction, installation, or modification allowed by this permit has been completed.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1 of 2: The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality/ Water Quality Division, Groundwater Program, 1866 South Sheridan Avenue, Sheridan, WY 82801, 307-673-9337, fax 307-672-2213, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 2: Monitoring Requirements:

Groundwater monitoring at the impoundments shall be performed on a quarterly basis until further notice and shall include the following information:

- Measurement of static water level and sampling and analysis of groundwater at monitor wells MW 1, MW 2, MW 4 and MW5 (see constituents listed below);
- Reporting results of quarterly monitoring and sampling to the department by January 15th, April 15th, July 15th, and October 15th of each year. The first set of data will be due by October 15, 2005.

The parameters listed in the table below are required for groundwater compliance monitoring at each impoundment:

12-32-5572 Impoundment (MW 1)

Parameter	Background Value (mg/L)	Trigger Value (mg/L)	Class II Water Quality Standards (mg/L)
Arsenic	0.005	≥ 0.08	0.1
Selenium	<0.005	≥ 0.016	0.02
Sulfate	77	≥ 160	200
Total Dissolved Solids (TDS)	758	≥ 1600	2000
pH	7.26	≤ 6.5	6.5 – 8.5 (s.u)

13-30-5572 Impoundment (MW 2)

Parameter	Background Value (mg/L)	Trigger Value (mg/L)	Class III Water Quality Standards (mg/L)
Arsenic	<0.001	≥ 0.16	0.2
Selenium	0.006	≥ 0.04	0.05
Sulfate	378	≥ 2400	3000
Total Dissolved Solids (TDS)	871	≥ 4000	5000
pH	7.04	≤ 6.5	6.5 – 8.5 (s.u)

14-31-5572 Impoundment (MW 4)

Parameter	Background Value (mg/L)	Trigger Value (mg/L)	Class III Water Quality Standards (mg/L)
Arsenic	0.010	≥ 0.16	0.2
Selenium	<0.005	≥ 0.04	0.05
Sulfate	862	≥ 2400	3000
Total Dissolved Solids (TDS)	1570	≥ 4000	5000
pH	7.79	≤ 6.5	6.5 – 8.5 (s.u)

Cale 42-18-5472 Impoundment (MW 5)


Parameter	Background Value (mg/L)	Trigger Value (mg/L)	Class III Water Quality Standards (mg/L)
Arsenic	0.019	≥ 0.16	0.2
Selenium	0.007	≥ 0.04	0.05
Sulfate	1550	≥ 2400	3000
Total Dissolved Solids (TDS)	2450	≥ 4000	5000
pH	Not Established	≤ 6.5	6.5 – 8.5 (s.u)

Trigger values have been assigned to each constituent and are also listed in the table. If one or more of these trigger values is exceeded during a quarterly sampling event, monthly sampling of the groundwater for all listed parameters is required, with the analytical results due by the 15th day of each month.

In order to address the potential mobilization of metals in the subsurface, when groundwater monitoring reveals a pH measurement of 6.5 standard units (s.u.) or less, the WDEQ may require monthly sampling and analysis of groundwater for the following additional parameters: aluminum, boron, cadmium, chromium, copper, lead and zinc.

The analytical results from each sampling event, along with impoundment and monitor well location information must be included in an Excel spread sheet formatted to match the attached template (Attachment 1). These data shall be submitted electronically by the due dates established above to the following department address: cbmgroundwater@state.wy.us. An electronic copy of the spreadsheet is available by contacting the Groundwater Program in the Sheridan DEQ office at 307-673-9337. The analytical laboratory reports must also be submitted either electronically (pdf format) or hard copy via mail.

AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality

6/15/05

Date of Issuance

Df/hjk/jc/5-0679



Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 9, 2005

Scott Harvey, Owner
1004 Broadway
Thermopolis, WY 82443

RE: Harvey's Small Wastewater Treatment Facility, Permit Number: 05-291, Section 7, T44N, R94W, Hot Springs County

Dear Mr. Harvey:

The above application for coverage under General Permit to construct a gravity flow septic tank and leachfield in accordance with Chapter 3, Section 7; and Chapter 11, Part D of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough
Environmental Engineer
Water Quality Division

xc: IPS, Cheyenne
Lee Campbell, Hot Springs County, 415 Arapahoe, Thermopolis, WY 82443

encl: General Permit For a Small Wastewater Facility



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
"AS-BUILT" PERMIT TO CONSTRUCT

PERMIT NO. 05-292

Knudsen 9 CBM Development Project

This permit hereby authorizes the applicant:

Pennaco Energy, Inc.
3601 Southern Drive
Gillette, Wyoming 82718

to have installed a compliance monitoring well according to the procedures and conditions of the application number 05-292. The facility is proximal to the on channel coalbed methane produced water impoundments located in Township 52N, Range 77W, Section 17 in the county of Johnson, in the State of Wyoming. All construction, installation, or modification allowed by this permit has been completed.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1 of 2: The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality/ Water Quality Division, Groundwater Program, 1866 South Sheridan Avenue, Sheridan, WY-82801, 307-673-9337, fax 307-672-2213, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 2: Monitoring Requirements:

Groundwater monitoring at the impoundments shall be performed on a quarterly basis until further notice and shall include the following information:

- Measurement of static water level and sampling and analysis of groundwater at monitor well Fort's View MW-01 (downgradient of Fort's View and Heatstroke impoundments) (see constituents listed below);
- Reporting results of quarterly monitoring and sampling to the department by January 15th, April 15th, July 15th, and October 15th of each year. The first set of data will be due by October 15, 2005.

The parameters listed in the table below are required for groundwater compliance monitoring at the impoundments:

Parameter	Dec 21, 2004 Background Value (mg/L)	Trigger Value (mg/L)	Class III Water Quality Standards (mg/L)
Arsenic	<0.005	≥ 0.16	0.2
Selenium	<0.005	≥ 0.04	0.05
Sulfate	563	≥ 2400	3000
Total Dissolved Solids (TDS)	1200	≥ 4000	5000
PH	8.3	≤ 6.5	6.5 – 8.5 (s.u)


Trigger values have been assigned to each constituent and are also listed in the table. If one or more of these trigger values is exceeded during a quarterly sampling event, monthly

sampling of the groundwater for all listed parameters is required, with the analytical results due by the 15th day of each month.


In order to address the potential mobilization of metals in the subsurface, when groundwater monitoring reveals a pH measurement of 6.5 standard units (s.u.) or less, the WDEQ may require monthly sampling and analysis of groundwater for the following additional parameters: aluminum, boron, cadmium, chromium, copper, lead and zinc.

The analytical results from each sampling event, along with impoundment and monitor well location information must be included in an Excel spread sheet formatted to match the attached template (Attachment 1). These data shall be submitted electronically by the due dates established above to the following department address: cbmgroundwater@state.wy.us. An electronic copy of the spreadsheet is available by contacting the Groundwater Program in the Sheridan DEQ office at 307-673-9337. The analytical laboratory reports must also be submitted either electronically (pdf format) or hard copy via mail.

AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality

6/9/05

Date of Issuance

Df/hjk/jc/5-0649



GROUNDWATER PROGRAM
REVIEW COMMENTS:
PLANS/SPECIFICATIONS/PROPOSALS/REPORTS

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
1866 South Sheridan Avenue
Sheridan, WY 82801
Phone: 307-673-9337

PERMIT TYPE: CBM: Groundwater Compliance Monitoring Program

WATER QUALITY DIVISION REFERENCE (PERMIT) NUMBER: 05-292

SITE (POD) NAME: Knudsen 9 CBM Development Project

APPLICANT: Pennaco Energy, Inc
Attn: Greg Smith
3601 Southern Drive
Gillette, Wyoming 82718

CONSULTANT: CBM Associates, Inc.
Attn: Tom Nissen
920 East Sheridan
Laramie, Wyoming 82070

LOCATION: Drainage: Powder River
County: Johnson
Township 52 North; Range 77 West

DATE ON REPORT: May 18, 2005

REVIEWING OFFICIAL: Heidi Kaiser, North District Groundwater Sr. Analyst

DATE OF THIS REVIEW: June 3, 2005

ACTION: Compliance Monitoring Plan authorized for Knudsen 9 CBM Development Project pursuant to conditions on permit # 05-292

COMMENTS: GROUNDWATER SECTION

1.0 SITE SUMMARY:

1.1 Site Description.

Watershed Name: Powder River

Type of Impoundment(s)

_____ "Off channel "
 X "On channel"

Groundwater Classification:

Class 1 (domestic) _____

Class 2 (irrigation) _____

Class 3 (agricultural) X

Basis for Classification: Laboratory analysis of groundwater indicates ambient water quality meets Water Quality Rules and Regulations Chapter 8 Class III standards (Table 1- Chapter 8).

Hydrogeology Description: Groundwater occurs in a sand and gravel deposit approximately 55 feet thick. This water bearing zone is overlain by approximately 50 feet of clay and is perched on an underlying claystone. The direction of groundwater flow is to the east-southeast in the vicinity of the proposed impoundments.

Names of Impoundments covered under Permit 05-292:

Impoundment Name	Qtr Qtr	Section	Township	Range	GW Class
Fort's View	SESE	17	52 N	77 W	III
Heatstroke	SESE	17	52 N	77 W	III

2.0 MONITORING AND REPORTING REQUIREMENTS

Groundwater monitoring at the impoundments shall be performed on a quarterly basis until further notice and shall include the following information:

- Measurement of static water level and sampling and analysis of groundwater at monitor well Fort's View MW-01 (downgradient of Fort's View and Heatstroke impoundments) (see constituents listed below);
- Reporting results of quarterly monitoring and sampling to the department by January 15th, April 15th, July 15th, and October 15th of each year. The first set of data will be due by October 15, 2005.

The parameters listed in the table below are required for groundwater compliance monitoring at the impoundments:

Parameter	Dec 21, 2004 Background Value (mg/L)	Trigger Value (mg/L)	Class III Water Quality Standards (mg/L)
Arsenic	<0.005	≥ 0.16	0.2
Selenium	<0.005	≥ 0.04	0.05
Sulfate	563	≥ 2400	3000
Total Dissolved Solids (TDS)	1200	≥ 4000	5000
pH	8.3	≤ 6.5	6.5 – 8.5 (s.u)


Trigger values have been assigned to each constituent and are also listed above. If one or more of these trigger values is exceeded during a quarterly sampling event, monthly sampling of the groundwater for all listed parameters is required, with the analytical results due by the 15th day of each month. If groundwater monitoring reveals a pH measurement of 6.5 standard units (s.u.) or less, the WDEQ may require sampling and analysis of groundwater for the following additional parameters: aluminum, boron, cadmium, chromium, copper, lead and zinc.

The analytical results for each sampling event, along with impoundment and monitor well location information must be included in an Excel spread sheet formatted to match the attached template (Attachment 1). These data shall be submitted electronically on the due dates established above to the following department address: cbmgroundwater@state.wy.us. An electronic copy of the spreadsheet is available by contacting the Groundwater Program in the Sheridan DEQ office at 307-673-9337. The analytical laboratory reports must also be submitted either electronically (pdf format) or hard copy via mail.

END OF REVIEW

WDF/jc/5-0653

POD Permit 05-292 Knudsen9



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

January 20, 2006

Ernie and Adella Duran
4300 Everton Drive
Cheyenne, Wyoming 82009

RE: **Inactive Permit Application being Returned:**
Location: NW ¼, Section 10, T19N, R81W,

Number 05-293
Carbon County

Dear Mr. and Mrs. Duran:

Thank you for your timely response to the five month reminder inquiry regarding this permit application. On the Project Status Report Form you indicated that you were unable to dig the percolation holes, and because it is now winter time you will be unable to start work on the septic system again until spring. You also indicated that everything had been left as it was and no further construction had been done. Because of your response and our regulations the DEQ Water Quality Division is required at this time to consider your application Number 05-293 as inactive, and therefore must be returned.

In the spring, when you plan to resume work on this septic system application, you will need to submit a whole new application package as if nothing had been previously submitted. A complete new blank application package is included with this notice so you can start with clean pages to work with. Please note the official notification language in the following paragraph which we are required to include.

This project has not been permitted. Construction of this facility without a permit is a violation of the Environmental Quality Act and is punishable with fines not to exceed \$10,000 per day of violation. **If this project has already been constructed**, it is your responsibility to immediately contact this office for further information and instructions. If you wish to reconsider construction of this facility, then application

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH
(307) 777-7758
FAX 777-3610

ABANDONED MINES
(307) 777-6145
FAX 777-6462

AIR QUALITY
(307) 777-7391
FAX 777-5616

INDUSTRIAL SITING
(307) 777-7369
FAX 777-6937

LAND QUALITY
(307) 777-7756
FAX 777-5864

SOLID & HAZ. WASTE
(307) 777-7752
FAX 777-5973

WATER QUALITY
(307) 777-7781
FAX 777-5973



procedures pursuant to Chapter 3 of the Wyoming Water Quality Rules and Regulations must be followed.

Sincerely,

A handwritten signature in cursive script that reads "Ronald L. Ewald".

Ronald L. Ewald
Senior Analyst
SE District, Water Quality Division

RLE/jc/6-0044

cc: IPS

Enclosure: New Septic System Application Package

Project Status Report Form: Application # 05-293

___ The additional information requested will not be submitted as the proposed project has been canceled and the application is hereby withdrawn.

___ The requested information will be submitted within 30 days.

___ The facility has already been constructed, or is under construction. Construction of any sewerage system, water system, treatment works, or disposal system will stop until an approved permit is issued. The requested information will be submitted within 30 days.

✓ Other / Remarks:

Was not able to dig perc holes as was out of town and other issues. If I need to re-do the whole application, I will, as the soonest I will be able to begin the septic system is this Spring. Everything was left as it was and no further construction has been done. If you need additional info, you can reach me @ 634-4814. Thanks.

Please note and be reminded that the construction, installation, or modification of any sewerage system, treatment works, disposal system, or any other facility capable of causing or contributing to pollution, or a public water supply system **without a Permit To Construct** is a violation of Wyoming State Statutes and can result in enforcement actions being undertaken by this Department.

Otherwise, unless this form is returned to the reviewing engineer identified within 30 days of the receipt of this letter, this application package will be returned. However, please note that the return of this application will not eliminate the possibility of future appropriate enforcement actions at a later date should a violation be discovered.

Mail To: Wyoming DEQ / Water Quality Division
Attn: Ronald L. Ewald
Herschler Building - 4 West
122 West 25th Street
Cheyenne, Wyoming 82002

Return Envelope Included

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 05-294RR

Wapiti Village Wastewater System #2

This permit hereby authorizes the applicant:

Tony Nardacci
P.O. Box 3251
Alpine, WY 83128

to construct a sewage collection system and a small wastewater treatment (septic) system according to the procedures and conditions of the application number 05-294RR. The facility is located in SW1/4 Section 3, T36N, R119W, in the county of Lincoln, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by November 30, 2007.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality/Water Quality Division, SW District, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, fax 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".


AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality

 9/1/05

Date of Issuance

DHC/dc/jc/5-0971

cc: Lincoln County Planning & Zoning; Attn: Mark Resig; P.O. Box 414; Afton, WY 83110

STATEMENT OF BASIS

1. Permit Number: 05-294RR
2. Application reviewed for compliance with the following regulations :
Chapter(s) 3 and 11 of the Wyoming Water Quality Rules and Regulations
3. Does the permit comply with all applicable regulations identified above?

Yes
4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3.

Not required


Small wastewater systems are exempted from review by Chapter 3, Section 17.
Sewerage systems are exempted from review by Chapter 3, Section 17.
5. Documentation of Statement of Basis: The archives file for this permit include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle H. Conklin, dconkl@state.wy.us, Southwest District Engineering Supervisor and completed on August 29, 2005. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

July 22, 2005

John A. Sulenta
Redstone Corporation
P.O. Box 377
Pinedale, WY 82941

RE: Pinedale-Redstone Ninth Addition - Water and Sewer Main Extensions -Permit Number 05-295, NW1/4 Section 4, T33N, R109W, Sublette County, PWS # WY5600041

Dear Mr. Sulenta:

The above application for coverage under General Permits to Construct a public water supply distribution system extension consisting of 1140 linear feet (LF) of 8 - inch Ductile Iron water main and a sewage collection system extension consisting of 640 LF of 8-inch PVC sewer main to serve 11 lots in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.
Environmental Senior Analyst
Water Quality Division

xc: IPS, Cheyenne

encl: General Permit for Public Water Supply Distribution System,
General Permit for a Sewage Collection System
Flat Grade Sewer Variance 13.9.13

Page 1 of 1





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

July 7, 2008

Mr. Eric Sandberg
Williams Production RMT Company
300 North Works Avenue
Gillette, WY 82716

RE: Barber Creek Land Application Project
Permit #06-295

Dear Mr. Sandberg:

On June 7, 2005, the Wyoming Department of Environmental Quality, Water Quality Division (WDEQ/WQD) issued the above referenced Permit to Construct. The construction, installation and operation of the land application expired on June 1, 2008. Please notify this office within 30 days of the date of this letter if you wish to renew the Permit to Construct and continue to operate the land application facility referenced above. After 30 days, the permit will be considered expired and any land application after that date will be considered a violation of Wyoming Water Quality Rules and Regulations.

If there are any questions concerning this matter, please call Kim Medina at (307) 473-3476, or contact her at kmedin@state.wy.us, or 152 North Durbin, Suite 100, Casper, Wyoming 82601.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
Wyoming Department of Environmental Quality

cc: IPS, Cheyenne
WDEQ file






Dave Freudenthal, Governor

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



John Corra, Director

NOTIFICATION OF COVERAGE

August 3, 2005

Donald Schooley, Superintendent
Upper Green River Cemetery District
P.O. Box 1931
Pinedale, WY 82941

RE: Upper Green River Cemetery District, Water Main Extension -Permit Number 05-296R,
SW1/4 Section 34, T34N, R109W, Sublette County

Dear Mr. Schooley:

The above application for coverage under General Permit to Construct a public water supply system extension consisting of 900 linear feet (LF) of 6 - inch ductile iron water main and 500 LF of 8-inch ductile iron water main in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.
Environmental Senior Analyst
Water Quality Division

xc: IPS, Cheyenne

encl: General Permit for Public Water Supply Distribution System

Page 1 of 1

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 05-297RR

Wapiti Village Wastewater System #1

This permit hereby authorizes the applicant:

Tony Nardacci
P.O. Box 3251
Alpine, WY 83128

to construct a sewage collection system and a small wastewater treatment (septic) system according to the procedures and conditions of the application number 05-297RR. The facility is located in SW1/4 Section 3, T36N, R119W, in the county of Lincoln, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by November 30, 2007.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality/Water Quality Division, SW District, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, fax 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the SW District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division

9/1/05
Date of Issuance


John V. Corra
Director
Department of Environmental Quality

DHC/dc/jc/5-0972

cc: Lincoln County Planning & Zoning; Attn: Mark Resig; P.O. Box 414; Afton, WY 83110

STATEMENT OF BASIS

1. Permit Number: 05-297RR
2. Application reviewed for compliance with the following regulations :
Chapter(s) 3 and 11 of the Wyoming Water Quality Rules and Regulations
3. Does the permit comply with all applicable regulations identified above?

Yes
4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3.

Not required

Small wastewater systems are exempted from review by Chapter 3, Section 17.
Sewerage systems are exempted from review by Chapter 3, Section 17.
5. Documentation of Statement of Basis: The archives file for this permit include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Doyle H. Conklin, dconkl@state.wy.us, Southwest District Engineering Supervisor and completed on August 29, 2005. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 05-298

Buffalo Valley Resort Wastewater Treatment Facility
WYPDES # WY0053546

This permit hereby authorizes the applicant:

Henry Washut, President
Buffalo Valley Resort, Inc.
P.O. Box 92
Moran, WY 83013

to install a previously used Santec wastewater treatment facility and a new sewage collection system to serve 78 RV sites and 13 cabins; according to the procedures and conditions of the application number 05-298. The facility is located within Section 27, Township 45 North and Range 113 West in the county of Teton, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by July 8, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will provide immediate oral or written notice to the Wyoming Department Environmental Quality, Water Quality Division (WQD), Northwest District Engineer, 250 Lincoln Street, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 5 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
- a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 4 of 5 The wastewater facility must be operated by a Class IV, wastewater treatment operator and backup operator must be at least Class III.
- 5 of 5 A pressure and leakage test must be performed for the sewer mains and manhole, especially near the existing public water supply well. The sewer mains and manhole must meet the leakage requirements listed in the project specifications.

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

7/12/05
Date of Issuance

JSB/jsb/jc/5-0772

STATEMENT OF BASIS

1. Permit Number: 05-298
2. Application reviewed for compliance with the following regulations:
Chapters 3, and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?
No
4. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.
The isolation distance between an existing public drinking water well and the new sewer system is less than fifty feet in one area. Extra precautions such as the use of HDPE pipe, cement-treated fill, 'thoroseal' waterplug, and watersealing coatings are specified to ensure the water-tightness of the sewer mains and manhole.
5. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
NA
6. Documentation of Statement of Basis: The archives file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by James S. Brough, jbroug@state.wy.us, Environmental Engineer and completed on July 8, 2005. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

Xc: Robert Norton, P.E., Nelson Engineering, P.O. Box 1599, Jackson, WY 83001

F:\DIVISION\WQD\WP\2005 Permits & Reviews\05-298.pc.jsb.doc



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 8, 2005

James A. Pridgeon
102 Dove Avenue
Ft. Huachuca, AZ 85613

RE: Jim Pridgeon Residential Septic System, Permit # 05-299

Dear James:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of a small wastewater septic system in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. **You are required to submit a minimum of two (2) photos of the system installation and the Certificate of Completion to this office no later than 60 days following the installation.** All construction, installation, or modification allowed by this permit shall be completed by June 1, 2006.

On August 4, 2004, the Crook County Commissioners enacted Resolution NO. 9-2004. This resolution requires that ALL small wastewater treatment facilities permitted by the Wyoming Department of Environmental Quality (WDEQ) and installed in Crook County after September 1, 2004, MUST BE INSPECTED BY AN INSPECTOR DESIGNATED BY CROOK COUNTY.

Please contact the Crook County Clerks Office for requirements of this resolution.

If you have any questions please contact me at 1866 S. Sheridan Avenue 673-9337, 673-2213 (fax).

Thank you

Sincerely,

Rick J. Estes, P.E.
WDEQ/WQ NE District Senior Environmental Analyst

cc: IPS, Cheyenne
Crook County Clerk, P.O. Box 37, Sundance, WY 82729
Wagaman Construction, PO Box 100, Sundance, WY 82729

Page 1 of 1



LAND APPLICATION PERMIT

— X New
Renewal
Modified

PERMIT NO. 05-300
SPECIAL CONDITIONS
REFERENCE PERMIT NO. 03-400

BIG HORN MOUNTAIN LODGE WASTEWATER APPLICATION

This permit hereby authorizes the applicant:

William F. Cramer
P.O. Box 570
Dayton, WY 82836

to land apply pretreated wastewater from the ponds serving the lodge and cabins according to the procedures and conditions of the application number 05-300. The application site is located in Section 7, T556N, R88W in the county of Sheridan, in the State of Wyoming. This permit shall be effective until November 30, 2005.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the land application described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the land application. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 5. The permittee shall provide immediate oral and or written notice to the Sheridan WDEQ Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
- 2 of 5. The permittee shall provide certification that the land application is being completed in accordance with the terms and conditions of the permit to the Sheridan WDEQ Office by submission of the following:
 - a. Monthly reporting to Sheridan WDEQ office of fecal coliform of the first pond water quality; and
 - b. Certification that the land application was done in accordance with the terms and conditions of the permit; or certification the land application was completed with changes or modifications. Submit the information necessary to clearly indicate the land application was actually performed. This information shall include photographs of wastewater pond and areas where the water is applied.

- 3 of 5. The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
- 4 of 5. The permittee shall clearly identify the areas where the treated wastewater is being applied with signs to inform the public.
- 5 of 5. No application shall be made to grounds that are wet from recent rain, snow or to grounds that are froze.

AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality

6/8/05
Date of Issuance

RJE/jc/5-0640

STATEMENT OF BASIS

- I. General information.
 - A. Permit Number: 05-300
- II. Application reviewed for compliance with Chapter 21.
- III. Basis for issuing permit:: Review of application package indicates proposed facility will be in compliance with Chapter 21 and other applicable requirements identified in Section 2 of Chapter 3.
- V. Application requires review to determine groundwater impacts in accordance with Section 17 Chapter 3.
NO
- VII. Documentation of Statement of Basis.
 - A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Rick J. Estes, PE, restes1@state.wy.us, Northeast District Senior Environmental Analyst, and completed on June 6, 2005. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."