



# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

March 8, 2006

Shawn O'Malley, P.E.  
Town of Jackson,  
P.O. Box 1687  
Jackson, WY 83001

RE: Pine Drive's Water and Sewer Line Replacements, Permit Number: 06-101,  
Section 33, T41N, R116W, Teton County

Dear Mr. O'Malley:

The above application for coverage under General Permit to replace approximately 5,150 linear feet of existing 4-inch steel, water distribution lines and appurtenances with 8-inch ductile iron pipe and to replace about 2,890 linear feet of existing clay, gravity sanitary sewer collection mains and appurtenances with 8-inch PVC pipe has been reviewed in accordance with Chapter 3, Section 7; Chapter 11, Section 9; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.  
Environmental Engineer  
Water Quality Division

xc: Michael J. FitzPatrick, P.E., Jorgensen Associates, P.O. Box 9550, Jackson, WY 83002  
IPS, Cheyenne

encl: General Permits For a Public Water Supply Distribution System and Sewage Collection System

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES  
(307) 332-5085  
FAX 332-7726

AIR QUALITY  
(307) 332-6755  
FAX 332-7726

LAND QUALITY  
(307) 332-3047  
FAX 332-7726

SOLID & HAZARDOUS WASTE  
(307) 332-6924  
FAX 332-7726

WATER QUALITY  
(307) 332-3144  
FAX 332-3183



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
PERMIT TO CONSTRUCT

PERMIT NO. 06-102R

Town of Mountain View's Wastewater Lagoon Effluent Piping & Diffuser

This permit hereby authorizes the applicant:

David K. Dasher, Public Works Director  
Town of Mountain View  
P.O. Box 249  
Mountain View, WY 82939

to extend the lagoon discharge pipe to Blacks Fork River, install a manhole, and to install an in-stream diffuser with a cleanout; according to the procedures and conditions of the application number 06-102R. The facility is located within Section 17, Township 15 North and Range 114 West in the county of Uinta, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by June 27, 2007.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 4            The integrity of the in-stream diffuser shall be inspected routinely in conjunction with the sampling schedule. A periodic cleaning (perhaps annual) may be necessary.
- 2 of 4            The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Northwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 3 of 4            Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
- a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4            The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
John F. Wagner  
Administrator  
Water Quality Division

  
John V. Corra  
Director  
Department of Environmental Quality

June 27, 2006  
Date of Issuance  
JSB/rm/6-0569

## STATEMENT OF BASIS

1. Permit Number: 06-102R
2. Application reviewed for compliance with the following regulations:  
Chapters 3 and 11 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above? NA
4. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.  
Yes. Chapter 11, Section 5 allows for design of facilities that are not specifically addressed in the regulations provided that design was evaluated on a case-by-case basis using the best available technology.
5. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.  
Sewerage systems are exempted from review by Chapter 3, Section 17.
6. Documentation of Statement of Basis: The archives file for this permit includes adequate documentation of all sections of this Statement of Basis.


## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by James S. Brough, [jbroug@state.wy.us](mailto:jbroug@state.wy.us), Environmental Engineer and completed on June 27, 2006. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."

Xc: James Denney, P.E., Sunrise Engineering, Inc., 12227 South Business Park Dr., Suite 220, Draper, UT 84020



# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

March 8, 2006

Bryan Edwards, Developer  
P.O. Box 2035  
Cody, WY 82414

RE: Cody Legacy Inn Water & Sewer Lines, Permit Number: 06-103 (revision of Permit Number: 05-651), Section 4, T52N, R101W, Park County

Dear Mr. Edwards:

This project involves the installation of 8-inch sanitary sewer line to serve the Cody Legacy Inn. This project was previously permitted under permit number 05-651, except for the addition of a swimming pool drain connection. The design flow rate has increased, however, the project is essentially the same. The above application for coverage under General Permit to construct a sanitary sewer line, extension of a sewage collection system, in accordance with Chapter 3, Section 7; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.


If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,


James Brough, P.E.  
Environmental Engineer  
Water Quality Division

xc: IPS, Cheyenne  
James G. Evans, P.E., Sage Civil Engineering, 2824 Big Horn Ave., Cody, WY 82414  
Stephen W. Payne, P.E., City of Cody, P.O. Box 2200, Cody, WY 82414





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

May 8, 2006

Jay Stender  
Director  
SAWS JPB  
1030 N. Main  
Sheridan, WY 82801

RE: Bridger Point Subdivision Water Main 06-104  
PWS# 5600052

Dear Jay:

The above application for coverage under General Permit to Construct, Install, Modify or Operate an extension to the Sheridan Area Water Supply Distribution system in accordance with Chapter 3 and Chapter 12 of the WWQRR has been reviewed and is hereby approved. You are now authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this permit shall be completed by May 1, 2007.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits. Following completion of construction of this facility please return the attached WDEQ Certificate of Completion. **It is required that the Certificate of Completion identify the type of pipe that was used - it was not identified in the permit application material. Any pipe type selected must meet WDEQ Chapter 12 minimum requirements.**

If you have any questions please contact me at 1866 S. Sheridan Avenue, Sheridan, WY, 82801, (307) 673-9337.

Sincerely,

Rick J. Estes, P.E.  
WDEQ/WQD NE District Senior Environmental Analyst

cc: IPS, Cheyenne  
Bill Mentock, P.E., Mentock Engineering, 1030 N. Main #2, Sheridan, WY 82801  
Jackie Flowers, PE, Public Works Director-Utilities, City of Sheridan



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
PERMIT TO CONSTRUCT

PERMIT NO. 06-105

IV ROAD SANITARY SEWER  
WYPDES #: 0020605

This permit hereby authorizes the applicant:

Town of Hulett  
P.O. Box 278  
Hulett, WY 82720

to construct, install or modify a 8" PVC gravity sewer main and 6" PVC sewer force main and pumping station in according to the procedures and conditions of the application number 06-105. The facility is located in portions of Sections 7 & 12 of Township 54 North, Range 64 & 65 West in the county of Crook, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by June 1, 2007.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does


not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the WDEQ located at 1866 S. Sheridan Avenue, Sheridan, Wyoming 82801; telephone (307) 673-9337; FAX (307) 673-2213, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the WDEQ located at 1866 S. Sheridan Avenue, Sheridan, Wyoming 82801; telephone (307) 673-9337; FAX (307) 673-2213 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
John F. Wagner  
Administrator  
Water Quality Division

  
John V. Corra  
Director  
Department of Environmental Quality

4/6/06  
Date of Issuance

RJE/jc/6-0270  
*JK* 4/3/06

cc: Kenny C. Rathbun, P.E., Bearlodge Ltd, Inc., P.O. Box 130, Sundance, WY 82729

## STATEMENT OF BASIS

1. Permit Number: 06-105
2. Application reviewed for compliance with the following applicable regulations :  
Chapter 11 of the Wyoming Water Quality Rules and Regulations:
3. Does the permit comply with all applicable regulations identified above?  
YES
4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was  
NOT REQUIRED
5. Documentation of Statement of Basis: The archives file for this permit include adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Rick J. Estes, PE, restes1@wy.gov, Northeast District Senior Environmental Analyst, and completed on March 31, 2006. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

May 9, 2006

G.L. Ross  
G.L. Ross, Construction LLC  
P.O. Box 2001  
Sheridan, WY 82801

RE: Aspen Grove Sewer, WDEQ Permit #06-107

Dear Gary:

The above application for coverage under General Permit to Construct, Install, Modify or Operate an extension to the City of Sheridan Wastewater Collection system in accordance with Chapter 3 and Chapter 12 of the WWQRR has been reviewed and is hereby approved. You are now authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this permit shall be completed by May 1, 2007.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits. Following completion of construction of this facility please return the attached WDEQ Certificate of Completion and the Transfer of Ownership. The sewer system must be transferred to the City of Sheridan at the end of the project if you do not wish to become the certified operator of the collection system.

**The City of Sheridan requires trench plugs to be placed at selected locations. The project engineer will provide locations of plugs to be approved by City staff. The As-Constructed plans will be submitted following completion of the project showing the final location of the plugs.**

If you have any questions please contact me at 1866 S. Sheridan Avenue, Sheridan, WY, 82801, (307) 673-9337.

Sincerely,

Rick J. Estes, P.E.  
WDEQ/WQD NE District Senior Environmental Analyst

cc: IPS, Cheyenne  
Megan Crow, PE, MC2 Engineering, 1101 Sugarview Dr, Suite 201, Sheridan, WY 82801  
Jackie Flowers, PE, Public Works Director-Utilities, City of Sheridan

Page 1 of 1


1866 SOUTH SHERIDAN AVENUE • SHERIDAN, WY 82801

AIR, LAND AND WATER DIVISIONS  
(307) 673-WDEQ (9337) • FAX (307) 672-2213





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

March 9, 2006

Mr. Herman Noe, Manager of Engineering  
Cheyenne Board of Public Utilities  
P.O. Box 1469  
Cheyenne, WY 82003-1469

RE: North Range Business Park Sanitary Sewer Extension, Application No.06-109, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Sewage Collection Systems described as 3.9 miles of sewer main, including 2,945 lf of 18" pipe, 351 lf of 15" pipe, 10,621 lf of 12" pipe, 6273 lf of 8" pipe and 70 manholes, Sections 1,2,3, & 4 T13N R67W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by May 10, 2008.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 06-109 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG  
Southeast District Engineer  
Water Quality Division

cc: IPS Cheyenne

Scott Cowley, A.V.I. pc  
2035 Westland Road  
Cheyenne, WY 82001

LBH/jc/6-0213

Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002 • <http://deg.state.wy.us>

ADMIN/OUTREACH  
(307) 777-7758  
FAX 777-3610

ABANDONED MINES  
(307) 777-8145  
FAX 777-6462

AIR QUALITY  
(307) 777-7391  
FAX 777-5616

INDUSTRIAL SITING  
(307) 777-7368  
FAX 777-6937

LAND QUALITY  
(307) 777-7756  
FAX 777-5864


SOLID & HAZ. WASTE  
(307) 777-7752  
FAX 777-5973

WATER QUALITY  
(307) 777-7781  
FAX 777-5973





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

March 3, 2006

Mr. Herman Noe, Manager of Engineering  
Cheyenne Board of Public Utilities  
P.O. Box 1469  
Cheyenne, WY 82003-1469

RE: Satterfield 3rd Filing Water and Sewer Extensions, Application No.06-110, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as 2220 ft of 8" diameter PVC sewer line, 1855 ft of 8" diameter DIP water line, 3 fire hydrants and all appurtenances, SW 1/4 NE 1/4 Section 26 T14N R66W; Laramie County; in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by May 10, 2008.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 06-110 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG  
Southeast District Engineer  
Water Quality Division

cc: IPS, Cheyenne  
Dahlgren Consulting  
914 East 23rd Street  
Cheyenne, WY 82001

LBH/jc/6-0192


Herschler Building • 122 West 25th Street • Cheyenne, Wyoming 82002 • <http://deg.state.wy.us>

ADMIN/OUTREACH (307) 777-7758 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7368 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

March 6, 2006

Travis & Mandi Connally  
P.O. Box 82721  
Moorcroft, WY 82721

RE: Connally Septic System, Permit # 06-111

Dear Travis & Mandi:

The above application for coverage under General Permit to Construct, Install, Modify or Operate extensions to or modifications of a small wastewater (septic) system in accordance with Chapter 3 and Chapter 11, Part B, of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. **A minimum of two (2) photos of the system installation, gravel and pipe or set infiltrators shall accompany the Certificate of Completion submitted to this office.** All construction, installation, or modification allowed by this permit shall be completed by March 1, 2007.

*On August 4, 2004, the Crook County Commissioners enacted Resolution NO. 9-2004. This resolution requires that ALL small wastewater treatment facilities permitted by the Wyoming Department of Environmental Quality (WDEQ) and installed in Crook County after September 1, 2004, MUST BE INSPECTED BY AN INSPECTOR DESIGNATED BY CROOK COUNTY.*

Please contact the Crook County Clerks Office for requirements of this resolution.

It was noted that no water well permit exists for your well. Please contact the State Engineers Office to permit this well. If you have any questions please contact me at; 1866 S. Sheridan Avenue 673-9337, 673-2213 (fax).

Sincerely,

Rick J. Estes, P.E.  
WDEQ/WQ NE District Senior Environmental Analyst

cc: ~~IPS~~, Cheyenne  
Crook County Clerk, P.O. Box 37, Sundance, WY 82729  
Tavis Dewey, Tri-City Excavation, 169 Thorn Divide Rd., Carlile, WY 82721

Page 1 of 1

1866 SOUTH SHERIDAN AVENUE • SHERIDAN, WY 82801

AIR, LAND AND WATER DIVISIONS  
(307) 673-WDEQ (9337) • FAX (307) 672-2213



**From:** Lou Harmon  
**To:** Barnes, Barb  
**Date:** 11/16/2007 4:16 PM  
**Subject:** Cedar Springs Permits Withdrawn

**CC:** Baron, Mark; McKenzie, Don

Barb: There are 33 permits for Cedar Springs in the database, numbered from 06-112 to 06-144 that should have an entry made for application withdrawn and marked completed in the tracking table. Use November 13, 2007 as the date for application withdrawn. Because these permits were replaced with a single UIC application, 07-789, no other paper work is necessary.  
Lou

**From:** Lesli Bartell  
**To:** Barnes, Barb; Spears, Chanda  
**Date:** 11/19/2007 10:13 AM  
**Subject:** Cedar Springs

Per Mark Baron's e-mail, we have the permits 06-112 thru 06-144 recorded as withdrawn here in Lander.

And here's a little bit of stuff....

11-16-07 07-774 NOC James Brough Fremont County  
11-16-07 07-702 RS **Subdivision** Mark Baron Lincoln County

Thank you so very much, enjoy your Monday !!!

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
PERMIT TO CONSTRUCT  
No PWS Number Assigned

PERMIT NO. 06-145RR

Lincoln County - Cedar Springs PUD - Water System

This permit hereby authorizes the applicant:

Tom Lewis, Owner  
LDL, LLC  
P.O. Box 842  
Thayne, WY 83127

to construct a public water distribution system to serve 107 residential townhouse units and four commercial structures consisting of three water wells, three well houses and 6-inch AWWA C-900 Class 150 PVC watermain according to the procedures and conditions of the application number 06-145RR. The facilities are located at NW 1/4 SW 1/4 Section 1 Township 34 North, Range 119 West in the county of Lincoln, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by November 30, 2008.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:


- 1 of 6            The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadow View Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
  
- 2 of 6            Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
  - a.            Date that construction of the facility was completed; and
  - b.            Date that the facility was placed in operation; and
  - c.            Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d.            Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
  
- 3 of 6            Water well yield and drawdown test information must be submitted upon completion of the three proposed well as per Chapter 12, Section 9 (b)(ii) along with a geological analysis of the aquifer as per Chapter 12, Section 10 (k)(ii)(C).
  
- 4 of 6            Water quality information must be submitted upon completion of the three proposed water wells indicating that the maximum contaminate levels for bacteriological contaminants, inorganic contaminants (IOC), volatile organic contaminants (VOC), synthetic organic contaminants (SOC) and radio nuclide contaminants has not been exceeded per the United States Environmental Protection Agency National Primary Drinking Water Standards and Chapter 12, Section 6 (c)(v)(A)(II).

- 5 of 6 An operation and maintenance manual is to be submitted as per Chapter 12, Section 16. The manual must include a section specifying the housing, location, operation and maintenance of the required alternative power source as required by Chapter 12, Section 8. Final plans and specifications for the alternative power source must be submitted.
- 6 of 6 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



John F. Wagner  
Administrator  
Water Quality Division



John V. Corra  
Director  
Department of Environmental Quality

12-4-06  
Date of Issuance

MDB/rm/6-1125

---

## STATEMENT OF BASIS

1. Permit Number: 06-145RR
2. Application reviewed for compliance with the following regulations:  
Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?  
No.  
Chapter 12, Section 13 (c) requires finished water storage when serving more than 50 homes. Water demands will be met reliably by using variable frequency drive submersible pumps, alternative power and a separate fire protection system which uses water stored in lined ponds onsite.
4. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.  
Not required.
5. Documentation of Statement of Basis: The archive file for this permit include adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Mark D Baron P.E. mbaron@state.wy.us, Southwest District Engineer and completed on November 30, 2006. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
PERMIT TO CONSTRUCT

PERMIT NO. 06-146

Medicine Bow Lift Station Replacements

This permit hereby authorizes the applicant:

Town of Medicine Bow  
P.O. Box 156  
Medicine Bow, Wyoming, 82329-0156

to construct, install or modify a replacement of main lift station and 3 collector lift stations according to the procedures and conditions of the application number 06-146. The facility is located in SW 1/4 Section 5, NW 1/4 Section 8 T22N R78W in the county of Carbon, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by March 14, 2007.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and


permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088, FAX 307-777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 4 The heaters in each lift station shall be permanently mounted heaters rated for corrosive environments. Each heater shall be controlled by a thermostat rated for use in a corrosive environment and calibrated in degrees Fahrenheit.
- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
John F. Wagner  
Administrator  
Water Quality Division

  
John V. Corra  
Director  
Department of Environmental Quality

3/14/06  
Date of Issuance

LBH/jc/6-0218 *AKM 3/14/06*  
cc:

## STATEMENT OF BASIS


1. Permit Number: 06-146
2. The application complies with Chapters 3 and 11 of Water Quality Division Rules and Regulations. Sewerage systems are exempted from review by Chapter 3, Section 17.
3. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.
4. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon PE-PG, Southeast District Engineer, lharmon@state.wy.us, and completed on March 14, 2006. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

March 9, 2006

The Honorable Rich Johnson, Mayor  
Town of Pavillion  
203 1/2 N. Main Street  
Pavillion, WY 82523

RE: Pavillion's 2006 Sewer Line Replacement Project, Permit Number: 06-147,  
Sections 7 & 18, T3N, R2W, Fremont County

Dear Mayor Johnson:

This project involves the replacement of existing clay sewer lines with approximately 2,627 linear feet of 8-inch, PVC sanitary sewer lines. The above application for coverage under General Permit to construct sanitary sewer lines has been reviewed in accordance with Chapter 3, Section 7; and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.  
Environmental Engineer  
Water Quality Division

xc: IPS, Cheyenne  
Terry Zenk, P.E., Apex Surveying, Inv., P.O. Box 1751, Riverton, WY 82501

encl: General Permit For an Existing Sewage Collection System

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES  
(307) 332-5085  
FAX 332-7726

AIR QUALITY  
(307) 332-6755  
FAX 332-7726

LAND QUALITY  
(307) 332-3047  
FAX 332-7726

SOLID & HAZARDOUS WASTE  
(307) 332-6924  
FAX 332-7726

WATER QUALITY  
(307) 332-3144  
FAX 332-3183





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

March 27, 2006

John Joyce, Project Director  
Big Horn Regional Joint Powers Board  
101 Grace Avenue  
Worland, Wyoming 82401

RE: Big Horn Regional Northern Supply Pipeline Project - Element 3 (West River Road); Sections 1, 36, 25, 19, 24, 18, 7 & 6; T47 & 48N; R92W, Permit Number: 06-148, Washakie County

Dear Mr. Joyce:

The above application to install a 9,800 linear feet of 8-inch and 24,750 linear feet of 12-inch water line (primarily PVC pipe with some HDPE pipe) has been reviewed in accordance with Chapter 3, Section 7; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved with the following stipulation:

*If hydrocarbon contaminated soil is encountered during the installation of the waterline, the engineering consultant firm's representative must notify Wyoming's Water Quality Division (WQD) of the problem. The installation of the pipeline project shall cease in the area of the contaminated soil until a solution has been presented and approved by WQD.*

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.  
Environmental Engineer  
Water Quality Division


xc: IPS, Cheyenne  
Robert Overfield, P.E., Engineering Associates, P.O. Box 1900, Cody, WY 82414

encl: General Permit For a Public Water Supply Distribution System





The State  
of Wyoming



## Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

### NOTIFICATION OF COVERAGE

April 10, 2006

Mr. Robert L. Tarufelli  
Hunter's Ridge Development, Inc.  
1257 Palisades Way  
Rock Springs, WY 82901

RE: Umbria Addition, Phase 1, Application No. 06-149

Dear Mr. Tarufelli:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations and for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Sewage Collection Systems in accordance with Chapter 3 and Chapter 11 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V. Section O. of the general permits.

If you have any questions, please contact me at 307-473-3471.

Sincerely,

*Kevin J. Frank*

Kevin J. Frank, PE  
Senior Analyst  
Water Quality Division

cc: IPS, Cheyenne





The State  
of Wyoming



## Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

### NOTIFICATION OF COVERAGE

March 22, 2006

David D. Keanini, VP Engineering, Environmental, and Safety  
Lance Oil and Gas Company  
1099 18<sup>th</sup> Street, Suite 1200  
Denver, CO 80202

RE: Dry Creek Rohm and Haas CBM Water Treatment Facility, Permit # 06-150

Dear Mr. Keanini:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Pilot Plant in accordance with Section 5, Chapter 11, of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit.

The following items need to be submitted to WDEQ/WQD:


1. Prior to construction: detailed drawings and technical data on the Rohm and Haas skid and the ion exchange process;
2. A seven day notice prior to starting up the facility;
3. The facility will treat/blend the water based on an EC/Na correlation that has yet to be established. The department requests that the analytical data from the initial start up used to establish this correlation be submitted to the department for review as soon as the relationship between the two parameters has been defined. During the first month of operation of the facility following start up, lab samples for EC/Na are to be taken weekly to validate the parametric relationship and this data should be submitted to DEQ for review as soon as the lab completes the analysis. Based upon this information DEQ will set a sampling schedule for the facility.



4. A laboratory analysis of any wastes generated at the facility and information regarding any disposal of wastes including prior notification of when and where the material is to be disposed;
5. An O&M manual and an operator daily checklist prior to full start up. This should include protocols for when the plant is operating out of compliance to prevent discharge violations.

If you have any questions please contact Dennis Lamb at 152 North Durbin, Casper, WY, 82601, (307) 473-3452 or [dlamb@state.wy.us](mailto:dlamb@state.wy.us). Thank you.

Sincerely,



Dennis Lamb  
NE District Supervisor  
DEQ/WQD

cc: IPS Cheyenne