

The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

September 14, 2006

Philip Dinsmoor
501 South Douglas Highway Suite A-307
Gillette, WY 82716

RE: Dinsmoor Residential Septic System
Permit # 06-651

Dear Mr. Dinsmoor:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
Tim Lyons, Crook County Growth and Development Coordinator, P.O. Box 848, Sundance, WY 82729

Page 1 of 1



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 06-652

REFERENCE PERMIT NO 85-594.

Baggs Wastewater Lagoons - Mixon Irrigation

This permit hereby authorizes the applicant:

Town of Baggs
P.O. Box 300
Baggs, WY, 82321

to provide treated wastewater for land application meeting Class C or better Water Quality Division Chapter 21 standards to the Mixon hay fields according to the procedures and conditions of the application number 06-652. The facility is located in NW 1/4 SW 1/4 Sec5, East 1/2 & SE 1/4 Section 6 T12N R91W in the county of Carbon, in the State of Wyoming. Land application of treated wastewater shall be allowed until 15 September 2011.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:


1 of 2 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088, FAX 307-777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 2 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".


AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality



Date of Issuance

LBH/bb/6-0860.PER

STATEMENT OF BASIS

1. Permit Number: 06-652
2. Application reviewed for compliance with the following applicable regulations :
Chapter(s) 3 and 21 of the Wyoming Water Quality Rules and Regulations
3. Does the permit comply with all applicable regulations identified above?
YES
4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.
Reuse of treated wastewater is exempted from review by Chapter 3, Section 17.
5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.


CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon PE-PG, Southeast District Engineer, lharmo@state.wy.us, and completed on September 14, 2006. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LBH/bb/6-0860.STM



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

September 20, 2006

Jason Nehl
P.O. Box 134
Sundance, WY 82729

RE: Nehl Residential Septic System
Permit # 06-654

Dear Mr. Nehl:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion
Transfer of Ownership Form

cc: IPS, Cheyenne
Tim Lyons, Crook County Growth and Development Coordinator, P.O. Box 848, Sundance, WY 82729

Page 1 of 1



IPS



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

September 20, 2006

Ryan Kaski
Kaski Homes Inc.
1935 Samco Road, Suite 102
Rapid City, SD 57702

RE: Lot 3, Block 3, Residential Septic System
Permit # 06-655

Dear Mr. Kaski:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

Additionally, the following project specific conditions also apply:

- A. Transfer of Ownership – A *Transfer of Ownership* form must be completed and submitted to this office within 30 days after sale of the property.
- B. Number of Bedrooms – This permit is authorized for up to 3 bedrooms. Additional bedrooms may require an increase in the septic tank and/or leachfield. Any modification of the existing septic system will require the submittal of new application for *Permit to Construct*.



JMT
PUBLIC
WAST

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,



Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion
Transfer of Ownership Form

cc: IPS, Cheyenne
Tim Lyons, Crook County Growth and Development Coordinator, P.O. Box 848, Sundance, WY 82729



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

September 21, 2006

Ryan Kaski
Kaski Homes Inc.
1935 Samco Road, Suite 102
Rapid City, SD 57702

RE: Lot 14, Block 1, Residential Septic System
Permit # 06-656

Dear Mr. Kaski:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

Additionally, the following project specific conditions also apply:

- A. Transfer of Ownership – A *Transfer of Ownership* form must be completed and submitted to this office within 30 days after sale of the property.
- B. Number of Bedrooms – This permit is authorized for up to 3 bedrooms. Additional bedrooms may require an increase in the septic tank and/or leachfield. Any modification of the existing septic system will require the submittal of new application for *Permit to Construct*.

Page 1 of 2



If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,




Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion
Transfer of Ownership Form

cc: IPS, Cheyenne
Tim Lyons, Crook County Growth and Development Coordinator, P.O. Box 848, Sundance, WY 82729



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

September 21, 2006

Ryan Kaski
Kaski Homes Inc.
1935 Samco Road, Suite 102
Rapid City, SD 57702

RE: Lot 7, Block 1, Residential Septic System
Permit # 06-657

Dear Mr. Kaski:


The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

Additionally, the following project specific conditions also apply:

- A. Transfer of Ownership – A *Transfer of Ownership* form must be completed and submitted to this office within 30 days after sale of the property.
- B. Number of Bedrooms – This permit is authorized for up to 3 bedrooms. Additional bedrooms may require an increase in the septic tank and/or leachfield. Any modification of the existing septic system will require the submittal of new application for *Permit to Construct*.

Page 1 of 2





If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,


Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion
Transfer of Ownership Form

cc: IPS, Cheyenne
Tim Lyons, Crook County Growth and Development Coordinator, P.O. Box 848, Sundance, WY 82729



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

October 26, 2006

Wayne C. Christensen
Redwood Land, LLC
5190 West 700 South
Salt Lake City, UT 84104

RE: Pinedale - BLM Office - Water Main Extension and Sewage Disposal System - Permit
Number 06-658, SE 1/4 Section 32, T33N, R109W, Sublette County, PWS # WY5600041

Dear Mr. Christensen:

The above application for coverage under General Permits to Construct a water main extension consisting 1072 feet of 10-inch and 308 feet of 8-inch ductile iron water main and 751 of 6-inch PVC sewer main, two 1500 gallon septic tanks, one 1500 gallon pump tank and 457 feet of SDR 11 2-inch septic effluent pressure line to serve the BLM Building and the Sublette County Conservation District Building in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne

encl: General Permit for a Public Water Supply Distribution System,
General Permit for a Sewage Collection System



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
LAND APPLICATION PERMIT

PERMIT NO. 06-659

Greybull Field Land Application Project

This permit hereby authorizes the applicant:

Stephen R. Monninger, Environmental Manager
RockWell Petroleum, Inc.
7000 W. Yellowstone Hwy
Casper, WY 82604

to land apply RockWell's tunnel produced shallow groundwater blended with surface water from a Dry Creek fed irrigation canal to forty-five (45) acres of land owned by RockWell according to the procedures and conditions of application number 06-659. The application site is located in SW1/4 Section 8, T52N, R93W in the county of Big Horn, in the State of Wyoming. This permit shall be effective until November 1, 2007.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 7 Section 9, Chapter III, Wyoming Water Quality Rules and Regulations requires notification of DEQ for any changes or modifications to the approved permit package. The permittee shall provide

immediate verbal or written notice to the Northwest District Engineer, Wyoming DEQ/WQD, 510 Meadowview Drive, Lander, WY 82520, phone 307-332-3144.

- 2 of 7 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the Northwest District Engineer on the attached Certification of Completion form.
- a. Date that the land application was completed; and
 - b. Certification the land application was done in accordance with the terms and conditions of the permit; or
 - c. Certification the land application was completed with changes or modifications. Submit the information necessary to clearly indicate the land application as actually performed. This information shall include a contour map depicting only those sections of land that actually received.
- 3 of 7 The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
- 4 of 7 The flow rate from the tunnel water shall not exceed 40 gpm. The blending ratio shall be at least 2.25 parts irrigation water from the Dry Creek fed irrigation ditch to be blended with 1 part tunnel water.
- 5 of 7 Application shall not be initiated during the spring runoff period or at times saturated soil conditions exist. Applications shall not be applied during the period from November 1 to April 10.
- 6 of 7 Application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
- 7 of 7 Only the lands designated in this permit are authorized for application of the oil and water mixture. Additional or alternate sections of land meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.


AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division

11/7/06

Date of Issuance



John V. Corra
Director
Department of Environmental Quality

JSB/rm/6-1026

STATEMENT OF BASIS

1. Permit Number: 06-659
2. Application reviewed for compliance with the following applicable regulations:

Chapter 11 of the Wyoming Water Quality Rules and Regulations.

3. Basis for issuing permit.

It is estimated that the blended water EC (5.6 dS/m), TDS (4,606 mg/L), and sulfate (2,250 mg/L) levels would exceed the Chapter 11 land application criteria (Table 2). However, the salinity (as measured by the EC and TDS) and sulfate in the blended water would not adversely affect site vegetation and soils or the groundwater below them because these levels are similar to or less than the naturally occurring background soil EC, TDS, and sulfate. The resulting blended water SAR would be less than the Chapter 11 land application limit for SAR.

RockWell has a proposed monitoring plan (see attachment) for this land application project. DEQ concurs with this proposed monitoring plan and will recognize it as a requirement for this land application permit.

4. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.

The Water-Reel sprinkler application system may be operated at variable rates which allows RockWell to optimize land application with respect to the hydraulic capacity of the sites soil and vegetation. Irrigation will be rotated through zones and each zone will have a several day rest period between applications to prevent soil saturation and minimize groundwater impacts.

5. Documentation of Statement of Basis.

The archive file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter 3, Wyoming Water Quality Rules and Regulations. This review was performed by James S. Brough, jbroug@state.wy.us, Environmental Engineer and completed on October 30, 2006. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

Attachment: Table 4, RockWell's Proposed Monitoring Plan For Land Application Project


Cc: David Cameron, P.E., K.C. Harvey, 233 Edelweiss #11, Bozeman, MT 59718 (w/attachment)
Jean Lawlor, P.G., Gene R. George & Associates, P.O. Box 2775, Casper, WY 82602 (w/attachment)

F:\DIVISION\WQDI\WP\2006 Permits & Reviews\06-659.landappl.jsb.doc



Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

September 20, 2006

Diane Baird Hudson, Superintendent
Wyoming State Training School
8204 State Highway 789
Lander, Wyoming 82520

RE: Sanitary Sewer Reconstruction, MH-14 to MH-15, Permit Number 06-660,
SE ¼ Sec. 8, T33N, R99W, Fremont County.

Dear Ms. Hudson:

The above application for coverage under a General Permit to construct a replacement sewer main between manholes 14 and 15 on the Wyoming State Training School campus in accordance with Chapter 3, Section 7 and Chapter 11, Section 9, of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. Please note that the slope of this sewer doesn't meet the current standards but is acceptable due to existing constraints. As a result, this line may require more cleaning than a line meeting the standards.

You are authorized to construct the water main and appurtenances in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Jeff Hermansky
Northwest District Engineering Supervisor

xc: ✓IPS, Cheyenne

encl: General Permit for a Sewer Collection System

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 06-662

Water System: Phase II for North Star Utility Company - Lincoln County

This permit hereby authorizes the applicant:

Michail T. Halpin, President of North Star Utility Company
P.O. Box 610
Jackson, WY 83001

to construct a 540,000 gallon glass-fused-to-steel storage tank in accordance with AWWA D103-97 located on United States Forest Service lands to serve residential and commercial users near the town of Alpine, according to the procedures and conditions of the application number 06-662. The facility is located at NW1/4SW1/4, Section 21 Township 37 North, Range 118 West in the county of Lincoln, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by September 29, 2008.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and


permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadow View Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
- a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

10/02/06
Date of Issuance
PDR/rm/6-0902


STATEMENT OF BASIS

1. Permit Number: 06-662
2. Application reviewed for compliance with the following regulations:
Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?
Yes
4. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Not required.
5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.


CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Perry D Roberson Environmental Senior Analyst, prober2@state.wy.us and approved by Mark D Baron P.E., and completed on 9/29/06. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

cc: John Woodward
Lincoln County Office of Planning and Development
P. O Box 414
Afton, WY 83110



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

October 24, 2006

Mark S. Norden
The Ridge Investment Properties, LLC
One East Center Street, Suite 300
Provo, Utah 84606

RE: Hunters Run P.U.D. Phase I - Permit Number 06-663, SE ¼ Section 27, T18N, R107W,
Sweetwater County, Wyoming
PWS: WY5600050

Dear Mr. Norden:

The above application for coverage under General Permits to Construct water and sewer main extensions of a 10-inch PVC water main and an 8-inch PVC sewer main to serve phase 1 of a proposed subdivision to service 69 units in accordance with Chapter 3, Section 7, Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Perry Roberson
Environmental Senior Analyst
Water Quality Division

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: ✓IPS, Cheyenne

encl: General Permit for a Sewage Collection System,
General Permit for a Public Water Supply Distribution System





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

January 19, 2007

Michael & Betty Flaherty
425 Center Street
Douglas, Wyoming 82633

RE: Park Storage / R.V. Park – Two Septic Systems, Application No. **06-665**
Location: SW¼ SW ¼, Section 9, T29N, R68W, Platte County

Dear Mr. and Mrs. Flaherty:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Small Wastewater Facilities for **2 separate on-site wastewater systems** for an R.V. Park in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of both septic tanks** must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on January 19, 2009. Please reference Application Number **06-665** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald, P.E.
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/rm/7-0060


Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Russell D. Schamel, Sunshot Engineering, 608 9th St., Suite 4, Wheatland,
Wyoming 82201
Platte County Planner, P.O. Box 728, Wheatland, Wyoming 82201





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

December 19, 2006

Bill Urbigit, Public Works Director
City of Riverton
816 North Federal Blvd.
Riverton, WY 82501

RE: Madison Water Line Replacement, Permit Number: 06-666R, NE ¼, Section 34,
T1N, R4E, Fremont County

Dear Mr. Urbigit:

The above application for coverage under General Permit to install approximately 825 linear feet of 8-inch water line replacement along Madison street (near the proposed fire hall) has been reviewed in accordance with Chapter 3, Section 7; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.
Environmental Engineer
Water Quality Division

xc: IPS, Cheyenne
Christina D. Willhelm, P.E., Inberg-Miller Engineers, 124 East Main St., Riverton, WY 82501

encl: General Permit For a Public Water Supply System

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726


SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

October 12, 2006

Councilman Rocky Greenwood,
Town of Riverside
207 West Welton
Riverside, WY 82325

RE: Riverside Sewer Extension to Casey Wailes Property, Application No.06-668, in Carbon County.

Dear Councilman Greenwood:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Sewage Collection Systems described as 743 lf of 8" diameter pvc sewer with manholes, Blocks 16 and 17 Town of Riverside; Carbon County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by May 10, 2010.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 06-668 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

cc: IPS, Cheyenne

Barney Horrell, WWC Engineering
611 Skyline Road
Laramie, WY 82070

LBH/rm/6-0944

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH
(307) 777-7758
FAX 777-3610

ABANDONED MINES
(307) 777-6145
FAX 777-6462

AIR QUALITY
(307) 777-7391
FAX 777-5616

INDUSTRIAL SITING
(307) 777-7369
FAX 777-6937

LAND QUALITY
(307) 777-7756
FAX 777-5864

SOLID & HAZ. WASTE
(307) 777-7752
FAX 777-5973

WATER QUALITY
(307) 777-7781
FAX 777-5973





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

January 25, 2007

Mr. Jerome Deveraux
Stone Development LLC
304 S. 3rd St
Laramie WY 82070

Subject: Application for Permit to Construct No. **06-670**, Returned Without Action.
Overland Heights

Dear Mr. Deveraux:

Your application for a permit to construct No. **06-670** has been inactive four months. Your engineer, James Johnson of Johnson Engineering Associates, has attempted to get a statement from the City of Laramie that the City agrees to provide water and sewer service for the proposed development. This statement has not been provided. For this reason the application is being returned without action. When the City of Laramie can provide a statement committing to providing water and sewer service or is willing to sign the permit application as the owner, the permit application should be resubmitted.

A permit to construct has not been authorized and no construction of water or waste water facilities subject to permitting requirements should have been initiated or completed. If such construction has occurred, please notify the Water Quality Division immediately.

Sincerely,

Louis B. Harmon PE
SE District Engineering Supervisor
Water Quality Division

LBH/rm/7-0080


cc: Rich Merrill, City Engineer, City of Laramie, P.O. Box C, Laramie WY 82073





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 12, 2007

Victor R. Blackmon
P.O. Box 551
Franklin, TX 77856

RE: Kemmerer - BLM Office - Water and Sewer Main Extensions - Permit Number 06-671R,
Tracts 62 & 71, SW 1/4 Section 12, T21N, R116W, Lincoln County

Dear Mr. Blackmon:

The above application for coverage under General Permits to Construct water and sewer main extensions consisting of about 575 linear feet (LF) of 8-inch PVC water main and 140 LF of 6-inch PVC sewer main, 565 LF of 1 1/2 - inch pressure sewer and lift station to serve a new BLM Office in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.
Southwest District Engineer
Water Quality Division


xc: IPS, Cheyenne
Christina D. Willhelm, P.E., Inberg-Miller Engineers, 124 East Main Street, Riverton, WY
82501

encl: General Permit for a Public Water Supply Distribution System,
General Permit for a Sewage Collection System





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

October 19, 2006

Mr. Duané Stolns, Director of Public Works
City of Rawlins
P.O. Box 953
Rawlins, WY 82301

RE: Walmart Water Improvement Project, Application No.06-672,Carbon County

Dear Mr. Stolns:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems described as replacement of 6" diameter water line with an 8" diameter water line, Section 15 T21N R87W; Carbon County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations. The general permit and the materials submitted in your application package. All service connections will be protected by the appropriate backflow device as required by Chapter 12, Section 14(i) of the Water Quality Division Rules and Regulations. All construction, installation, or modification allowed by this notification of coverage shall be completed by May 10, 2009.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 06-672 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

cc: IPS, Cheyenne

Gary Steele, PMPC
P.O. Box 370
Saratoga WY 82331

LBH/rm/6-0970

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH
(307) 777-7758
FAX 777-3610

ABANDONED MINES
(307) 777-6145
FAX 777-6462

AIR QUALITY
(307) 777-7391
FAX 777-5616


INDUSTRIAL SITING
(307) 777-7369
FAX 777-6937

LAND QUALITY
(307) 777-7756
FAX 777-5864


SOLID & HAZ. WASTE
(307) 777-7752
FAX 777-5973

WATER QUALITY
(307) 777-7781
FAX 777-5973





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 3, 2006

Ben Doud
Doud BTS, Inc.
25528 Genesee Trail Road
Golden, CO 80401-9366

RE: Replacement of 1850 Feet of 20 Inch Diameter AC Water Line - Permit Number 06-673R,
Section 3 and 4, T18N, R105W, Sweetwater County, Wyoming PWS: WY5600050

Dear Mr. Doud:

The above application for coverage under General Permits to Construct water main replacement of 1850 feet of 20 inch AC water line with 18 inch diameter PVC main to retain serviceability in the area of new rail spur installations in accordance with Chapter 3, Section 7, Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Perry Roberson
Environmental Senior Analyst
Water Quality Division

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne

encl: General Permit for a Public Water Supply Distribution System





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

October 12, 2006

Mr. Herman Noe, Manager of Engineering
Cheyenne Board of Public Utilities
P.O. Box 1469
Cheyenne WY 82003-1469

RE: Western Hills 30" Watermain Extension Project, Application No.06-674, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems described as 5600 lf of 30" diameter ductile iron pipe watermain, Sections 15 and 16 T14N R67W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by May 10, 2009.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 06-674 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

cc: IPS, Cheyenne

Scott Cowley, AVI pc
2035 Westland Road
Cheyenne WY 82001

LBH/rm/6-0945

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH
(307) 777-7758
FAX 777-3610

ABANDONED MINES
(307) 777-6145
FAX 777-6462

AIR QUALITY
(307) 777-7391
FAX 777-5616

INDUSTRIAL SITING
(307) 777-7369
FAX 777-6937

LAND QUALITY
(307) 777-7756
FAX 777-5864


SOLID & HAZ. WASTE
(307) 777-7752
FAX 777-5973

WATER QUALITY
(307) 777-7781
FAX 777-5973





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 3, 2006

B.J. and Steve Travis
P.O. Box 1732
Pinedale, WY 82941

RE: Travis Septic System - Permit Number 06-675, Lot 24 Old Brazzill Ranch S/D, 33N 109W
Sec 10 SE1/4, Sublette County, WY

Dear B.J. and Steve Travis:

The above application for coverage under General Permit to Construct a small wastewater enhanced treatment facility consisting of a septic tank and pump tank, 1000 gallons each, a gravity fed intermittent sand filter with infiltrators installed over a bed of washed sand to serve a three bedroom home in accordance with Chapter 3, Chapter 11, Part D and Chapter 23 Section 7 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

Required pump tank vent and effluent sample point notation added to drawing per phone conversation with Steve Wonacott P.E.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Perry Roberson
Environmental Senior Analyst
Water Quality Division

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Keith Raney, Environmental Health, Sublette County, P.O. Box 722, Pinedale, WY 82941


encl: General Permit for Small Wastewater Treatment Systems





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

October 23, 2006

c/o Bart Bader
1203 Missouri Flat Rd.
Thermopolis, WY 82443

RE: Residential Small Wastewater Treatment Facility for Bart Bader, Terry D. & Melodi Alldredge, Permit Number: 06-676, NW ¼, Section 14, T8N, R4E, Hot Springs County

Dear Mr. Bader:

The above application for coverage under General Permit to construct a gravity flow septic tank and leachfield to serve a four bedroom home in accordance with Chapter 3, Section 7; and Chapter 11, Part D of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved with the following stipulation:

The total minimum length of the trench with perforated pipe was calculated to be 395 linear feet. Thus the actual length of each of the four trenches must be about 100 feet long, rather than 20 feet long. This sheet has been corrected on your application form and must be adhered to during the construction.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please contact Lee Campbell, Hot Springs County Planner, at 307-864-2961 to schedule a construction inspection at least 24 hours prior to the beginning of construction.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.
Environmental Engineer
Water Quality Division

xc: IPS, Cheyenne
Lee Campbell, Hot Springs County, 415 Arapahoe, Thermopolis, WY 82443 (w/enclosures)
Scott Harvey, Hot Springs Backhoe Service, 320 Red Lane, Thermopolis, WY 82443

encl: General Permit For a Small Wastewater Facility

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726


WATER QUALITY
(307) 332-3144
FAX 332-3183



IPS



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

October 20, 2006

Tonn Construction
P.O. Box 2211
Gillette, WY 82717

RE: Tonn Construction Commercial Septic System, 3481 Garmin Road, Lot 4, Hannum Road Industrial Park, Permit # 06-681

Gentleman:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD



PLIC
NSTAL
PURSU
up
○

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
Bret H. Wolz, P.E., Falcon Consulting Services, LLC, P.O. Box 3943, Gillette, WY 82717-3943.
Keith Bowar, Campbell County, 500 South Gillette Avenue, Suite 1500, Gillette, WY 82716



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

October 4, 2006

Pete Iacobill, Managing Member
Hunt Club Investment Group
1231 Sunnyside Drive
Cadillac, MI 49601

RE: Commercial Septic System, 3601 Southern Drive, Gillette, WY
Permit # 06-682

Dear Mr. Iacobill:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

J. Dennis Lamb
CBM Program Supervisor
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
Keith Bowar, Campbell County, 500 South Gillette Avenue, Suite 1500, Gillette, WY 82716
Brent Thumma, P.E., LLC, 8 Doe Court, Gillette, WY 82718

Page 1 of 1



ROAD APPLICATION PERMIT

X New
Renewal
Modified

PERMIT NO. 06-683
SPECIAL CONDITIONS
REF/PERMIT

Steward Point, Mesa, Riverside, Warbonnet, and Jonah Areas

This permit hereby authorizes the applicant:

Ultra Resources, Inc.
P.O. Box 1768
Pinedale, WY 82941

to road apply treated water from the Anticline Disposal facility according to the procedures and conditions of application number 06-683. The application site is located in various sections throughout the county of Sublette, in the State of Wyoming. This permit shall be effective until November 1, 2009.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:


- 1 of 10 The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion date. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: **DEQ/WQD, Casper WDEQ Field Office, 152 No. Durbin Street, Suite 100, Casper, WY 82601, telephone (307) 473-3452; FAX (307) 473-3458.**
- 2 of 10 The permittee shall provide immediate oral and/or written notice to the **Casper WDEQ Field Office** in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
- of 10 The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
- 4 of 10 Only treated water from the Anticline pilot water treatment plant shall be applied. Untreated water or water from the proposed full scale water treatment plant is **not authorized for road application.**

- 5 of 10 The treated water shall be uniformly and incorporated into the road bed. Treated water shall not be applied during the period from November 1 to April 10.
- 6 of 10 The application site slope shall not exceed eight percent (8%) for vehicular application.
- 7 of 10 Water application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
- 8 of 10 Only the roads designated in this permit are authorized for application of the treated water.
- 9 of 10 For the first year of operation, monthly testing of the water to be applied will be conducted. This analysis will be submitted to WDEQ on a monthly basis. The monthly analysis will include EC, pH, and major ions.
- 10 of 10 An annual report will be submitted to WDEQ **prior to April 1 of each year**. The annual report will include a map showing the location of roads receiving water the previous year, road bed testing of the roads which received water, and a current water analysis. The annual road bed testing and water analysis will include laboratory analysis for EC, pH, major ions, total iron, total boron, total RCRA metals, and radionuclides.


AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality



Date of Issuance

KJM/rm/7-0483

STATEMENT OF BASIS

I. General information.

A. Permit Number: 06-683

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are no numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized. Beneficial use includes dust control.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

District Policy 10.2 (10/17/86)

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NA

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying treated water onto the roadbed. Repeated applications of treated water on the same sections of road will be monitored by roadbed analyses.

B. Quality of waste is such that it will not cause a violation of groundwater standards. Briefly describe:

NA

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

NA

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

NA

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

NA

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

NA

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

NA

VII. Documentation of Statement of Basis.


A. The archive file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb and Kim Medina, CBM/Oil and Gas Group and completed on June 8, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

October 5, 2006

Rosalie Brimmer
P.O. Box 333
Moorcroft, WY 82721

RE: Brimmer Residential Septic System
Permit # 06-684

Dear Ms. Brimmer:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion
Transfer of Ownership Form

cc: IPS, Cheyenne
Tim Lyons, Crook County Growth and Development Coordinator, P.O. Box 848, Sundance, WY 82729

Page 1 of 1





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

October 10, 2006

Paul Rasmussen
P.O. Box 152
Moorcroft, WY 82721

RE: Rasmussen Residential Septic System
Permit # 06-685

Dear Mr. Rasmussen:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

Additionally, the following project specific conditions also apply:

- A. Isolation Distance from Well to Septic Tank and Adsorption Field – Any well drilled on the site must maintain isolation distances, as specified in Part D, Chapter 11, Wyoming Water Quality Rules and Regulations. The well must be more than 50 feet from the septic tank and more than 100 feet from the absorption system.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Page 1 of 2




Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
Tim Lyons, Crook County Growth and Development Coordinator, P.O. Box 848, Sundance, WY 82729



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 9, 2006

Mr. Cal Van Zee, Utilities Division
City of Laramie
P.O. Box C
Laramie, WY 82073

RE: Laramie Sewer Outfall Project, Application No. **06-686**, Albany County

Dear Mr. Van Zee:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Sewage Collection Systems described as an interceptor line consisting of 1405 ft of 21" diameter SDR 35 PVC sewer line and 4300 ft of PVC 36" diameter SDR 26. PVC sewer line. Sections 28, 29, 32, 33 T16N R73W; Albany County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by May 10, 2010. **The existing 15" diameter line down gradient of M.H. #8 must be connected into the manhole as opposed to plugged and capped as shown on the plans.**

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **06-686** in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

cc: IPS, Cheyenne


James Cavalli, Aspen-Banner Engineering
1575 North 4th Street, Suite 105
Laramie WY 82073

LBH/rm/6-1065





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

October 12, 2006

Diana I. Clapp, Superintendent
Fremont County School District
P.O. Box 10
Pavillion, WY 82523

RE: Wind River Elementary School Water & Sewer Lines, Permit Number: 06-687,
Section 7, T3N, R2E, Fremont County

Dear Ms. Clapp:

The Department of Environmental Quality understands that this project will serve a replacement elementary school with an estimated student body of 150 persons and that the fire flow demand is estimated at 500 gpm. The above application for coverage under General Permit to construct 422 linear feet of 8-inch water distribution lines for domestic and fire suppression purposes and 385 linear feet of 8-inch sanitary sewer lines has been reviewed in accordance with Chapter 3, Section 7; Chapter 11, Section 9; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.
Environmental Engineer
Water Quality Division

xc: IPS, Cheyenne
Frank Grimes, P.E., Nelson Engineering, P.O. Box 1599, Jackson, WY 83001
Larry Zoller, Town of Pavillion, P.O. Box 278, Pavillion, WY 82523

encl: General Permits For a Public Water Distribution System & Existing Sewage Collection System

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183



PERMIT TO CONSTRUCT

CHANGE OF OWNERSHIP

PERMIT NO. 06-689
SPECIAL CONDITIONS

REF/PERMIT NO. 95-017, 95-118, 95-235, 95-313, 95-416, 01-483, 02-190

Champ, LLC, Swine Feeding, Waste Storage and Land Application Areas

This permit hereby authorizes the applicant:

Champ, LLC.
515 Albin St.
P.O. Box 127
Albin WY 82050

to assume ownership of the 12,750 swine (5100 animal unit) in Section 33 T17N R60W and the 12,000 feeder pig (4000 swine or 1600 animal unit) confined swine feeding operations, waste collection, storage and treatment lagoons and land application of swine wastes, and operate it according to the procedures and conditions of this permit number 06-689, as derived from the reference permit numbers 95-017, 95-118, 95-235, 95-313, 95-416, 01-483, 02-190. The facility is located in all or part of Sections 26, 27, 33, 34, 35 T17N R60 W, and Section 3 T16N R60 W in the county of Laramie, in the State of Wyoming.

The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator. Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility will meet applicable permit conditions or other effluent or operational requirements. Compliance with discharge and land application standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction, design or operation of the facility described herein. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction, maintenance or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or where land application of waste is made for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of this permit, 06-389; referenced permits 95-017, 95-118, 95-235, 95-313, 95-416 as modified by permit, 01-483, 02-190, and applicable supporting documents. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

Conditions from Permit 95-017 Signed June 9, 1995

Permit 95-017 had 11 numbered conditions. The numbered conditions of the permit that have been satisfied or are no longer applicable are 1 of 11, 2 of 11, 3 of 11, 6 of 11, 7 of 11, 9 of 11. Conditions 4 of 11, 5 of 11, 8 of 11, 10 of 11, and 11 of 11 have been carried forward and renumbered as conditions of this permit.

Conditions from Permit 95-118 Signed May 2, 1995.

Permit 95-118 had 8 numbered conditions. The numbered conditions of the permit that have been satisfied or are no longer applicable are 1 of 8, 2 of 8, 3 of 8, and 8 of 8. Conditions 4 of 8, 5 of 8, 6 of 8 and 7 of 8 have been carried forward and renumbered as conditions of this permit.

Conditions from Permit 95-416 Signed September 18, 1995.

Permit 95-416 had 5 numbered conditions. All conditions have been satisfied or are no longer applicable.

- 1 of 8 This permit is based on the drawdown cone and radius of influence from the production well known as 3-M Trout No. 1, Wyoming State Engineer Permit U.W. 139366 located in the E 1/2 Section 34 T17N R60W being pumped at a minimum rate of 400 gpm at all times. A report done by Lidstone & Anderson dated March 2, 1995 and submitted with the application package illustrates that the drawdown cone and radius of influence for the production well will be such that groundwater will be protected.
- 2 of 8 If the hog feeding operation shuts down for 30 days or more, the wastewater lagoon or lagoons shall be emptied and all sludges removed and properly disposed of. The production well shall maintain a minimum pumping rate of 400 gpm during intermittent or permanent shutdown of the hog feeding facilities. The well shall maintain the minimum pumping rate until the permittee demonstrates that contamination from any hog operation sources has been removed from the groundwater.
- 3 of 8 In order to verify the groundwater modeling and to show that groundwater is being protected, the following procedures for groundwater monitoring and sampling shall be followed for the wells listed.
 - a. The following four wells shall be monitored for static water levels and for nitrates as N. The wells shall be measured and sampled on a semiannual basis before and after the irrigation season.

<u>Well Name</u>	<u>Permit Number</u>
3M Trout Nebraska Well	
3-M Trout No. 1, Wyoming	U.W. 139366
Anderson #2	P6845W
Malm 33-1	P2712

- b. The amount of water pumped from the production well on a monthly basis and the amount of water pumped from the other wells on an annual basis shall be measured and reported.
- c. The report shall have a cover sheet referencing this permit, 06-689. The information gathered from the wells shall be correlated and placed in an annual report to be submitted to DEQ/WQD. The report shall include a map showing the location of all wells being sampled as well as all major physical features such as roads and buildings.

The contours of the groundwater surface shall be shown at 10 foot intervals. The four wells shall be annotated on the map with the well name, the spring static level and the fall static level.

(This condition is replaces Condition 10 of 11 to permit 95-017. Modifications are made based on the knowledge gathered from the collection of 11 years of data for the operation.)

4 of 8 If the total nitrate as N is 10 mg/l or greater in any well, the permittee shall conduct an analysis to determine the cause of the elevated levels of nitrates. If the measured water table elevations and nitrate sampling of wells do not indicate complete recapture of any contamination plume emanating from the permitted swine operations, the permittee will be required to develop and implement a corrective action plan. This plan must be approved and any construction permitted by DEQ before implementation. (This condition replaces part of Condition 10 of 11 and all of condition 11 of 11 to permit 95-017. Modifications are made based on the knowledge gathered from the collection of 11 years of data for the operation.)

5 of 8 All solid swine manure wastes generated by the operations allowed by this permit shall be disposed of in the following fashion:

(a) Buffer zone.

- a. A buffer zone of 200 feet is required between a land application site and current residential, commercial, school, or industrial development lands where solid manure is to be spread.
- b. Solid manure shall not be land applied within 200 feet of a perennial or intermittent water body or water well permitted for current domestic purposes.
- (iii) Solid manure shall not leave the property where it is applied.

(b) Pathogen controls:

- (i) Solid manure wastes shall not leave the application site when solid manure wastes are land applied.
- c. Solid manure wastes shall be applied only to lands with a low potential for public contact with the solid manure wastes or the soil. This restriction does not preclude hunting or fishing.
- (iii) Crops shall not be harvested for 30 days after the application of solid manure wastes.
- d. Direct human consumption crops, which are consumed fresh, shall not be harvested for one (1) year after the application of solid manure wastes.
- e. Turf grass or sod grown on land where solid manure wastes are applied shall not be harvested for landscaping for one year after application of solid manure wastes.

(c) Solid manure wastes may be sold or given away. The permittee must maintain a record of who received solid manure and the amount received. The permittee must assure that the use of the solid manure complies with the requirements of this condition.

6 of 8 The waste water piping and the irrigation well connections shall be completed and maintained in accordance with the attached Water Quality Division Policy 13.29.3, Use of Chemigation Check Valves for Well Head Protection. This policy allows the use of agricultural chemigation valves in addition to the reduced pressure backflow prevention devices permitted in permit 95-118. Either device must be protected by downstream low pressure relief valves to eliminate the possibility of valve damage due to freezing.


7 of 8 The following conditions shall apply to all land application of liquid swine wastes:


- a. Any groundwater wells shall be protected from backflow in accordance with the attached Water Quality Division Policy 13.29.3.
- b. The land application rates shall be limited for both hydraulic loading and nutrient loading. The total nitrogen available in the soil after harvest plus nitrogen applied from all sources during the following growing year shall not exceed the anticipated nitrogen uptake of the crop seeded.
- c. Directly edible crops, such as dry beans and potatoes, may not be irrigated with liquid animal wastes.
- d. The hydraulic loading shall not exceed the transevaporation plus the assimilative capacity of the soil. The total amount of water applied, including precipitation, shall be recorded and reported in the annual report.
- e. Center pivot irrigated lands receiving land application of liquid swine wastes shall be divided into quadrants. Each quadrant shall be considered a management parcel.
 - (a) A soil test for irrigated land shall consist of three samples tested individually. Each sample shall be a composite from four locations within the management parcel. One sample shall be from the 0" to 6" depth, one sample from the 6" to 24" depth, and one sample for the 24" to 48" depth. If test results of the 24"-48" horizon indicate increasing nutrient levels, additional sampling shall be conducted of the 48" to 72" horizon.
 - (b) Standard soil tests shall be taken, including analysis for phosphorus and Nitrate as N reported as parts per million and as pounds per acre for the horizon represented by the sample.
- f. The nutrients supplied by a land application plus the residual nutrients in the soil shall not exceed the agronomic requirements of the crop to be seeded.
- g. The liquid applied by an application of animal wastes shall not exceed the retention capacity of the upper 12 inches of the soil less the pre-existing moisture content of the soil. The liquid application rates shall be adjusted as necessary for the most restrictive soil type within a management parcel.
- h. The amount of phosphorus present in the upper 12 inches of soil shall be monitored using tests appropriate for the soil pH. If the phosphorus loading exceeds 300 pounds per acre, additional soil testing shall be undertaken to evaluate the potential for deleterious salt and alkali accumulations.
- i. If phosphorus loading exceeds 300 pounds per acre or deleterious amounts of salt accumulate, land application to that management parcel shall stop until the parameter of concern is remedied.

- j. An annual report shall be submitted to the Water Quality Division. The annual report shall include all soil sampling results, analysis of the liquid animal wastes applied, the amounts of commercial fertilizers applied, the crops planted, crop yields and an analysis of all plant nutrients tested, which shall include phosphorus and potassium in addition to nitrogen.

8 of 8 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

10/2/06
Date of Issuance

LBH/rm/6-0903

cc: Keith Burrton
Associated Legal Group
1807 Capitol Avenue, Suite 203
Cheyenne WY 82001

STATEMENT OF BASIS

IV. Permit Number: 06-689

V. Application reviewed for compliance with the following regulations.

A. Chapter 11. YES

B. Chapter 12 NO

VI. Basis for issuing permit: Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

VII. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.

YES

VIII. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

N/A

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

N/A

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe: Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

N/A

D. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter 8. Briefly describe:

The permit is based on groundwater modeling which indicated that all contamination entering the groundwater from the wastewater ponds will be captured by the 3-M Trout No. 1, Wyoming State Engineer Permit U.W. 139366. The 3-M Trout No. 1, Wyoming State Engineer Permit U.W. 139366 is located approximately one mile downgradient and must be pumped at a minimum of 400 gpm at all times. The pumping rate for the 3-M Trout No. 1, Wyoming State Engineer Permit U.W. 139366 well may be increased depending upon demand, however it will not be less than the 400 gpm.

- E. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

This permit allows the nitrates as N concentrations in the unconfined aquifer underlying the site to exceed the Chapter 8 standard of 10 ppm of nitrates as N. The limits of the allowable impact are the portions of Sections 33,34,35 T17N R60W that is owned by Malm Trout Ranch, Inc. or subject to land application agreements benefitting the permit. The cone of drawdown produced by the continuous pumping of 3-M Trout No. 1, Wyoming State Engineer Permit U.W. 139366 well will confine the impacted waters of the aquifer to Sections 33,34,35 T17N R60.

- F. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

The permit requires that the wells in the table below be monitored to verify the groundwater model and to verify that the groundwater is not impacted beyond the limits of Sections 33,34,35 T17N R60W. All four wells will be monitored for static water levels and nitrogen. The annual water production will be reported for the 3-M Trout No. 1, Wyoming State Engineer Permit U.W. 139366 well and irrigation wells in the land application areas. Monitoring shall be required until such time as the department is satisfied the groundwater modeling is accurate and that and adverse impacts to the aquifer have been restored to U.S. Safe Drinking Water Standards.

<u>Well Name</u>	<u>Permit Number</u>
3M Trout Nebraska Well	
3-M Trout No. 1,	Permit U.W. 139366
Anderson #2	P6845W
Malm 33-1	P2712

IX. Documentation of Statement of Basis.

The archive file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Louis B. Harmon, Southeast District Engineering Supervisor, and completed on October 2, 2006. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT
PWS WY5600189

PERMIT NO. 06-690

Town Of Albin-2006 Wells, Pumphouse and Transmission Lines

This permit hereby authorizes the applicant:

Mayor Lon Johnson
TOWN OF ALBIN
PO BOX 188
ALBIN, WY 82050

to connect two wells to a water distribution system with pumps, chlorinators, and a new well house according to the procedures and conditions of the application number 06-690. The facility is located in Sections 20 and 29 T17N R60W; Laramie County, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed May 10, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088, FAX 307-777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

Date of Issuance

2/20/07

LBH/rm/7-0142

ARS 2/20/07

STATEMENT OF BASIS

1. Permit Number: 06-690

1. This application was reviewed for compliance with the applicable regulations ;

Chapters 3, 12

2. Does the permit comply with all applicable regulations identified above?

Yes

3. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.

Public water supplies are exempted from review by Chapter 3, Section 17.

4. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Louis Harmon, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on February 20, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 06-692

Discharge Water Treatment Facility-Jensen Site
Anticline Disposal, LLC

This permit hereby authorizes the applicant:

AntiCline Disposal, LLC
P.O. Box 273
Boulder, Wyoming 82923

to construct, install or modify a discharge water treatment facility (multiple technologies) in accordance with the procedures and conditions of the application number 06-692. The facility is located in southwest quarter of Section 18, Township 311 North, Range 108 West in the county of Sublette, in the State of Wyoming. This permit shall be effective until June 1, 2009.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the water treatment process described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the land application is located for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor: any infringement of federal, state or local laws or regulations.

The permittee shall conduct permitted water treatment in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 6 The applicant will provide immediate oral or written notice to the DEQ/WQD CBM Program in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 6 The applicant shall notify the DEQ/WQD CBM Program two weeks prior to start up of the treatment facility.
- 3 of 6 The following system monitoring and analytical testing shall be conducted by AntiCline:

- a) Start-Up – Monitoring during start-up will be conducted on a weekly basis and will include flow rate, chemical usage, analytical data of the influent and effluent water. All applicable information regarding the operation of the project facility including any changes/problems in the operation of the facility and any modifications to the equipment or operating procedures made to correct the problems. This shall include any changes in valves/piping, use of any chemicals (prior approval by DEQ required), tank overflows, and any other applicable information.

Start-up monitoring shall include analytical testing for inorganic constituents, EC, TDS, Ph, DRO, GRO, BTEX, TOC, and methanol. The testing can be done by the lab at AntiCline with periodic commercial lab confirmation testing or it can be the SCADA data from the EC/Ph monitors. The data shall be submitted to DEQ/WQD CBM Group in electronic format.


- b) Monitoring – Following start-up monitoring, monitoring at the facility will be conducted on a monthly basis. A monthly report on the plant's operation, including flow rate, chemical usage, analytical data of the influent and effluent water, needs to be submitted to WDEQ within 30 days after the end of the month. The analytical data is to include the constituents listed in 3 of 6 a) for start-up. The monthly report will include any changes, problems, and/or modifications to the equipment or operating procedures. Any sludge removal, testing and disposal shall also be included in the monthly report. Additional monitoring requirements may be required by WDEQ and AntiCline may request a change in frequency and/or constituents based the performance of the facility

- 4 of 6 The validity of this permit is subject to the owner maintaining a bond acceptable to the State of Wyoming, DEQ/WQD for the amount of the facility closure and post-closure costs. The bonding amount is subject to review on an annual basis.


- 5 of 6 An annual report will be submitted to DEQ CBM / Oil and Gas Group by April 1 of each year. The annual report will include relevant details of the construction, modification, and operation details of the facility covered under Permit 06-692 and any anticipated construction, modification and/or operational changes for the water treatment facility for the upcoming year. The annual report will also include a review of the closure and post closure requirements, including financial costs. A renewal of the bond will be required as part of the annual report. Reporting requirements are subject to modification by DEQ.

6 of 6 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality

9/28/07

Date of Issuance

JDL/LBH/cs/7-0853

cc: WDEQ Casper Field Office
Jay Allin, Forerunner Corporation, 3900 S. Wadsworth Blvd #600, Lakewood, CO, 80235

STATEMENT OF BASIS

1. Permit Number: 06-692
2. Application reviewed for compliance with the following applicable regulations :
 - a. Chapter 11.
3. Does the permit comply with all applicable regulations identified above?
 - a. Yes
4. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.


The site has a ground water monitoring network in place. The new plant will not affect ground water at the site.

5. Documentation of Statement of Basis.

The archive file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, CBM Program, and completed on May 30, 2007. The bond for the facility was approved on August 23, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

October 19, 2006

Landis Benson, Manager
The Development Company, LLC
744 Big Horn Ave.
Worland, Wyoming 82401

RE: Bomber Peak Addition Water and Sewer, Permit Number 06-693, SW1/4 SW1/4 Sec. 20 and NW1/4 NW1/4 Sec. 29, T47N, R92W, Washakie County.

Dear Mr. Landis:

The above application for coverage under General Permits to construct 660 feet of 8-inch and 2,140 feet of 12-inch sewer main, 7 manholes, and 24 sewer service connections; and 1,770 feet of 12-inch, 1440 feet of 8-inch, and 1,980 feet of 6-inch water main with 6 fire hydrants and 33 water service connections, to serve twenty four single family lots in accordance with Chapter 3, Section 7, Chapter 11, Section 9, and Chapter 12, Section 14, of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved.

You are authorized to construct the sewer mains, manholes, and services; and water mains, appurtenances, and services, in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Jeff Hermansky
Northwest District Engineering Supervisor

xc: Mike Donnell, Donnell & Allred, Inc.
✓IPS, Cheyenne

encl: General Permits for Sewer Collection and Water Distribution Systems



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 06-694R

Wilson Park Subdivision's Public Water System & Sewage Collection Lines
PWS # Unassigned

This permit hereby authorizes the applicant:

Christine Walker, Executive Director
Teton County Housing Authority
P.O. Box 714
Jackson, WY 83001

to construct a "new" public water system consisting of two new wells (60 gpm capacity each), a well house, hydropneumatic tank, disinfection system, 850 linear feet of 4-inch diameter water lines, a fire suppression well with associated water lines and two hydrants, and a sewer collection system consisting of 600 linear feet of 8-inch diameter sewer lines that will connect to the Wilson Sewer District system; according to the procedures and conditions of the application number 06-694R. The facility is located within Section 22, Township 41 North, Range 117 West in the county of Teton, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by November 15, 2008.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not

relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:


- 1 of 4 Routine inspections and maintenance are essential for the long-term efficiency of this new water system. The owner needs to adhere to the manufacturer's maintenance recommendations for each piece of equipment.


- 2 of 4 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Northwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

- 3 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

11-21-06
Date of Issuance
JSB/rm/6-1086

STATEMENT OF BASIS

1. Permit Number: 06-694R
2. Application reviewed for compliance with the following regulations:
Chapters 3, 11, and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?
Yes.
4. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Public water supplies and sewage collection systems are exempted from review by Chapter 3, Section 17.
5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by James S. Brough, jbroug@state.wy.us, Environmental Senior Analyst and completed on November 14, 2006. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

Cc: David Dufault, P.E., Nelson Engineering, P.O. Box 1599, Jackson, WY 83001

F:\DIVISION\WQD\WP\2006 Permits & Reviews\06-074R.pc.jsb.doc

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 06-696

General Chemical (Soda Ash Partners) - Ultrafiltration Water Treatment
PWS # WY5600636

This permit hereby authorizes the applicant:

Peter J. Kalivas, Vice President of Manufacturing
General Chemical (Soda Ash Partners)
P.O. Box 551, Green River, WY 82935

to install a 150 gpm capacity ultrafiltration water treatment plant that will replace one of two existing sand filters, according to the procedures and conditions of the application number 06-696. The facility is located at SE 1/4 Section 30, T19N, R109W in the county of Sweetwater, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by November 14, 2008.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit. The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not

relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:


- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

11-21-06
Date of Issuance
JSB/rm/6-1087

STATEMENT OF BASIS

1. Permit Number: 06-696
2. Application reviewed for compliance with the following regulations:

Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.

3. Does the permit comply with all applicable regulations identified above?

The approval is based upon a deviation from applicable regulations in accordance with Section 5 of Chapter 12.

4. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of the applicable regulations.

- a. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulations.

- 1) Chapter 12, Section 5 allows for new technology and equipment and provides a process for evaluating and permitting designs which deviate from these regulations. Chapter 12, Section 5 (a)(ii) allows data obtained from a full scale, comparable installation which demonstrates the acceptability of the design. This process is met with the successful operation of a similar ultrafiltration plant at Little America for the past two years. The Green River is the same raw water source for both plants.

- 2) Results from the Environmental Protection Agency's (EPA) and the National Sanitation Foundation's (NSF) Environmental Technology Verification Program testing of the proposed ultrafiltration membrane module indicates an average 4.2 log removal, of particles greater than 2 micron.

- 3) EPA's Surface Water Treatment Rule's fact sheet from EPA Region 8 credits ultrafiltration with ">2" log removal for cryptosporidium, ">3" log removal for giardia, and with "0" log removal for viruses. Thus, ultrafiltration satisfies EPA's requirement for cryptosporidium and giardia removal. However, the 4 log removal of viruses still needs to be maintained by disinfection.

5. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.

Public water supplies are exempted from review by Chapter 3, Section 17.

6. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION


The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by James Brough, jbroug@state.wy.us, Environmental Engineer and completed on November 14, 2006. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

Xc: Robert Fischer, Veco USA, Inc., 1471 Dewar Dr., Suit 11B, Rock Springs, WY 82901
Randy Tolman, P.E., Green River Soda Ash Operations, P.O. Box 551, Green River, WY 82935-0551

F:\DIVISION\WQD\WP\2006 Permits & Reviews\06-696.pc.jsb.doc



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 17, 2006

Sue Rigano
Town of Bairoil
P.O. Box 58
Bairoil, WY 82322

RE: Bairoil - Sales Tax Project 2006 - Water Main Extensions - Permit Number 06-698,
Sections 10&11, T26N, R90W, Sweetwater County, PWS # WY5600003

Dear Mayor Rigano:

The above application for coverage under General Permit to Construct a water main extension consisting of approximately 2600 feet of 6-inch and 950 feet of 2-inch PVC water main in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.
Southwest District Engineer
Water Quality Division


xc: IPS, Cheyenne

encl: General Permit for a Public Water Supply Distribution System





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

February 26, 2007

Bill Budd
Sublette County Rural Health Care District
P.O. Box 742
Pinedale, WY 82941

RE: Pinedale - Pinedale Medical Clinic - Sewer Main Extensions - Permit Number 06-699R,
NE 1/4 of the SW 1/4 Section 34, T34N, R109W, Sublette County

Dear Mr. Budd:

The above application for coverage under General Permit to Construct a sewer main extension consisting of approximately 464 feet of 6-inch PVC sewer main in accordance with Chapter 3, Section 7 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Joseph Reed Armijo, P.E., Jorgensen Associates, P.O. box 9550, Jackson, WY 83002


encl: General Permit for a Sewage Collection System





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

December 8, 2006

Brad Vernon
Alpine Development Group, LLC
P.O. Box 12910
San Luis Obispo, CA 93406

RE: Lincoln County - Snake River Junction Phases 1 and A - Water and Sewer Main Extensions - Permit Number 06-700R, N 1/2 Section 20 & S 1/2 Section 29, T37N, R118W, Lincoln County

Dear Mr. Vernon:

The above application for coverage under General Permits to Construct a water and sewer main extensions to serve 29 commercial perimeter lots, 35 commercial mixed used lots along with 170 condominium units in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne

encl: General Permit for a Public Water Supply Distribution System,
General Permit for a Sewage Collection System

Page 1 of 1

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183

