



Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 15, 2007

Alan Huish
P.O. Box 20000 PMB 25214
Jackson, WY 83001

RE: Huish Septic, Permit No. 07-201, Sublette County

Location: Small waste system at edge of Fremont Lake, NW1/4 Sec 26 T34N R109W

Dear Mr. Hartmann:

The above application for coverage under General Permit to Construct a small wastewater system consisting of a 3000 gallon concrete septic holding tank and appurtenances to serve a 3 bedroom home, in accordance with Chapter 3, Section 7 and Chapter 11, Part D of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Perry Roberson
Environmental Senior Analyst
Water Quality Division

Mark Baron, P.E.
Southwest District Engineer

xc: IPS, Cheyenne
Mark C. Eatinger
District Ranger, Forest Service, Pinedale
encl: General Permit for Small Wastewater Treatment Systems





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 6, 2007

Joe Oleinik
Oleinik Property Holding Company, LLC.
439 Prarieview Drive, Suite C
Gillette, Wyoming 82716

RE: Evanston - Kentucky Fried Chicken & Taco Bell Restaurant - Sewer Service - Permit
Number 07-202, Lat 41.2575, Long 110.9856, Uinta County

Dear Mr. Oleinik:

The above application for coverage under General Permit to Construct, a sewer service consisting of about 100 linear feet (LF) of 6-inch PVC sewer main to serve a restaurant accordance with Chapter 3, Section 7, Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Tom E. Axthelm, P.E., Inberg-Miller Engineers, 124 East Main Street, Riverton, WY 82501

encl: General Permit for a Sewage Collection System





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

April 26, 2007

Joseph A. & Sharon L. DiPasqua
44 14th Street
Wheatland, Wyoming 82201

RE: DiPasqua Small Wastewater,
Location: SE¼, Section 27, T26N, R70W,

Application No. **07-203**
Platte County

Dear Mr. & Mrs. DiPasqua:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a **3 bedroom** house in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the septic tank** must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on April 26, 2009. Please reference Application Number **07-203** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald, P.E.
Consulting Engineer
Southeast District, Water Quality Division

RLE/rm/7-0346

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Platte County Planner, Marlin Johnson, P.O. Box 728, Wheatland, Wyoming 82201

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 12, 2007

Mike Vowell, Superintendent of Buildings and Grounds
Park County
1002 Sheridan Ave.
Cody, Wyoming 82414

RE: Park County Road and Bridge Shop's Small Wastewater Treatment Facility -
Option 2, Permit Number: 07-204, NE ¼, Section 8, T52N, R101W, Park County

Dear Mr. Vowell:

This project consists of the installation of a 1,500-gallon septic tank, a constructed wetland, followed by a non-discharging pond to serve both the restroom facilities and the truck wash bays at a 75-person county shop. This application for the described project has been reviewed in accordance with Chapter 3, Section 7; and Chapter 11, Part D of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

James Brough, P.E.
Environmental Engineer
Water Quality Division

xc: IPS, Cheyenne
James G. Evans, P.E., Sage Civil Engineering, 2824 Big Horn Ave., Cody, WY 82414
Gene Smith, Park County Planning, 1002 Sheridan Ave., Cody, Wyoming 82414

encl: General Permit For a Small Wastewater Facility

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

Dave Freudenthal, Governor

NOTIFICATION OF COVERAGE

June 13, 2007

Don Aullman, Mayor
Town of Thayne
P.O. Box 298
Thayne, WY 83127

RE: Thayne - Thayne Elementary School - Water and Sewer Main Extensions - Permit
Number 07-205, NW 1/4 Section 23, T34N, R119W, Lincoln County

Dear Mr. Blackmon:

The above application for coverage under General Permits to Construct water and sewer main extensions consisting of about 1645 linear feet (LF) of 8-inch PVC water main and 1378 LF of 8-inch PVC sewer main in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.
Southwest District Engineer
Water Quality Division


xc: IPS, Cheyenne
Robert V. Hood, P.E., Sunrise Engineering, Inc., P.O. Box 609, Afton, WY 83110

encl: General Permit for a Public Water Supply Distribution System,
General Permit for a Sewage Collection System





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

Dave Freudenthal, Governor

NOTIFICATION OF COVERAGE

May 30, 2007

Kip Platts
P.O. Box 691
Lyman, WY 82937

RE: Lyman - Connor Estates Subdivision- Water and Sewer Main Extensions - Permit Number 07-206R, N 1/2 SW 1/4, Section 32, T16N, R114W, Uinta County

Dear Mr. Platts:

The above application for coverage under General Permits to Construct water and sewer main extensions consisting of about 1189 linear feet (LF) of 8-inch PVC sewer main and 1880 LF of 6 - inch PVC water main to serve 30 residential lots accordance with Chapter 3, Section 7, Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Brent Sanders, P.E., Cook-Sanders, 1004 Main Street, Evanston, WY 82931

encl: General Permit for a Public Water Supply Distribution System,
General Permit for a Sewage Collection System

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT
PWS # 5600050

PERMIT NO. 07-207R

Rock Springs - Morningside at Rock Springs - Water and Sewer Main Extensions

This permit hereby authorizes the applicant:

Bryson Garbett, Owner
Sweetwater Development Group, LC.
8438 Gad Way
Sandy, UT 84093

to construct water and sewer main extensions consisting of 8 and 12-inch PVC water mains connected to a 16-inch water line paralleling Foothill Boulevard and a combination of 8 and 10-inch gravity and 6-inch forced sewer main to serve 381 residential lots; according to the procedures and conditions of the application number 07-207R. The subdivision is located within the city limits of Rock Springs within SW 1/4, Section 15, T19N, R105W in the county of Sweetwater, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by February 6, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

2/7/08
Date of Issuance

PDR/rm/8-0101

STATEMENT OF BASIS


1. Permit Number: 07-207R
2. Application reviewed for compliance with the following regulations:
3. Chapters 3, 11 and 12 of the Wyoming Water Quality Rules and Regulations.
4. Does the permit comply with all applicable regulations identified above?
Yes
5. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.
NA
6. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Not Required
7. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Perry Roberson, prober2@state.wy.us, Engineering Consultant, approved by Mark Baron P.E. Southwest District Engineer and completed on February 6, 2008. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

May 9, 2007

Troy Massie
P.O. Box 876
Moorcroft, WY 82721

RE: Massie Residential Septic System
Permit # 07-209

Dear Mr. Massie:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

Additionally, the following project specific conditions also apply:

- A. Distribution Box – A distribution box will be required to evenly split the flow between the four trenches.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3476. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
Matt Steward, MCS Services, 154 Robinson Road, Moorcroft, WY 82721
Tim Lyons, Crook County, P.O. Box 37, Sundance, WY 82729
WDEQ File





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

May 7, 2007

Douglas Crisp
P.O. Box 770
Sundance, WY 82729

RE: Crisp Residential Septic System
Permit # 07-210

Dear Mr. Crisp:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

Additionally, the following project specific conditions also apply:

- 1) Isolation Distance – The end of the leach field must be at least 25 feet from any potable water lines and 10 feet from any property lines.
- 2) Cleanouts - Cleanouts must be installed at any change in alignment in the sewer line 22.5° degrees or greater.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3478. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

June 12, 2007

Jeff Feck, PE
Vista West Engineering
P.O. Box 785
Sheridan, WY 82801

RE: Cloud Peak Ranch – Fifth Filing, WDEQ #07-212, Sheridan County

Dear Sirs:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations and for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Sewage Collection Systems in accordance with Chapter 3 and Chapter 11 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V. Section O. of the general permits.

If you have any questions, please contact me at 307-473-3465.

Sincerely,

Karen L. Farley, P.E.
Northeast District Supervisor
Water Quality Division

Enclosures: General Permits
Application
Plans and Specifications
Certificate of Completion

cc: Don Roberts, System Land LLC, 2 Soldier Creek Road, Sheridan, WY 82801
Mike Cole, City of Sheridan, P.O. Box 848, Sheridan, WY 82801
WDEQ File
IPS (Cheyenne)





The State
of Wyoming



Department of Environmental Quality

John Corra, Director

Dave Freudenthal, Governor

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

July 24, 2007

Rich Fairservis
RICOR Properties
P.O. Box 50730
Casper, WY 82605

RE: Sundown No. 3 Residential Development, WDEQ #07-213 (modified)

Dear Mr. Fairservis:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Sewage Collection Systems in accordance with Chapter 3 and Chapter 11 of the Wyoming Water Quality Rules and Regulations and General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. Your attention is directed to the mandatory reporting requirements outlined in Part V. Section O. of the general permits.

If you have any questions, please contact me at 307-473-3465.

Sincerely,

Karen L. Farley, P.E.
Northeast District Supervisor
Water Quality Division


Enclosures: General Permit
 Plans

cc: Steve Hollister, P.E., WLC, 200 Pronghorn, Casper, WY 82601(w/plans)
 Town of Mills, 704 Fourth Street, P.O. Box 789, Mills, WY 82644
 WDEQ File
 IPS, Cheyenne





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

July 2, 2007

Andy Schwartz, Chair
Teton County Commission
P. O. Box 3594
Jackson, WY 83001

RE: Pacific Meadows Subdivision, WDEQ Application #07-215

Dear Mr. Schwartz:

The Wyoming Department of Environmental Quality (WDEQ) has completed the review of the above referenced subdivision pursuant to W.S. 18-5-306. This letter constitutes our conclusions regarding the feasibility of the proposed water and sewage systems pursuant to the W.S. 18-5-306 (c). WDEQ noted that Teton County Planning Office was copied with the State Engineer's Office (SOE) letter.

Summary of Proposed Subdivision

The development is located about three miles northeast of the Moran Junction in Teton County. This application proposes to subdivide an existing 8.8 acre tract into 2 lots. The resulting lots will be 3.0 and 5.8 acres in size. The 3-acre lot already contains three seasonal residences, an existing wastewater disposal system, and a well.

Findings As To The Safety And Adequacy Of The Proposed Sewage System

The consultant pointed out that enhanced small wastewater treatment facilities are required due to potential long pathogen travel distance and that a mounded leachfield is required in the lower area of Lot 2 to ensure that a minimum vertical separation of 4 feet is maintained between the bottom of the leachfield and seasonal high groundwater level. The consultant submitted a design that incorporates an Advantex system with a pressurized mound system.

WDEQ recognizes that Teton County currently has qualified, in-house staff who may perform the engineering review in place of doing a joint review with WDEQ. WDEQ understands that Teton County requires a recorded Operation and Maintenance agreement to insure that current and future owners have the small wastewater treatment facility inspected at least annually.



Findings As To The Safety And Adequacy Of The Proposed Water System

The proposed subdivision will use individual on-site wells for drinking water. Water quality data from a nearby well indicates that the water quality meet EPA drinking water standards. WDEQ concurs with the consultant that the aquifer can be expected to produce sufficient supply for the proposed development.

Conclusion(s):


WDEQ has a minor adverse recommendation due to the fact that the proposed development already has existing septic tank and leachfield systems which are most likely not constructed in accordance with the engineering plans that were submitted with the application.

Disclaimer

Nothing in WDEQ's recommendations or comments regarding the subdivider's proposal shall be construed to relieve the subdivider of their obligation to obtain any permits or additional approval from any local state or federal agencies/entities as required by law, rules and regulations, or ordinance. Nothing in these recommendations commits the WDEQ or the delegated county to the issuance of required permits for construction, operation, or modification of water supply and/or wastewater systems. It is the duty of the subdivider/developer to comply with all applicable federal, state and local requirements.

Please do not hesitate to contact me at (307) 332-3144 if you have any questions on the recommendations or need any assistance on how to proceed with this application.

Sincerely,




James Brough, P.E.
Northwest District Engineer
Water Quality Division

cc: Chris Baxter, Pacific Meadows LLC, 2137 34th Ave. West, Seattle, WY 98199-3903
Philip Gyr, Nelson Engineering, P.O. Box 1599, 430 South Cache, Jackson, WY 83001
Planning Director, Teton County Planning Department, P.O. Box 1727, Jackson, WY 83001
Ray Shriver, Teton County Engineering Department, P.O. Box 3594, Jackson, WY 83001
DEQ Subdivision File

F:\DIVISION\WQD\W&WW Section\NW Subdivision Reviews\Teton\Pacific Meadows Subd\07-215 Pacific Meadows.doc



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 1, 2007

Ed Higbie, Developer
1002 Sheridan Ave.
Cody, WY 82414

RE: Cody - Trailhead 3, Phase 3 Addition, Water & Sewer, Permit Number: 07-216, N 1/2, SW 1/4, Tract 39, T53N, R101W, Park County

Dear Mr. Higbie:

This project involves the installation of approximately 3,000 linear feet of 8-inch treated water line and 1,480 linear feet of 8-inch sanitary sewer line to serve 32 residential lots. The above application for coverage under General Permit to construct a water distribution line, extension of a public water supply system and a sanitary sewer line, extension of a sewage collection system, in accordance with Chapter 3, Section 7; Chapter 11, Section 9; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.
Environmental Engineer
Water Quality Division

xc: IPS, Cheyenne
James G. Evans, P.E., Sage Civil Engineering, 2824 Big Horn Ave., Cody, WY 82414
Stephen W. Payne, P.E., City of Cody, P.O. Box 2200, Cody, WY 82414

encl: General Permits For a Public Water Distribution System & Existing Sewage Collection System

F:\DIVISION\WQDIW&WW Section\2007 Permits & Reviews\07-216.noc.jsb.doc

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726


SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 19, 2007

Todd Gnose
A&T Land Development, LLC.
2280 West Teton
Green River, WY 82901

RE: Rock Springs - Stonebrook Estates Subdivision Phases 1&2 - Water and Sewer Main Extensions - Permit Number 07- 217, NW 1/4, SW 1/4, Section 28, T19N, R105W, Sweetwater County

Dear Mr. Gnose:

The above application for coverage under General Permits to Construct water and sewer main extensions consisting of 1529 Linear Feet (LF) of 12-inch and 6195 (LF) of 8-inch PVC water main and 5811 LF of 8-inch sewer main to serve 75 residential lots in accordance with Chapter 3, Section 7, Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Shawn M. Arnoldi, P.E., Choice Engineering, 450 South Main, Rock Springs, WY 82901

encl: General Permit for a Public Water Supply Distribution System,
General Permit for a Sewage Collection System

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726


SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

June 25, 2007

Wally Johnson, Chairman
Sweetwater County Board of Commissioners
80 West Flaming Gorge Way
Green River, WY 82935

RE: Antelope Flats Subdivision, Sweetwater County, and WDEQ Application #07-218R

Dear Mr. Chairman:

The Wyoming Department of Environmental Quality (WDEQ) has completed the review of the above referenced subdivision pursuant to W.S. 18-5-306. The WDEQ has an **'Non - Adverse'** recommendation on this proposed subdivision. Our recommendation regarding the feasibility of the proposed water and sewage systems pursuant to the requirements of W.S. 18-5-306 (c) is based on the following findings:

Findings as to the safety and adequacy of the proposed sewage system:

WDEQ has reviewed the suitability of the subdivision soils for the use of septic systems and finds that the use of conventional septic can be used. Soil percolation rates ranged from 2.6 to 9.3 minutes per inch. The following language, or similar, language needs to be added to the plat and/or all offers, solicitations, advertisements, contacts, and agreements relating to the subdivision, advising potential buyers of the Wyoming Department of Environmental Quality's requirements for the construction of septic systems:

It is the Individual lot owners responsibility to contact the Sweetwater County Environmental Health Service (307-352-6709) at 550 Uinta Drive, Suite D, Green River, WY 82935 to obtain a Permit to Construct to authorize the construction of a septic system with leach field.

Findings as to the safety and adequacy of the proposed water system:

The proposed water system is an extension of the Ten Mile Water & Sewer District water system (public water system number WY5601369). The WDEQ finds the proposed water system to be adequate for this 15-lot subdivision. The water system, is regulated by the Water Quality Division of the Wyoming Department of Environmental Quality and the United States Environmental Protection Agency. It is the responsibility of the subdivider to apply to The Wyoming Department of Environmental Quality Water Quality Division for a Chapter 3 Permit to Construct before starting construction on the water distribution system.

Page 1 of 2

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183



Chairman
Sweetwater County Board of Commissioners
June 25, 2007

Conclusion(s):

The department has an 'Non - Adverse' recommendation on this proposed subdivision.

Disclaimer

Nothing in WDEQ's recommendations or comments regarding the subdivider's proposal shall be construed to relieve the subdivider of their obligation to obtain any permits or additional approval from any local state or federal agencies/entities as required by law, rules and regulations, or ordinance. Nothing in these recommendations commits the WDEQ or the delegated county to the issuance of required permits for construction, operation, or modification of water supply and/or wastewater systems. It is the duty of the subdivider/developer to comply with all applicable federal, state and local requirements.

Please do not hesitate to contact me at (307) 332-3144 if you have any questions on the recommendations or need any assistance on how to proceed with this application.

Sincerely,



Mark Baron, P. E.
Southwest District Engineer
Water Quality Division

xc:

Mark Kot, Sweetwater County Planning & Zoning, 80 West Flaming Gorge Way, Green River,
Wyoming 82935
Russ and Robin Robison, 449 Yellowstone Road. Rock Springs, WY 82901
Robert Young, P.E., UESI, 2638 Commercial Way, Rock Springs, WY 82901
IPS-Cheyenne

chron & file(3)



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

April 26, 2007

Mr. Jess Gray
Tisdale Creek Ranch, Inc.
P.O. Box 457
Gillette, WY 82717

RE: Tisdale Creek Ranch Camper Facility
Small Wastewater Permit No. **07-219**
NE NE Section 12 Township 48 North, Range 72 West, Campbell County

Dear Mr. Gray,

The referenced application for coverage under a General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a six camper facility, in accordance with Chapter 3 Section 9 of the Wyoming Water Quality Rules and Regulations (WWQRR), has been reviewed and approved.

This septic system was constructed prior to the issuance of a DEQ permit and this general permit as-built authorization is provided pursuant to NOV Docket #4006-07 and the associated settlement agreement commitments.

If you have any questions, please contact me at (307) 777-7075.

Yours truly,

Don McKenzie, P.E.
Manager
Water & Wastewater Section
Water Quality Division

DRM/rm/7-0342

Enclosures: General Permit Package for Small Wastewater Facility

cc: IPS, Cheyenne
Karen Farley, Casper w/ application package



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 07-220

REFERENCE PERMIT NO. 06-275

CALPET CELLS 7 & 8 SPRINKLERS

This permit hereby authorizes the applicant:

Calpet LLC
P.O. Box 173
Evanston, WY 82930

to construct, install or modify an evaporation sprinkler system on Cells 7 & 8 according to the procedures and conditions of the application number 07-220. The facility is located in NW/4 of Sec 27 and NE/4 of Sec 28, Township 28 North, Range 113 West in the county of Sublette, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by August 1, 2007.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the DEQ/WQD Northeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the DEQ/WQD Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality

5/7/07

Date of Issuance

JDL/rm/7-0366
cc: WDEQ Casper Field Office

STATEMENT OF BASIS

1. Permit Number: 07-220
2. Application reviewed for compliance with the following applicable regulations :
 - a. Chapter 11
3. Does the permit comply with all applicable regulations identified above?
 - a. Yes
4. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.

not rqd
5. Documentation of Statement of Basis.

The archive file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, CBM Group Supervisor, and completed on April 24, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

ROAD APPLICATION PERMIT

X New
Renewal
Modified

PERMIT NO. 07-221
SPECIAL CONDITIONS
REF/PERMIT #

This permit hereby authorizes the applicant:

HAMILTON DOME STATION ROAD APPLICATION
ROCKY MOUNTAIN PIPELINE SYSTEM LLC
1575 HIGHWAY 150 SOUTH
EVANSTON, WY 82930

to road apply 200 cyds of tank bottom oil/sludge according to the procedures and conditions of the application number 07-221. The application sites are located in NE/SE/4 of Section 14 T44N, R98W in the county of Hot Springs, in the State of Wyoming. This permit shall be effective until November 1, 2007.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the land application described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the land application. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 5. The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Casper WDEQ Field Office, 152 North Durbin Street, Casper, WY 82601, telephone (307) 473-3452; FAX (307) 473-3458.


of 5. The permittee shall provide immediate oral and/or written notice to the Casper WDEQ Field Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.

- 3 of 5. The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the Casper WDEQ Field Office on the attached Certification of Completion form.
- a. Date that the land application was completed; and
 - b. Certification the land application was done in accordance with the terms and conditions of the permit; or
 - c. Certification the land application was completed with changes or modifications. Submit the information necessary to clearly indicate the land application as actually performed. This information shall include a contour map depicting only those sections that actually received the tank bottom oil.
- 4 of 5. The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
- 5 of 5. Tank bottom oil/sludge application shall be terminated within 300 feet of the definable high water Mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.

AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality

5-1-07

Date of Issuance

JDL/rm/7-0360

cc: WDEQ Casper Field Office

STATEMENT OF BASIS

I. General information.

A. Permit Number: 07-221

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are no numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State. District Policy 10.2 (10/17/86)

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III¹. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NA

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

¹Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

A. Facility will not allow a discharge to groundwater. Briefly describe:

NA

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

NA

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

NA

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

NA

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

NA

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

NA

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

NA

VII. Documentation of Statement of Basis.

A. The archive file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, CBM Group Supervisor and completed on April 24, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 07-222

TOWN OF GLENDO, DOWNEY WELL NO 1
PWS WY5600231

This permit hereby authorizes the applicant:

Mayor Jay Collins
TOWN OF GLENDO
PO BOX 396
GLENDO, WY 82213

to construct, install or modify improvements to Downey Well No. 1 according to the procedures and conditions of the application number 07-222. The facility is located in NW/NE1/4 Section 20 T29N R68W; Platte County; in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed May 10, 2009.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088, FAX 307-777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

Date of Issuance April 26, 2007

JFK 4/26/07
LBH/rm/7-0345

STATEMENT OF BASIS

1. Permit Number: 07-222

1. This application was reviewed for compliance with the applicable regulations ;

Chapters 3, 12

2. Does the permit comply with all applicable regulations identified above?

Yes

3. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.


Public water supplies are exempted from review by Chapter 3, Section 17.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Louis Harmon, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on April 26, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 25, 2007

Samuel Archuleta
Box 1527
Rawlins, Wyoming 82301

RE: Archuleta Residential Septic System,
Location: SW¼ NE¼, Section 30, T21N, R87W,

Application No. **07-223**
Carbon County

Dear Mr. Archuleta:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a **4 bedroom** house in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

The approval granted under this Notification Of Coverage and the General Permit shall expire on May 25, 2009. Please reference Application Number **07-223** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald, P.E.
Consulting Engineer
Southeast District, Water Quality Division

RLE/rm/7-0435

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Kent Smith, P.E., Box 684, Saratoga, Wyoming 82331
Carbon County Planning Director, Lou Kline, 215 W. Buffalo Street, #304,
P.O. Box 487, Rawlins, Wyoming 82301


Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 2, 2007

Jake Hamon, Mayor
Town of Hudson
333 South Main Street
Hudson, WY 82515

RE: Hudson's Sewer Replacement and Grade Correction, Permit Number: 07-224, NW ¼, Section 7, T2S, R3E, Fremont County

Dear Mayor Hamon:

This project involves the installation of approximately 610 linear feet of 10-inch gravity sewer line, abandoning two manholes, and replacing one manhole to correct existing adverse sewer grades. WDEQ understands that the new sewer line will be installed to satisfy all of the conditions in WDEQ's Flat Grade Sewer Variance Policy 13.9.13. Namely, the 10-inch line will be installed at a minimum 0.21% grade and the Town of Hudson sent an acceptance letter for the new sewer line. The above application for coverage under General Permit to install the sewer and manhole replacement has been reviewed in accordance with Chapter 3, Section 7 and Chapter 11, Section 9 and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.
Environmental Engineer
Water Quality Division

xc: IPS, Cheyenne
Charles Spurlock, P.E., Trihydro Corp., 350 Garfield, Lander, WY 82520

encl: General Permit For an Existing Sewage Collection System

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726


SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 18, 2007

Dennis Hacklin, Mayor
Town of LaBarge
P.O. Box 327
LaBarge, WY 83123

RE: LaBarge - 1st Avenue Sewerline Extension - Permit Number 07- 225, SE 1/4, Section 6, T26N, R112W, Lincoln County

Dear Mayor Hacklin:

The above application for coverage under General Permit to Construct a sewer main extension consisting of 510 LF of 8-inch sewer main in accordance with Chapter 3, Section 7 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Clarence S. Kemp, P.E., Forsgren Engineering, 849 Front Street, Ste. 201, Evanston, WY 82930

encl: General Permit for a Sewage Collection System



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT
PWS # 5601569

PERMIT NO. 07-226

Reference Permit #06-732

Sublette County - High Meadow Ranch, Sauk Trail II Well and Wellhouse

This permit hereby authorizes the applicant:

Tim Wells, President
High Meadow Ranch Property Owners Inc.
P.O. Box 95
Boulder, WY 82923

to have constructed a wellhouse and connect a drilled, developed, and tested well, Sauk Trail II, to the High Meadow Ranch public water distribution water system; according to the procedures and conditions of the application number 07-226. The facility is located within NE 1/4, Section 20, T33N, R108W; Lot 49 Block 1 Barger Subdivision in the county of Sublette, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by April 30, 2009.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not


relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

5/7/57
Date of Issuance

DRK 5/4/7
PDR/rm/7-0359

STATEMENT OF BASIS

1. Permit Number: 07-226
2. Application reviewed for compliance with the following regulations:
Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?
No.
 - a) Chapter 12 Section 9 (b)(i) requires where 2 wells are provided, the sources shall be capable of equaling or exceeding the design average daily demand with the largest producing well out of service. Given present circumstance of the existing well providing insufficient capacity, this condition will not be met.
 - b) Chapter 12 Section 9 (b)(ii) requires well pump testing for a period of 24 hours until stabilized drawdown has continued for at least 6 hours when test pumped at 1.5 times the design pumping rate. Test results submitted with this application suggests a safe pump rate capacity of 67 gpm, which is less than 1.5 times the design pump rate.
4. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.
No.
5. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Public water supply wells are exempted from review by Chapter 3, Section 17
6. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Perry Roberson, prober2@state.wy.us, Senior Environmental Analyst, approved by Mark Baron P.E. Southwest District Engineer and completed on April 30, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."

May 4, 2007

Tim Wells, President
High Meadow Ranch Property Owners Inc.
P.O. Box 95
Boulder, WY 82923

RE: Permit Process for Sauk Trail II Well, Permit #07-226

Dear Mr. Wells:

Permit # 06-732 was previously issued to initiate the first of a two phase approach for developing and permitting the Sauk Trail II Well. The design was for a deeper and increased capacity well, 150 gpm instead of the nominal 50 gpm production rate of the existing High Meadow Well #5. The #06-732 permit applied only to the drilling, development and testing of the above referenced well. Sizing and installation of the pump to the head works (e.g., well head discharge piping and well house design) was the subject of this second permit, #07-226 for the Sauk Trail II Well.

Submittal of an aquifer test was required with the permit application #07-226 to comply with Chapter 12 Section 9 (b)(ii) of the Wyoming Water Quality Rules and Regulations for a pump test rate of 1.5 times the design rate anticipated, for 24 hours with drawdown, recovery records and aquifer/hydraulic properties. Well test results submitted with the second phase #07-226 application show a 24-hour test rate of 100 gpm. The initial goal of developing a 150 gpm well was not tested. The applied test rate of 100 gpm suggests an anticipated reliable production capacity of 67 gpm ($100/1.5 = 67$). This "safe" yield is a number DEQ uses to determine how many connections a well can adequately supply.

Future projections for High Meadows Ranch Property to fill to 600 lots from the present occupancy of 110 lots indicate an inadequate developed supply. Chapter 12 Section 9 (b) requirements will not be met even after the Sauk Trail II Well is placed in service. Chapter 11 Section 8 (d)(iii) also requires an alternative power source which has not been met for the present facility configuration. These regulations require the maximum daily demand can be achieved with the largest well (Sauk Trail II) out of service. High Meadow Well #5 is presently insufficient. The design report submitted by Steve Wonacot of Advance Engineering, P.C. with the initial application #06-732 described the desirable addition of a storage tank to the system. The DEQ concurs that this would add significantly to providing a reliable and adequate water supply to High Meadow Ranch Property Owners Inc.

Please contact either Mark Baron at 307-335-6962 or Perry Roberson 307-335-6978 with any questions or comments.

Sincerely,

Perry Roberson
Senior Environmental Analyst

Xc: Steve Wonacott, P.E., Advance Engineering, P.C., 2085 South Park Ranch Rd., Jackson, WY 83001
File

F:\DIVISION\WQD\W&WW Section\2007 Permits & Reviews\07-226.well.pdr.doc

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
"AS-BUILT" PERMIT TO CONSTRUCT

PERMIT NO. 07-227

WEST GAS DRAW BETA: PHASE I, MEADOW PASTURE STOCK RESERVOIR

This permit hereby authorizes the applicant:

Lance Oil and Gas Company
Attn.: Mr. James Alsop
1099 18TH Street, Suite 1200
Denver, CO 80202

to have installed a compliance monitoring well according to the procedures and conditions of the application number 07-227. The facilities are proximal to coalbed methane produced water impoundments located in Township 54N, Range 74W, Section 7 in the county of Campbell, in the State of Wyoming. All construction, installation, or modification allowed by this permit has been completed.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit

does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1 of 3: The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality/ Water Quality Division, Groundwater Program, 1866 South Sheridan Avenue, Sheridan, WY 82801, 307-673-9337, fax 307-672-2213, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 3: The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality/ Water Quality Division, Groundwater Program, 1866 South Sheridan Avenue, Sheridan, WY 82801, 307-673-9337, fax 307-672-2213 when discharge to each impoundment covered under this permit commences.

3 of 3: Monitoring Requirements:

Groundwater monitoring at the impoundments shall be performed on a quarterly basis until further notice and shall include the following information:

Measurement of static water level and sampling and analysis of groundwater at downgradient wells: MW22-7

Reporting results of quarterly monitoring and sampling need to be at the department by January 15th, April 15th, July 15th, and October 15th of each year. The first set of data will be due by July 15, 2007.

The parameters listed in the tables below are required for groundwater compliance monitoring beneath the listed impoundments:

Meadow Pasure Stock Reservoir


Parameter	Monitor Well MW22-7 Background Value (mg/L) (01/22/2007)	Trigger Value (mg/L)	Class III Water Quality Standards (mg/L)
Arsenic	Not Detected	≥ 0.16	0.2
Selenium	Not Detected	≥ 0.04	0.05
Sulfate	1650	≥ 2400	3000
Total Dissolved Solids (TDS)	2920	≥ 4000	5000


THIS SPACE INTENTIONALLY LEFT BLANK

Trigger values, specific to the groundwater samples at each impoundment, have been assigned to each constituent and are also listed above. If one or more of these trigger values is exceeded during a quarterly sampling event, monthly sampling of the groundwater for all listed parameters is required, with the analytical results due by the 15th day of each month. If groundwater monitoring reveals a pH measurement of 6.5 or less, the WDEQ may require sampling and analysis of groundwater for the following additional parameters: aluminum, boron, cadmium, chromium, copper, lead and zinc.

The analytical results for each sampling event, along with impoundment and monitor well location information must be submitted in the Excel spread sheet "Compliance Monitoring Data Reporting", which can be found on the WDEQ website at the following address: (<http://deq.state.wy.us/wqd/groundwater/pollution.asp>). These data shall be submitted electronically on the due dates established above to the following department address: cbmgroundwater@state.wy.us. In addition, the accompanying analytical laboratory reports must also be submitted either electronically (pdf format) or hard copy via mail to the WDEQ, Sheridan office at the address listed above.

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

4/30/07
Date of Issuance

AWV/rm/7-0357



GROUNDWATER PROGRAM
REVIEW COMMENTS:
PLANS/SPECIFICATIONS/PROPOSALS/REPORTS

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
1866 South Sheridan Avenue
Sheridan, WY 82801
Phone: 307-672-6457

PERMIT TYPE: CBM: Groundwater Compliance Monitoring Program

WATER QUALITY DIVISION REFERENCE (PERMIT) NUMBER: 07-227

SITE (POD) NAME: West Gas Draw Beta POD, Meadow Pasture Reservoir,
Phase I

APPLICANT: Lance Oil and Gas Company
Attn.: Mr. James Alsop
1099 18th Street, Suite 1200
Denver, CO 80202

CONSULTANT: WWC Engineering
Attn.: Ben Schiffer
1849 Terra Ave.
Sheridan, WY 82801

LOCATION: Drainage: Spotted Horse Creek, tributary to Powder River
County : Campbell
Township 54 North; Range 74 West

WYPDES NO: DISCHARGE PERMIT NUMBER WY0049859

DATE ON REPORT: April 10, 2007

REVIEWING OFFICIAL: Pete Vogel, North District Groundwater Sen. Analyst

DATE OF THIS REVIEW: April 25, 2007

ACTION: Compliance Monitoring Plan authorized for Meadow Pasture Reservoir,
Phase I CBM Facility pursuant to conditions on permit # 07-227

COMMENTS: GROUNDWATER SECTION

1.0 SITE SUMMARY:

1.1 Site Description:

Watershed Name: Spotted Horse Creek, tributary to Powder River

Groundwater Classification:

- Class 1 (domestic) _____
- Class 2 (agricultural) _____
- Class 3 (livestock) 1

Basis for Classification: Laboratory analysis of groundwater indicates ambient water quality meets Water Quality Rules and Regulations Chapter 8 Class III standards (Table 1- Chapter 8) as follows:

Table 1. Basis for Ground Water Classification by Impoundment Name covered under Permit 07-227

Reservoir Name	Down Gradient Monitor Well	Sulfate Concentration and Classification	TDS Concentration and Classification	SAR Calculation	Overall Ground Water Class
Meadow Pasture Stock	MW22-7	1650 – III	2920 – III	3.4 – n/a	III

Description of Hydrogeology:

Table 2. Names of Impoundments covered under Permit 07-227

Impoundment Name	Capacity (acre/ft)	Qtr	Section	Town.	Range	Downgradient Monitoring Well
Meadow Pasture Stock	44.6	NEN W	7	54N	74W	MW22-7

Groundwater occurs at the locations cited above in a partially saturated sandstone. The top of the aquifer is 3981.8 feet amsl and is 31.5 feet thick. A similar sandstone is encountered in well MW22-7C1 but is not present in DH22-7.

THIS SPACE INTENTIONALLY LEFT BLANK

Initial ground water parameters are:

Reservoir Name	Depth to Ground Water (feet BGS)	Static Water Depth (feet BTOC)	Static Water Elevation (feet amsl)	Aquifer Rock Type
Meadow Pasture Stock	113.0	89.6	4015.2	Sandstone

Groundwater flow is southeast.

2.0 MONITORING AND REPORTING REQUIREMENTS

Groundwater monitoring at the impoundments shall be performed on a quarterly basis until further notice and shall include the following information:

- Measurement of static water level and sampling and analysis of groundwater at downgradient wells: MW22-7
- Reporting results of quarterly monitoring and sampling to the department by January 15th, April 15th, July 15th, and October 15th of each year. The first set of data will be due by **July 15, 2007**
- The parameters listed in the tables below are required for groundwater compliance monitoring beneath the listed impoundments:

Meadow Pasture Stock Reservoir

Parameter	Monitor Well MW22-7 Background Value (mg/L) (01/22/2007)	Trigger Value (mg/L)	Class III Water Quality Standards (mg/L)
Arsenic	Not Detected	≥ 0.16	0.2
Selenium	Not Detected	≥ 0.04	0.05
Sulfate	1650	≥ 2400	3000
Total Dissolved Solids (TDS)	2920	≥ 4000	5000

Trigger values, specific to the groundwater samples at this impoundment, have been assigned to each constituent and are also listed above. If one or more of these trigger values is exceeded during a quarterly sampling event, monthly sampling of the groundwater for all listed parameters is required, with the analytical results due by the 15th day of each month. If groundwater monitoring reveals a pH measurement of 6.5 or less, the WDEQ may require sampling and analysis of groundwater for the following additional parameters: aluminum, boron, cadmium, chromium, copper, lead and zinc.

THIS SPACE INTENTIONALLY LEFT BLANK

The analytical results for each sampling event, along with impoundment and monitor well location information must be submitted in the Excel spread sheet "Compliance


Monitoring Data Reporting", which can be found on the WDEQ website at the following address: (<http://deq.state.wy.us/wqd/groundwater/pollution.asp>). These data shall be submitted electronically on the due dates established above to the following department address: cbmgroundwater@state.wy.us. In addition, the accompanying analytical laboratory reports must also be submitted either electronically (pdf format) or hard copy via mail to the WDEQ, Sheridan office at the address listed above.

END OF REVIEW

AWV/rm/7-0357



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

July 12, 2007

J. Bruce McGirr
2070 S. Walsh Dr.
Casper, Wyoming 82609

RE: McGirr Septic System,
Location: NE¼, Section 12, T27N, R84W,

Application No. 07-228
Carbon County

Dear Mr. McGirr:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a **2 bedroom mobile home** in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific conditions also apply:

1. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the septic tank** must be extended to the ground surface.
2. Polyethylene Septic Tank Installation Requirements - To ensure structural integrity, the **manufacturer's instructions** regarding bedding the tank and filling the tank with water during burial **must be followed during installation**. Additionally, immediately after cleaning out the tank, the tank must be refilled with water according to the manufacturer's instructions to maintain structural integrity.

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



The approval granted under this Notification Of Coverage and the General Permit shall expire on July 11, 2009. Please reference Application Number 07-228 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,



Ronald L. Ewald, P.E.
Consulting Engineer
Southeast District, Water Quality Division

RLE/rm/7-0567

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Mike Metcalf, 610 S. Walsh, Casper, Wyoming 82609
Carbon County Planning Director, Lou Kline, 215 W. Buffalo Street, #304,
P.O. Box 487, Rawlins, Wyoming 82301

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

Herschler Bldg., 4 West
Cheyenne, Wyoming 82002

PROJECT: McGirr Septic System

LOCATION: NE¼, Section 12, T27N, R84W, Carbon County


GEOLOGIST: Mike Metcalf
610 S. Walsh
Casper, WY 82609
Ph: (307) 472-1133

APPLICANT: J. Bruce McGirr
2070 S. Walsh Dr.
Casper, WY 82609
PH: (307) 235-3582

WATER QUALITY DIVISION REFERENCE NUMBER:

REVIEWING ENGINEER: Ronald L. Ewald, P.E.
Phone: (307) 777-6183

DATE OF REVIEW: June 1, 2007



ACTION: **NOT AUTHORIZED FOR CONSTRUCTION.** In accordance with Section 12 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 7. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. Percolation Rate Miscalculated - In the application package a percolation rate (perk rate) of 6.7 minutes per inch (mpi) was selected from test hole #3. The data from test hole #2 should have been used instead where the final drop was 1"; resulting in a perk rate of 10mpi (10 minutes / 1 inch).

2. Leachfield Size Too Small - Using the correct perk rate from above results in a corrected loading rate factor of 0.62. Using this to determine the required leachfield size results in a minimum size of 565 sf (350gpd / 0.62) instead of the 493 sf used in the application. Using 565 sf then requires a minimum of 22 *Quick4 Infiltrator* units (565 / 26.5). Therefore, **a minimum of 22 *Quick4 Infiltrator* units shall be installed.**
3. Header Entry Split into Leachfield Incorrect - the side corner entry of the septic tank effluent discharge pipe into the leachfield as depicted on the site plan is incorrect because it will not divide the flow equally into the two trenches. Most of the flow, because of momentum, will go straight past the tee fitting into the far trench. An elbow must be installed in the effluent line to turn the flow towards the two leachfield lines, then the tee can be installed to split the flow equally to each trench. See the detail sheet, and sketch on the site plan included.
4. Surface Ground Slope and Trench Depths? - the application indicates that the surface ground slopes are about 6% at this site. Over a 44 foot trench length (add one more unit) that equals a 2.64 foot elevation change. If one end of the trench starts out at 4 to 4½ feet deep, how deep(7 feet) or shallow(1½ feet) is it at the other end? OR, does the trench run across the slope so that it is at a relatively constant depth. Please describe the physical trench layout better and show some down slope arrows on the site plan, especially around the trench area.
5. Seasonal High Groundwater Level? - in the geologist report (dated January 14, 2007) he states that the "soil was dry with no ground water encountered." This observation was made from a 10 foot vertical hole dug for the septic tank installation. All this tells us is that when he observed the 10 foot deep hole sometime in early January, was that no actual live ground water was leaking out into the bottom of the hole. His report does not indicate that he ever examined the side walls of the excavation for any signs of seasonal high groundwater, such as soil mottling. Therefore, the question about seasonal high groundwater levels remains unanswered.
6. Water Supply? - the application does not indicate what type of water supply is to be used. If it is a well, where is the well to be located? Please indicate this location on the site plan.

RLE/rm/7-0456

Enclosures: Old site plan with examples
Blank site plan
Blank work sheets and detail sheets



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

August 15, 2007

MS Karen Hughes, President
SOUTH CHEYENNE W&S DIST
215 E ALLISON RD
CHEYENNE, WY 82007

RE: TRIUMPH HIGH SCHOOL, Application No. 07-229, Laramie County

Dear MS Hughes:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as water and sewer lines, SE1/4 Section 7 T13N R66W; LAR County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 18, 2009.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. 07-229 in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/rm/7-0714

cc: IPS, Cheyenne

Ryan S. Rigg; AVI pc; 2035 Westland Road, Cheyenne, WY 82001



REVIEW OF PLANS AND SPECIFICATIONS

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY / WATER QUALITY DIVISION
122 West 25th Street, Herschler Building 4 West, Cheyenne, Wyoming 82002

PROJECT: Triumph High School Water and Sewer Extensions
ENGINEER: AVI pc
APPLICANT: South Cheyenne Water and Sewer District

WATER QUALITY DIVISION REFERENCE NUMBER: 07-229
REVIEWING ENGINEER: Louis B. Harmon
DATE OF REVIEW: May 16, 2007



ACTION: NOT AUTHORIZED FOR CONSTRUCTION. In accordance with Section 14(a), Chapter 3, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with said Section 9. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS

1. The design report needs to address the fire flow requirements for the school house as determined by the Wyoming State Fire Marshall.
 - a. The minimum pressure and fire flow to the building sprinkler system should be listed.
 - b. The minimum pressure to the sprinkler system should be maintained in the system while the required external fire flow is withdrawn from two adjacent hydrants. For example, if the required external fire flow is 1500 gpm, it can be withdrawn as 750 gpm from each hydrant.
2. The strength of the water distribution system being tied into needs to be verified.
 - a. The design report might include a plan of the distribution system east to Walterschied and from College north to the north edge of the Harmony development.
 - b. A flow test of two existing hydrants along Grand Harmony flowing simultaneously at the design required total fire flow including the sprinkler and external requirement would verify that the required fire flow is available.

LBH/rm/7-0408

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 07-230

WINDY HILLS SUBDIVISION
PWS WY5600188

This permit hereby authorizes the applicant:

Mayor Don Myers
Town of Burns
PO BOX 66
BURNS, WY 82053

to construct, install or modify a Windy Hills Subdivision water distribution, waste water collection and lift station according to the procedures and conditions of the application number 07-230. The facility is located in W 1/2 Section 7 T14N R62W; in the Town of Burns, Laramie County, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed May 10, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088, FAX 307-777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

Date of Issuance

4-27-07

LBH/rm/7-0348

ORC 4/27/07

cc: Vernon Testerman
P.O. Box 280
Burns WY 82053

STATEMENT OF BASIS

1. Permit Number: 07-230
2. This application was reviewed for compliance with the applicable regulations ;
Chapters 3, 11, and 12
3. Does the permit comply with all applicable regulations identified above?
Yes
4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.
Sewerage systems are exempted from review by Chapter 3, Section 17.
Public water supplies are exempted from review by Chapter 3, Section 17.
5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Louis Harmon, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on April 27, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

April 27, 2007

Town Of Dixon
975 4th Street
Dixon, WY 82323

RE: Dixon Membrane Filtration Water Treatment Pilot Plant Study, Application No. **07-231**, Carbon County

Dear Mayor Feldmann:

The above application for coverage under General Permit to operate a pilot plant to evaluate membrane filtration, Section 4 T12N R90W; Carbon County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the water distribution system in accordance with Chapter 12, Section 5 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by September 15, 2007.

Disinfection by products must be tested on a weekly basis at appropriate points in the water supply system during operation of the pilot plant.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **07-231** in any future correspondence.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/bb/7-0352.NOC

cc: IPS, Cheyenne
James A O'Neil, Lidstone & Associates, 4025 Automation Way,
Ft Collins Co 80525

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

July 10, 2007

Larry Miller
Antelope Ridge Development
42 North 200 East, Suite 3
American Fork, Utah 84003

RE: Kemmerer- Antelope Ridge - Water and Sewer Main Extensions - Permit Number 07-232R, SE 1/4, Section 14, T21N, R116W, Lincoln County

Dear Mr. Larry:

The above application for coverage under General Permits to Construct water and sewer main extensions consisting of 8-inch PVC water main and 8-inch PVC sewer main to serve 83 residential lots in accordance with Chapter 3, Section 7, Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
James W. Denny, P.E., Horizon Engineering, Inc., 1776 West Hamilton Drive, Riverton, UT, 84065 83110

encl: General Permit for a Public Water Supply Distribution System,
General Permit for a Sewage Collection System





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 11, 2007

Mr. Jerry Theil
Jerry Theil & Sons
P.O. Box 1566
Cody, Wyoming 82414

RE: Theil & Sons Fire Main, Permit Number 07-233R, Lot 1, Block 2, Kinder Subdivision, City of Cody, Park County.

Dear Mr. Theil:

The above application for coverage under a General Permit to construct a 4-inch diameter AWWA C-900, Class 150 PVC water main and appurtenances with backflow protection device to serve your building in accordance with Chapter 3, Section 7 and Chapter 12, Section 14, of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved.

You are authorized to construct the water main, appurtenances, and backflow device in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Jeff Hermansky, PE
Northwest District Engineering Supervisor

xc: Heather Christensen, GDA Engineers
Steve Payne, City of Cody
IPS, DEQ/WQD Cheyenne

encl: General Permit for a Water Distribution System





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 1, 2007

John Albrecht, Coordinator of Support Services
Park County School District #1
150 N. Evarts
Powell, WY 82435

RE: Powell - Southside Elementary School Water & Sewer, Permit Number: 07-234,
SW ¼, Section 14, T55N, R99E, Park County

Dear Mr. Albrecht:

This project involves the installation of looped 6-inch water line for domestic and fire suppression flows and 8-inch sewer line that will serve a new elementary school. The above application for coverage under General Permit to construct a water distribution line, extension of a public water supply system and a sanitary sewer line, extension of a sewage collection system, in accordance with Chapter 3, Section 7; Chapter 11, Section 9; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.
Environmental Engineer
Water Quality Division

xc: Mark Westenskow, P.E., CTA Architects Engineers, P.O. Box 1153, Livingston, MT 59047
Sean Christensen, P.E., City of Powell, P.O. Box 1008, Powell, WY 82435
IPS, Cheyenne

encl: General Permits For a Public Water Distribution System & Existing Sewage Collection System

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 07-235

WYCOLO LODGE WTR SUPPLY WELL REPLACEMENT
PWS WY5601558

This permit hereby authorizes the applicant:

AMANDA & DALE ECKDAHL
4039 HWY 230
LARAMIE, WY 82070

to modify the WYCOLO Lodge water supply system with a replacement well, water storage, and disinfection according to the procedures and conditions of the application number 07-235. The facility is located in SENE1/4 Section 17 T12N R78W; 41 miles Southeast of Laramie on Highway 230 in Albany County in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed May 10, 2009.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1. The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088, FAX 307-777-7610, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
2. Before scheduling a final inspection by the Southeast District, Water Quality Division, the applicant must submit a certification of completion signed by Weston Engineering accompanied by Engineer signed and sealed as-built plans. As a part of the certificate of completion, the Engineer must certify that the Magee Well has been plugged and abandoned as required by Chapter 11, WQD Rules and Regulations.
3. Before the new well is placed into service, a final inspection of the WYCOLO Lodge water supply system must be scheduled with and conducted by the Southeast District, Water Quality Division.
4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality

Date of Issuance 5-2-07

LBH/rm/7-0367

STATEMENT OF BASIS

1. Permit Number: **07-235**

2. This application was reviewed for compliance with the applicable regulations ;

 Chapters 3, 11,12

3. Does the permit comply with all applicable regulations identified above?

 Yes

4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.

5. Public water supplies are exempted from review by Chapter 3, Section 17.

6. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Louis Harmon, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on May 2, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

May 2, 2007

Amanda and Dale Eckdahl
WYCOLO Lodge
4039 Highway 230
Laramie WY 82070

Subject: WYCOLO Water Supply and Wastewater System

Dear Mr. and Mrs. Eckdahl:

Permit to Construct 07-235, which authorizes construction of a new well, water storage, and disinfection, is enclosed. I would like to call your attention to the conditions attached to this permit. Before the new well and water system can be placed into service, you must schedule a final inspection with me. Before the inspection can be scheduled, I must receive from Weston Engineering a certificate of completion accompanied by as-built plans. The Magee well must be plugged and abandoned, as certified by Weston Engineering.

The average daily demand of all users of the WYCOLO Lodge property is 2956 gallons per day. The lodge and restaurant generates a maximum wastewater flow of 3330 gallons per day. The existing lodge and restaurant septic tank and leachfield was designed for a maximum flow of about 350 gallons per day. As the average wastewater flow exceeds 2000 gpd, the subsurface wastewater disposal systems on the property must be permitted as underground injection wells by the Wyoming Department of Environmental Quality Water Quality Program Groundwater Pollution Control Program. Please contact John Passehl P.G., 307-777-5623, for detailed permitting requirements.

Please call me at 307-777-7088 if you have additional questions.

Sincerely:

Louis B. Harmon PE-PG
Southeast District Supervisor
Water and Wastewater Program, Wyoming Water Quality Division

LBH/rm/7-0367

Enclosure: Permit to Construct 07-235



cc: Jeff McPherson
Water Technical Enforcement Program
U. S. EPA, Region 8
1595 Wynkoop Street
Denver, CO 80202-1129

John N. Gillis, Ph.D.
U. S. EPA, Region 8 (8P-W-DW)
1595 Wynkoop Street
Denver, CO 80202-1129

Tracy D. Murphy, MD
Wyoming Department of Health
State Epidemiologist
6101 Yellowstone Rd, Suite 510
Cheyenne, WY 82002

Kelly N. Weidenbach, MPH
Wyoming Department of Health
851 Werner Court, Suite 292
Casper, Wyoming 82601


Dean Finkenbinder
Program Manager, Consumer Health Services
Wyoming Department of Agriculture
2219 Carey Ave.
Cheyenne, WY 82002

Ben Jordan
Weston Engineering, Inc.
1050 North 3rd St, Suite E
Laramie WY 82072

John Passehl, P.G.
Wyoming DEQ/WQD
122 West 25th St
Cheyenne, WY 82002



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

May 9, 2007

Ken Nelms
701 Maple Street
Spearfish, SD 57783

RE: Nelms Residential Septic System
Permit # 07-236

Dear Mr. Nelms:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

Additionally, the following project specific conditions also apply:

- A. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.
- B. Polyethylene Septic Tank Installation Requirements - To ensure structural integrity, the **manufacturer's instructions** regarding bedding the tank and filling the tank with water during burial **must be followed during installation**. Additionally, immediately after clean-outs, the tank must be refilled with water according to the manufacturer's instructions to maintain structural integrity.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3478. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
Rob Anderson, Anderson Trucking, 15 Ridge Road, Moorcroft, WY 82721
Tim Lyons, Crook County, P.O. Box 37, Sundance, WY 82729





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

July 3, 2007

Jim Willey, P.E.
13 Buffalo run Drive
Banner, WY 82832

RE: East College Avenue Street and Utility Improvements, WDEQ #07-237, Sheridan County

Dear Mr. Willey:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations and for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Sewage Collection Systems in accordance with Chapter 3 and Chapter 11 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V. Section O. of the general permits.

In addition, the following permit conditions apply:

- 1) All water and sewer service crossings are required to meet WDEQ requirements for horizontal and vertical separation, per Chapter 11, Section 9 (f)(ii).

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley, P.E.
Northeast District Supervisor
Water Quality Division


Enclosures: General Permits
Plans and Specifications
Certificate of Completion

cc: Scott Badley, SBC Development, LLC, P.O. Box 391, Big Horn, WY 82833
Mike Cole, City of Sheridan, P.O. Box 848, Sheridan, WY 82801
WDEQ File
IPS (Cheyenne)





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

May 17, 2007

Brad Plaga
204 East St. Andrews Drive
Sioux Falls, SD 57108

RE: Plaga Residential Septic System
Permit # 07-238

Dear Mr. Plaga:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD


Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WDEQ File
Kerry Barker, Barker Concrete and Construction, Inc., P.O. Box G, Edgemont, SD 57735





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 22, 2007

Robert L. Tarufelli
Hunter's Ridge Development
1257 Palisades Way
Rock Springs, WY 82901

RE: Rock Springs - Umbria Addition Phases 2&3 - Water and Sewer Main Extensions -
Permit Number 07- 241, SW 1/4 Section 28, T19N, R105W, Lincoln County

Dear Mr. Tarufelli:

The above application for coverage under General Permits to Construct water and sewer main extensions consisting of 2341 LF of 8-inch water main and 1948 LF of 8-inch sewer main to serve 36 residential lots accordance with Chapter 3, Section 7, Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron P.E.
Southwest District Engineer
Water Quality Division


xc: IPS, Cheyenne
Randy Hansen, P.E., JFC Engineering & Surveying, 1515 Ninth Street, Rock Springs, WY
82901

encl: General Permit for a Public Water Supply Distribution System,
General Permit for a Sewage Collection System





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 08, 2007

Marty Kleeman
P.O. Box 482
Pinedale, WY 82941

RE: Kleeman - Small Enhanced Wastewater Treatment System- Permit Number 07-242,
SE1/4 Section 11, T33N, R109W, Sublette County, Old Brazzill Ranch Subdivision, 4th
Filing, Lot 50

Dear Mr. Kleeman:

The above application for coverage under General Permit to Construct a small enhanced wastewater treatment facility, to serve a four bedroom home, in accordance with Chapter 3, Section 7, Chapter 11, Part D and Section 5, Chapter 23, Section 7(d)(viii) of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

In carrying out the activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 4: This permit is for an enhanced (1000 gallon septic tank with 1000 gallon pump tank and pressure dosed mounded leach field) small wastewater treatment system. The permittee is required to obtain a maintenance contract and submit annual documentation that maintenance is being provided in accordance with the manufacturer requirements and recommendations and the permit conditions. Authority for this requirement is found in Sections 11 (a) and (c), Chapter 3 of the Wyoming Water Quality Rules and Regulations. Annual maintenance documentation must be submitted before December 31 of each year, starting December 31, 2007 to: Southwest District Engineer, Wyoming Department of Environmental Quality, 510 Meadowview Drive, Lander, WY 82520. Failure to submit annual maintenance documentation is a violation of the compliance requirements for this permit issued under Wyoming Statute 35-11-301.

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183



2 of 4 The permittee shall ensure that the system is maintained and regularly serviced, as recommended by the manufacturer, for the life of the system. An inspection of the system, as recommended by the manufacturer in the owner's manual, shall be performed every six months by a qualified or certified individual to ensure the system is operating correctly, and to determine when maintenance is required.


3 of 4 In the event that authority for permitting enhanced small wastewater treatment systems is delegated to Sublette County by the Department of Environmental Quality, the permittee shall be subject to all county requirements and resolutions that may be in effect, or subsequently enacted, affecting the inspection, operation, maintenance, monitoring, or replacement of this system.

4 of 4 This small enhanced wastewater treatment system must continually achieving the following minimum treatment standards as required by Chapter 23, Section 7(d)(viii)(C) of the Wyoming Water Quality Rules and Regulations at a depth of at least 6 feet above the seasonally high groundwater:

- Fecal Coliform: < 800 colonies/100mL (maximum 30 day geometric mean)
- Total Kjeldahl Nitrogen: < 25mg/L (maximum 30 day average)

If you have any questions, please contact me at 307-332-3144.

Sincerely,



Perry Roberson
Environmental Senior Analyst
Water Quality Division



Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Keith Raney, Environmental Health, Sublette County, P.O. Box 722, Pinedale, WY 82941
Aaron Seehafer, Rio Verde Engineering
encl: General Permit for Small Wastewater Treatment Systems

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 07-243

DRY CREEK HEAT EXCHANGER PROJECT

This permit hereby authorizes the applicant:

Mr. Jim Hughes
CHEYENNE BOPU
2100 PIONEER AVE
CHEYENNE, WY 820031469

to construct, install or modify a heat exchanger at the Dry Creek Water Reclamation Facility located on Camp Stool Road, Laramie County according to the procedures and conditions of the application number 07-243. The facility is located in portions of section 6 T13N R65W and section 1 T13N, R66W ; Laramie County, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed May 10, 2009.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088, FAX 307-777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

Date of Issuance 3/16/07
ARC 5-16-7
LBH/rm/7-0405

STATEMENT OF BASIS

1. Permit Number: 07-243
2. This application was reviewed for compliance with the applicable regulations ;
3. Chapters 3.11
4. Does the permit comply with all applicable regulations identified above?

Yes

5. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.

The basis for determining groundwater will be protected is that the facility will not allow a discharge to groundwater.

6. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Louis Harmon, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on May 16, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 07-244

Land Application of Produced CBM Water,
Wyarno JV Land Application Project

This permit hereby authorizes the applicant:

Fidelity Exploration & Production Company
2585 Heartland Drive
Sheridan, Wyoming 82801

to construct, install or modify a land application water system for produced CBM discharge water procedures and conditions of the application number 07-244. The facility is located in portions of Sections 6 and 7, Township 57 North, Range 81 West in the county of Sheridan, in the State of Wyoming. This permit shall be effective until June 1, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the land application described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the land application is located for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor: any infringement of federal, state or local laws or regulations.


The permittee shall conduct permitted land application in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit

does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:


- 1 of 5 The applicant will provide immediate oral or written notice to the DEQ/WQD Northeast District Office in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 5 The applicant shall submit an annual report to the department providing relevant details of the land application, including quantity of water applied, quality of water applied, type and quantity of soil amendments applied, any violations of DEQ regulations (WYPDES or groundwater), soil sampling data from the land receiving the water, and any other information deemed applicable by the department. The annual report shall be due to DEQ by the end of April of the year following land application and prior to the beginning of the irrigation season.
- 3 of 5 Any check dams or other devices installed to prevent unauthorized flow in to drainages will be checked at least daily during periods of active irrigation. No overland flow or ponding of water will be allowed in any land application areas, including those with check dams.
- 4 of 5 Within sixty days of completion of the land application, the applicant will submit to the DEQ/WQD Northeast District Office on the form provided (CERTIFICATION OF COMPLETION), the following information:
 - a. Dates that the land application was initiated and terminated for the irrigation season; and
 - b. Certification the land application was performed in accordance with the terms and conditions of the permit; or
 - c. Certification the land application was completed with changes or modifications. Submittal of documentation of the land application sites where the changes or modifications were performed if appropriate. All modifications or deviations from the authorized plans must be highlighted; and
 - d. Landowner certification and applicable documentation that the site has been properly reclaimed.
- 5 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



John F. Wagner

Administrator
Water Quality Division



John V. Corra

Director
Department of Environmental Quality

5-2-07

Date of Issuance

STATEMENT OF BASIS

1. Permit Number: 07-244
2. Application reviewed for compliance with the following applicable regulations :
 - a. Chapter 11.
3. Does the permit comply with all applicable regulations identified above?
 - a. Yes
4. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3.

The water is being applied at an agronomic rate determined by soil testing to prevent groundwater impacts.

5. Documentation of Statement of Basis.


The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Kim Medina, Senior Environmental Analyst, and completed on May 1, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 15, 2007

Douglas Hartmann
1920 Berry Drive
Kemmerer, WY 83101

RE: Hartmann, Small Wastewater Leachfield System - Permit Number 07-245, Lot 8-L-3, Rolling Hills First Addition, Kemmerer, Lincoln County

Location: A southwest addition located at SW1/4, Sec 22 Resurvey of T21N R 116 W, Lot 8-L-3, Rolling Hills First Addition, Kemmerer

Dear Mr. Hartmann:

The above application for coverage under General Permit to Construct a small wastewater treatment facility consisting of a 1000 gallon septic tank, 4 trench leach field 75 feet in length to serve a 3 bedroom home, in accordance with Chapter 3, Section 7 and Chapter 11, Part D of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Perry Roberson
Environmental Senior Analyst
Water Quality Division

Mark Baron, P.E.
Southwest District Engineer


xc: IPS, Cheyenne
George D. Crank, P.E.
Tom

encl: General Permit for Small Wastewater Treatment Systems





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 15, 2007

Douglas Hartmann
1920 Berry Drive
Kemmerer, WY 83101

RE: Hartmann, Small Wastewater Leachfield System - Permit Number 07-246, Lot 6-L-3, Rolling Hills First Addition, Kemmerer, Lincoln County

Location: A southwest addition located at SW1/4, Sec 22 Resurvey of T21N R 116 W, Lot 6-L-3, Rolling Hills First Addition, Kemmerer

Dear Mr. Hartmann:

The above application for coverage under General Permit to Construct a small wastewater treatment facility consisting of a 1000 gallon septic tank, 4 trench leach field 70 feet in length to serve a 3 bedroom home, in accordance with Chapter 3, Section 7 and Chapter 11, Part D of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Perry Roberson
Environmental Senior Analyst
Water Quality Division

Mark Baron, P.E.
Southwest District Engineer


xc: IPS, Cheyenne
George D. Crank, P.E.
Tom

encl: General Permit for Small Wastewater Treatment Systems





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 29, 2007

Eric and Bobbee Rudy
1804 Holland Drive
Kemmerer, WY 83101

RE: Holland Drive Addition 3rd Filing - Water and Sewer Main Extension, Kemmerer- Permit Number 07-247, Section 23, T21N, R116W, Lincoln County

Dear Eric:

The above application for coverage under General Permits to Construct water and sewer main modifications consisting of a looped 6-inch PVC water main and 575 feet of 8-inch PVC sewer main extension making up a replat of Lot 2, Holland Drive Addition 2nd Filing, Kemmerer to serve 6 proposed residential lots in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Perry Roberson
Environmental Senior Analyst
Water Quality Division

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne

encl: General Permit for a Sewage Collection System,
General Permit for a Public Water Supply Distribution System



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 07-250

FLAMINGO LIFT STATION PLAN-TOWN OF BAGGS

This permit hereby authorizes the applicant: Town of Baggs
P.O. Box 300
Baggs, WY 82321

to modify the Baggs Flamingo Lift Station according to the procedures and conditions of the application number 07-250. The facility is located in SE1/4 Section 5 T12N R91W; Carbon County, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed July 13, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting

documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:


- 1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088, FAX 307-777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

- 2 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

- 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

Date of Issuance June 7, 2007

LBH/rm/7-0467

STATEMENT OF BASIS

1. Permit Number: 07-250
2. This application was reviewed for compliance with the applicable regulations ;

Chapters 3, 11

3. Does the permit comply with all applicable regulations identified above?

Yes

4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.

Sewerage systems are exempted from review by Chapter 3, Section 17.

5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Louis Harmon, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on June 6, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."