WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO.07-251

DISPOSAL OF CONTAMINATED SOILS FROM THE RAWLINS SPRUCE STREET PROJECT

This permit hereby authorizes the applicant:

Mr. Jake Lonn
WYOMING DEPARTMENT OF TRANSPORTATION
PO BOX 1040
RAWLINS, WY 82301

to construct, install or modify a land application of petroleum contaminated soils to county roads from the Rawlins Spruce Street Project according to the procedures and conditions of the application number 07-251. The facility is located in Section 17 T21N R87W; Carbon County, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed July 13, 2010.
The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements. representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088, FAX 307-777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.

3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

John F. Wagner
Administrator
Water Quality Division

John V. Corra
Director
Department of Environmental Quality

Date of Issuance 6/1/07

LBH/rm/7-0451

## STATEMENT OF BASIS

1. Permit Number: **07-251**

2. This application was reviewed for compliance with the applicable regulations ;

   Chapters 3, 11

3. Does the permit comply with all applicable regulations identified above
   Yes

4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.

5. Land application of qualifying petroleum contaminated soils is exempted from review by Chapter 3, Section 17.

6. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Louis Harmon, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on May 31, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director


May 25, 2007

Platte County Commissioners
P.O. Box 728
Wheatland, Wyoming 82201

RE: Sybille Creek Equestrian Park Subdivision Application- Platte County
WDEQ/WQD Application **#07-252**

Dear Commissioners:

The Wyoming Department of Environmental Quality (WDEQ) has received application material related to the Sybille Creek Equestrian Park Subdivision for review of the safety and adequacy of water supply and sewer systems pursuant to W.S. §18-5-306. The application material was received May 2, 2007. As described in the statute, WDEQ has 30 days to respond with comments and recommendations, however, if necessary WDEQ may extend the review period for an additional 30 days. Due to workload, at this time WDEQ is extending the review period. Therefore, WDEQ's recommendations will be provided to the Commission by July 1, 2007.

A copy of the subdivision application package has been provided to the Wyoming State Engineer's Office for their information and advice to the Water Quality Division.

Please do not hesitate to contact me at (307) 777-7088 if you have any questions regarding this subdivision application or WDEQ's subdivision application review process.

Sincerely,

Louis B. Harmon

Louis B. Harmon, PE-LS
Southeast District Supervisor
Water and Wastewater Program, Wyoming Water Quality Division

LBH/rm/7-0433

cc: David Kidd, 1114 Sybille Creek Road, Wheatland, WY 82201
Andrew Smits, Terracon Inc. 1505 Old Happy Jack Road, Cheyenne, WY 82001
Marlin Johnson, Platte County Planner, P.O. Box 728, Wheatland, Wyoming 82201
Mike Ebsen, SEO - with enclosure

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

# NOTIFICATION OF COVERAGE

June 1, 2007

Joel D. Finch
P.O. Box 1398
Saratoga, Wyoming 82331

RE: Finch Septic System, Application No. **07-253**
Location: NW¼ NW¼, Section 33, T18N, R83W, Carbon County

Dear Mr. Finch:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a **3 bedroom** house in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

> Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the septic tank** must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on June 1, 2009. Please reference Application Number **07-253** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald

Ronald L. Ewald, P.E.
Consulting Engineer
Southeast District, Water Quality Division

RLE/rm/7-0457

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Carbon County Planning Director, Lou Kline, 215 W. Buffalo Street, #304, P.O. Box 487, Rawlins, Wyoming 82301

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

# NOTIFICATION OF COVERAGE

June 1, 2007

Dossie Overfield, Manager
Northwest Rural Water District
P.O. Box 2347
Cody, Wyoming 82414

RE: Northwest Rural Water District - Southfork Service Area - Koster Waterline Extension, Permit Number: 07-254, Lot 46-K, T52N, R102W, Park County, PWS #WY5601254C

Dear Ms. Overfield:

This project includes the installation of about 991 linear feet of 3-inch water line to serve seven residential connections along Cascade Drive. The above application for coverage under General Permit to construct a water distribution line, extension of a public water supply system has been reviewed in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough

James Brough, P.E.
Environmental Engineer
Water Quality Division

cc: Troy Koster, 1526 Rumsey Ave., Cody, WY 82414
Robert Overfield, P.E., Engineering Associates, P.O. Box 1900, Cody, WY 82414
IPS, Cheyenne

encl: General Permit For a Public Water Supply Distribution System

# WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
# WATER QUALITY DIVISION
# PERMIT TO CONSTRUCT

PERMIT NO. 07-255

Cody - Maple Leaf Addition and Trailhead Treated Water Line Extension

This permit hereby authorizes the applicant:

Corey Rosencranse, Developer
Sunlight Investments, LLC
2348 Meadowlark Ct.
Cody, WY 82414

to install approximately 1,885 linear feet of 8-inch water main and appurtenances, and install a low pressure sanitary sewer collection system with approximately 2,350 linear feet 2-inch sewer main and appurtenances, according to the procedures and conditions of the application number 07-255. This project will serve 27 residential connections within the northwest quadrant of Cody, west of Cooper Lane and north of Bighorn Avenue. The facilities are located within S ½, S ½, Lot 6 Resurvey, Township 53 North and Range 101 West in the county of Park, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by June 1, 2008.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

ranting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, ocedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1 of 4 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Northwest District Engineer, 510 Meadowview Dr., Lander, WY 82520, 307-332-3144,FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

3 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

4 of 4 All Environment One (E/One) pumping units and controls must be installed by factory certified installers or under the direct supervision of a factory certified installer. It is the responsibility of the permittee or their successor to ensure compliance.

AUTHORIZED BY:

John F. Wagner
Administrator
Water Quality Division

John V. Corra
Director
Department of Environmental Quality

5-31-07
Date of Issuance

5/31/7
JSB/rm/7-0438

STATEMENT OF BASIS

1. Permit Number: 07-255

2. Application reviewed for compliance with the following regulations:

   Chapters 3, 11 and 12 of the Wyoming Water Quality Rules and Regulations.

3. Does the permit comply with all applicable regulations identified above? No

   Chapter 11, Section 9 (c)(ii)(B) states that the minimum force main size is 4-inch diameter. The 2-inch diameter force mains proposed for this facility are sufficiently large enough since the mains are preceded by Environment One (E/One) grinder pumps at each residence. The small diameter forced mains have a proven track record in similar installations and are correctly sized for this application.

   Chapter 11, Section 9 (c)(ii) gives a maximum spacing of 400 feet between cleanouts. Similar installations have a proven track record of dependability with spacing greater than 400 feet. The manufacturer recommends minimum spacing of 1,000 feet between cleanouts.

4. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.

   Yes. The Environment One (E/One) residential pumping system and pressure sewer lines are not adequately addressed in Chapter 11, Section 9 (c)(ii)(B). As such, a Section 5 review was done to verify that the data obtained from full scale, comparable installations demonstrated the acceptability of the design.

5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by James Brough, jbroug@state.wy.us, Environmental Engineer and completed on May 29, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

xc: Ed Higbie, 1002 Sheridan Ave., Cody, WY 82414
James Evans, P.E., Sage Civil Engineering, 2824 Big Horn Ave., Cody, WY 82414
Stephen Payne, P.E., City of Cody, P.O. Box 2200, Cody, WY 82414

F:\DIVISION\WQD\W&WW Section\2007 Permits & Reviews\07-255.pc.jch.doc

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

# NOTIFICATION OF COVERAGE

June 11, 2007

Al Carollo Jr.
150 Collier Circle
Green River, WY 82935

RE: Carollo Cabin - Small Enhanced Wastewater Treatment System- Permit Number 07-256, NW1/4 Section 3, T33N, R109W, Sublette County, Lot 1 Carollo Minor Subdivision

Dear Mr. Carollo:

The above application for coverage under General Permit to Construct a small enhanced wastewater treatment facility, to serve a four bedroom home, in accordance with Chapter 3, Section 7, Chapter11, Part D and Section 5, Chapter 23,Section 7(d)(viii) of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

<u>In carrying out the activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:</u>

1 of 4 This permit is for an enhanced (1000 gallon septic tank with 1000 gallon pump tank and pressure dosed intermittent sand filter mounded leach field) small wastewater treatment system. The permittee is required to obtain a maintenance contract and submit annual documentation that maintenance is being provided in accordance with the manufacturer requirements and recommendations and the permit conditions. Authority for this requirement is found in Sections 11 (a) and (c), Chapter 3 of the Wyoming Water Quality Rules and Regulations. Annual maintenance documentation must be submitted before December 31 of each year, starting December 31, 2007 to: Southwest District Engineer, Wyoming Department of Environmental Quality, 510 Meadowview Drive, Lander, WY 82520. Failure to submit annual maintenance documentation is a violation of the compliance requirements for this permit issued under Wyoming Statue 35-11-301.

2 of 4 The permittee shall ensure that the system is maintained and regularly serviced, as recommended by the manufacturer, for the life of the system. An inspection of the system, as recommended by the manufacturer in the owner's manual, shall be performed every six months by a qualified or certified individual to ensure the system is operating correctly, and to determine when maintenance is required.

3 of 4 In the event that authority for permitting enhanced small wastewater treatment systems is delegated to Sublette County by the Department of Environmental Quality, the permittee shall be subject to all county requirements and resolutions that may be in effect, or subsequently enacted, affecting the inspection, operation, maintenance, monitoring, or replacement of this system.

4 of 4 This small enhanced wastewater treatment system must continually achieving the following minimum treatment standards as required by Chapter 23, Section 7(d)(viii)(C) of the Wyoming Water Quality Rules and Regulations at a depth of at least 4 feet above the seasonally high groundwater:

- Fecal Coliform: < 800 colonies/100mL (maximum 30 day geometric mean)

- Total Kjeldahl Nitrogen: < 25mg/L (maximum 30 day average)

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Perry Roberson
Environmental Senior Analyst
Water Quality Division

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Keith Raney, Environmental Health, Sublette County, P.O. Box 722,Pinedale,WY 82941
Aaron Seehafer, Rio Verde Engineering
encl: General Permit for Small Wastewater Treatment Systems

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

# NOTIFICATION OF COVERAGE

July 9, 2007

Timothy German
619 SW Higgins
Missoula, MT 59803

RE: Evanston - Yellow Creek Village - Water and Sewer Main Extensions - Permit Number 07- 257, NE 1/4, Section 29, T15N, R120W, Uinta County

Dear Mr. German:

The above application for coverage under General Permits to Construct water and sewer main extensions consisting of 1176 linear feet of 8-inch PVC water and 814 linear feet of 8-inch PVC sewer main to serve a 48 unit apartment complex in accordance with Chapter 3, Section 7, Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Harry Moore, P.E., Uinta Engineering & Surveying, Inc., 808 Main Street, Evanston, WY 82930

encl: General Permit for a Public Water Supply Distribution System,
General Permit for a Sewage Collection System

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

# NOTIFICATION OF COVERAGE

July 16, 2007

Garry Ellingford
Quality General Contractors, LLC
P.O. Box 173
Evanston, WY 82930

RE: Dream Catcher Townhomes (formerly Kickapoo Addition) - Water and Sewer Main Extensions - Permit Number 07-258, SE1/4 Section 30, T15N, R120W, Uinta County, Wyoming

Dear Mr. Ellingford:

The above application for coverage under General Permits to Construct water and sewer main extensions of 6-inch ductile iron water main and 8-inch PVC sewer main to the proposed Kickapoo Addition serving a 30 lot town home subdivision in accordance with Chapter 3, Section 7, Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Perry Roberson
Consulting Engineer
Water Quality Division

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Gareth Powell, Uinta Engineering and Surveying Inc., Evanston
Alan Hansen, Public Works Director, 1200 Main Street, Evanston, WY 82930-3396
encl: General Permit for a Sewage Collection System,
General Permit for a Public Water Supply Distribution System

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

# NOTIFICATION OF COVERAGE

July 9, 2007

Jack Vogt
WYBAL, LLC
1004 Old Barn Road
Parkton, MD 21120

RE: Pinedale - Trails Creek Subdivision - Water and Sewer Main Extensions - Permit Number 07- 259, Section 33, T43N, R109W, Sublette County

Dear Mr. Vogt:

The above application for coverage under General Permits to Construct water and sewer main extensions consisting of 6543 Linear Feet (LF) of 8-inch ductile iron water main and 5195 LF of 8-inch PVC sewer main to serve 83 residential lots in accordance with Chapter 3, Section 7, Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Reed Armijo, P.E., Jorgensen Associates, P.C., P.O. Box 9550, Jackson, WY 83002

encl: General Permit for a Public Water Supply Distribution System,
General Permit for a Sewage Collection System

The State
of Wyoming

Dave Freudenthal, Governor

# Department of Environmental Quality

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

## NOTIFICATION OF COVERAGE

June 4, 2007

Stanley B. Huebner
3312 10th Avenue
Spearfish, SD 57783

RE: Huebner Residential Septic System
Permit # 07-260

Dear Mr. Huebner:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WDEQ File
Tim Lyons, Crook County, P.O. Box 37, Sundance, WY 82729

Dave Freudenthal, Governor

# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

## NOTIFICATION OF COVERAGE

June 1, 2007

DANN HARVEY
CATHEDRAL HOME FOR CHILDREN
4898 N 3RD ST
LARAMIE, WY 82070

RE: CATHEDRAL HOME FOR CHILDREN WATER DISTRIBUTION IMPROVEMENTS
Application No. **07-261**, Albany County

Dear Mr. Harvey:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems described as 345 ft of 6" diameter water main to loop system, NE SW NW1/4 Section 16 T16N R73W; Albany County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by July 13, 2010.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **07-261** in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/rm/7-0453

cc: IPS, Cheyenne
Richard Allen, Trihydro Corp., 1252 Commerce Dr., Laramie, WY 82070

Dave Freudenthal, Governor

# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

## NOTIFICATION OF COVERAGE

June 5, 2007

Mr. Duane Stolns
CITY OF RAWLINS
PO BOX 953
RAWLINS, WY 82301

RE: CITY OF RAWLINS SPRUCE ST.WATER AND SEWER LINE REPLACEMENT, Application No. **07-262**, Carbon County

Dear Mr. Stolns:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as water and sewer line replacements, Section 7 T21N R87W; Carbon County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by July 13, 2009.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **07-262** in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/rm/7-0461

cc: IPS, Cheyenne
KASSEY BENSEN, PMPC, PO BOX 370, SARATOGA WY 82331

Dave Freudenthal, Governor

# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

## NOTIFICATION OF COVERAGE

June 19, 2007

Cord Merrill
P.O. Box 486
Byers, Colorado 80103

RE: Merrill Small Wastewater Facility, Application No. **07-263**
Location: SW¼, Section 19, T15N, R83W, Carbon County

Dear Mr. Merrill:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a **4 bedroom** house in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific conditions also apply:

1. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.

2. Polyethylene Septic Tank Installation Requirements - To ensure structural integrity, the **manufacturer's instructions** regarding bedding the tank and filling the tank with water during burial **must be followed during installation.** Additionally, immediately after clean-outs, the tank must be refilled with water according to the manufacturer's instructions to maintain structural integrity.

The approval granted under this Notification Of Coverage and the General Permit shall expire on June 19, 2009. Please reference Application Number **07-263** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald

Ronald L. Ewald, P.E.
Consulting Engineer
Southeast District, Water Quality Division

RLE/rm/7-0498

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Carbon County Planning Director, Lou Kline, 215 W. Buffalo Street, #304, P.O. Box 487, Rawlins, Wyoming 82301

Dave Freudenthal, Governor

# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

## NOTIFICATION OF COVERAGE

June 19, 2007

Robert E. Worthington
Box 493
Encampment, Wyoming 82325

RE: Worthington Small Wastewater Facility, Application No. **07-264**
Location: Part of Sec. 5,6,or 7, T14N, R82W, Monroe Sub. Carbon County

Dear Mr. Worthington:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a **3 bedroom** house in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific conditions also apply:

1. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.

2. Polyethylene Septic Tank Installation Requirements - To ensure structural integrity, the **manufacturer's instructions** regarding bedding the tank and filling the tank with water during burial **must be followed during installation.** Additionally, immediately after clean-outs, the tank must be refilled with water according to the manufacturer's instructions to maintain structural integrity.

The approval granted under this Notification Of Coverage and the General Permit shall expire on June 19, 2009. Please reference Application Number **07-264** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald

Ronald L. Ewald, P.E.
Consulting Engineer
Southeast District, Water Quality Division

RLE/rm/7-0499

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Carbon County Planning Director, Lou Kline, 215 W. Buffalo Street, #304, P.O. Box 487, Rawlins, Wyoming 82301

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

June 7, 2007

Mr. Rich Merrill
CITY OF LARAMIE
PO BOX C
LARAMIE, WY 82070

RE: CITY OF LARAMIE-SPRING CREEK SANITARY SEWER OUTFALL
Application No. **07-265**, Albany County

Dear Mr. Merrill:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Sewage Collection Systems described as 18" diameter sewer outfall replacement, N1/2 Section 4 T15N R73W; Albany County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by July 13, 2010.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **07-265** in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/rm/7-0475

cc: IPS, Cheyenne

Jim Cavalli; Aspen-Banner Engineering; 1575 N 4th St. #105, Laramie,WY 82072

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

# NOTIFICATION OF COVERAGE

June 4, 2007

Mike Ready, Public Works Director
Town of East Thermopolis
112 East Warren St.
Thermopolis, WY 82443

RE: East Thermopolis - 8" Sewer Outfall, Permit Number: 07-266, SE ¼, Section 36, T43N, R95W, Hot Springs County

Dear Mr. Ready:

This project involves the installation of 1,043 linear feet of 8-inch sewer line which will reroute sewage north to an existing lift station, rather than to an existing cast iron siphon under the Big Horn River. The existing cast iron siphon will be lined with a 4-inch HDPE force main which will be used as a back-up. The majority of the new sewer line will be installed at a 0.0352 grade which variance is allowed by Policy 13.9.13. The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough

James Brough, P.E.
Environmental Engineer
Water Quality Division

cc: Mike Donnell, P.E., Donnell & Allred, Inc., P.O. Box 638, Worland, WY 82401
Heath Overfield, P.E., Engineering Associates, P.O. Box 1900, Cody, WY 82414
IPS, Cheyenne

encl: General Permit For a Sewage Collection System

Dave Freudenthal, Governor

# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

## NOTIFICATION OF COVERAGE

June 5, 2007

Curtis Ryan, Manager
Green Wing Properties, L.L.C.
P.O. Box 85
Cody, WY 82414

RE: Greenwing Addition Sewer Collection & Treated Water Mains, Permit Number: 07-267, Tract A of Tract 40, T53N, R101W, Park County

Dear Mr. Ryan:

This project involves the installation of 757 linear feet of 8-inch water line and 840 linear feet of 8-inch sewer line which will serve 12 lots which are primarily residential. The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; Chapter 11, Section 9; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough

James Brough, P.E.
Environmental Engineer
Water Quality Division

xc: IPS, Cheyenne
James Evans, P.E., Sage Civil Engineering, 2824 Big Horn Ave., Cody, WY 82414
Stephen W. Payne, P.E., City of Cody, P.O. Box 2200, Cody, WY 82414

encl: General Permits For a Public Water Distribution System & Existing Sewage Collection System

The State
of Wyoming

# Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

## NOTIFICATION OF COVERAGE

May 9, 2007

Ronald G. Perkins
7600 Riverside Drive
Casper, WY 82604

RE: Advanced Heating & Plumbing Fire Suppression Line, WDEQ #07-268, Natrona County

Dear Mr. Perkins:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V. Section O. of the general permits.

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley

Karen L. Farley, P.E.
Northeast District Supervisor
Water Quality Division

Enclosures: General Permit
Application
Certificate of Completion

cc: Gloria Brianard, WWSD, P.O. Box 728, Mills, WY 82644
WDEQ File
IPS (Cheyenne)

The State
of Wyoming

# Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

## NOTIFICATION OF COVERAGE

May 18, 2007

Mark Thompson
P.O. Box 963
Sundance, Wyoming 82729

RE: Thompson Trust Residential Septic System
Permit # 07-269

Dear Mr. Thompson:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WDEQ File
Tim Lyons, Crook County, P.O. Box 37, Sundance, WY 82729

The State
of Wyoming

# Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

## NOTIFICATION OF COVERAGE

June 7, 2007

Dave Hardegger
Hardleider, LLC
P.O. Box 2402
Gillette, WY 82718

RE: Hardleider, LLC Commercial Septic System, 1022 Robertson Circle, Campbell County
WDEQ Permit # 07-270

Dear Mr. Hardegger:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit, Certificate of Completion
cc: Keith Bowar, Campbell County, 500 South Gillette Avenue, Suite 1500,Gillette, WY 82716 (no plat map)
Wes Butts, Bruce Engineering, Inc., 1300 East Highway 14-16, Gillette, WY 82716 (no plat map)
IPS, Cheyenne
WDEQ/WQD Casper File



SOLID & HAZARDOUS WASTE DIVISION
(307) 473-3450
Fax: (307) 473-3458

AIR QUALITY DIVISION
(307) 473-3455
Fax: (307) 473-3458

WATER QUALITY DIVISION
(307) 473-3465
Fax: (307) 473-3458

The State
of Wyoming

# Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

## NOTIFICATION OF COVERAGE

June 22, 2007

Terry Jones
B&T Investments, LLC
P.O. Box 1886
Gillette, WY 82717

RE: Commercial Septic System, 1176 Robertson Circle, Campbell County
WDEQ Permit # 07-272

Dear Mr. Jones:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions, please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3465. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit, Certificate of Completion

cc: Keith Bowar, Campbell County, 500 South Gillette Avenue, Suite 1500, Gillette, WY 82716
E.J. Collins, P.E., 200 Hogeye Drive, Gillette, WY 82716 (without enclosures)
IPS, Cheyenne
WDEQ/WQD Casper File



SOLID & HAZARDOUS WASTE DIVISION
(307) 473-3450
Fax: (307) 473-3458

AIR QUALITY DIVISION
(307) 473-3455
Fax: (307) 473-3458

WATER QUALITY DIVISION
(307) 473-3465
Fax: (307) 473-3458

The State
of Wyoming

# Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

## NOTIFICATION OF COVERAGE

May 23, 2007

Eugene Adams
1981 Highway 585
Sundance, Wyoming 82729

RE: Adams Residential Septic System
Permit # 07-273

Dear Mr. Adams:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WDEQ File
Tim Lyons, Crook County, P.O. Box 37, Sundance, WY 82729

The State
of Wyoming

# Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

## NOTIFICATION OF COVERAGE

May 24, 2007

Lee Greene
P.O. Box 1686
Gillette, WY 82718

RE: 3106 Coulter Lane, Commercial Small Wastewater System, Campbell County
WDEQ Permit # 07-274

Dear Mr. Greene:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

Additionally, the following project specific conditions also apply:

A. **Aeration Piping** – Aeration piping will be installed 10 feet from each end of each leachfield trench. The piping will extend into the gravel bed. Peforated pipe will extend vertically up through the gravel bed, then solid pipe to the surface.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit, Certificate of Completion
cc: Keith Bowar, Campbell County, 500 South Gillette Avenue, Suite 1500,Gillette, WY 82716
Brent Thumma, Brent Thumma, P.E., LLC, 8 Doe Court, Gillette, WY 82718
IPS, Cheyenne
WDEQ/WQD Casper File



SOLID & HAZARDOUS WASTE DIVISION
(307) 473-3450
Fax: (307) 473-3458

AIR QUALITY DIVISION
(307) 473-3455
Fax: (307) 473-3458

WATER QUALITY DIVISION
(307) 473-3465
Fax: (307) 473-3458

The State
of Wyoming

Dave Freudenthal, Governor

# Department of Environmental Quality

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

## NOTIFICATION OF COVERAGE

May 17, 2007

Keith Sarkinen
P.O. Box 101
Piedmont, South Dakota 57769

RE: Sarkinen Residential Septic System
Permit # 07-275

Dear Mr. Sarkinen:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WDEQ File
Tim Lyons, Crook County, P.O. Box 37, Sundance, WY 82729

The State
of Wyoming

# Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

## NOTIFICATION OF COVERAGE

June 8, 2007

Joseph D. Schoen, P.E.
City of Sheridan
55 Grinnell Plaza
Sheridan, WY 82801

RE: 2007 Fire Hydrant Upgrades, WDEQ #07-277, City of Sheridan, WY

Dear Mr. Schoen:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V. Section O. of the general permits.

If you have any questions, please contact me at 307-473-3465.

Sincerely,

Karen L. Farley

Karen L. Farley, P.E.
Northeast District Supervisor
Water Quality Division

Enclosures: General Permit
Application
Certificate of Completion

cc: WDEQ File
IPS (Cheyenne)

The State
of Wyoming

# Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

## NOTIFICATION OF COVERAGE

August 29, 2007

Matt Williams, P.E.
WLC Engineering
200 Pronghorn
Casper, WY 82601

RE: Six Mile Sewer District Sanitary Sewer, Natrona County
WDEQ Application #07-278

Dear Mr. Williams:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Sewage Collection Systems in accordance with Chapter 3 and Chapter 11 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V. Section O. of the general permits.

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley

Karen L. Farley, P.E.
Northeast District Supervisor
Water Quality Division

Enclosures: General Permit
Application
Certificate of Completion

cc: Bill Barnard, Six Mile Sewer District, 421 S. Center, Casper, WY 82601
Dave Hill, City of Casper, 200 North David, Casper, WY 82601
WDEQ File (w/plans & specifications)
IPS, Cheyenne (w/plans & specifications)

The State
of Wyoming

# Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

## NOTIFICATION OF COVERAGE

June 13, 2007

Trevor Schilling
Equal LLC
P.O. Box 1052
Gillette, WY 82717

RE: Red Man Commercial Septic System, Lot 10 Hannum Road Industrial Park, Campbell County
WDEQ Permit # 07-279

Dear Mr. Schilling:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3465. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit, Certificate of Completion
cc: Keith Bowar, Campbell County, 500 South Gillette Avenue, Suite 1500, Gillette, WY 82716
Vaughn Spielgelberg, Mountain Peak Builders, P.O. Box 1052, Gillette, WY 82717
McKinley Wood, Powder River Heating and Plumbing, P.O. Box , Gillette, WY 82717
IPS, Cheyenne
WDEQ/WQD Casper File



SOLID & HAZARDOUS WASTE DIVISION
(307) 473-3450
Fax: (307) 473-3458

AIR QUALITY DIVISION
(307) 473-3455
Fax: (307) 473-3458

WATER QUALITY DIVISION
(307) 473-3465
Fax: (307) 473-3458

Dave Freudenthal, Governor

# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

## NOTIFICATION OF COVERAGE

August 23, 2007

Reg Phillips, President
Dubois Rural Fire District
P.O. Box 443
Dubois, WY 82513

RE: Dubois Rural Fire District Fire Station's Water & Sewer Lines, Permit Number: 07-280R, Latitude 43.53 N, Longitude 109.63 W, Fremont County

Dear Mr. Phillips:

This project was previously issued a permit to construct (Permit No. 06-599), however, the project was subsequently relocated. The above application for coverage under General Permit to install a new 4-inch fire suppression line and a 4-inch sewer service equipped with a sand-oil separator has been reviewed in accordance with Chapter 3, Section 7; Chapter 11, Section 9; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough

James Brough, P.E.
Northwest District Engineer
Water Quality Division

xc: Arvin Miller, Town of Dubois, P.O. Box 555, Dubois, WY 82513
Sinclair Buckstaff, P.E., Nelson Engineering, P.O. Box 1599, Jackson, WY 83001
IPS, Cheyenne

encl: General Permits For a Public Water Supply System and an Existing Sewage Collection System

Dave Freudenthal, Governor

# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

## NOTIFICATION OF COVERAGE

June 8, 2007

Mark Allphin, Project Manager
MOA Hospitality, Inc.
807 East South Temple, STE 210
Salt Lake City, UT 84102

RE: MOA Hospitality Treated Water & Sewer Collection Mains, Permit Number: 07-281, SE ¼, Lot 74, T52N, R102W, Park County

Dear Mr. Allphin:

This project involves the installation of 794 linear feet of 10-inch water line, 90 linear feet of 6-inch water line and 78 linear feet of 8-inch sewer line which will serve a new motel. The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; Chapter 11, Section 9; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough

James Brough, P.E.
Environmental Engineer
Water Quality Division

xc: IPS, Cheyenne
Lynn Stutzman, P.E., Engineering Associates, P.O. Box 1900, Cody, WY 82414
Stephen W. Payne, P.E., City of Cody, P.O. Box 2200, Cody, WY 82414

encl: General Permits For a Public Water Distribution System & Existing Sewage Collection System

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO.07-282

TOWN OF GLENDO-MUNICIPAL TEST WELL
PWS WY5600231

This permit hereby authorizes the applicant:

WYOMING WATER DEVELOPMENT COMMISSION
6920 YELLOWTAIL RD
CHEYENNE, WY 82002

to construct, install, or modify a Municipal Test Well for Conversion to a Municipal Water Supply according to the procedures and conditions of the application number 07-282. The facility is located in SW 1/4 and the NW1/4 Section 9 T29N R68W; Platte County, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed July 13, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088, FAX 307-777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2. The casing must extend at least 18 inches above the ground surface.

3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

4. The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Donald R. McKenzie for
John F. Wagner
Administrator
Water Quality Division

John V. Corra
Director
Department of Environmental Quality

Date of Issuance June 7, 2007

LBH/bb/7-0473.PER

STATEMENT OF BASIS

1. Permit Number: 07-282

2. This application was reviewed for compliance with the applicable regulations ;

   Chapters 3, 12

3. Does the permit comply with all applicable regulations identified above?

   Yes

4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.

Public water supplies are exempted from review by Chapter 3, Section 17.

5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Louis Harmon, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on June 6, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

LBH/bb/7-0473.STM

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

# NOTIFICATION OF COVERAGE

May 21, 2007

Gary Waldner
Wamsutter Trailer Court, LLC
P.O. Box 67
Wamsutter, WY 82336

RE: Wamsutter - Prairie Sky Subdivision & RV Park - Water and Sewer Main Extensions - Permit Number 07- 283, SE 1/4, Section 27, NE 1/4, Section 34, T20N, R94W, Sweetwater County

Dear Mr. Waldner:

The above application for coverage under General Permits to Construct water and sewer main extensions to serve 30 residential lots and 39 recreational vehicle spaces accordance with Chapter 3, Section 7, Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Paul Ng, Sweetwater County Environmental Health, 550 Uinta Drive, Suite D, Green River, WY 82935

encl: General Permit for a Public Water Supply Distribution System,
General Permit for a Sewage Collection System

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

# NOTIFICATION OF COVERAGE

June 6, 2007

Mr. Bill Craig
TOWN OF ENCAMPMENT
PO BOX 5
ENCAMPMENT, WY 82325

RE: TOWN OF ENCAMPMENT-RANKIN AVENUE WATER LINE REPLACEMENT, Application No. **07-284**, Carbon County

Dear Mr. Craig:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as water and sewer line replacements, Block 4 Town of Encampment; Carbon County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by July 13, 2009.

Where the water line crosses under the sewer line flow fill must be used from the water line to the top of the sewer line, extending a minimum distance of 5 ft each way from the centerline of the water line.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **07-284** in any future correspondence. If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/bb/7-0468.NOC
cc: IPS, Cheyenne
JON L ANDERSON, PMPC, PO BOX 370, SARATOGA WY 82331

Dave Freudenthal, Governor

# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

## NOTIFICATION OF COVERAGE

May 16, 2007

Mr. Herman Noe
Cheyenne Board of Public Utilities
P.O. Box 1469
Cheyenne WY 82003

RE: WARREN FED CREDIT UNION-YELLOWSTONE RD, Application No. **07-285**, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems described as 8" diameter water main, fire service, and two fire hydrants, SW1/4 Section 18 T14N R66W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by May 10, 2009.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **07-285** in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/rm/7-0406

cc: IPS, Cheyenne

LAWRENCE R GALLAGHER, Summit Engineering, 5907 Townsend Pl, Cheyenne, WY 82009

Dave Freudenthal, Governor

# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

## NOTIFICATION OF COVERAGE

June 6, 2007

Mr. Bill Craig
TOWN OF ENCAMPMENT
PO BOX 5
ENCAMPMENT, WY 82325

RE: TOWN OF ENCAMPMENT-BLKS 109,110,119,120 Water and Sewer Line Extensions
Application No. **07-286**, Carbon County

Dear Mr. Craig:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as water and sewer line extensions, Blocks 109,110,119,120 Town of Encampment; Carbon County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by July 13, 2009.

Where the water line crosses under sewer lines flow fill must be used from the water line to the top of the sewer line, extending a minimum distance of 5 ft each way from the centerline of the water line.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **07-286** in any future correspondence. If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/bb/7-0469.NOC
cc: IPS, Cheyenne
JON L ANDERSON, PMPC, PO BOX 370, SARATOGA WY 82331

Dave Freudenthal, Governor

# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

## NOTIFICATION OF COVERAGE

June 14, 2007

Cheyenne Board of Public Utilities
Attn. Herman Noe, Engineering & Water Resource Division
2406 Snyder
Cheyenne, Wyoming 82001

RE: Saddle Ridge Development, Application No. **07-287**
Location: W½, Section 25, T14N, R66W, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and Existing Sewage Collection Systems in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permits, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits. Additionally, the following project specific conditions also apply:

1. Additions to Wyoming Public Works Standard Specifications for Waterline Construction:

   a. Section 2675 D - Flushing shall achieve minimum velocities of at least 5 feet per second for pipelines 12 inches in diameter or less. Flushing shall be through flush valves and a discharge pipe to the surface. Fire hydrants shall not flushed until after the water main or distribution line is flushed.

2. MH # 128 Sewer Pipe Elevations - MH # 128 at the intersection of Fire Side Drive and Foster Avenue, as shown on plan sheet # 25.0, has sewer pipes connected to it from all four street directions. The plans show the inverts of the 8" diameter sewer line running down Fire Side at the same elevation as the inverts of the 12" diameter sewer line running down Foster. This could create a problem during peak loading periods if significant amounts of the sewage coming down the 12" line somehow went down the 8" line instead and overloaded it's capacity somewhere down gradient. To avoid this possibility, **both of the inverts of the 8" sewer lines entering MH # 128 must be raised to a point at least above the center line level of the highest 12" sewer line connected to this manhole.**

The approval granted under this Notification Of Coverage and the General Permit shall expire on June 14, 2009. Please reference Application Number **07-287** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald

Ronald L. Ewald
Environmental Senior Analyst
Southeast District, Water Quality Division

RLE/rm/7-0494

Enclosures: Certificate of Completion form

cc: IPS, Cheyenne
Jim I. Cavalli, P.E., Aspen-Banner Engineering, 1575 N. 4th, Suite 105, Cheyenne, Wyoming 82072

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

June 22, 2007

DUANE STOLNS, PUBLIC WORKS DIRECTOR
CITY OF RAWLINS
PO BOX 953
RAWLINS, WY 82301

RE: CITY OF RAWLINS-WEST RAWLINS UTILITY EXTENSION PROJECT
Application No. **07-288**, Carbon County

Dear Mr. Stolns:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Sewage Collection Systems described as a collector sewer line, Sections 19, 20, 21 T21N R87W; Carbon County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by May 10, 2012.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **07-288** in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/rm/7-0528

cc: IPS, Cheyenne

GARY STEELE, PMPC, PO BOX 370, SARATOGA WY 82331

# ROAD APPLICATION PERMIT

X New
Renewal
Modified

PERMIT NO. **07-289**
SPECIAL CONDITIONS
REF/PERMIT #06-455

This permit hereby authorizes the applicant:

MARATHON/PENNACO UPPER POWDER RIVER ROAD APPLICATION
MARATHON OIL COMPANY/PENNACO ENERGY INC
3601 SOUTHERN DRIVE
GILLETTE, WY 82718

to road apply 500 bbls of produced CBM water/drilling fluids according to the procedures and conditions of the application number **07-289**. The application site is the Upper Powder River Road located in Sections 2, 3,10, 11, 14, and 15 of T53N, R77W in the county of Sheridan, in the State of Wyoming. This permit shall be effective until November 1, 2007.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the land application described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the land application. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division (WQD), upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 5. The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Casper WDEQ Field Office, 152 North Durbin Street, Casper, WY 82601, telephone (307) 473-3452; FAX (307) 473-3458.

of 5. The permittee shall provide immediate oral and/or written notice to the Casper WDEQ Field Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.

3 of 5. The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the Casper WDEQ Field Office on the attached Certification of Completion form.

a. Date that the land application was completed; and

b. Certification the land application was done in accordance with the terms and conditions of the permit; or

c. Certification the land application was completed with changes or modifications. Submit the information necessary to clearly indicate the land application as actually performed. This information shall include a contour map depicting only those sections that actually received the CBM fluids.

4 of 5. The review and approval of this permit is based upon the items identified in the attached Statement of Basis.

5 of 5. The CBM fluids application shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.

AUTHORIZED BY:

John F. Wagner
Administrator
Water Quality Division

John V. Corra
Director
Department of Environmental Quality

5/16/09
Date of Issuance

5/15/7
JDL/rm/7-0400
cc: WDEQ Casper Field Office

STATEMENT OF BASIS

I. General information.

A. Permit Number: **07-289**

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are no numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State. District Policy 10.2 (10/17/86)

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III[1]. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NA

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

[1]Sediment ponds, public water supplies, sewerage systems and small wastewater systems are exempt from the requirements of Section 15.

A. Facility will not allow a discharge to groundwater. Briefly describe:

NA

B. Quality of wastewater is such that it will not cause a violation of groundwater standards. Briefly describe:

NA

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

NA

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

NA

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

NA

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

NA

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

NA

VII. Documentation of Statement of Basis.

A. The archives file for this permit will include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Dennis Lamb, CBM Group Supervisor and completed on May 14, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

# NOTIFICATION OF COVERAGE

July 9, 2007

Kevin Paul
P.O. Box 1387
Afton, WY 83110

RE: Thayne- Paul and Merica Additions - Water and Sewer Main Extensions - Permit Number 07- 290, SE 1/4 NE 1/4, Section 23, T34N, R119W, Lincoln County

Dear Mr. Paul:

The above application for coverage under General Permits to Construct water and sewer main extensions consisting of 2230 linear feet of 8-inch PVC water main and 1783 linear feet of 8-inch PVC sewer main to serve the Thayne Elementary School, 14 commercial lots and 6 residential lots in accordance with Chapter 3, Section 7, Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Robert Hood, P.E., Sunrise Engineering, Inc., P.O. Box 609, Afton, WY 83110

encl: General Permit for a Public Water Supply Distribution System,
General Permit for a Sewage Collection System

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

# NOTIFICATION OF COVERAGE

June 8, 2007

DAVID J DANFORD
FRONTIER REFINERY, INC
2700 E 5TH ST
CHEYENNE, WY 82007

RE: FRONTIER REFINERY, INC Fire Service and Sewer Line Extension
Application No. **07-291**, Laramie County

Dear Mr. Danford:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as a fire hydrant, fire service line, HDPE Sanitary Sewer Service with small lift station, NE1/4 Section 5 T14N R66W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by July 13, 2009.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **07-291** in any future correspondence. If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/rm/7-0480

cc: IPS, Cheyenne

ROBERT S COWLEY,AVI PC, 2035 WESTLAND RD, CHEYENNE WY 82001

Dave Freudenthal, Governor

# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

June 4, 2007

Albany County Board of Commissioners
525 Grand Avenue
Laramie, WY 82070

RE: Southbend Estates Subdivision, Albany County
WDEQ Application #**07-292**

Dear Commissioners:

The Wyoming Department of Environmental Quality (WDEQ) has received application material related to the Southbend Estates Subdivision for review of the safety and adequacy of water supply and sewer systems pursuant to W.S. §18-5-306. The application material was received May 14, 2007. As described in the statute, WDEQ has 30 days to respond with comments and recommendations, however, if necessary WDEQ may extend the review period for an additional 30 days. Due to workload, at this time WDEQ is extending the review period. Therefore, WDEQ's recommendations will be provided to the Commission by July 13, 2007.

A copy of the subdivision application package has been provided to the Wyoming State Engineer's Office for their information and advice to the Water Quality Division.

Please do not hesitate to contact me at (307) 777-7088 if you have any questions regarding this subdivision application or WDEQ's subdivision application review process.

Sincerely,

Louis B. Harmon

Louis B. Harmon, PE-LS
Southeast District Supervisor
Water and Wastewater Program, Wyoming Water Quality Division

LBH/rm/7-0459

cc: John and Heidi Schutterle, 1217 Hillside Drive, Laramie WY 82070
Aspen-Banner Engineering, 1575 North 4th Street, Suite 105, Laramie, WY 82072
Doug Bryant, Director, Albany County Planning Office, 1002 South Third Street, Laramie, Wyoming 82070
Mike Ebsen, SEO - with enclosure

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

# NOTIFICATION OF COVERAGE

June 8, 2007

Christopher Hawks
Hawks Associates
P.O. Box 12830
Jackson, WY 83001

RE: Waterline Relocation, Permit Number: 07-293, SW ¼, Section 16, T41N, R116W, Teton County

Dear Mr. Hawks:

This project involves the realignment of an 8-inch ductile iron water line. The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough

James Brough, P.E.
Environmental Engineer
Water Quality Division

xc: IPS, Cheyenne
David Dufault, P.E., Nelson Engineering, P.O. Box 1599, Jackson, WY 83001

encl: General Permit For a Public Water Distribution System

Dave Freudenthal, Governor

# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

## NOTIFICATION OF COVERAGE

May 18, 2007

DENNIS STRIEGEL
205 East Highway 71
Rawlins, Wy 82301

RE: KOA KAMPGROUND- SEWER MAIN EXTENSION, Application No. **07-294**, Carbon County

Dear Mr. Striegel:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Sewage Collection Systems described as sewer line extension, NW1/4 Section 21 T21N R87W; Carbon County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by May 10, 2009.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **07-294** in any future correspondence.

If you have any questions, please contact me at 307-777-7088.

Sincerely,

Louis B. Harmon

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/rm/7-0415

cc: IPS, Cheyenne
Dave Guetig
Galloway, Romero & Associates 5350 DTC PKWY ,Greenwood Village, CO 80111

# AS-BUILT
## PERMIT TO CONSTRUCT

X New

PERMIT NO. **07-295**
SPECIAL CONDITIONS

Sharron As-Built Residential Septic System

This permit hereby authorizes the applicant:

Raymond F. Sharron
1075 Sybille Creek Road
Wheatland, Wyoming 82201

to have constructed and installed a residential septic system with a 1000 gallon concrete septic tank and a 120 foot long single trench chamber type leachfield according to the procedures and conditions of the application number **07-295**. The facility is located in the N½ SW¼ of Section 30, Township 23N, Range 68W, in the county of Platte, in the State of Wyoming.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator.

Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility, meets applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, upon the presentation of credentials and during working hours, to have access to inspect the facilities, at the above location, for the purpose of compliance with the provisions of this construction permit.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee has constructed and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

AUTHORIZED BY:

John F. Wagner
Administrator
Water Quality Division

John V. Corra
Director
Department of Environmental Quality

6-25-07
Date of Issuance

RLE/rm/7-0525

cc: Platte County Planner, Marlin Johnson, P.O. Box 728, Wheatland, WY 82201

# STATEMENT OF BASIS

1. Permit Number: **07-295**

2. Application reviewed for compliance with the following regulations :

   Chapter 11 of the Wyoming Water Quality Rules and Regulations

3. Does the permit comply with all applicable regulations identified above?

   COMPLY? YES

4. Application requires review to determine groundwater impacts in accordance with Section 17, Chapter 3?

   NOT Required

5. Circumstances Requiring an As-Built Permit:

   When Built: 1999

   Why permit not obtained at the time: The current owner does not know why a permit was not obtained at the time the house was constructed in 1999. He purchased the house just last year from a Mr. Richard Winger.

   Why was As-Built permit applied for at this time: The current owner is adding on 1 bedroom to the existing 1 bedroom house and when he went to apply at the county they told him he needed proof of a septic permit first. When he found out that a septic permit was never obtained for the property, he applied for an as-built permit for a 2 bedroom house to see if the existing septic was enough to cover both bedrooms.

6. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Ronald L. Ewald, P.E., rewald@state.wy.us, Environmental Senior Analyst, and completed on June 21, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

P:50007.DOC

The State
of Wyoming

Dave Freudenthal, Governor

# Department of Environmental Quality

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

## NOTIFICATION OF COVERAGE

June 4, 2007

Jack McGee
1105 Warren
Gillette, Wyoming 82776

RE: McGee Residential Septic System
Permit # 07-296

Dear Mr. McGee:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WDEQ File
Tim Lyons, Crook County, P.O. Box 37, Sundance, WY 82729

The State
of Wyoming

# Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

## NOTIFICATION OF COVERAGE

May 25, 2007

Royce Robinson
P.O. Box 916
Moorcroft, Wyoming 82721

RE: Robinson Residential Septic System
Permit # 07-297

Dear Mr. Robinson:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

Additionally, the following project specific conditions also apply:

A. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.

B. Polyethylene Septic Tank Installation Requirements - To ensure structural integrity, the **manufacturer's instructions** regarding bedding the tank and filling the tank with water during burial **must be followed during installation.** Additionally, immediately after clean-outs, the tank must be refilled with water according to the manufacturer's instructions to maintain structural integrity.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WDEQ File
Tim Lyons, Crook County, P.O. Box 37, Sundance, WY 82729

The State
of Wyoming

# Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

## NOTIFICATION OF COVERAGE

May 25, 2007

Alfredo and Suzanne Quiroz
P.O. Box 682
Moorcroft, Wyoming 82721

RE: Quiroz Residential Septic System
Permit # 07-299

Dear Mr. and Mrs. Quiroz:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WDEQ File
Tim Lyons, Crook County, P.O. Box 37, Sundance, WY 82729
Travis Dewey, Tri-City Excavating, Inc., 169 Thorn Divide Road, Carlile, Wyoming 82721

The State
of Wyoming

# Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

## NOTIFICATION OF COVERAGE

June 25, 2007

Tim Gimbel
80 Patrick Henry Road
Gillette, WY 82718

RE: Gimbel Residential Septic System, Crook County, Permit # 07-300

Dear Mr. Gimbel:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

Additionally, the following project specific conditions also apply:

A. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the tank** must be extended to the ground surface.

B. Polyethylene Septic Tank Installation Requirements - To ensure structural integrity, the **manufacturer's instructions** regarding bedding the tank and filling the tank with water during burial **must be followed during installation.** Additionally, immediately after clean-outs, the tank must be refilled with water according to the manufacturer's instructions to maintain structural integrity.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3452. Thank you.

Sincerely,

Kim J. Medina for
Senior Environmental Analyst
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WDEQ File
Tim Lyons, Crook County, P.O. Box 848, Sundance, WY 82729