


Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 20, 2007

Pat Akers
Bridger Coal Company
P.O. Box 68
Point of Rocks, WY 82942

RE: Bridger Coal Company - Underground Mine Facility - Potable Water
Transmission Main - Permit Number 07-701, NE1/4, NW 1/4, SW 1/4 Section 12 and
NW 1/4 Section 13, T21N, R101W, Sweetwater County

Dear Mr. Akers:

The above application for coverage under General Permit to Construct a public water supply transmission main consisting of 6700 linear feet of 4-inch HDPE water main to serve a mine office, bathroom and garage complex in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.
Southwest District Engineer
Water Quality Division


xc: IPS, Cheyenne
Thomas G. Michel, P.E., Hydro-Engineering, 4685 E. Magnolia, Casper, WY 82604

encl: General Permit for a Public Water Supply Distribution System





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

December 12, 2007

Kent Connelly, Chairman
Lincoln County Board of Commissioners
925 Sage Avenue, Suite 302
Kemmerer, WY 83101

RE: Legacy Village Subdivision, Lincoln County, and WDEQ Application #07-702

Dear Mr. Chairman:

The Wyoming Department of Environmental Quality (WDEQ) has completed the review of the above referenced subdivision pursuant to W.S. 18-5-306. The WDEQ has a 'Non-Adverse' recommendations on this proposed subdivision. Our recommendation regarding the feasibility of the proposed water and sewage systems pursuant to the requirements of W.S. 18-5-306 (c) is based on the following findings:

Findings as to the safety and adequacy of the proposed sewage system:

WDEQ has reviewed the suitability of the subdivision soils for the disposal of septic effluent using leach fields. WDEQ's 'Non-Adverse' recommendation is therefore based on the following language, or similar, language needs to be added to the plat and/or all offers, solicitations, advertisements, contacts, and agreements relating to the subdivision, advising potential buyers of the Wyoming Department of Environmental Quality's requirements for the construction of septic systems:

Enhanced wastewater septic systems are required to be used in this subdivision. Each small enhanced wastewater treatment system must continually achieving the following minimum treatment standards as required by Chapter 23, Section 7(d)(viii)(C) of the Wyoming Water Quality Rules and Regulations at a depth of 4 feet above the seasonally high groundwater: - Fecal Coliform: < 800 colonies/100mL (maximum 30 day geometric mean) - Total Kjeldahl Nitrogen: < 25mg/L (maximum 30 day average) The proposed Norweco Singulair enhanced treatment system effluent must be disinfected by using the optional chlorination system. The septic effluent standard before discharging into a leach field for fecal colonies is zero (0) for any leach field within 351 feet of the subdivision water well. This includes lots 313, 318, 417, 418, 419, 420, and 421.

Findings as to the safety and adequacy of the proposed water system:

The WDEQ finds the water supply proposed by the developer's consultant which consists of one centralized water supply well and finished water storage to appear to be safe and adequate. The report indicates for a travel time of 2 years and a zone of contribution with a 351 foot radius. Therefore septic system effluent discharged into leach fields within this zone must contain zero (0) fecal colonies.



Chairman
Lincoln County Board of Commissioners
December 12, 2007

Conclusion(s):

The department has an 'Non-Adverse' recommendation on this proposed subdivision. When the above safety and adequacy issues of the proposed sewage and water system are resolved a non-adverse recommendation will be given.

Disclaimer

Nothing in WDEQ's recommendations or comments regarding the subdivider's proposal shall be construed to relieve the subdivider of their obligation to obtain any permits or additional approval from any local state or federal agencies/entities as required by law, rules and regulations, or ordinance. Nothing in these recommendations commits the WDEQ or the delegated county to the issuance of required permits for construction, operation, or modification of water supply and/or wastewater systems. It is the duty of the subdivider/developer to comply with all applicable federal, state and local requirements. Please do not hesitate to contact me at (307) 332-3144 if you have any questions on the recommendations or need any assistance on how to proceed with this application.

Sincerely,




Mark Baron, P. E.
Southwest District Engineer
Water Quality Division

xc:

David Benton, P.E., Benton Engineering, 550 Linden, WY 83401
Thomas R. Wood, P.G., 510 East 17th St., Suite 205, Idaho Falls, ID 83404
Bruce M. & Betty B. Davis, P.O. Box 946, Afton, WY 83110
John Woodward, Lincoln County Office of Planning and Development, P.O. Box 414, Afton, WY 83110
Mike Ebsen, Wyoming State Engineers Office, Herschler Building, 4th Floor East, Cheyenne, WY 82002
Lou Harmon, WDEQ/WQD, Cheyenne
IPS-Cheyenne
chron & file(3)



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

January 9, 2008

Vern Burress & Troy Trombetta
Lifestyle Properties
2920 W. Main Suite #2
Rapid City, SD 57702

RE: Lot 5 Block 2 Sundance View Estates Small Wastewater System, Permit # 07-704
Crook County

Dear Sirs:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

Additionally, the following permit conditions apply:

- 1) ALL easements and property lines shall be surveyed and located by a licensed surveyor prior to construction of the septic system so that all setback distances can be maintained as shown on the site plan.
- 2) A cleanout is required at the 90 degree bend between the house and the septic tank.

Sincerely,

Karen L. Farley, P.E.
Northeast District Supervisor
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
Allan Schreier, P.E., Schreier Engineering, 1403 5th Avenue, Suite 6, Belle Fourche, SD 57717
Bryan Rick, Quality Excavating, Inc., 4314 Wonderland Drive, Rapid City, SD 57702
Tim Lyons, Crook County Growth and Development
WDEQ File





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

November 9, 2007

Lifestyle Properties
Vern Burress
2920 West Main Street, Suite 2
Rapid City, SD 57702

RE: Lot 3 Block 2 Sundance View Estates Residential Septic System
Permit # 07-705

Dear Sirs:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

In addition, the following permit conditions apply:

1) A cleanout must be installed at the 90° bend shown on the site plan between the septic tank and the leachfield.

If you have any questions, please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3478. Thank you.

Sincerely,

Karen L. Farley, P.E.
Northeast District Supervisor
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WDEQ File
Tim Lyons, Crook County, P.O. Box 37, Sundance, WY 82729
Allan Schreier, P.E., Schreier Engineering, 1403 5th Avenue, Suite, Belle Fourche, SD 57717





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

November 2, 2007

Lifestyle Properties
Vern Burress
2920 West Main Street, Suite 2
Rapid City, SD 57702

RE: Lot 5 Block 4 Sundance View Estates Residential Septic System
Permit # 07-706

Dear Sirs:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions, please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3478. Thank you.

Sincerely,

Karen L. Farley, P.E.
Northeast District Supervisor
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WDEQ File
Tim Lyons, Crook County, P.O. Box 37, Sundance, WY 82729
Allan Schreier, P.E., Schreier Engineering, 1403 5th Avenue, Suite, Belle Fourche, SD 57717





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

November 5, 2007

Lifestyle Properties
Vern Burress
2920 West Main Street, Suite 2
Rapid City, SD 57702

RE: Lot 6 Block 3 Sundance View Estates Residential Septic System
Permit # 07-707

Dear Mr. Burress:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

In addition, the following permit conditions apply:

1) Cleanouts – Cleanouts are required to be installed at all bends in the sewer line 22.5° and greater.

If you have any questions, please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3478. Thank you.

Sincerely,

Karen L. Farley, P.E.
Northeast District Supervisor
WDEQ/WQD


Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WDEQ File
Tim Lyons, Crook County, P.O. Box 37, Sundance, WY 82729
Allan Schreier, P.E., Schreier Engineering, 1403 5th Avenue, Suite, Belle Fourche, SD 57717





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

Dave Freudenthal, Governor

NOTIFICATION OF COVERAGE

October 30, 2007

Dossie Overfield, Manager
Northwest Rural Water District
P.O. Box 2347
Cody, Wyoming 82414

RE: Northwest Rural Water District - Lewis Bros Subdivision - Lovell Service Area
Waterline Extension, Permit Number: 07-708, Lot 77-A & 79, T56N, R96W, Park County,
PWS #WY5601254C

Dear Ms. Overfield:

This application is a re-submittal of a project which was permitted under DEQ permit #97-132. The project involves the installation of about 834 linear feet of 3-inch water line to serve six residential connections with a looped distribution main. The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 of the Wyoming Water Quality Rules and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.
Northwest District Engineer
Water Quality Division

cc: Robert Overfield, P.E., Engineering Associates, P.O. Box 1900, Cody, WY 82414
IPS, Cheyenne

encl: General Permit For a Public Water Supply Distribution System

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 1, 2007

Mr. Herman Noe
Cheyenne Board of Public Utilities
P.O. Box 1469
Cheyenne WY 82003

RE: SIMON CONTRACTOR ASPHALT AST FIRE HYDRANTS AND WATER MAIN,
Application No. **07-709**, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as 4 fire hydrants, water main, and a new manhole, Section 3 T13N R66W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations; and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by May 10, 2010.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **07-709** in any future correspondence.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/cs/7-0941

cc: IPS, Cheyenne
BRUCE PERRYMAN
AVI, P.C.
2035 WESTLAND RD
CHEYENNE WY 82001

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

December 17, 2007

Craig Welling, Chairman
225 9th Street
Uinta County Courthouse
Evanston, WY 82930

RE: The Meadows at Fort Bridger PUD Subdivision, Uinta County, WDEQ Application #07-710

Dear Mr. Chairman:

The Wyoming Department of Environmental Quality (WDEQ) has completed the review of the above referenced subdivision pursuant to W.S. 18-5-306. The WDEQ has an 'Adverse' recommendation on this proposed subdivision. Our recommendation regarding the feasibility of the proposed water and sewage systems pursuant to the requirements of W.S. 18-5-306 (c) is based on additional information being required to be submitted. The WDEQ's November 19, 2007 review letters addressing the following questions and statements have not been answered.

Findings as to the safety and adequacy of the proposed sewage system:

The WDEQ finds that the proposed sewage system is safe and adequate. The applicant's consultant has indicated that a sewage collection system will be connected to the Fort Bridger Sewer District.

Findings as to the safety and adequacy of the proposed water system:

The WDEQ finds does not find the proposed water system to be safe and adequate. Chapter 23, Section 8 (a)(vi) requires that the information required by W.S. 18-5-306 (a)(xi) is to be submitted. In a November 13, 2007 letter from the State Engineer's Office the State Engineer has responded in the following manner:

1. A check of our latest maps showing the Service Area for the Bridger Valley Water Project Pipeline-Smith's Fork Creek under Permit Nos. 26355 and 26356 includes Lot 5, S $\frac{1}{2}$ SW $\frac{1}{4}$ and the NE $\frac{1}{4}$ SW $\frac{1}{4}$ of Section 34, T16N, R115W. It would appear that the Service Area needs to be expanded (enlarged) to include the NW $\frac{1}{4}$ SW $\frac{1}{4}$ and the NW $\frac{1}{4}$ of said Section 34.



Chairman
Lincoln County Board of Commissioners
December 17, 2007

2. Our preliminary search also revealed other existing and subject water rights as attaching to the lands proposed to be subdivided. Therefore, further action on the part of the subdivider or his agent in addressing Wyoming Statute 18-5-306 (a) (xi) is yet required. Please reference Department of Environmental Quality, Water Quality Rules and Regulations, Chapter 23, Section 8 (a) (xi). As of the date of this letter the Board of Control Division of the State Engineers Office had not received this required documentation.

Therefore in summary, the State Engineers Office is generally not supportive of approving the development of the proposed subdivision at this time. Additionally, any number of events could occur at some point in the future which may preclude the State Engineer from issuing permits for this type of activity.

The above water rights issues must be resolved before a non-adverse recommendation can be given.

Conclusion(s):

The department has an 'Adverse' recommendation on this proposed subdivision. When the above safety and adequacy issues of the water system are resolved the developer can have his consultant resubmit the Chapter 23 review for consideration.

Disclaimer

Nothing in WDEQ's recommendations or comments regarding the subdivider's proposal shall be construed to relieve the subdivider of their obligation to obtain any permits or additional approval from any local state or federal agencies/entities as required by law, rules and regulations, or ordinance. Nothing in these recommendations commits the WDEQ or the delegated county to the issuance of required permits for construction, operation, or modification of water supply and/or wastewater systems.

It is the duty of the subdivider/developer to comply with all applicable federal, state and local requirements. Please do not hesitate to contact me at (307) 332-3144 if you have any questions on the recommendations or need any assistance on how to proceed with this application.

Chairman
Lincoln County Board of Commissioners
December 17, 2007

Sincerely,

A handwritten signature in cursive script that reads "Mark Baron".


Mark Baron, P. E.
Southwest District Engineer
Water Quality Division

xc:

Kent Williams, Uinta County Complex, 225 9th Street, Evanston, WY 82930
Fred Hofer, General Delivery, Fort Bridger, Wyoming, 82933
Mark Davidson, P.E., Sunrise Engineering, Inc., 12227 South Business Park Dr.,
Suite 220, Draper, Utah 84020
Mike Ebsen, Wyoming State Engineers Office, Herschler Building, 4th Floor East,
Cheyenne, WY 82002
Lou Harmon, WDEQ/WQD Cheyenne
IPS-Cheyenne
chron & file(3)



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

December 11, 2007

Mr. Nathan McAdams
Wind River Transport
P.O. Box 202
Daniel, WY 83115

RE: Lot 46, Sand Draw Industrial Park Subdivision, 2nd Filing, Small Waste Water System, Permit Number 07-711R, NW ¼ Section 5, T30N, R107W, Sublette County

Dear Mr. McAdams:

The above application for coverage under General Permit to Construct a conventional wastewater treatment and disposal system to serve the new 15 person business building with a 1,408 sq ft leach field has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.
Southwest District Engineer
Water Quality Division


Steve Warner
Reviewer

xc: IPS, Cheyenne


Keith Raney, Sublette County Environmental Health, P.O. Box 722, Pinedale, WY 82941

Encl: General permit for one Small Waste Water System





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 27, 2007

Eric Fairbanks
P.O. Box 10
Boulder, WY 82923

RE: Sand Draw Industrial Park Phase II - Lots 38 and 39- Small Wastewater Treatment Facilities - Permit Number 07-712, Section 5, T30N, R107W, Sublette County

Dear Mr. Fairbanks:

The above application for coverage under General Permit to Construct two small wastewater treatment facilities consisting of a septic tank and leach field, to serve an office on Lot 38 and a shop on Lot 38 in accordance with Chapter 3, Section 7, Chapter 11, Part D of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

In carrying out the activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1) Both leach fields must be at least 100 feet from all water wells.
- 2) Both septic systems must have replacement areas equivalent to the original leach fields.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Steven Warner
Reviewer
Water Quality Division

Mark Baron, P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Keith Raney, Environmental Health, Sublette County, P.O. Box 722, Pinedale, WY 82941
Robert E. Johnson, P.E., P.O. Box 1616, Pinedale, WY 82941

encl: General Permit for Small Wastewater Treatment Systems





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

October 16, 2007

Harry Berger
965 Cabin Creek Road
Oshoto, WY 82721

RE: Berger Residential Septic System, Replacement Leachfield
Permit #07-713

Dear Mr. Berger:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions, please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3478. Thank you.

Sincerely,

Karen L. Farley, P.E.
Northeast District Engineer
WDEQ/WQD


Enclosures: General Permit

cc: IPS, Cheyenne
WDEQ File
Tim Lyons, Crook County Growth and Development, P.O. Box 848, Sundance, WY 82729
Travis Dewey, Tri-City Excavation, Inc., 169 Thorn Divide Rd, Carlile, WY 82721





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

January 17, 2008

Timothy W. Lewis
P.O. Box 159
Torrington, Wyoming 82240

RE: Lewis Residential Septic System,
Location: NE¼, Section 34, T27N, R66W,

Application No. **07-714**
Platte County

Dear Mr. Lewis:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a **3 bedroom** house in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific conditions also apply:

1. Equal Leachfield Flow Distribution - a "wye" fitting cannot be used to split the effluent flow from the septic tank equally between the two leachfield trenches. A tee fitting installed with the "trunk" of the tee used as the inflow and the two "branches" of the tee serving as the outflow, going ½ to the left and ½ to the right, shall be install instead. Or, a commercial "Flow Splitting", or "Flow Splitter" tee can also be used.
2. Polyethylene Septic Tank Installation Requirements - To ensure structural integrity, the **manufacturer's instructions** regarding bedding the tank and filling the tank with water during burial **must be followed during installation**. Additionally, immediately after clean-outs, the tank must be refilled with water according to the manufacturer's instructions to maintain structural integrity.

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>


ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



The approval granted under this Notification Of Coverage and the General Permit shall expire on January 16, 2010. Please reference Application Number 07-714 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,



Ronald L. Ewald, P.E.
Consulting Engineer
Southeast District, Water Quality Division


RLE/rm/8-0046

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Platte County Planner, Marlin Johnson, P.O. Box 728, Wheatland, Wyoming 82201



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 30, 2007

Charles F. Guschewsky
754 South 2nd Street
Lander, WY 82520

RE: Fremont Business Park Subdivision Sewer & Water Lines, Permit Number: 07-715,
N 1/2 SE 1/4, Section 12, T33N, R100W, Fremont County

Dear Mr. Guschewsky:

This project involves the installation of about 4,900 linear feet of 8-inch water line, fourteen fire hydrants and about 3,620 linear feet of 8-inch sewer line to serve a commercial business park. This application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; Chapter 11, Section 9; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.
Northwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Charles Spurlock, P.E., Trihydro Corp., 350 Garfield St., Lander, WY 82520
Mickey Simmons, City of Lander, 240 Lincoln, Lander, WY 82520

encl: General Permits For a Public Water Supply System and an Existing Sewage Collection System

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

November 21, 2007

Myles Smith
164 Prairie Street
Moorcroft, WY 82721

RE: Myles Smith Small Wastewater System
Permit # 07-716

Dear Mr. Smith:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

In addition, the following permit conditions apply:

- 1) The septic tank and leachfield shall be located a minimum of 50' from the drainageway.
- 2) Leachfield shall be located at least 100' from the west property boundary.
- 3) A new replacement area must be designated to accommodate the 50' required separation from the drainageway. Please submit with the Certificate of Completion.

If you have any questions, please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3478. Thank you.

Sincerely,

Karen L. Farley, P.E.
Northeast District Supervisor
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: Wilbur Troyer, 55 Kanode Road, Moorcroft, WY 82721
IPS, Cheyenne
WDEQ File
Tim Lyons, Crook County, P.O. Box 37, Sundance, WY 82729





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

December 12, 2007

Ted Ertman
Weston County Commissioners
1 West Main Street
Newcastle, WY 82701

RE: Countryside Subdivision, Weston County – **ADVERSE RECOMMENDATION**
WDEQ Application #07-717

Dear Mr. Chairman:

Attached, please find comments developed by the Wyoming Department of Environmental Quality (WDEQ) with respect to the content and adequacy of the subdivision application materials submitted to WDEQ pursuant to Wyoming Statute §18-5-306. The subdivision application was received in this office on October 15, 2007. The Department of Environmental Quality is required by law to respond with comments within 60 days after receipt of the application as described in W.S. §18-5-306 (c). The 60-day time statute as defined in W.S. §18-5-306 has expired. The statute does not allow the extension of the 60 day completion date even with the consent of all parties.

Therefore, if the County Commissioners desire a determination of the safety and adequacy of the proposed water and sewer systems from the Department of Environmental Quality, the developer should re-submit the complete application with the additional information necessary. The submittal will be assigned a new application number with a new 60-day clock.

Please feel free to contact me at (307) 473-3478 should you have any questions related to these comments or the application and review process.

Sincerely,

Karen L. Farley, P.E.
WDEQ/WQD Northeast District Supervisor

Attachments: WDEQ Comments, SEO Comments

cc: Gideon Dixon, P.O. Box 324, 5129 Hwy 16, Newcastle, WY 82729
Ralph W. Goodson, P.E., Bearlodge Limited, Inc., P.O. Box 130, Sundance, WY 82729
Greg Stumpff, Salt Creek Water District, P.O. Box 847, Newcastle, WY 82729
Mike Ebsen, SEO (w/o attachments)
WDEQ Subdivision File
IPS (Cheyenne)



**SUBDIVISION PROGRAM
REVIEW OF PLANS & SPECIFICATIONS / REPORTS**

**WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
152 North Durbin Street, Suite 100
Casper, Wyoming 82601
Phone (307) 473-3465**

PROJECT: Countryside Subdivision

LOCATION: Weston County

ENGINEER: Ralph W. Goodson, P.E., Bearlodge Limited, Inc. P.O. Box 130, Sundance, WY 82729

OWNER: Gideon Dixon, P.O. Box 324, 5129 Hwy 16, Newcastle, WY 82729

WATER QUALITY DIVISION APPLICATION NUMBER: 07-717

TITLE: Subdivision Application to the State of Wyoming Department of Environmental Quality for the Countryside Subdivision, Weston County, Wyoming

DATE ON PROPOSAL/PLANS/REPORT: October 2007

DATE RECEIVED BY DEQ: October 15, 2007

DATE OF THIS REVIEW: December 12, 2007

WDEQ REVIEWER: Karen L. Farley, P.E.,

ACTION: **ADVERSE RECOMMENDATION –**
Application is Incomplete

WDEQ COMMENTS

Safety and Adequacy of Proposed Sewage System

- 1) Chapter 23, Section 5 (b) – The engineering design report must be stamped by a professional engineer licensed in the State of Wyoming.
- 2) Chapter 23, Section 7(a)(ii) – Please provide further information on the existing and future land uses that may affect the adequacy of the proposed system.
- 3) Chapter 23, Section 7(c)(i) – Please provide certification from Salt Creek Water District that addresses the ability of "...all downstream sewers, lift stations and treatment facilities to handle the hydraulic and organic loading from the proposed subdivision."

- 4) Chapter 23, Section 7(c)(ii) – Please provide all of the information required by *Wyoming Water Quality Rules and Regulations Chapter 11, Section 6 (b) – Sewerage Systems*.

Safety and Adequacy of Proposed Water System

- 5) Chapter 23, Section 8 – The water supply for the new subdivision is proposed to be provided by the Salt Creek Water District. However, a letter from the State Engineer’s Office (SEO) dated December 5, 2007, states the following:

1) *“State Engineer records indicate that all but the lands in the SE ¼ NE ¼ of Section 34 are currently covered under 2 existing permits. Therefore, permits for this well serving the District would need to be amended and/or enlarged to cover this proposed new area of use, prior to any use of the water within the proposed subdivision.”*

2) *“Further, these permits have Additional Conditions and Limitations attached to them, including annual water use report requirements. This report should include the total annual amount of water produced, and include at least two semi-annual static water level measurements. No evidence was found that these required reports have ever been filed.”*

We have included a copy of the SEO comments as part of this document. Please address.

- 6) Chapter 23, Section 8 (a)(ii) – Please provide the assumptions and back-up documentation used in obtaining the average and maximum day use for the subdivision.
- 7) Chapter 23, Section 8(b)(i) – Please provide documentation pertaining to “...the potability of the proposed water supply for the subdivision as evidenced by historic water quality analytical data and current compliance status;”
- 8) Chapter 23, Section 8(b)(ii) – Please provide certification by Salt Creek Water District that addresses “...the hydraulic capacity of the distribution system and the ability of the treatment facilities to provide potable water to the proposed subdivision.”
- 9) Chapter 23, Section 8(b)(iii) – Please provide the information as required in *Wyoming Water Quality Rules and Regulations Chapter 12, Section 6 (b)*.



State Engineer's Office

HERSCHLER BUILDING, 4-E CHEYENNE, WYOMING 82002
(307) 777-7354 FAX (307) 777-5451
seoleg@state.wy.us

DAVE FREUDENTHAL
GOVERNOR

PATRICK T. TYRRELL
STATE ENGINEER

5 December 2007

Received

DEC 07 2007

Casper DEQ

✓ Karen L. Farley, P.E., Supervisor
DEQ/WQD/Northeast District
152 North Durbin Street – Suite 100
Casper, Wyoming 82601

RE: Countryside Subdivision, Weston County, WDEQ Application #07-717

Dear Ms. Farley:

State Engineers Office, Ground Water Division staff has reviewed the submittal referenced above in compliance with Wyoming Statute 18-5-306 (c) (i). The proposed subdivision would develop 11 residential lots on acreage approximately 1.3 miles southeast of the City of Newcastle. The subdivision lands lie northeast of US Highway 16 and appear to be contained within the S $\frac{1}{2}$ NE $\frac{1}{4}$ and the NE $\frac{1}{4}$ SE $\frac{1}{4}$, Sec 34, T45N, R61W. The submittal indicates that there are existing water main lines through the development that are to be used for water service, however sewer lines would need to be installed. The submittal further states that all services currently provided by the Salt Creek Water District, both water and sewer, will be maintained. As a part of our review a cursory search of the State Engineer's Water Right Records in the area of the subdivision was conducted. We offer the following comments:

1. State Engineer records indicate that all but the lands in the SE $\frac{1}{4}$ NE $\frac{1}{4}$ of Section 34 are currently covered under 2 existing permits (copies enclosed). Therefore, permits for this well serving the District would need to be amended and/or enlarged to cover this proposed new area of use, prior to any use of the water within the proposed subdivision.
2. Further, these permits have Additional Conditions and Limitations attached to them, including annual water use report requirements. This report should include the total annual amount of water produced, and include at least two semi-annual static water level measurements. No evidence was found that these required reports have ever been filed.

Therefore, the State Engineers Office is not supportive of approving the development of the proposed subdivision at this time. Further, any number of events could occur at some point in the future which may preclude the State Engineer from issuing new permits for this type of activity.

Once item one (2) has been addressed; and upon final approval of the subdivision by the appropriate County Officials, the State Engineers Office hereby requests a copy of the final county approved plat in order to assist new owners in properly filing new water right applications.

In all correspondence regarding this application please reference the State Engineers Office Review Number 2007-112-70. If you have any questions, please feel free to contact me at (307) 777-6166, or if you prefer E-mail, my address is mebsen@seo.wyo.gov.

Thank you for this opportunity to comment.

Sincerely,



Mike Ebsen
Cooperative Programs Coordinator

Cc: Don McKenzie, DEQ-WQD, Environmental Program Manager
Michael Whitaker, Superintendent, Water Division Number II
Kody Steinbrecher, Hydrographer-Commissioner, Water District Number 1
Roger Ralph, Hydrographer-Commissioner, Water District Number 1
John Barnes, Administrator, Surface Water Division
Lisa Lindemann, Administrator, Ground Water Division
Allan Cunningham, Adjudication Officer, Board of Control Division
Ted Ertman, Weston County Commission, 1 West Main Street, Newcastle, WY 82701
Bearlodge Ltd, Inc., P.O. Box 130, Sundance, WY 82729
Gideon Dixon, P.O. Box 324, Newcastle, WY 82729
Greg Stumpff, P.O. Box 130, Newcastle, WY 82729
Jed Rockweiler, Permit Compliance Coordinator, Ground Water Division



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

December 12, 2007

Craig G. Mader, Chairman
Campbell County Commissioners
500 South Gillette Avenue, Suite 1100
Gillette, WY 82716

RE: Cradle Butte, Campbell County – **ADVERSE RECOMMENDATION**
WDEQ Application #07-718


Dear Mr. Chairman:

Attached, please find comments developed by the Wyoming Department of Environmental Quality (WDEQ) with respect to the content and adequacy of the subdivision application materials submitted to WDEQ pursuant to Wyoming Statute §18-5-306. The subdivision application was received in this office on October 12, 2007. The Department of Environmental Quality is required by law to respond with comments within 60 days after receipt of the application as described in W.S. §18-5-306 (c). The 60-day time statute as defined in W.S. §18-5-306 has expired. The statute does not allow the extension of the 60 day completion date even with the consent of all parties.

Therefore, if the County Commissioners desire a determination of the safety and adequacy of the proposed water and sewer systems from the Department of Environmental Quality, the developer should re-submit the complete application with the additional information necessary. The submittal will be assigned a new application number with a new 60-day clock.

Please feel free to contact me at (307) 473-3478 should you have any questions related to these comments or the application and review process.

Sincerely,


Karen L. Farley, P.E.
WDEQ/WQD Northeast District Supervisor

Attachments: WDEQ Comments, SEO Comments

cc: Jeff Swaney, PO Box 2501, Gillette, WY 82717
Thomas Hollingsworth, Hollingsworth Associates, 2875 Oxford Avenue Unit 7, Sheridan, CO 80110
Mike Ebsen, SEO (w/o attachments)
WDEQ Subdivision File
IPS (Cheyenne)



**SUBDIVISION PROGRAM
REVIEW OF PLANS & SPECIFICATIONS / REPORTS**

**WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
152 North Durbin Street, Suite 100
Casper, Wyoming 82601
Phone (307) 473-3465**

PROJECT: Cradle Butte Subdivision

LOCATION: Campbell County

ENGINEER: Thomas Hollingsworth, P.E., Hollingsworth Associates, 2875 Oxford Avenue, Unit 1
Sheridan, CO 80110

OWNER: Jeff Swaney, PO Box 2501, Gillette, WY 82717

WATER QUALITY DIVISION APPLICATION NUMBER: 07-718

TITLE: Subdivision Application to the State of Wyoming Department of Environmental
Quality for the Cradle Butte Subdivision, Campbell County, Wyoming

DATE ON PROPOSAL/PLANS/REPORT: October 2007

DATE RECEIVED BY DEQ: October 12, 2007

DATE OF THIS REVIEW: December 12, 2007

WDEQ REVIEWER: Dennis Lamb/Karen L. Farley, P.E.,

ACTION: **ADVERSE RECOMMENDATION –**
Application is Incomplete

WDEQ COMMENTS

Safety and Adequacy of Proposed Sewage System

- 1) Chapter 23, Section 7(a)(ii) – Please provide further information on the existing and future land uses that may affect the adequacy of the proposed system.
- 2) Chapter 23, Section 7(d)(ii)(A) – Please provide all information required by the WDEQ/WQD percolation test procedures information sheet.

Safety and Adequacy of Proposed Water System

- 3) The proposed subdivision water supply well has been constructed without a WDEQ/WQD permit. Please submit an as-built permit application as per WWQR&R Chapter 12 and Chapter 11 Part G for the well.

SEO Comments

- 4) The SEO has identified issues with water rights at the proposed subdivision. We have included a copy of the SEO comments as part of this document so the items can be addressed.



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

October 29, 2007

Mairia McLaughlin
P.O. Box 7254
Gillette, WY 82717

RE: McLaughlin Residential Septic System
Permit # 07-719

Dear Mairia:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions, please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3465. Thank you.

Sincerely,

Karen L. Farley, P.E.
Northeast District Engineer
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WDEQ File
Tim Lyons, Crook County, P.O. Box 37, Sundance, WY 82729
Wilbur Troyer, 95 Kanode Road, Moorcroft, WY 82721





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

November 5, 2007

Robert and Janet Olver
104 Kanode Road
Moorcroft, WY 82721

RE: Olver Residential Septic System
Permit # 07-720

Dear Mr. and Mrs Olver:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions, please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3478. Thank you.

Sincerely,

Karen L. Farley, P.E.
Northeast District Supervisor
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WDEQ File
~~Tim Lyons~~, Crook County, P.O. Box 37, Sundance, WY 82729



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 07-721

REFERENCE PERMIT NO. N/A

Hagens Estates Subdivision Water Supply Well

This permit hereby authorizes the applicant:

Mr. Patrick Hagens
4900 Blue Tick Drive
Gillette, WY 82718

to drill, construct, develop and test the Hagens Estates Subdivision Water Supply Well according to the procedures and conditions of the application number 07-721. The facility is located in the county of Campbell, approximately 10 miles northeast of the Town of Wright, Wyoming. All construction, installation, or modification allowed by this permit shall be completed within one year of issuance.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will provide immediate oral or written notice to the Northeast District, Water Quality Division, 152 North Durbin, Suite 100, Casper, WY, 82601, Phone 307-473-3465, FAX 307-473-3458, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District, Water Quality Division, 152 North Durbin, Suite 100, Casper, WY, 82601 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
- a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
 - e. Submission of bond logs and specifications on the cement grout used to seal the annular space.
- 3 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".
- 4 of 4 Disinfection in accordance with Chapter 12, Section 9(b)(A)(II) shall be performed.

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

1-18-08
Date of Issuance

KLF/rm/8-0040
cc: John Wetstein, PE/PG, Wester-Wetstein & Associates, Inc, P.O. Box 2202, Laramie, WY 82073
Phillip Giffin, Campbell County Department of Public Works, 500 S. Gillette Ave., Ste 1400,
Gillette, WY 82716

STATEMENT OF BASIS

1. Permit Number: 07-721
2. Application reviewed for compliance with the following applicable regulations :
Chapter 3, Chapter 11 & Chapter 12 of the Wyoming Water Quality Rules and Regulations
3. Does the permit comply with all applicable regulations identified above?

NO – see below

The permit approval is based upon a deviation from applicable regulations in accordance with Section 5 of Chapter 11.

4. Facilities include components not specifically covered or differing from applicable regulations and approval is based upon a deviation in accordance with Section 5.
 - a. The permit includes approval to deviate from the following regulatory requirements:
 - i) Chapter 11, Section 65 (b) requires "...an oversized hole, at least four inches greater in diameter than the production casing...". A 5 ½ inch O.D. production casing will be allowed inside an 8 ¾ inch borehole. This will provide an oversized hole of 3 ¼ inches greater in diameter than the casing. **Any deviation of this directive will require a modification of this permit and will need to be obtained by the WDEQ prior to drilling.**
 - ii) Chapter 11, Section 65 (c) (i) requires "Neat cement shall be composed of one sack of Portland Cement to 4 ½ to 6 ½ gallons of clean water." 7.7 gallons of water per sack will be allowed.
 - b. Briefly state the basis for these deviations:
 - i) Well construction methods will consist of pressure grouting from the bottom to top in combination with regularly spaced centralizers (300 feet +/-), followed by submission of bond logs upon completion of the well.
 - ii) The use of the "lighter" cement is requested due to the possibility of lost circulation during the cementing process, caused by the loss of pressure within the formations encountered during drilling. Submission of cement mix specifications are to be provided upon completion of the well.

5. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 is not required.
6. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Karen L. Farley, P.E., and completed on January 16, 2008. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 29, 2007

Three Forks Ranch Corp.
Attn: Jay Linderman, Director/General Manager
P.O. Box 69
Savery, Wyoming 82332

RE: Three Forks Ranch Laundry – Septic System, Application No. **07-722**
Location: SW¼ SW¼, Section 2, T12N, Range 90W, Carbon County

Dear Mr. Linderman:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a **stand-alone laundry building with employee facilities** in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway **from each compartment of the septic tanks** must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on November 30, 2009. Please reference Application Number 07-722 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald, P.E.
Consulting Engineer
Southeast District, Water Quality Division

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

RLE/cs/7-1029

cc: IPS, Cheyenne

Timothy S. Travis, NWCC, Inc., 2580 Copper Ridge Drive, Steamboat Springs,
Colorado 80487

Carbon County Planning Director, Lou Kline, 215 W. Buffalo Street, #304,
P.O. Box 487, Rawlins, Wyoming 82301



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 2, 2007

Mr. Herman Noe
Cheyenne Board of Public Utilities
P.O. Box 1469
Cheyenne WY 82003

RE: DELL RANGE, PRAIRIE AVE & HOBBS SAN. SEWER AND FIRE HYDRANT,
Application No. **07-723**, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and of Existing Sewage Collection Systems described as 161 ft of 8" diameter sanitary sewer with 2 manholes and 1 fire hydrant, Section 19 T14N R66W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by May 10, 2010.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **07-723** in any future correspondence.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/cs/7-0948

cc: IPS, Cheyenne
LAWRENCE R GALLAGHER
SUMMIT ENGINEERING, LLC
5907 TOWNSEND PLACE
CHEYENNE WY 82009

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
AS-BUILT PERMIT TO CONSTRUCT

PERMIT NO. 07-724

Kelly - Teton Science School Well
PWS #WY5680099

This permit hereby authorizes the applicant:

Thayne O'Brien, Contracting Officer
Grand Teton National Park
P.O. Box 170
Moose, WY 83012

to have completed and equipped Teton Science School Well; according to the procedures and conditions of the application number 07-724. Permit 07-188R was issued for the drilling and testing of this well; this permit is issued for the completion and equipping of this well. The well is located about 10 miles north, northeast of Jackson and within SW ¼, SE ¼, Section 24, T43N, R115W in the county of Teton, in the State of Wyoming.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Northwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

11-7-07
Date of Issuance

JSB/DRM/cs/7-0923

ARC 11/5/17

STATEMENT OF BASIS

1. Permit Number: 07-724
2. Application reviewed for compliance with the following regulations:
Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?
Yes.
4. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.
No.
5. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Public water supply wells are exempted from review by Chapter 3, Section 17
6. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by James S. Brough, jbroug@state.wy.us, Environmental Engineer and completed on October 23, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."

Xc: Bob Wemple, Grand Teton National Park, P.O. Box 170, Moose, WY 83012
Mike Machupa, Grand Teton National Park, P.O. Box 170, Moose, WY 83012



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

August 31, 2007

Albany County Board of Commissioners
525 Grand Avenue
Laramie, WY 82070

RE: Non-Adverse Recommendation, Pronghorn Subdivision, Albany County
WDEQ Application #07-725

Dear Commissioners:

The Wyoming Department of Environmental Quality has completed the review of the proposed Pronghorn Subdivision located in the North 1/2 of the NE 1/4 of Section 23, T13N, R79W, 6th P.M., in Albany County, Wyoming. The Pronghorn Subdivision will create 14 lots out of approximately 80 acres. The information was submitted by Trihydro Corporation, signed by Richard Allen, P.E., a Wyoming Licensed Engineer and signed by Ryan David Athey, a Wyoming Professional Geologist. This letter represents the recommendations of the Wyoming Department of Environmental Quality as required by W.S. 18-5-306(c).

Findings as to the safety and adequacy of the proposed sewage system:

The proposed sewage system is a septic tank and leachfield on each lot. Each lot has an area designated for the construction of the leachfield. The leachfield must be constructed entirely within the designated envelope. All construction must be permitted by and constructed to Wyoming Department of Environmental Quality Water Quality Rules and Regulations and Albany County Construction Standards. The information submitted addresses the safety and adequacy of the proposed sewage system, provided compliance with the statements indicated in the "Notes required to be added to the final plat and other pertinent documents."

Findings as to the safety and adequacy of the proposed water system:

The proposed water system is individual wells. Each lot has an area designated for the construction of a well. All construction must be permitted by and constructed to Wyoming State Engineer's Office Rules and Regulations and Construction Standards. The information submitted addresses the safety and adequacy of the proposed water system, provided compliance with the statements indicated in the "Notes required to be added to the final plat, and other pertinent documents."

Notes required to be added to the final plat, and other pertinent documents:

1. All wells must be completed within the areas designated as well envelope on each lot.
2. All leachfields must be completed within the areas designated as leachfield envelope on each lot.

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



Conclusions:

The Department of Environmental Quality has "No Adverse" recommendations applicable to the Pronghorn Subdivision.


Disclaimer:

The Non-Adverse recommendation provided above has nothing to do with, nor has any bearing on the water rights associated with the Pronghorn Subdivision. Any questions or concerns about the water rights for the Pronghorn Subdivision should be directed to the State Engineer's Office. The State Engineer's Office has issued a letter dated 29 November 2007 detailing requirements for construction of water wells.

Nothing in Department of Environmental Quality recommendations or comments regarding the Trihydro Corporation proposal for the Pronghorn Subdivision shall be construed to relieve Ben Dalton of the obligation to obtain any permits or additional approval from any local, state or federal agencies as required by law, rules, regulations, or ordinances. Nothing in these recommendations commits the Department of Environmental Quality or Albany County to the issuance of required permits for construction, operation, or modification of water supply or sewage systems.

Please do not hesitate to contact me at (307) 777-7088 if you have any questions regarding this subdivision application or Department of Environmental Quality's subdivision application review process.

Sincerely,




Louis B. Harmon, PE-PG
Southeast District Supervisor
Water and Wastewater Program, Wyoming Water Quality Division

LBH/cs/7-1037

cc: Ben Dalton, 5125 W. Oquendo #4, Las Vegas, NV 89118
Richard Allen, Trihydro Corp. 1252 Commerce Drive, Laramie, WY 82070
Doug Bryant, Director, Albany County Planning Office, 1002 South Third Street,
Laramie, Wyoming 82070
Mike Ebsen, SEO



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 2, 2007

Charlie Hilton, President
Windsor, Inc.
P.O. Box 1762
Cody, WY 82414

RE: Windsor Estates Subdivision Water & Sewer Lines, Permit Number: 07-726, NW 1/4, Lot 65, T52N, R102W, Park County

Dear Mr. Hilton:

This project involves the installation of approximately 1,490 linear feet of 8-inch water line and 1,772 linear feet of 8-inch sewer line which will serve twenty-four residential connections. The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; Chapter 11, Section 9; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.
Northwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Gregory Meinecke, Meinecke Engineering, LLC., 1527 Rumsey Ave., Cody, WY 82414
Stephen W. Payne, P.E., City of Cody, P.O. Box 2200, Cody, WY 82414

end: General Permits For a Public Water Distribution System & Existing Sewage Collection System

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726


AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

October 29, 2007

James Empfield
P.O. Box 644
Thermopolis, WY 82443

RE: Empfield Residential Small Wastewater Treatment Facility, Permit Number: 07-727, NE ¼, Section 11, T42N, R95W, Hot Springs County

Dear Mr. Empfield:

The above application for coverage under General Permit to construct a gravity flow septic tank and leachfield to serve a three bedroom home has been reviewed in accordance with Chapter 3, Section 7; and Chapter 11, Part D of the Wyoming Water Quality Rules and Regulations and is hereby approved with the following recommendations.

DEQ recommends the use of a flow divider tee to evenly split the wastewater flows between the two trenches. DEQ recommends that the soil cover depth not exceed three feet. Adherence to both of these recommendations will lead to better treatment in the soils and will help ensure that the leachfield doesn't fail prematurely.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please contact Lee Campbell, Hot Springs County Planner, at 307-864-2961 to schedule a construction inspection at least 24 hours prior to the beginning of construction.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.
Northwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Lee Campbell, Hot Springs County, 415 Arapahoe, Thermopolis, WY 82443 (w/enclosures)

encl: General Permit For a Small Wastewater Facility

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726

SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

ERMIT NO. 07-728RR

Snake River Junction - Water Supply Well
No Public Water System Number Assigned Snake River Junction
Snake River Junction Will Connect to the North Star Utility Water System

This permit hereby authorizes the applicant:

Alpine Development Group, LLC
Brad Vernon
P.O. Box 12910
San Luis Obispo, CA 93406

to construct a public water supply well system consisting of a pitless unit, above ground meter vault and connection pipe to serve a residential subdivision through the North Star Utility Water System according to the procedures and conditions of the application number 07-728RR. The facility is located about ½ miles northeast of the Town of Alpine at S ½ Section 20, N ½, Section 29, T37N, R118W in the county of Lincoln, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by July 28, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, presentations, procedures, terms and conditions of the permit application, supporting documents and permit.

This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadow View Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
- a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality

30 July 2008
Date of Issuance

MDB/rm/8-0575

STATEMENT OF BASIS

1. Permit Number: 07-728RR
2. Application reviewed for compliance with the following regulations:
Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?
Yes.
4. If a Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Not Required.
5. Documentation of Statement of Basis: The archive file for this permit include adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Mark D. Baron, P.E., mbaron@state.wy.us, Southwest District Engineer and completed on July 28, 2008. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

cc: Thomas Kirsten, P.E., Jorgensen Associates, P.O. Box 9550, Jackson, WY 83002

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 07-730R

Town of Diamondville 2007 Deal Alley Sewer Rehabilitation Project

This permit hereby authorizes the applicant:

Megan McCloud, Mayor
Town of Diamondville
P.O.Box 281
Diamondville, WY 83116

to construct 1160 feet of new 12 inch and 60 feet of new 15 inch PVC sewer main with appurtenances to include alternative power for a lift station; according to the procedures and conditions of the application number 07-730R. The facility is located approximately within the Town of Diamondville within NW 1/4, Section 25, T21N, R116W in the county of Lincoln, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by January 16, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not


relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 4 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 4 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 4 Complete drawings of the building used to house the generator to include engine ventilation, exhaust, heating and cooling if applicable must be submitted as a separate application to construct.
- 4 of 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

1-18-08
Date of Issuance

PDR/rm/8-0043

STATEMENT OF BASIS

1. Permit Number: 07-730R
2. Application reviewed for compliance with the following regulations:
3. Chapters 3, and 11 of the Wyoming Water Quality Rules and Regulations.
4. Does the permit comply with all applicable regulations identified above?
Yes
5. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.
NA
6. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Not Required
7. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Perry Roberson, prober2@state.wy.us, Consulting Engineer, approved by Mark Baron P.E. Southwest District Engineer and completed on January 16, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
AS - BUILT
PERMIT TO CONSTRUCT
PWS # WY5601595

PERMIT NO. 07-731R

Settlement Agreement Docket No. 4140-07

BP America - Jonah Field Office & Man Camp - Public Water Supply System

This permit hereby authorizes the applicant:

Thomas Rinker
BP America
P.O. Box 270
Farson, WY 82932

to construct a public water supply well, a reverse osmosis treatment system, treatment building, a 1000 gallon finished water and a 1000 gallon wastewater storage tanks to serve a 60 person office and 20 person mancamp according to the procedures and conditions of the application number 07-731R. The facilities are located about 32 miles southeast of Pinedale at NW 1/4 Section 26, T29N, R107W in the county of Sublette, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by February 12, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:


- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadow View Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
- a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division

2/14/08
Date of Issuance

MDB/rm/8-0120


John V. Corra
Director
Department of Environmental Quality

STATEMENT OF BASIS

1. Permit Number: 07-731R
2. Application reviewed for compliance with the following regulations:
Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?
Yes.
4. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Not required.
5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Mark D. Baron, P.E., mbaron@state.wy.us, Southwest District Engineer and completed on February 12, 2008. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

cc: Christina D. Wilhelm, P.E., Inberg-Miller, 124 East Main St., Riverton, WY 82501

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 07-732

FORT FETTERMAN WELL #~~2~~ ³ *JK*
PWS WY5680174

This permit hereby authorizes the applicant:

WYOMING STATE PARKS & HISTORIC SITES
2301 CENTRAL AVE
CHEYENNE, WY 82002

to construct, install or modify a Fort Fetterman Well #3 according to the procedures and conditions of the application number 07-732. The facility is located in NW 1/4 SE1/4 Section 10 T33N R72W; Converse County, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed May 10, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:


- 1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088, FAX 307-777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

- 2 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

- 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

Date of Issuance 11-7-07

LBH/cs/7-0960
JKZ 11/2/7

STATEMENT OF BASIS

1. Permit Number: 07-732
2. This application was reviewed for compliance with the applicable regulations ;
Chapters 3, 12
3. Does the permit comply with all applicable regulations identified above?
4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.

Public water supplies are exempted from review by Chapter 3, Section 17.

5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Louis Harmon, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on November 6, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 07-733

REFERENCE PERMIT NO. 90-261, 00-254

CENTENNIAL WATER & SEWER DISTRICT ARSENIC REMOVAL
PWS WY5601232

This permit hereby authorizes the applicant:

CENTENNIAL WATER & SEWER DISTRICT
PO BOX 185
CENTENNIAL, WY 82055

to construct, install or modify an arsenic removal project according to the procedures and conditions of the application number 07-733. The facility is located in NWSW1/4 Section 3 T15N R78W; Albany County, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed May 10, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088, FAX 307-777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
2. The chlorine disinfection system must be operated at all times to satisfy the requirements of the arsenic removal system.
- 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality

Date of Issuance 11/16/07

LBH/cs/7-0991
JRS 11/15/07

STATEMENT OF BASIS

1. Permit Number: 07-733
2. This application was reviewed for compliance with the applicable regulations ;

Chapters 3, 12

3. Does the permit comply with all applicable regulations identified above?

Yes

4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.

Public water supplies are exempted from review by Chapter 3, Section 17.


5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Louis Harmon, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on November 15, 2007. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 8, 2007

Mr. Bob Juve
CITY OF TORRINGTON
2042 E A STREET
TORRINTON, WY 82240

RE: WATER MAIN EXTENSION PROJECT-20TH AVE-TORRINGTON,WY,
Application No. **07-734**, Goshen County

Dear Mr. Juve:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems described as 8" diameter water line to loop 4" water lines, SW 1/4 Section 10 T24N R61W; Goshen County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by May 10, 2010.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **07-734** in any future correspondence.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/cs/7-0966

cc: IPS, Cheyenne

LARRY D MCCASLIN
M.C. SCHAFF & ASSOC, INC
818 S BELTLINE HWY E
SCOTTSBLUFF NE 69361


Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 30, 2007

Bill Thompson
19250 39th Avenue S
Seattle, WA 98188

RE: Deer Creek RV Park and Campground: Wastewater Updates, App. No. **07-735**
Location: SE¼ & NW¼, Section 4, T33N, R75W, Converse County

Dear Mr. Thompson:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Sewage Collection Systems in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, the general permit, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

The approval granted under this Notification Of Coverage and the General Permit shall expire on November 30, 2009. Please reference Application Number **07-735** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald, P.E.
Consulting Engineer
Southeast District, Water Quality Division

Enclosures: GENERAL PERMIT - Extensions/Modifications of Existing Sewage Collection Systems
Certificate of Completion Form

RLE/cs/7-1038

cc: IPS, Cheyenne
Matt Williams, WLC, Engineering, Surveying & Planning, Inc., 200 Pronghorn,
Casper, Wyoming 82601

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 07-736

REFERENCE PERMIT NO. 05-239

Burnett Land and Livestock LTD New Pond Construction

This permit hereby authorizes the applicant:

Burnett Land and Livestock LTD
291 Road 151
Carpenter, WY 82054

to construct, install or modify a third storage pond with bentonite amended liner according to the procedures and conditions of the application number 07-736. The facility is located in NE1/4 Section 7 T12 N R61 W; Laramie County, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by January 23, 2013.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088, FAX 307-777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
2. The new pond may be excavated immediately under this permit. The liner need not be installed as long as livestock waste is not permitted to enter the excavation. If the liner construction is not completed before January 23, 2013, the permit must be renewed.
- 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

Date of Issuance 1/23/08

LBH/rm/8-0061

STATEMENT OF BASIS

1. Permit Number: **07-736**
2. This application was reviewed for compliance with the applicable regulations ;

 Chapters 3, 11
3. Does the permit comply with all applicable regulations identified above?

 Yes
4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was
 required.
5. The basis for determining groundwater will be protected is


 The liner design which restricts limits exfiltration and the groundwater monitoring and
 protection plan required by permit 05-239. The groundwater measures required by permit
 05-239 include all of the area affected by construction allowed under permit **07-736**. The
 liner will protect the groundwater from contamination above Class I Table 1, Chapter 8
 standards.
6. Documentation of Statement of Basis: The archive file for this permit includes adequate
 documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Louis Harmon, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on January 22, 2008. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documentation, permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 1, 2007
Dr. Justin Johnson, West Side Animal Hospital
631 Ash Street
Casper WY 82601

RE: Equine Medical Facility Holding Tank
Location SW ¼ Sec. 10 T33N R77W

Application No. **07-737**
Converse County

Dear Dr. Johnson:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

With the certificate of completion please submit pictures of the capped discharge line and the high level alarm.

The approval granted under this Notification Of Coverage and the General Permit shall expire on May 1, 2008. Please reference Application Number **07-737** in any future correspondence.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/cs/7-0942

cc: IPS, Cheyenne
John Wagner, Don McKenzie
Paul Musselman, Converse County Special Ass't, 105 North 5th Street Suite B-6,
Douglas, WY 82633
Tom Brauer, CEPI, 6080 Enterprise Drive, Casper, WY 82609

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion


Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 2, 2007

Mr. Herman Noe
Cheyenne Board of Public Utilities
P.O. Box 1469
Cheyenne WY 82003

RE: DUTCHER FIELD WATER LINE EXTENSION,
Application No. **07-738**, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems described as 8" water line extension to loop a dead-end, NW1/4 Section 28 T14N R66W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by May 10, 2010.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **07-738** in any future correspondence.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/cs/7-0950

cc: IPS, Cheyenne

JEFFREY PECENKA
CBPU
2406 SNYDER AVE
CHEYENNE WY 82001

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

Dave Freudenthal, Governor

NOTIFICATION OF COVERAGE

November 16, 2007

Dossie Overfield, Manager
Northwest Rural Water District
P.O. Box 2347
Cody, Wyoming 82414

RE: Northwest Rural Water District - Buchanan Park - Block 3 Waterline Extension,
Permit Number: 07-739, W 1/2 W 1/2 of Lot 52, T52N, R101W, Park County, PWS
#WY5601254C

Dear Mrs. Overfield:

This project involves the construction of approximately 6,550 linear feet of 2-inch water line to serve 27 residential connections in Buchanan Park Block 3 Subdivision. This application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 of the Wyoming Water Quality Rules and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact James Brough at 307-332-3144.

Sincerely,

James Brough, P.E.
Northwest District Engineer
Water Quality Division

cc: Robert Overfield, P.E., Engineering Associates, P.O. Box 1900, Cody, WY 82414
IPS, Cheyenne

encl: General Permit For a Public Water Supply Distribution System

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-5085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726


SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-3183





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

December 28, 2007

David G. Westling, Assistant City Engineer
City of Green River
50 E. 2nd N
Green River, WY 82935

RE: Northside B, C and Jensen Street - Water and Sewer Main Extensions, Modification to PN 07-177; Permit Number 07-740, SE and SW1/4 Section 15, T18N, R107W, Sweetwater County, Wyoming
PWS: WY5600050

Dear Mr. Westling:

The application for coverage under General Permits to Construct water and sewer main supplemental extensions to the reconstruction of 6219 feet sewer main and 7476 feet PVC water main serving chiefly residences located in the Northwest established area of Green River previously permitted as PN 07-177 to include water and sewer main modifications and a boring for services to a Visitor Center in accordance with Chapter 3, Section 7, Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permits.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Perry Roberson
Environmental Senior Analyst
Water Quality Division

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne

encl: General Permit for a Sewage Collection System,
General Permit for a Public Water Supply Distribution System





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

December 21, 2007

Ms. Sue Belish, Superintendent
Sheridan County School District #1
PO Box 819
Ranchester, WY 82839

RE: New Tongue River High School - Water and Sanitary Sewer Systems
Application No. 07-741

Dear Ms. Belish:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations and for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Sewage Collection Systems in accordance with Chapter 3 and Chapter 11 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V. Section O. of the general permits.

If you have any questions, please contact me at 307-473-3471.

Sincerely,

Kevin J. Frank

Kevin J. Frank
Engineering Consultant
Water Quality Division

cc: IPS, Cheyenne
Jeff Feck; Vista West Engineering; 1470 Sugarland Drive, Ste 3; Sheridan, WY 82801





The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

November 13, 2007

Ben Glenn
Glenn Construction, LLC
P.O. Box 543
Moorcroft, WY 82721

RE: Glenn Residential Septic System
Permit # 07-744

Dear Mr. Glenn:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions, please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3478. Thank you.

Sincerely,

Karen L. Farley, P.E.
Northeast District Supervisor
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WDEQ File
Tim Lyons, Crook County, P.O. Box 37, Sundance, WY 82729



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
"AS-BUILT" PERMIT TO CONSTRUCT

PERMIT NO. 07-746

Kenai Project

This permit hereby authorizes the applicant:

Comet Energy Services, Inc.
Att. Mr. Kent Fink
1241 Eagle View
Buffalo, Wyoming 82834

to have installed one compliance monitoring well according to the procedures and conditions of the application number **07-746**. The facilities are proximal to the on channel coal bed methane produced water impoundment located in Township 53N, Range 75W, SENE Section 4, in the county of Campbell, in the State of Wyoming. The WYPDES Permit Number is #0054330 (002). All construction, installation, or modifications allowed by this permit have been completed.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facilities to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facilities described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facilities. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facilities. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facilities are located or are being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1 of 4: The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality/ Water Quality Division, Groundwater Program, 1866 South Sheridan Avenue, Sheridan, WY 82801, (307)-673-9337, fax (307)-672-2213, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 4: The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality/ Water Quality Division, Groundwater Program, 1866 South Sheridan Avenue, Sheridan, WY 82801, 307-673-9337, fax 307-672-2213 when discharge to each impoundment covered under this permit commences.

3 of 4: Monitoring Requirements:

Groundwater monitoring at the impoundments shall be performed on a quarterly basis until further notice and shall include the following information:

- Measurement of static water level and sampling and analysis of groundwater at downgradient well, MW#2.
- Reporting results of quarterly monitoring and sampling to the department by January 15th, April 15th, July 15th, and October 15th of each year. The first set of data will be due by April 15, 2008.

The parameters listed in the table below are required for groundwater compliance monitoring beneath the listed impoundment:

**Impoundment 42-4-5375
WYPDES #WY0054330 (002)**

Parameter	Crump MW#2 Background Value (mg/L) (6/20/07)	Trigger Value (mg/L)	Class III Water Quality Standards (mg/L)
Arsenic	ND	≥ 0.16	0.2
Selenium	ND	≥ 0.04	0.05
Sulfate	2500	≥ 2750	3000

Total Dissolved Solids (TDS)	4630	≥ 4815	5000
pH	7.5	≤ 8.15	6.5 – 8.5 (s.u)

Trigger values, specific to the groundwater samples at each impoundment, have been assigned to each constituent and are also listed above. If one or more of these trigger values is exceeded during a quarterly sampling event, monthly sampling of the groundwater for all listed parameters is required, with the analytical results due by the 15th day of each month. If groundwater monitoring reveals a pH measurement of 6.5 or less, the WDEQ may require sampling and analysis of groundwater for the following additional parameters: aluminum, boron, cadmium, chromium, copper, lead and zinc.

The analytical results for each sampling event, along with impoundment and monitor well location information must be submitted in the Excel spread sheet "Compliance Monitoring Data Reporting", which can be found on the WDEQ website at the following address: (<http://deq.state.wy.us/wqd/groundwater/pollution.asp>). These data shall be submitted electronically on the due dates established above to the following department address: cbmgroundwater@state.wy.us. In addition, the accompanying analytical laboratory reports must also be submitted either electronically (pdf format) or hard copy via mail to the WDEQ, Sheridan office at the address listed above.


4 of 4: Exceedence

Any exceedence of a groundwater quality standard listed in the preceding table, or as applicable in Table I of Chapter 8, Water Quality Rules and Regulations is a violation of this permit. If an exceedence of groundwater standards occurs as a result of the operation of the impoundment the WDEQ may require, among other things, further investigation of the groundwater impacts, remediation of the groundwater impacts, and cessation of discharge into the impoundment.

AUTHORIZED BY:



John F. Wagner
 Administrator
 Water Quality Division



John V. Corra
 Director
 Department of Environmental Quality

2/21/05

Date of Issuance



GROUNDWATER PROGRAM
REVIEW COMMENTS:
PLANS/SPECIFICATIONS/PROPOSALS/REPORTS

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
1866 South Sheridan Avenue
Sheridan, WY 82801
Phone: 307-672-6457

PERMIT TYPE: CBM: Groundwater Compliance Monitoring Program

WATER QUALITY DIVISION REFERENCE (PERMIT) NUMBER: 07-746

SITE (POD) NAME: Kenai Project: Reservoir 42-4-5375

APPLICANT: Kent Fink
Comet Energy Services, Inc.
1241 Eagle View
Buffalo, Wyoming 82834

CONSULTANT: Pilch Engineering
Attn.: Tom Pilch
41 E. Burkitt Street
Sheridan, WY 82801

LOCATION: Middle Prong of Wild Horse Creek tributary to the Powder
River
County: Campbell
Township 53 North; Range 75 West; Parts of Section 3 & 4

WYPDES No: WY0054330 – Outfall 002

DATE ON INITIAL REPORT: July, 2007

REVIEWING OFFICIAL: Don Fischer, North District Geologic Supervisor

DATE OF THIS REVIEW: February 14, 2008

ACTION: Permit authorized pursuant to conditions in Permit #07-746

COMMENTS: GROUNDWATER SECTION

1.0 SITE SUMMARY:

1.1 Site Description.

Watershed Name: Middle Prong of Wild Horse Creek, tributary to Powder River

Groundwater Classification:

- Class 1 (domestic)
- Class 2 (agricultural)
- Class 3 (livestock) 1

Basis for Classification: Laboratory analysis of groundwater indicates ambient water quality meets Water Quality Rules and Regulations Chapter 8 Class III standards and exceeds both Class I and Class II standards for Sulfate and TDS (Table 1- Chapter 8).

Table 1. Basis for Ground Water Classification by impoundment Name covered under Permit 07-746

Impoundment Name	Down Gradient Monitoring Well	Sulfate Concentration and Classification	TDS Concentration and Classification	SAR Calculation	Overall Groundwater Class
Crump 42-4-5375	MW-2	2500	4630	2.6	III

Description of Hydrogeology:

Groundwater occurs in a gravel at a depth of 69 to 80 feet. Static water level was established at 26.7 feet. As such the area represents a confined alluvial (terrace) aquifer. The stratigraphy in the borehole consisted of silts, claystones, clinker fragments, and thin coal beds.

Table 2. Names of Impoundments covered under Permit 07-746

Impoundment Name	Capacity (acre/ft)	Qtr	Qtr	Section	Town.	Range	Down gradient Monitoring Well
Crump 42-4-5375	17.09	SENE		4	53N	75W	MW-2

2.0 MONITORING AND REPORTING REQUIREMENTS

Groundwater monitoring at the impoundments shall be performed on a quarterly basis until further notice and shall include the following information:

- Measurement of static water level and sampling and analysis of groundwater at downgradient well: MW-2
- Reporting results of quarterly monitoring and sampling to the department by January 15th, April 15th, July 15th, and October 15th of each year. The first set of data will be due by April 15, 2008
- The parameters listed in the tables below are required for groundwater compliance monitoring beneath the listed impoundment:

Crump 42-4-5375

Parameter	MW-2 Background Value (mg/L) (06/20/2007)	Trigger Value (mg/L)	Class III Water Quality Standards (mg/L)
Arsenic	ND	≥ 0.16	0.2
Selenium	ND	≥ 0.04	0.05
Sulfate	2500	≥ 2750	3000
Total Dissolved Solids (TDS)	4630	≥ 4815	5000
pH	7.5	≤ 8.15	6.5 – 8.5 (s.u)

Trigger values, specific to the groundwater samples at this impoundment, have been assigned to each constituent and are also listed above. If one or more of these trigger values is exceeded during a quarterly sampling event, monthly sampling of the groundwater for all listed parameters is required, with the analytical results due by the 15th day of each month. If groundwater monitoring reveals a pH measurement of 6.5 or less, the WDEQ may require sampling and analysis of groundwater for the following additional parameters: aluminum, boron, cadmium, chromium, copper, lead and zinc.

The analytical results for each sampling event, along with impoundment and monitor well location information must be submitted in the Excel spread sheet "Compliance Monitoring Data Reporting", which can be found on the WDEQ website at the following address: (<http://deq.state.wy.us/wqd/groundwater/pollution.asp>). These data shall be submitted electronically on the due dates established above to the following department address: cbmgroundwater@state.wy.us. In addition, the accompanying analytical laboratory reports must also be submitted either electronically (pdf format) or hard copy via mail to the WDEQ, Sheridan office at the address listed above.

END OF REVIEW

WDF/rm/8-0134

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 07-747R

Energy Industrial Park - Rock Springs

This permit hereby authorizes the applicant:

Tony Tarufelli, Owner
1006 Corporation, LLC
2623 Driftwood Lane
Rock Springs, WY 82901

to construct water and sewer main extensions of 2410 feet 8-inch PVC sewer main, 900 feet of 4 inch forced main with lift station complete with alternative power and 2900 feet 12-inch PVC water main serving 22 industrial lots; according to the procedures and conditions of the application number 07-747R. The facility is located in Rock Springs within NW ¼ and SE1/4, Section 15, T19N, R05W in the county of Sweetwater, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by January 17, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not


relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

1-24-08
Date of Issuance


PDR/rm/8-0053

STATEMENT OF BASIS


1. Permit Number: 07-747R
2. Application reviewed for compliance with the following regulations:
3. Chapters 3, 11 and 12 of the Wyoming Water Quality Rules and Regulations.
4. Does the permit comply with all applicable regulations identified above?
Yes
5. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.
NA
6. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Not Required
7. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Perry Roberson, prober2@state.wy.us, Consulting Engineer, approved by Mark Baron P.E. Southwest District Engineer and completed on January 17, 2008. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."



The State
of Wyoming



Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

November 9, 2007

West Berlin Developers YO
P.O. Box 6689
Sheridan, WY 82801

RE: Transfer of Ownership,
Cloud Peak Ranch – Seventh Filing
Reference Permit #07-584
Permit #07-748

Dear Sirs:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations and for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Sewage Collection Systems in accordance with Chapter 3 and Chapter 11 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V. Section O. of the general permits.

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley, P.E.
Northeast District Supervisor
Water Quality Division


Enclosures: General Permits

cc: Jeff Feck, P.E., Vista West Engineering, P.O. Box 785, Sheridan, WY 82801
Mike Cole, City of Sheridan, P.O. Box 848, Sheridan, WY 82801
System Land, LLC, 2 Soldier Creek Road, Sheridan, WY 82801
WDEQ File, IPS (Cheyenne)





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 2, 2007

Mayor Greg Salisbury
TOWN OF ENCAMPMENT
PO BOX 5
ENCAMPMENT, WY 82325

RE: TOWN OF ENCAMPMENT-TREATED WATER TRANSMISSION LINE,
Application No. **07-749**, Carbon County

Dear Mayor Salisbury:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems described as a dedicated transmission line from clear well to water storage tank, Section 11 T14N R84W; Carbon County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by May 10, 2010.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **07-749** in any future correspondence.

Sincerely,

Louis B. Harmon PE-PG
Southeast District Engineer
Water Quality Division

LBH/cs/7-0945

cc: IPS, Cheyenne

TRAVIS HIGBY
FORSGREN ASSOCIATES, INC
370 E 500 SOUTH #200
SALT LAKE CITY UT 84111


Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

November 15, 2007

Babcock Builders, LLC
27 Old Brazzill Trail
Pinedale, WY 82941

RE: Babcock Builders Septic System - Permit Number: 07-750, Lot 17 Old Brazzill Ranch S/D, Second Filing, Sublette County, WY

Dear Babcock Builders, LLC:

The above application for coverage under General Permit to Construct a small wastewater enhanced treatment facility consisting of a Hydro-Action Set and Go system consisting of a pretreatment tank, 500 gallon aerobic treatment unit, flow splitter and 24 Quick 4 infiltrator chambers to serve a three bedroom home in accordance with Chapter 3, Chapter 11, Part D and Chapter 23 Section 7 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

In carrying out the activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 5 This permit is for an enhanced (extended aeration, activated sludge treatment system with and leach field) small wastewater treatment system. The permittee is required to obtain a maintenance contract and submit annual documentation that maintenance is being provided in accordance with the manufacturer requirements and recommendations and the permit conditions. Authority for this requirement is found in Sections 11 (a) and (c), Chapter 3 of the Wyoming Water Quality Rules and Regulations. Annual maintenance documentation must be submitted before December 31 of each year, starting December 31, 2008 to: Southwest District Engineer, Wyoming Department of Environmental Quality, 510 Meadowview Drive, Lander, WY 82520. Failure to submit annual maintenance documentation is a violation of the compliance requirements for this permit issued under Wyoming Statue 35-11-301.

2 of 5 The permittee shall ensure that the system is maintained and regularly serviced, as recommended by the manufacturer, for the life of the system. An inspection of the



system, as recommended by the manufacturer in the owner's manual, shall be performed every six months by a qualified or certified individual to ensure the system is operating correctly, and to determine when maintenance is required.

3 of 5 In the event that authority for permitting enhanced small wastewater treatment systems is delegated to Sublette County by the Department of Environmental Quality, the permittee shall be subject to all county requirements and resolutions that may be in effect, or subsequently enacted, affecting the inspection, operation, maintenance, monitoring, or replacement of this system.

4 of 5 This small enhanced wastewater treatment system must continually achieving the following minimum treatment standards as required by Chapter 23, Section 7(d)(viii)(C) of the Wyoming Water Quality Rules and Regulations at a depth of 4.0 feet above the seasonally high groundwater:


- Fecal Coliform: < 800 colonies/100mL (maximum 30 day geometric mean)

- Total Kjeldahl Nitrogen: < 25mg/L (maximum 30 day average)

5 of 5 The bottom of the leach field must be at least 6.0 feet above the seasonally high ground water.

If you have any questions, please contact me at 307-332-3144.

Sincerely,



Perry Roberson
Consulting Engineer
Water Quality Division



Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Keith Raney, Environmental Health, Sublette County, P.O. Box 722, Pinedale, WY 82941

encl: General Permit for Small Wastewater Treatment Systems