Dave Freudenthal, Governor

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

NOTIFICATION OF COVERAGE

January 8, 2009

William, Thielemann, Manager
Fred-T-Mac, LLC
9 Northview Drive
Cody, WY 82414

RE: WDEQ Permit No. 09-001, Cody Cattle Company Treated Water Service

Dear Mr. Stein:

This project involves the construction of a 4" PVC water line, 192 ft in length from an existing 8" water main to serve domestic water and fire protection to a proposed commercial building locatedon Lot 9-A of the Old Trail Town Addition in Cody, WY, T52N, R102W.

The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. If you have any questions, please contact either myself or the NW District Engineer: James Brough at 307-332-3144.

Sincerely,

Tod Polson, P.E.
Environmental Engineer
Water Quality Division

xc: David R. Shultz, Sage Civil Engineering, 2824 Bighorn Ave. Cody WY 824144
IPS

encl: General Permits For an Public Water Supply System

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

January 26, 2009

Michael Flock
220 Main Street
P.O. Box 448
Lingle, WY 82223

RE: Town of Lingle -Sani-Swr Main Replacement Project,
Application No. **09-002**, Goshen County

Dear Michael Flock:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and or Existing Sewage Collection Systems described as removal of existing clay sewer main and manholes & replace with PVC main and new pre-cast manholes, Section 20 T25N R62W; Goshen County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by January 23, 2011. The flatter grade for sewer line is acceptable.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **09-002** in any future correspondence.

If you have any questions, please contact me at 307-777-7075.

Sincerely,

Richard R Cripe

Richard R. Cripe PE
Southeast District Engineer
Water Quality Division

RRC/rm/9-0050

Enclosure: Certificate of Completion
cc: IPS, Cheyenne
Erin Gates, Benchmark Engineers, 1920 Thomes Ave., Suite 620, Cheyenne, WY 82001

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

March 20, 2009

Don Berland
13394 East Control Tower Road
Englewood, CO 80112

RE: Rock Springs - The Preserve Apartments Phase I- Water and Sewer Main Extensions - Permit Number 09-003R, E ½, Section 28, T19N, R105W, Sweetwater County

Dear Mr. Berland:

The above application for coverage under General Permits to Construct the extension of a public water supply distribution system and the extension of a sewage collection system to serve 11 multi-family dwellings (184 units) a clubhouse and swimming pool in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the General Permits. These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at :
http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron

Mark Baron, P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Frederick W. Thaete, P.E., Manhard Consulting,345 Inverness Drive South, Suite A110 Englewood, CO 80112
Paul D. Kauchich, P.E., 212 D Street, Rock Springs, WY 82901
Vess Walker, 212 D Street, Rock Springs, WY 82901

The State
of Wyoming

Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

May 14, 2009

Brian and Ranae Todd
6 Double Tree Road
Rozet, WY 82727

RE: Return of Application for the Todd Residential Septic System, WDEQ #09-005
Campbell County

Dear Mr. and Mrs. Todd:

The Wyoming Department of Environmental Quality (DEQ) received an application on December 17, 2008, for a Permit to Construct a small wastewater system in Campbell County for the proposed Todd residential septic system. DEQ performed multiple reviews of the application and sent the last review to your engineer, Bruce Engineering, on February 27, 2009. On May 14, 2009, Bruce Engineering informed DEQ that the proposed septic system design will not be installed and that they are in the process of designing a mound system for your site.

Therefore, in accordance with Wyoming Department of Environmental Quality/Water Quality Rules and Regulations Chapter 3, Section 14 – Denial of a Permit or Coverage under a General Permit, DEQ is returning all of the application materials to you, as DEQ is unable to process your application without the required information.

You can resubmit the application at any time. It will be assigned a new DEQ tracking number and will be reviewed in accordance with Chapter 3 of the Wyoming Department of Environmental Quality/Water Quality Rules and Regulations.

If you have any questions, please contact me at (307) 473-3473 or spagor@wyo.gov

Sincerely,

Suzanne Pagorek

Suzanne Pagorek
WDEQ/WQD

Enclosures: application materials

cc: WDEQ File (w/o encl)
IPS (w/o encl)
Keith Bowar, Campbell County, 500 S. Gillette Ave, Ste 1500, Gillette, WY 82716 (w/o encl)
Steve Bruce, Bruce Engineering, P.O. Box 2284, Gillette, WY 82717 (w/encl)

The State
of Wyoming

Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

February 20, 2009

Thomas Brauer, P.E.
Roadrunner, LLC
6080 Enterprise Drive
Casper, WY 82609

RE: Roadrunner, LLC, 6" Fire Service Line, WDEQ #09-007, Natrona County

Dear Mr. Brauer:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. **Your attention is directed to the mandatory reporting requirements outlined in Part V. Section O. of the general permits:**

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley

Karen L. Farley, P.E.
Northeast District Supervisor
Water Quality Division

Enclosures: Chapter 12 - General Permit
Certificate of Completion

cc: Gloria Brainard, WWSD, P.O. Box 728, Mills, WY 82644
Barry Venn, P.E., 609 Consulting, LLC, 5830 East 2nd Street, Casper, WY 82609
WDEQ File
IPS (Cheyenne)

The State
of Wyoming

Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

August 14, 2009

Ronnie Hein
Cambria Water District
23447 Hwy 85
Newcastle, WY 82701

RE: Bridle Bit Road Water Pipeline, WDEQ #09-010, Weston County

Dear Mr. Hein:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage,

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley

Karen L. Farley, P.E.
WDEQ/WQD Northeast District Engineer

Enclosures: Certificate of Completion

cc: Ed Nowak, P.E., Camp Creek Engineering, 410 E. Grand Ave., Suite 205, Laramie, WY 82070
WDEQ File
IPS (Cheyenne)

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
"AS-BUILT" PERMIT TO CONSTRUCT

PERMIT NO. **09-011**

West Gas Draw Beta POD

This permit hereby authorizes the applicant:

Lance Oil and Gas Company Inc.
Attn.: Mr. Shane Gasvoda
1400 East Lincoln
Sheridan, WY 82801

to have installed two (2) compliance monitoring wells according to the procedures and conditions of the application number **09-011**. The facilities are proximal to coalbed methane produced water impoundments located in Township 54N, Range 74W, Sections 4 and 18 in the county of Campbell, in the State of Wyoming. All construction, installation, or modification allowed by this permit has been completed.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1 of 4 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality/Water Quality Division, Groundwater Section, 1866 South Sheridan Avenue, Sheridan, WY 82801, 307-673-9337, fax 307-672-2213, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 4 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality/Water Quality Division, Groundwater Section, 1866 South Sheridan Avenue, Sheridan, WY 82801, 307-673-9337, fax 307-672-2213 when discharge to each impoundment covered under this permit commences.

3 of 4 Monitoring Requirements:
Unless otherwise specified, monitoring and reporting of the groundwater beneath the impoundments shall be performed on a quarterly basis until further notice and shall include the following information:

- Measurement of static water elevation in monitoring wells: MW31-4 and MW23-18;
- Sampling and analysis of groundwater at down-gradient wells: MW31-4 and MW23-18;
- The parameters listed in the table below are required for groundwater compliance monitoring beneath the listed impoundments:

Pit 31-4-5474

Parameter	MW31-4 Background Value (mg/L) (6/27/2007)	Class III Water Quality Standards (mg/L)
Arsenic	ND	0.2
Selenium	ND	0.05
Sulfate	1940	3000
TDS	3110	5000
pH	7.9	6.5 – 8.5 (s.u)

23-18-5474

Parameter	MW23-18 Background Value (mg/L) (1/2/2009)	Class III Water Quality Standards (mg/L)
Arsenic	ND	0.2
Selenium	0.006	0.05
Sulfate	2570	3000
TDS	4060	5000
pH	7.4	6.5 – 8.5 (s.u)

- Reporting results of quarterly monitoring and sampling to the department by January 15th, April 15th, July 15th, and October 15th of each year. The first set of data will be due by April 15th, 2009;
- If the initial discharge into the impoundment has not occurred by the quarterly report date, a groundwater compliance sample is not required for that quarterly period. The operator shall notify the DEQ that discharge has not occurred;
- If a groundwater monitoring event reveals a pH measurement of 6.5 or less, the DEQ may require sampling and analysis of groundwater for the following additional parameters: aluminum, boron, cadmium, chromium, copper, lead and zinc.
- The analytical results for each sampling event, along with impoundment and monitor well location information must be submitted in the Excel spread sheet "Compliance Monitoring Data Reporting", which can be found on the WDEQ website at the following address: (http://deq.state.wy.us/wqd/groundwater/pollution.asp). These data shall be submitted electronically on the due dates established above to the following department address: DEQ-CBMGroundwater@WYO.GOV. In addition, the accompanying analytical laboratory reports and field documentation must also be submitted either electronically (pdf format) or hard copy via mail to the WDEQ, Sheridan office at the address listed above.

4 of 4 Any exceedence of the water quality standards listed above will be considered a violation of this permit. If an exceedence of groundwater standards occurs as a result of the operation of the impoundment, the WDEQ may require a more frequent monitoring schedule, further investigation of the groundwater impacts, remediation of the groundwater impacts, and cessation of discharge into the impoundment.

AUTHORIZED BY:

John F. Wagner
Administrator
Water Quality Division

John V. Corra
Director
Department of Environmental Quality

12/13/09
Date of Issuance

CBD/rm/9-0117

GROUNDWATER PROGRAM
REVIEW COMMENTS:
PLANS/SPECIFICATIONS/PROPOSALS/REPORTS

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
1866 South Sheridan Avenue
Sheridan, WY 82801
Phone: 307-672-6457

PERMIT TYPE: CBM: Groundwater Compliance Monitoring Program

WATER QUALITY DIVISION REFERENCE (PERMIT) NUMBER: 09-011

SITE (POD) NAME: West Gas Draw Beta POD

APPLICANT: Lance Oil and Gas Company Inc.,
an Anadarko Company
Attn: Mr. Shane Gasvoda
1400 East Lincoln
Gillette, WY 82716

CONSULTANT: WWC Engineering
Attn: Ben Schiffer
1849 Terra Ave.
Sheridan, Wyoming 82801

LOCATION: Drainage: Box Draw and Chicken Creek Draw, tributaries to Spotted Horse Creek, tributary to Powder River
County: Campbell
Township 54 North; Range 74 West

WYPDES No: Discharge Permit: N/A

DATE ON REPORT: December 29, 2008

REVIEWING OFFICIAL: Carrie Donnell, North District Geological Project Analyst

DATE OF THIS REVIEW: January 27, 2009

ACTION: Compliance Monitoring Plan authorized for Pit 31-4-5474 and Reservoir 23-18-5474 pursuant to conditions on permit # 09-011.

COMMENTS: GROUNDWATER SECTION

1.0 SITE SUMMARY:

1.1 Site Description.

Watershed Name: Box Draw and Chicken Creek Draw, tributaries to Spotted Horse Creek, tributary to Powder River

Groundwater Classification:

Class 1 (domestic) _____
Class 2 (agricultural) _____
Class 3 (livestock) ___2___

Basis for Classification: Laboratory analysis of groundwater indicates ambient water quality meets Water Quality Rules and Regulations Chapter 8 Class III standards and exceeds both Class I and Class II standards for Sulfate, Total Dissolved Solids (TDS) and Manganese (Table 1- Chapter 8).

Table 1. Basis for Ground Water Classification by Impoundment Name covered under Permit 09-011

Impoundment Name	Compliance Monitoring Well	Sulfate (mg/L)	TDS (mg/L)	Mn (mg/L)
Pit 31-4-5474	MW31-4	1940	3110	2.68
23-18-5474	MW23-18	2570	4060	1.42

Description of Hydrogeology:

Pit 31-4-5474

First groundwater occurs in sandstone that is bisected by a three foot thick claystone. The upper portion of the sandstone is not fully saturated. The water-bearing zone underlying the cited reservoir therefore exhibits unconfined conditions. Monitor well MW31-4 is determined to be appropriately located to monitor groundwater quality.

23-18-5474

First groundwater occurs in sandstone approximately 50.5 feet below ground surface. The water bearing zone exhibits unconfined conditions; monitoring well MW23-18 is appropriately located to monitor groundwater quality.

Table 2. Name of Impoundments covered under Permit 09-011

Impoundment Name	Capacity (acre/ft)	Qtr Qtr	Section	Town.	Range	Down gradient Monitoring Well
Pit 31-4-5474	41.5	NWNE	4	54N	74W	MW31-4
23-18-5474	14.9	NESW	18	54N	74W	MW23-18

No other domestic, agricultural or livestock wells are noted in the immediate area that will be impacted. No seeps or springs are noted in the immediate area.

2.0 MONITORING AND REPORTING REQUIREMENTS

Unless otherwise specified, monitoring and reporting of the groundwater beneath the impoundments shall be performed on a quarterly basis until further notice and shall include the following information:

- Measurement of static water elevation in monitoring wells: MW31-4 and MW23-18;
- Sampling and analysis of groundwater at down-gradient wells: MW31-4 and MW23-18;
- The parameters listed in the table below are required for groundwater compliance monitoring beneath the listed impoundments:

Pit 31-4-5474

Parameter	MW31-4 Background Value (mg/L) (6/27/2007)	Class III Water Quality Standards (mg/L)
Arsenic	ND	0.2
Selenium	ND	0.05
Sulfate	1940	3000
TDS	3110	5000
pH	7.9	6.5 – 8.5 (s.u)

23-18-5474

Parameter	MW23-18 Background Value (mg/L) (1/2/2009)	Class III Water Quality Standards (mg/L)
Selenium	0.006	0.05
Arsenic	ND	0.2
Sulfate	2570	3000
TDS	4060	5000
pH	7.4	6.5 – 8.5 (s.u)

- Reporting results of quarterly monitoring and sampling to the department by January 15th, April 15th, July 15th, and October 15th of each year. The first set of data will be due by April 15th, 2009;
- If the initial discharge into the impoundment has not occurred by the quarterly report date, a groundwater compliance sample is not required for that quarterly period. The operator shall notify the DEQ that discharge has not occurred;
- If a groundwater monitoring event reveals a pH measurement of 6.5 or less, the DEQ may require sampling and analysis of groundwater for the

following additional parameters: aluminum, boron, cadmium, chromium, copper, lead and zinc.

- The analytical results for each sampling event, along with impoundment and monitor well location information must be submitted in the Excel spread sheet "Compliance Monitoring Data Reporting", which can be found on the WDEQ website at the following address: (http://deq.state.wy.us/wqd/groundwater/pollution.asp). These data shall be submitted electronically on the due dates established above to the following department address: DEQ-CBMGroundwater@WYO.GOV. In addition, the accompanying analytical laboratory reports and field documentation must also be submitted electronically (pdf format) via email to the WDEQ, Sheridan office at the email address listed above.

END OF REVIEW

CBD/rm/9-0117

Dave Freudenthal, Governor

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

NOTIFICATION OF COVERAGE

January 21, 2009

Dossie Overfield
Northwest Rural Water District
PO Box 2347
Cody, WY 82414

RE: WDEQ Permit No. 09-012, NRWD - Schaller TW Extension - Sage Creek Service Area

Dear Mr. Overfield:

Project includes installation of approx. 885 lf of 2" wateline and 545 lf of 4" waterline along Hwy 120, South of Cody to serve two new service taps, located in the E1/2, NE1/4, Sec 8, T.52N, R.101W, Park County.

The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. If you have any questions, please contact either myself or the NW District Engineer: James Brough at 307-332-3144.

Sincerely,

Tod Polson, P.E.
Environmental Engineer
Water Quality Division

xc: Robert Overfield, Engineering Associates, PO Box 1900, Cody WY 82414
IPS

encl: General Permits For an Public Water Supply System

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

February 13, 2009

South Cheyenne Water and Sewer District
Dena Hansen, Manager
215 E. Allison Road
Cheyenne, WY 82009

RE: SCWSD – Sanitary Sewer Main Replacement 2009,
Application No. **09-013**, Laramie County

Dear Dena Hansen:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and or Existing Sewage Collection Systems described as replacement of deficient sanitary sewer mains, Section 8, T13N R 66W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by February 12, 2011.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **09-013** in any future correspondence.

If you have any questions, please contact me at 307-777-7075.

Sincerely,

Richard R. Cripe PE
Southeast District Engineer
Water Quality Division

RRC/rm/9-0116

Enclosure: Certificate of Completion
cc: IPS, Cheyenne
James Johnson, Johnson Engineering Assoc., 1527 Superior Ct., Laramie, WY 82072

The State
of Wyoming

Department of Environmental Quality

John Corra, Director

ave Freudenthal, Governor

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

January 30, 2009

Randy Crowley
19 Timber Meadows Drive
P.O. Box 1019
Moorcroft, WY 82721

RE: Crowley Small Residential Wastewater System, Crook County
Permit # 09-014

Dear Mr. Crowley:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

Additionally, the following permit condition applies:

1. Cleanouts are required every 100 feet and at all changes in direction 22.5 degrees and greater, both horizontal and vertical. This requirement includes both the pipeline from the house to the septic tank and from the septic tank to the leachfield.
2. Either a 6-inch diameter clean-out riser or a manway from each compartment of the septic tank must be extended to the ground surface from all septic tanks.
3. The septic tank and leachfield must meet the required setback distances from your water well and any neighbors water well. The septic tank must be 50 feet and the leachfield must be 100 feet from any water well.

Please be advised that Crook County inspects all small wastewater systems permitted through WDEQ. Please contact Crook County Growth and Development at 307.283.4548 to arrange an inspection of the system.

Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.

SW/NW

CRO cty: Sec 13 T50 R66

SOLID & HAZARDOUS WASTE DIVISION
(307) 473-3450
Fax: (307) 473-3458

AIR QUALITY DIVISION
(307) 473-3455
Fax: (307) 473-3458

WATER QUALITY DIVISION
(307) 473-3465
Fax: (307) 473-3458

If you have any questions, please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3473.

Sincerely,

Suzanne Pagorek

Suzanne Pagorek
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WYDEQ File
Tim Lyons, Crook County Growth and Development
Josh Franzen, JW Services, 519 State Highway 116, Sundance,, WY 82729

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

September 30, 2009

M.C. Schaff & Associates
Larry McCaslin, P.E.
818 South Beltline High.way East
Scottsbluff, NE 69361

RE: **Application Withdrawn Number: 09-016**
Action: Application Returned-Non Response
Facility: Torrington Golf Course Proposed Potable Water System
Location: Goshen County

Dear Mr. McCaslin:

As of today, WQD has not received any correspondence on this application since the review comments were sent out. Your application, number **09-016**, for a Torrington Golf Course Proposed Potable Water System, is considered inactive. It has been over 6 months since the Wyoming Department of Environmental Quality / Water Quality Division (WQD) sent out review comments done over the phone dated February 2, 2009 with the **Action: Not Authorized For Construction**. These review comments indicated that this application could not be permitted as proposed because the application package had numerous deficiencies or incomplete. It states in Chapter 3, Section 9(a)(ii) of Water Quality Rules and Regulations the following:

Incomplete applications will be processed in the following manner:

1) Additional information shall be requested in detail or the application may be returned to the applicant. Incomplete permit applications will result in permit denial;

2) If an application is denied because of incompleteness necessitating a request for additional information, the applicant shall have a maximum of six months to comply with the request. If the applicant fails to provide the requested information within that period, the entire incomplete application shall be returned;

This project **has not been permitted**. Construction of this facility without a permit is a violation of the Environmental Quality Act and is punishable with fines not to exceed $10,000 per day of violation. If you wish to reconsider construction of this facility, then the application process must be started over and the application procedures pursuant to Chapter 3 of the Wyoming Water Quality Rules and Regulations must be followed.

If you should have any questions, please contact Richard Cripe at either (307) 777-7075 or rcripe@wyo.gov. Please be reminded that the WQD could show up anytime in the future to verify that this facility was not constructed without a permit.

Sincerely,

Richard R Cripe

Richard R. Cripe PE
Southeast District Engineer
Water Quality Division

RRC/rm/9-0864

Enclosures: Application Package 09-016
Copy of review comments dated February 2, 2009

cc: IPS

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

January 30, 2009

Frontier Refining Inc.
Ross Smith, Senior Project Engineer
2700 East 5th Street
Cheyenne, WY 82007

RE: East Control Building – Sanitary Sewer Line Project,
Application No. **09-017**, Laramie County

Dear Ross Smith:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and or Existing Sewage Collection Systems described as Sanitary Sewer Line and New Manhole, NW ¼ of NW ¼, Section 4, T13N R 66W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by January 30, 2011.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **09-017** in any future correspondence.

If you have any questions, please contact me at 307-777-7075.

Sincerely,

Richard R. Cripe PE
Southeast District Engineer
Water Quality Division

RRC/rm/9-0073

Enclosure: Certificate of Completion
cc: IPS, Cheyenne
David Beehler, Jacobs Engineer Group, 1527 Cole Blvd. Building #2, Golden, CO 80401

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

X New
Renewal
Modified

PERMIT NO**09-018**
SPECIAL CONDITIONS

F.E. Warren Air Force Base Road Application of ROWPU Water

This permit hereby authorizes the applicant:

F.E. Warren Air Force Base
300 Vesle Drive, Bldg 316
F.E. Warren AFB, WY, 82005-2793

to conduct road application of brine water from reverse osmosis water purification units according to the procedures and conditions of the application number **09-018**. The facility is located in Sec. 22 T14N R67W in the county of Laramie, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by February 12, 2014.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the F. E. Warren AFB and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the F. E. Warren AFB.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The F. E. Warren AFB, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The F. E. Warren AFB shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the F. E. Warren AFB, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The F. E. Warren AFB shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the F. E. Warren AFB from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the F. E. Warren AFB, owner and operator shall comply with all of the following permit conditions:

1 of 3 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7075, FAX 307-777-7610, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 3 The applicant will maintain records in house as to the locations where the ROWPU Water is land applied for the life of this permit. DEQ doesn't need a copy of these records sent to them.

3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

John F. Wagner
Administrator
Water Quality Division

John V. Corra
Director
Department of Environmental Quality

2/13/09
Date of Issuance

RRC/rm/9-0113

cc: Robert Farwell, Deputy Base Civil Engineer
F.E. Warren Air Force Base
300 Vesle Dr., Bldg 316
F.E. Warren AFB, WY 82005-2793

STATEMENT OF BASIS

Permit Number: **09-018**

Application reviewed for compliance with the following applicable regulations :

Chapter(s) 11 of the Wyoming Water Quality Rules and Regulations

Does the permit comply with all applicable regulations identified above?

Yes

Road application of acceptable wastes are protective of the groundwater.

A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.

Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Richard R. Cripe PE, Southeast District Engineer, rcripe@wyo.gov and completed on February 12, 2009. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

March 4, 2009

Tortilla Factory
Genaro Tapia, Owner
2702 S. Greeley Highway
Cheyenne, WY 82007

RE: Tortilla Factory- Water and Sewer,
Application No. **09-021**, Laramie County

Dear Mr. Tapia :

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and or Existing Sewage Collection Systems described as installation of approximately 231 ft 8 inch PVC water main, one new fire hydrant, one 1 ½ inch service with backflow prevention, one 6 inch fire sprinkler line, 180 ft 8 inch PVC SDR-35 sanitary sewer main and two 4 ft manholes, Section 8, T13N R 66W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by March 4, 2011.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **09-021** in any future correspondence.

If you have any questions, please contact me at 307-777-7075.

Sincerely,

Richard R Cripe

Richard R. Cripe PE
Southeast District Engineer
Water Quality Division

RRC/rm/9-0170

Enclosure: Certificate of Completion
cc: IPS, Cheyenne
Kelly W. Hafner, BenchMark Engineers, 1920 Thomes Ave., Suite 620, Cheyenne, WY 82001

The State
of Wyoming

Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

January 21, 2009

Tyler Baltz
UTRAN, LLC
131 Buffalo Creek Road
Upton, WY 82730

RE: UTRAN, LLC Wastewater Holding Tank for Shop Wastewater, WDEQ # 09-022

Dear Mr. Baltz:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

If you have any questions please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3473. Thank you.

Sincerely,

Suzanne Pagorek

Suzanne Pagorek
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
Clifford Root, UTRAN, LLC, 642 S. Federal Blvd., Riverton, WY 82501
Todd A. Noblin, Three T's Plumbing, 103 N. Heptner Rd., Rozet, WY 82727

WES CTY

The State
of Wyoming

Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

August 18, 2009

Michelle Belknap
1621 Terra Avenue
Sheridan, WY 82801

RE: Easter Seals Apartment Building Project, WDEQ #09-023, Natrona County

Dear Ms. Belknap:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage,

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley

Karen L. Farley, P.E.
WDEQ/WQD Northeast District Engineer

Enclosures: Certificate of Completion

cc: Megan L. Crow, P.E., MC2 Engineering, P.C., 1101 Sugarview Dr., Suite 201, Sheridan, WY 82801
Chris Knodel, City of Sheridan
WDEQ File
IPS (Cheyenne)

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT
PWS WY5601115

PERMIT NO. 09-024

Lovell Southwest Sewer and Water System Upgrade

This permit hereby authorizes the applicant:

Bruce Morrison, Mayor
Town of Lovell
P.O. Box 188
Lovell, WY 82431

to replace and construct 12,030 linear feet of water distribution main, 27,490 linear feet of transmission main, 21,090 linear feet of sanitary sewer main, and 45 sanitary sewer manholes; according to the procedures and conditions of the application number 09-024. The facility is located in the town of Lovell, within the Northwest ¼ of the Southwest ½ of Section 14, T56N,R96W in the county of Big Horn, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by November 1, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not

relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Northwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144,FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

John F. Wagner
Administrator
Water Quality Division

John V. Corra
Director
Department of Environmental Quality

2/19/09
Date of Issuance

HES/rm/9-0121

STATEMENT OF BASIS

1. Permit Number: 09-024

2. Application reviewed for compliance with the following regulations:

   Chapters 3, 11 and 12 of the Wyoming Water Quality Rules and Regulations.

3. Does the permit comply with all applicable regulations identified above?

   No.

   A variance was requested from Chapter 11, Section 9 (c)(i)(C) which requires a minimum slope of 0.004 ft/ft for 8-inch pipe. A variance from this regulation is granted based upon Policy 13.9.13. The construction of the proposed pipe will be installed at a 0.003 ft/ft slope. The construction of the proposed sewer line will satisfy Policy 13.9.13 by the following provisions:

   1. Pipe constructed of either ASTM D3034 SDR 35 PVC pipe or epoxy lined ductile iron pipe (both will result in flowing full velocity greater than 2 feet per second,
   2. The sewer grade will be established by a laser,
   3. The pipe will be bedded with Type 1 bedding material using Type A Trench Backfill methods or cement treated fill,
   4. The sewer line will be constructed under full time inspection,
   5. The Town has sent a letter stating their acceptance of the design.

   In the event that the water valves located at the intersection of Ninth St. and Shoshone Ave are less than 10 horizontal feet away from the sanitary sewer manhole, the sanitary sewer manhole shall be flowfilled to a thickness not less than eighteen (18) inches to provide additional support to all pipe penetration seals.

4. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.

   Sewerage systems are exempted from review by Chapter 3, Section 17.
   Public water supplies are exempted from review by Chapter 3, Section 17.

5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Hannes E. Stueckler, P.E., Assistant Northwest District Engineer hstuec@wyo.gov, and completed on February 9, 2009. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."

cc: Steve Gerber, Dowl HKM, 906 Main St., Lander, WY 82520

Dave Freudenthal, Governor

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

February 18, 2009

Tim French, Chair
Park County Commission
1002 Sheridan Ave.
Cody, WY 82414

RE: Powell Country Club Estates Subdivision, Park Coutny, WDEQ Application #09-025

Dear Mr. French:

The Wyoming Department of Environmental Quality (WDEQ) has completed the review of the above referenced subdivision pursuant to W.S. 18-5-306. This letter constitutes our conclusions regarding the feasibility of the proposed water and sewage systems pursuant to the W.S. 18-5-306 (c).

Summary of Proposed Subdivision

The project is located in the NE ¼ NE ¼, Section 32, T.56N., R.98W. and is about 2 miles northwest of Garland. The proposal lists 14 total lots on a 14.43 acre tract. The lots will range in size from 1.0 to 1.16 acres. Individual onsite septic systems are proposed for all fourteen lots. Powell Country Club Estates Subdivision proposes to connect to an existing public water supply, the Northwest Rural water system.

Findings As To The Safety And Adequacy Of The Proposed Sewage System

The consultant performed the requisite nitrate and travel-time calculations. The down-gradient nitrate concentration is projected to be less than the 10.0 mg/L maximum. The minimum isolation distance analysis model suggests a horizontal separation distance of at least 120 feet. Therefore a plat notation clearly stating a 120-feet building set back distance between septic systems and all property lines is recommended.

Two site limitations were identified: 1) high seasonal groundwater and 2) shallow bedrock. The consultant proffered perimeter drains (or 'French drains') as a mitigation strategy. In the event that "French drains' are implemented they must be installed in compliance with isolation distances as outlined in Chapter 11, part D, Section 35, Table 2 guidelines. In regard to these site limitations a plat notation should clearly identify the potential for encountering the shallow (or high) groundwater and/or shallow impermeable layers may require special engineered septic systems (e.g., mounded, pressurized systems).

Since Park County has been delegated by the department to issue small wastewater system permits, it is the county's responsibility to ensure, prior to issuing the permits, that all permit requirements and design standards will be met. If an engineered septic system facility is used, WDEQ must be involved in the small wastewater permit approval process by reviewing the design and providing comments to the Park County small wastewater system administrator.

Findings As To The Safety And Adequacy Of The Proposed Water System

The proposed subdivision has been reviewed by the Northwest Rural Water District with the conclusion that they have adequate capacity to serve the subdivision.

Conclusion(s):

WDEQ has "no adverse" recommendations on this proposed subdivision. DEQ recommends that the following two notations be added the plat: 1) a 120-feet building set back distance between septic systems and all property lines is recommended, and 2) the potential for encountering the shallow (or high) groundwater and/or shallow impermeable layers may require special engineered septic systems (e.g., mounded, pressurized systems).

Disclaimer

Nothing in WDEQ's recommendations or comments regarding the subdivider's proposal shall be construed to relieve the subdivider of their obligation to obtain any permits or additional approval from any local state or federal agencies/entities as required by law, rules and regulations, or ordinance. Nothing in these recommendations commits the WDEQ or the delegated county to the issuance of required permits for construction, operation, or modification of water supply and/or wastewater systems. It is the duty of the subdivider/developer to comply with all applicable federal, state and local requirements.

Please feel free to contact either Jim O'Connor at 307-335-6942 or James Brough at 307-335-6961 if you have any questions.

Sincerely,

James Brough

James Brough, P.E.
Northwest District Engineer
Water Quality Division

Jim O'Connor

Jim O'Connor, P.G.
Geological Project Analyst
Water Quality Division

cc: Will Ambrose III, 819 Road 8 ½
Julie Miller, Engineering Associates, 130 N. Bent St., Powell, WY 82435
Gene Smith, Park County Planner, 1002 Sheridan Ave., Cody, WY 82414
Mike Ebsen, State Engineer's Office, Herschler Building, 4-E, Cheyenne, WY 82002
DEQ Subdivision File; w/ enclosure
FPS

F:\DIVISION\WQD\W&WW Section\NW Subdivision Reviews\Park\Powell Country Club Estates\09-025 Powell Country Club Estates.doc

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 09-026R

Rock Springs - 2008 Miscellaneous Sewer Rehabilitation Project

This permit hereby authorizes the applicant:

City of Rock Springs
Paul D. Kauchich, P.E.
212 D Street
Rock Springs, WY 82901

to construct about 1333 feet of 8-inch and 236 feet 12-inch PVC water main, a Sewage Lift Station, 438 feet of 4-inch sewage force main, 1324 feet of 8-inch PVC sewer, 510 feet of 10-inch PVC sewer main, 529 feet of 12-inch PVC sewer main, 710 feet of 18-inch PVC sewer main, 2896 feet of 24-inch PVC sewer main, according to the procedures and conditions of the application number **09-026R**. The facility is located at four different locations within the City of Rock Springs at Foothill Blvd. and Dewar in Section 33,T19N,R105W, Plaza Mall, Section 34, T 19N, R105W, McCarty Crossing, Section 35, T19N, R105W, and at Flying "J" Section 23, T19, R105W in the county of Sweetwater, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by March 24, 2010.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer,510 Meadow View Drive, Lander, WY 82520, 307-332-3144,FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.

a. Date that construction of the facility was completed; and
b. Date that the facility was placed in operation; and
c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

John F. Wagner
Administrator
Water Quality Division

John V. Corra
Director
Department of Environmental Quality

3/26/09
Date of Issuance

MDB/rm/9-0245

STATEMENT OF BASIS

1. Permit Number: 09-026R

2. Application reviewed for compliance with the following regulations:

   Chapters 3, 11 and 12 of the Wyoming Water Quality Rules and Regulations.

3. Does the permit comply with all applicable regulations identified above?

   Yes.

4. If a Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.

   Not Required.

5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Mark D. Baron, P.E., mbaron@state.wy.us, Southwest District Engineer and completed on March 24, 2009. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

cc: Shawn M. Arnoldi, P.E., Choice Engineering Services, Inc., 404 N. Street, Suite 201, Rock Springs, WY 82901

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

March 9, 2009

Paul Kauchich, Director of Engineering
City of Rock Springs
212 "D" Street
Rock Springs, WY 82901

RE: City of Rock Springs - Grant Street Extension Number 09-027R, SW1/4 Sec 26&35 T19N R105W, Sweetwater County

Dear Mr. Kauchich:

The above application for coverage under General Permits to Construct an extension to a public water service distribution system consisting of 1100 linear feet of 12 inch PVC to include a 120 foot ductile iron heated and insulated bridge crossing, and a sewer distribution extension of 1700 linear feet of 8, 12, and 18-inch PVC pipe with similar ductile iron bridge crossing to be constructed in accordance with Chapter 3, Section 7, Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the General Permits. These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at:

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Perry Roberson
Consulting Engineer
Water Quality Division

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
C. Robert Gerrard, JFC Engineers & Surveyors 1515 Ninth Street, Rock Springs, WY 82901

Dave Freudenthal, Governor

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

NOTIFICATION OF COVERAGE

February 18, 2009

Sean Christian, PE
City of Powell
PO Box 1008
Powell, WY 82414

RE: WDEQ Permit No. 09-028, City of Powell - Panther Boulevard Water Line Project

Dear Mr. Christian:

Project includes installation of approx. 4350 lf of 12" and 400 if of 8" ductile iron water line with fittings and hydrants, along Panther Boulevard, City of Powell, Park County.

The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. If you have any questions, please contact either myself or the NW District Engineer: James Brough at 307-332-3144.

Sincerely,

Tod Polson, P.E.
Environmental Engineer
Water Quality Division

xc: David R. Shultz, Sage Civil Engineering, 2824 Big Horn Avenue, Cody WY 82414
IPS

encl: General Permits For an Public Water Supply System

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

February 17, 2009

Jerry U. Gale
P.O. Box 1193
Rawlins, Wyoming 82301

RE: Gale Septic System #1,
Location: NW¼, Section 13, T21N, R88W,

Application No. **09-030**
Carbon County

Dear Mr. Gale:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a **3 bedroom mobile home** in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the septic tank** must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on February 17, 2011. Please reference Application Number **09-030** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald

Ronald L. Ewald
Consulting Engineer
Southeast District, Water Quality Division

RLE/rm/9-0124

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Kristy Rowan, Administration - Carbon County Planning & Development Office,
Carbon Building, 215 West Buffalo Street, Suite 336, Rawlins, WY 82301

NOTIFICATION OF COVERAGE

January 23, 2009

Ken Muller
Sheridan County
224 South Main Street, Suite B8E
Sheridan, WY 82801

RE: Sheridan County Roads, Brine Application Pilot Project, Permit No. 09-031

Dear Mr. Muller:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Pilot Project in accordance with Section 5, Chapter 11, of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit.

The following items need to be submitted to WDEQ/WQD CBM Group:

a. Date that the road application was completed; and

b. Certification the road application was done in accordance with the terms and conditions of the permit; or

   Certification the road application was completed with changes or modifications. Submit the information necessary to clearly indicate the road application as actually performed. This information shall include a contour map depicting only those sections of road where produced CBM water was used in the construction.

c. Only brine water generated by an EMIT water treatment plant shall be used for this project.

d. Use of brine water shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs. No brine water will be allowed to run off project roads.

e. Only the roads designated in this permit are authorized for application of the brine water. Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.

f. A report documenting the results of the application shall be submitted to WQD within 30 days after completion of the project. The report shall contain photographs documenting the results.

Please notify WDEQ at least one week prior to applying brine water to roads. If you have any questions, please contact Kim Medina at 152 North Durbin, Casper, WY, 82601, (307) 473-3476 or kmedin@state.wy.us . Thank you.

Sincerely,

Kim J. Medina
Geological Project Analyst
DEQ/WQD

cc: IPS Cheyenne
John Sturtz, Sheridan County Road and Bridge Superintendant, 48 Short Road, Sheridan, WY 82801

Dave Freudenthal, Governor

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

NOTIFICATION OF COVERAGE

April 14, 2009

Jon Abrams, Superintendent
Lincoln County School District #2
P.O. Box 219
Afton, WY 83110

RE: Afton - Afton Elementary School - Water and Sewer Extension - Permit Number 09-032R, NW ¼, Section 30, T32N, R118W, Lincoln County

Dear Mr. Abrams:

The above application for coverage under General Permits to Construct a public water system distribution system extension consisting of about 1892 feet of 8-inch PVC water main and a sewage collection system extension consisting of about 228 feet of 6-inch PVC sewer main in accordance with Chapter 3, Section 7 and Chapter 11, Section 9 and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the General Permit. These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at :
http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron

Mark Baron, P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Evan J. Simpson, P.E., Sunrise Engineering, P.O. Box 609, Afton, WY 83110

The State
of Wyoming

Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

April 16, 2009

Kevin Christopherson
K&V Rentals
P.O. Box 880
Casper, WY 82602

RE: K&V Rentals Small Commercial Wastewater System, Campbell County, SE
Permit # 09-033 Sec 24, T49, R72

Dear Mr. Christopherson:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit.

Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.

If you have any questions, please contact me at 152 North Durbin Street, Suite 100, Casper, WY, 82601, or at (307) 473-3473. Thank you.

Sincerely,

Karen L. Farley

Karen L. Farley, P.E.
Northeast District Engineer
WDEQ/WQD

Enclosures: General Permit
Certificate of Completion

cc: IPS, Cheyenne
WYDEQ File
Keith Bowar, Campbell County Planning, 500 South Gillette Ave., Suite 1500, Gillette, WY 82716
Bret Wolz, P.E., Falcon Consulting Services, LLC, P.O Box 3943, Gillette, WY 82717

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 09-035 REFERENCE PERMIT NO. 08-202

CHEYENNE-BOPU-2008 WELL REHAB, Phase 2 - BELL 6-R AND STATE 1-R
PWS WY5600011

This permit hereby authorizes the applicant:

CITY OF CHEYENNE BOPU
2100 PIONEER AVE
CHEYENNE, WY 82001

to construct, install or modify a 60 hp pump,15 hp pump, VFD's, well housing and water lines according to the procedures and conditions of the application number 09-035. The facility is located in NW/SW1/4 Section 18 T14N R67W and NW/SE1/4 Section 28 T15N R69W; Laramie County, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed February 23, 2011.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7075, FAX 307-777-7610, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

John F. Wagner
Administrator
Water Quality Division

John V. Corra
Director
Department of Environmental Quality

Date of Issuance 2-26-09

RRC/rm/9-0142

STATEMENT OF BASIS

1. Permit Number: **09-035**

2. This application was reviewed for compliance with the applicable regulations ;

   Chapters 3, 12

3. Does the permit comply with all applicable regulations identified above?

   Yes

4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.

   Public water supplies are exempted from review by Chapter 3, Section 17.

5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Richard Cripe P.E., Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on February 23, 2009. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

The State
of Wyoming

Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

April 10, 2009

Robert Sieveke
Mayor, Town of Pine Haven
24 Waters Drive
Pine Haven, WY 82721

RE: Town of Pine Haven, Lakeview Estates Sewer Project, Phase I
WDEQ #09-037

Dear Mr. Sieveke:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Sewage Collection Systems in accordance with Chapter 3 and Chapter 11 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. **Your attention is directed to the mandatory reporting requirements outlined in Part V. Section O. of the general permits.**

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley

Karen L. Farley, P.E.
Northeast District Supervisor
Water Quality Division

Enclosures: General Permits
Certificate of Completion

cc: E.D. Stetson, P.E., Stetson Engineering, Inc., P.O. Box 457, Gillette, WY 82717
WDEQ File
IPS (Cheyenne)

Fre CTY: Sec 5 T 50 R 66 SW

Dave Freudenthal, Governor

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

NOTIFICATION OF COVERAGE

January 30, 2009

Kreg Lombard, Mayor
City of Worland
P.O. Box 226
Worland, WY 82401

RE: New 18" Sanitary Sewer, 8" Sanitary Sewer extension, Permit Number: 09-038, SE ¼, NE ¼, SW ¼, NW ¼, Sec. 19 & SW ¼ Sec. 20, T. 47 N., R. 92 W., Washakie County

Dear Mayor Lombard:

This project involves the construction of a new 7,367 foot 18" sanitary sewer outfall line on County Road No. 11 and then west to connect with the existing sewer outfall line. Additionally, the lift station for the Hillcrest Subdivision will be removed and the 8" sewer line extended to connect to the new 18" main. The above application for coverage under General Permit has been reviewed in accordance with Chapter 11, Part B of the Wyoming Water Quality Rules and Regulations is hereby approved.

You are authorized to construct the facility in accordance with the general permit and the materials submitted in your application package. If you have any questions, please contact me at (307) 335-6964 or James Brough at 307-335-6961.

Sincerely,

Hannes E. Stueckler, P.E.
Assistant Northwest District Engineer
Water Quality Division

James Brough

James Brough, P.E.
Northwest District Engineer
Water Quality Division

xc: David W. Anderson, P.E., Donnell & Allred, Inc., P.O. Box 638, Worland, WY 82401

JPS

encl: General Permit For a Sewage Collection System

Dave Freudenthal, Governor

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

NOTIFICATION OF COVERAGE

February 25, 2009

Edwin Higbie
1002 Sheridan Ave.
Cody, WY 82414

RE: Construction of sewer collection and treated water mains for the Trailhead subdivision, Phases 4&5, DEQ Permit #09-039, N 1/2, SW 1/4 Tract 39 Resurvey, Section 28, R101W, T53N, Park County

Dear Mr. Higbie:

This project involves the construction of a potable water distribution system and sanitary sewer system for the Trailhead subdivision. The subdivision is located on between Cooper Lane and Robert Street in Cody, Wyoming, as indicated in the attached plan drawings. The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; Chapter 11, Section 9; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact Hannes Stueckler at 307-335-6964 or James Brough at 307-335-6961.

Sincerely,

Hannes E. Stueckler
Assistant Northwest District Engineer
Water Quality Division

James Brough, P.E.
Northwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
James Evans, P.E., Sage Civil Engineering, 2824 Big Horn Ave., Cody, WY 82414

encl: General Permits for a Public Water System and for an Existing Sewer Collection System

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

February 4, 2009

Cheyenne Board of Public Utilities
Attn: Herman Noe, Engineering Manager
Box 1469
Cheyenne, Wyoming 82003

RE: Days Inn Redevelopment Project – Fire Hydrant & Line, Application No. **09-040**
Location: NW¼ SW¼, Section 1, T13N, R66W, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific conditions also apply:

1. Additions to Wyoming Public Works Standard Specifications for Waterline Construction:

   a. Section 2665 E.6 - Water tight plugs shall be maintained in all pipe openings in a trench any time pipe laying is not in progress or the trench is unattended.

   b. Section 2675 D - Flushing shall achieve minimum velocities of at least 5 feet per second for pipelines 12 inches in diameter or less. Flushing shall be through flush valves and a discharge pipe to the surface. Fire hydrants shall not flushed until after the water main or distribution line is flushed.

The approval granted under this Notification Of Coverage and the General Permit shall expire on February 4, 2011. Please reference Application Number **09-040** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald

Ronald L. Ewald
Consulting Engineer
Southeast District, Water Quality Division

RLE/rm/9-0090

Enclosures: GENERAL PERMIT - Extensions/Modifications of Existing Public Water Supply Distribution Systems
Certificate of Completion Form

cc: IPS, Cheyenne
Russell Dahlgren, Dahlgren Consulting, Inc., 914 East 23rd Street, Cheyenne, Wyoming 82001

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

March 24, 2009

Ken Battson
P.O. Box 310
Baggs, Wyoming 82321

RE: Lariat Restaurant Septic System, Application No. **09-042**
Location: SE¼, Section 32, T13N, R91W, Carbon County

Dear Mr. Battson:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a **36 seat Breakfast/Lunch Restaurant and Kitchen** in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the reporting requirements* contained in the attached "CERTIFICATION of COMPLETION" form. Additionally, the following project specific conditions also apply:

1. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the septic tank** must be extended to the ground surface.

2. Grease Interceptor Tank – Inlet & Outlet Requirements - the inlet and outlet of the concrete grease interceptor tank **shall include interior PVC baffles** consisting of a "Tee" fitting with a short upward vertical leg open to the air space in the tank and a downward vertical leg extending into the liquid. The **inlet downward leg shall extend down approximately 1/3 of the depth of the liquid**, and the **outlet downward leg shall extend down approximately 2/3's of the depth of the liquid**.

The approval granted under this Notification Of Coverage and the General Permit shall expire on March 23, 2011. Please reference Application Number **09-042** in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,

Ronald L. Ewald

Ronald L. Ewald
Consulting Engineer
Southeast District, Water Quality Division

* to see the entire "General Permit" for Small Wastewater Facilities go to the DEQ Home page at: http://deq.state.wy.us/ and ***click on*** Water Quality on the
- left side of the page, and then under WQD PROGRAMS,
- ***Click on*** the Water & Wastewater Program bullet, and then
- under Engineering & Technical Services scroll down to
- General Permits, and ***click on*** Small Wastewater Systems.

OR – Go directly to:

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp , and under Item #1. Small wastewater facilities, ***click on*** the "LINK TO PDF".

RLE/rm/9-0241

Enclosures: Certificate of Completion

cc: IPS, Cheyenne
Erin M. Gates, BenchMark Engineers, P.C., 1920 Thomes Avenue, Suite 620, Cheyenne, Wyoming 82001
Kristy Rowan, Carbon County Planning Director, Carbon Building, 215 West Buffalo Street, Suite 336, Rawlins, Wyoming 82301

REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

Herschler Bldg., 4 West
Cheyenne, Wyoming 82002

PROJECT: Lariat Quickstop Restaurant Septic System - Baggs

LOCATION: SE¼ SE¼, Section 32, T13N, R91W, **Carbon County**

ENGINEER: John L. Jolly III: ***Wyoming PE License Pending***
C&J Technical Solutions and Services, Inc.
4000 Valley Blvd., Suite 103
Walnut, California 91789
Ph: (909) 598-6067

APPLICANT: Ken Battson
Box 310
Baggs, Wyoming 82321
Ph: (307) 383-7700

WATER QUALITY DIVISION REFERENCE #: 09-042

REVIEWING ENGINEER: Ronald L. Ewald
Phone: (307) 777-6183

DATE OF REVIEW: February 12, 2009

Professional Engineer (Civil) RONALD L. EWALD 6279 WYOMING
Ronald L. Ewald
02-12-2009
Date

ACTION: **NOT AUTHORIZED FOR CONSTRUCTION**. In accordance with Section 14 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 9. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. Septic System design Loading Rates - it is not clear how much effluent (and what type of effluent) is going into the new septic tank from which different parts of the facility, such as the new restaurant, grease trap, hotel, store/gas station area, and/or whatever else.

- Next, how the effluent load values are calculated is inconsistent. On one handwritten note sheet 160 meals per day at 6 gal/meal for a total of 960gpd from the new restaurant is calculated and used. The value of 6 gal/meal is for kitchen wastes only. However, the appropriate design value is 13 gal/meal for restaurants with toilets and kitchen wastes. There is even a highlighted note on the page right below the 6 gal/meal calculation which says "***MUST USE 13 gal/meal, Chapter 11, Ron Ewald, WYDEQ***". Using 13 gallons yields a design flow of 2080gpd for just the new restaurant. Then, in another location the design flow for the restaurant is implied to be 936gpd by reverse calculating from 1800 square feet at the top of worksheet page 5. What is the design flow for the new restaurant?

- Also, how much wastewater loading is coming from the old hotel and store in gallons per day(gpd), not fixture counts. DEQ does not use fixture counts to determine wastewater flows. DEQ uses Table 1 from Chapter 11 which includes design flows like # of meals, # of employees, # of vehicles served, and for hotels - # of beds. And lastly, are any of these flows being separated into grey water, black water, or grease flows and directed to different locations. This is also unclear.

2. Septic Tank Size - the proposed septic tank size is 2500 gallons. This size will provide 36 hours of detention time for a total design flow of 1667gpd. Considering item #1 above the total design flows going into the new septic tank from the old building and hotel, new restaurant could be 2080gpd plus maybe 548gpd° from the old building, for a total of 2628gpd. A design flow of 2628gpd would require a total septic tank volume of 3942 gallons.

   ° Note – 548gpd design flow for the old building was pulled from the report, but it is not clear if this is the correct value to be used.

3. Existing Septic System Location - the location of the current existing septic tank and existing leachfield should be indicated on the site plan to avoid overlap of the new leachfield. If possible, the size(gallons) of the existing septic tank and the dimensions(length x width in feet) of the existing leachfield should also be provided.

4. Alternative Design for New Septic System for New Restaurant Only - an alternate proposal to install and construct a smaller septic tank and leachfield just for the wastewater flows from the new restaurant only has been proposed. This proposal has a glaring problem in that this proposed leachfield appears to be almost entirely off of the property. According to the property descriptions originally submitted, this leachfield is located north of the north property line of the 1.43 acre Parcel 1.

   - Next, the 300 feet of Quick4 Infiltrator trench proposed for this leachfield calculates to an equivalent area of 1954sq ft. At a percolation rate of 15mpi, this leachfield will only support a design effluent load of 1016gpd, which when compared to the uncertainty identified in item #1 above is probably much too small.

5. Worksheets Incomplete and Inconsistent - the worksheets provided with the application package were sometimes partially used to list information, but then not used to complete the calculations that were dependant on that information. Mixed in with the partially completed worksheets were hand written note sheets which seem to pull different information out of the air and then proceed with confusing calculations. This jumping back and forth from the worksheets to the personalized note sheets has introduced much inconsistency, errors, and noncompliance with the WQD minimum standards and regulations. Only some of these inconsistencies have been noted in items #1, 2, and 4 above. The flow paths of the waste from the sources through the system must be identified. Calculations must be based on appropriate and accurate information and carried straight through with consistency from the percolation test to the number of chambers required. And lastly, many of the hand written sheets are very hard to read because the copies came out so dark that the background and the writing blend together.

6. All In One Septic Systems and Plumbing Service - what are All In One's qualifications? This reviewer is not familiar with this company. From the look of the application package they have not been very helpful.

7. Wyoming Licensed Professional Engineer(PE) Required - a licensed Wyoming PE is required to stamp, sign, and seal this application and plans. The listed engineer, Mr. John L. Jolly III, is not a Wyoming PE, but his licensed is currently pending. On January 22, 2009 there was a phone conversation between Mr. Ron Ewald of DEQ and Mr. Jolly. At this time Mr. Jolly indicated he had been hired to be the engineer for this project but that he did not have his Wyoming License yet. Mr. Jolly also indicated that he was in the process of getting his Wyoming license and thought he would have it very soon and he asked if he could go ahead with working on the plans for this application. Mr. Jolly was very clearly told by Mr. Ewald that this decision was between him and his client, and if he thought he would have his Wyoming PE License before DEQ had reviewed it and was ready to approve it, he could complete the application and send it in with the condition that DEQ could not approve it until he got his license and stamped and sealed the plans, even if they were approvable. If this was a risk that he and his client were willing to take then it was up to them.

   As of this date Mr. Jolly has not produced any evidence to the DEQ that he has obtained his Wyoming PE License yet. Nor has he sent in replacement plans with his stamp and seal on them or showed up in person to stamp and seal the plans that DEQ has. Therefore, when the revised plans, worksheets, note sheets, and so on are submitted in response to this review, it must all be stamped, sealed and signed by a Wyoming PE, be it Mr. Jolly or someone else.

RLE/rm/9-0114

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

February 27, 2009

Jeff Pecenka
Cheyenne Board of Public Utilities
P.O. Box 1469
Cheyenne WY 82003

RE: 2009 Sewer Rehabilitation Projects,
Application No. **09-043**, Laramie County

Dear Mr. Pecenka:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and or Existing Sewage Collection Systems described as Sewer Rehabilitation for City of Cheyenne. This project also includes manhole additions, manhole rehabilitation, sewer main lining and point repairs, SW ¼ NE ¼ Section 36,T14N, R67W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by February 27, 2011.

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Please reference Application No. **09-043** in any future correspondence.

If you have any questions, please contact me at 307-777-7075.

Sincerely,

Richard R. Cripe

Richard R. Cripe PE
Southeast District Engineer
Water Quality Division

RRC/rm/9-0158

cc: IPS, Cheyenne
Jeff Pecenka, BOPU, P.O. Box 1469, Cheyenne, WY 82001

Dave Freudenthal, Governor

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

John Corra, Director

NOTIFICATION OF COVERAGE

July 10, 2009

John Alm
P.O. Box 10
Hyattville, WY 82428

RE: Phase 1 of the Paint Rock Crossing Subdivision AKA Blue Hills. DEQ Permit #09-044, Big Horn County,E1/2 E1/2, Section 1, T49N, R90W; and Lots 5 & SE1/4, Sect 6, T49N, R90W

Dear Mr. Alm,

This project consists the extension of approximately 1133 linear feet of 6-inch treated water main from the town of Hyattville.

The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7, and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at:

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact Hannes Stueckler at 307-335-6964 or James Brough at 307-335-6961.

Sincerely,

Hannes E. Stueckler
Assistant Northwest District Engineer
Water Quality Division

James Brough

James Brough, P.E.
Northwest District Engineer
Water Quality Division

xc: PDF to Cheyenne
Gregory R. Meinecke P.E., Meinecke Engineering Consulting and Land Development, LLC, Cody, WY 82414

The State
of Wyoming

Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

NOTIFICATION OF COVERAGE

February 5, 2009

City of Casper
Jim Evans, P.E.
200 North David Street
Casper, WY 82601

RE: City of Casper – C&D Drop-Off Waterline Reroute, WDEQ #09-045, Natrona County

Dear Mr. Evans:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V. Section O. of the general permits.

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley

Karen L. Farley, P.E.
Northeast District Supervisor
Water Quality Division

Enclosures: General Permits
Certificate of Completion

cc: Steve Moldt, P.E, Inberg-Miller Engineers, 1120 East "C" Street, Casper, WY 82601
WDEQ File
IPS (Cheyenne)

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

March 5, 2009

Mark Johnson, Super Center Manager
IPS
P.O. Box 159
Rock Springs, WY 82901

RE: IPS - Permit Number 09-046R, SW, NW&N1/2, N1/2SW1/4 Sec 2 T19N R105W, Sweetwater County

Dear Mr. Johnson:

The above application for coverage under General Permits to Construct an extension to a public water service distribution system consisting of 240 linear feet of 8 inch PVC, and meter vault located within one mile of the Rock Springs incorporated limits to serve the IPS facility in Sweetwater County in accordance with Chapter 3, Section 7, Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct the facilities in accordance with the General Permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the General Permits. These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services.

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Perry Roberson
Consulting Engineer
Water Quality Division

Mark Baron P.E.
Southwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Shawn M. Arnoldi, Choice Engineering Services, Inc., 404 N. Street, Rock Springs, WY 82901
Paul Kauchich, P.E, City of Rock Springs, 212 "D" St. Rock Springs, WY 82901

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT
PWS #5600036

PERMIT NO. **09-047** REFERENCE PERMIT NO. N/A

Town of Mills 2009 Water Tank Rehabilitation
(2.5 MG - Tank #2)

This permit hereby authorizes the applicant:

Town of Mills
P.O. Box 789
Mills, WY 82644

to construct, install or modify the Town of Mills 2009 Water Tank Rehabilitation Project, according to the procedures and conditions of the application number **09-047**. The facility is located in the NW ¼ of Section 11, Township 33 North, Range 80 West, Natrona County. All construction, installation, or modification allowed by this permit shall be completed within one year of issuance

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and/or operator. Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility meets applicable operational requirements. Compliance with applicable standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and/or operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place onor at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit. The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

1 of 3 The applicant will provide immediate oral or written notice tdhe Northeast District, Water Quality Division, 152 North Durbin, Suite 100, Casper, WY, 82601, Phone 307-473-3478, FAX 307-473-3458, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northeast District, Water Quality Division, 152 North Durbin, Suite 100, Casper, WY, 82601 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.

a. Date that construction of the facility was completed; and

b. Date that the facility was placed in operation; and

c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

Louis Hamon

John F. Wagner
for Administrator
Water Quality Division

John V. Corra
Director
Department of Environmental Quality

3-23-09

Date of Issuance

KLF/rm/9-0231

cc: Jason L. Meyers, P.E., WLC, 200 Pronghorn, Casper, WY 82601

STATEMENT OF BASIS

1. Permit Number: **09-047**

2. Application reviewed for compliance with the following applicable regulations :

   Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations

3. Does the permit comply with all applicable regulations identified above?

   YES

4. Facilities include components not specifically covered or differing from applicable regulations and approval is based upon a deviation in accordance with Section 5.

   N/A

5. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 is not required.

6. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Karen L. Farley, P.E., and completed on March 20, 2009. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

February 19, 2009

Karl Bertagnole
Greyco Investments, LLC
P.O. Box 68
Wright, WY 82732

RE: Installation of approximately 600 feet of Treated Water Distribution Pipe, Raw Water Distribution Pipe, and Sanitary Sewer. DEQ Permit #09-048, NW 1/4, Section 21, R93W, T51N, Bighorn County

Dear Mr. Bertagnole:

This project involves the installation of approximately 600 linear feet of 8-inch PVC water distribution pipe, approximately 600 linear feet of 4-inch PVC raw water distribution pipe and approximately 600 linear feet of 8-inch PVC water sewer pipe to serve a multiple residence development in the town of Basin, Wyoming. All piping is to tie in to existing water, raw water and sewer mains. The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations and is hereby approved with the following stipulations:

1. Raw water piping is to be differentiated from treated water piping in such a manner as to prevent accidental tie-in with a potable water system.
2. Treated water line crossings by raw water pipe shall be constructed as to center the section of raw water pipe over the water line.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact Hannes Stueckler at 307-335-6964 or James Brough at 307-335-6961.

Sincerely,

Hannes E. Stueckler
Assistant Northwest District Engineer
Water Quality Division

James Brough

James Brough, P.E.
Northwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Dustin D. Spomer, GDA Engineers, P.O. Box 338, Cody, WY 82414

encl: General Permit for an Existing Sewer Collection System

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

February 20, 2009

Ken Kemp
Kinder Morgan Upstream LLC
800 Werner Court, Suite 352
Casper, WY 82601

RE: Installation of mounded septic system and lift station. DEQ Permit #09-050, NE 1/4, Section 17, R88W, T37N, Fremont County

Dear Mr. Kemp:

This project involves the installation of a septic system, lift station and mounded infiltration system. The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; and Chapter 11, Parts A, B and D of the Wyoming Water Quality Rules and Regulations and is hereby approved with the following stipulations:

1. Infiltration mound is installed so that the top of the 4:1 sloped edge is at least three (3) feet from the edge of the infiltrators.
2. Lift station is constructed to allow drainage of the effluent line back into the lift station after a pump cycle is complete.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

If you have any questions, please contact Hannes Stueckler at 307-335-6964 or James Brough at 307-335-6961.

Sincerely,

Hannes E. Stueckler
Assistant Northwest District Engineer
Water Quality Division

James Brough

James Brough, P.E.
Northwest District Engineer
Water Quality Division

xc: IPS, Cheyenne
Dustin D. Spomer, GDA Engineers, P.O. Box 338, Cody, WY 82414

encl: General Permit for an Existing Sewer Collection System