

## PERMIT TO CONSTRUCT

X CHANGE OF OWNERSHIP

PERMIT NO. 09-401  
SPECIAL CONDITIONS  
REF/PERMIT NO. 94-272 and 96-442

### Silo Field Processing Facility

This permit hereby authorizes the applicant:

Western Environmental Services, Inc.  
2442 Peterson Drive  
Cheyenne, WY 82009

to assume ownership of the commercial oil and gas exploration and production exempt waste disposal and treatment pond permitted to receive produced water and non-hazardous wastewater, and operate it according to the procedures and conditions of this permit number 09-401, as derived from the reference permit numbers 94-272 and 96-442. The facility is located in the northeast quarter of Section 12, Township 15 North, Range 65 West, in the county of Laramie, in the State of Wyoming.

The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator. Granting this permit does not imply that the Wyoming DEQ guarantees or ensures that the permitted facility will meet applicable permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by the DEQ of the construction, design or operation of the facility described herein. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction, maintenance or operation of the permitted facility. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or where land application of waste is made for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of this permit, 09-401; referenced permits 94-272 and 96-442, and applicable supporting documents. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 5 The applicant will provide immediate oral and/or written notice to DEQ CBM / Oil and Gas Group, 152 North Durbin Street, Suite 100, Casper, WY 82601, in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 5 Permit to Construct 94-272 was issued for the construction of the Silo Processing Facility and allowed the facility to accept and treat produced water from oil exploration and production activities. Permit to Construct 96-442 was issued to allow the facility to accept and treat non-hazardous wastewater.
- 3 of 5 The validity of this permit is subject to the owner maintaining a bond acceptable to the State of Wyoming, DEQ/WQD for the amount of the facility closure and post-closure costs. The bonding amount is subject to review on an annual basis and is due to the DEQ CBM / Oil and Gas Group, 152 North Durbin Street, Suite 100, Casper, WY 82601 by **April 1**.
- 4 of 5 All other aspects and requirements of Permit to Construct 94-272 and 96-442 are still valid and need to be adhered to.
- 5 of 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
John F. Wagner  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
John V. Corra  
Director  
Department of Environmental Quality

7/30/09  
\_\_\_\_\_  
Date of Issuance

KJM/JDL/rm/9-0662

## STATEMENT OF BASIS

1. Permit Number: **09-401**
2. Application reviewed for compliance with the following applicable regulations :  
Chapters 3, 11, and 14 of the Wyoming Water Quality Rules and Regulations
3. Does the permit comply with all applicable regulations identified above?  
YES
4. Facilities include components not specifically covered or differing from applicable regulations and approval is based upon a deviation in accordance with Section 5.
  - a. The permit includes approval to deviate from the following regulatory requirements:  
Not applicable
  - b. Briefly state the basis for the deviation.  
Not applicable
  - c. Permit approval is based upon deviation from applicable regulations in accordance with approved policy statement.  
Not applicable

5. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was required.

6. If Section 17 of Chapter 3 review is required, indicate the basis for determining groundwater will be protected.

The facility will not allow a discharge to groundwater.

Permit to Construct 94-272 was permitted with a synthetic liner and leak detection system and was accepted on the basis that it would not have a discharge to groundwater.

Quality of wastewater is such that it will not cause a violation of groundwater standards.

Not applicable

Existing soils or geology will not allow a discharge to groundwater.

Not applicable

The facility is designed and will be operated so that it will not to violate groundwater standards.

Not applicable

~~Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:~~

Not applicable

If any groundwater quality standards are to be exceeded, briefly describe how any users of the affected aquifer will be protected. The description should include the water quality standard affected, the anticipated maximum concentration, the property boundaries, places of groundwater withdrawal and any other relevant information.

Not applicable

Briefly describe monitoring plan. The groundwater monitoring plan includes the monitoring wells or other sampling points, the parameters to be analyzed, the sampling frequency and reporting methods.

Not applicable

The permit should clearly state the parameters to be utilized for determining compliance and what occurrences constitute a violation. The permit should identify the corrective actions to be taken in the event of a violation of a groundwater standard.

Documentation of Statement of Basis.

The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.


#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Kim Medina, CBM / Oil and Gas Group and completed on July 29, 2009. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

October 23, 2009

Attn: Brad Cummings  
1133 Lane 7  
Powell, WY 82435

RE: Cedarwood Subdivision Phase Four Sewer and Water Main Extensions, Permit Number:  
09-402, Lot 75-K & Lot 75-L, T55N, R99W, Park County

Dear Mr. Cummings:

This project involves the installation of 8-inch water main extensions as well as 8 and 10-inch sewer main extensions to serve twenty-three new residential lots. The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

A variance was requested from Chapter 11, Section 9 (c)(i)(C) which requires a minimum slope of 0.004 ft/ft for 8-inch pipe. A variance from this regulation is granted based upon Policy 13.9.13. The construction of the proposed sewer line will satisfy Policy 13.9.13 by the following provisions: 1) Pipe constructed of either ASTM D3034 SDR 35 PVC pipe or epoxy lined ductile iron pipe (both will result in flowing full velocity greater than 2 feet per second, 2) the sewer grade will be established by a laser, 3) The pipe will be bedded with Type 1 bedding material using Type A Trench Backfill methods or cement treated fill, 4) the sewer line will be constructed under full time inspection, and 5) the Town has sent a letter stating their acceptance of the design.

You are authorized to construct the facilities in accordance with the general permits and materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit which can be downloaded from the Wyoming Department of Environmental Quality webpage at:

[http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

If you have any questions, please contact me at 307-335-6961.

Sincerely,

James Brough, P.E.  
Northwest District Engineer  
Water Quality Division

xc: Roy Holm, P.E., Holm, Blough, & Company, 1402 Stampede Ave., Cody, WY 82414  
Sean Christensen, P.E., City of Powell, P.O. Box 1008, Powell, WY 82435  
PDF to Cheyenne

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES  
(307) 332-5085  
FAX 332-7726

AIR QUALITY  
(307) 332-6755  
FAX 332-7726

LAND QUALITY  
(307) 332-3047  
FAX 332-7726

SOLID & HAZARDOUS WASTE  
(307) 332-6924  
FAX 332-7726

WATER QUALITY  
(307) 332-3144  
FAX 332-7726





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 25, 2009

Sandy Ruvolo  
Executive Access, LLC  
2931 HWY 24  
Aladdin, WY 82710

RE: Executive Access, LLC Small Residential Wastewater System, Crook County  
Location: S14, T54N, R63W; Permit # 09-403

Dear Mrs. Ruvolo:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

Additionally, the following permit conditions apply:

1. Cleanouts are required every 100 feet and at all changes in direction 22.5 degrees and greater, both horizontal and vertical. This requirement includes both the pipeline from the house to the septic tank and from the septic tank to the lagoon.
2. Either a 6-inch diameter clean-out riser or a manway from each compartment of the septic tank must be extended to the ground surface from all septic tanks.

Please be advised that Crook County inspects all small wastewater systems permitted through WDEQ. Please contact Crook County Growth and Development at 307.283.4548 to arrange an inspection of the system. **Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.** If you have any questions, please contact me at (307) 777-6941.

Sincerely,

Suzanne Engels  
WDEQ/WQD

SE/rm/9-0751

cc: IPS, Cheyenne  
WYDEQ Casper File  
Tim Lyons, Crook County Growth and Development, P.O. Box 848, Sundance, WY 82729  
Wade Habeck, Timberline Services, PO Box 867, Sundance, WY 82729


Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 4, 2009

Lana Love  
1805 HWY 450  
Newcastle, WY 82701

RE: Love Small Residential Wastewater System, Weston County, As-Built Permit # 09-404  
Location: SW ¼ SE ¼, S29, T44N, R64W

Dear Mrs. Love:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

This Notification of Coverage is issued in response to the submission of the septic system information for an as-built permit. This information was submitted without percolation test results. Completing a percolation test in the area of the leachfield will confirm if the field is sized appropriately for your residence. The system generally complies with Wyoming Department of Environmental Quality/Water Quality Regulations governing Small Wastewater Systems.

If you have any questions, please contact me at (307) 777-6941.

Sincerely,

Suzanne Pagorek  
WDEQ/WQD

SP/rm/9-0682

cc: IPS, Cheyenne  
WYDEQ Casper File  
Weston County Assessor, 1 W Main, Newcastle, WY 82701

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





The State  
of Wyoming



## Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

### NOTIFICATION OF COVERAGE

July 24, 2009

Christopher Johnson  
Town of Ranchester  
P.O. Box 695  
Ranchester, WY 82839

RE: Hwy 14 Water Line Extension, WDEQ #09-405  
Town of Ranchester, WY

Dear Mr. Johnson:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage,

[http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley, P.E.  
WDEQ/WQD, Northeast District Supervisor

Enclosures: Certificate of Completion

cc: Jeffrey Rosenlund, P.E., DOWL HKM, P.O. Box 7010, Sheridan, WY 82801  
WDEQ File  
IPS (Cheyenne)





The State  
of Wyoming



## Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

### NOTIFICATION OF COVERAGE

October 6, 2009

Fred D. Tschetter, Mayor  
City of Sundance  
P.O. Box 542  
Sundance, WY 82729

RE: I-90 Service Road Sanitary Sewerline Project, WDEQ #09-406  
City of Sundance, WY

Dear Mr. Tschetter:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Sewage Collection Systems in accordance with Chapter 3 and Chapter 11 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage,

[http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley, P.E.  
WDEQ/WQD, Northeast District Supervisor

Enclosures: Certificate of Completion

cc: Ralph W. Goodson, P.E., Bearlodge Ltd., Inc., 420 Cleveland Street, Sundance, WY 82729  
Fred Duncan, Crook County Growth and Development  
WDEQ File  
IPS (Cheyenne)

SOLID & HAZARDOUS WASTE DIVISION  
(307) 473-3450  
Fax: (307) 473-3458

AIR QUALITY DIVISION  
(307) 473-3455  
Fax: (307) 473-3458

WATER QUALITY DIVISION  
(307) 473-3465  
Fax: (307) 473-3458





The State  
of Wyoming



## Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

### NOTIFICATION OF COVERAGE

August 17, 2009

Larry Rubis  
Fabrication Technologies, Inc.  
4500 33 Miles Road  
Casper, WY 82604

RE: Modification to an Existing Small Wastewater System, WDEQ #09-407, Natrona County

Dear Mr. Rubis:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage,

[http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley, P.E.  
Northeast District Supervisor  
Water Quality Division

Enclosures: Certificate of Completion

cc: Lewis James, P.E., JKC Engineering, 5830 East 2<sup>nd</sup> Street, Casper, WY 82609  
April Gindulis, Natrona County Health Department  
WDEQ File  
IPS (Cheyenne)

SOLID & HAZARDOUS WASTE DIVISION  
(307) 473-3450  
Fax: (307) 473-3458

AIR QUALITY DIVISION  
(307) 473-3455  
Fax: (307) 473-3458

WATER QUALITY DIVISION  
(307) 473-3465  
Fax: (307) 473-3458





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 6, 2009

Roger Miller  
Thunder Creek Gas Services, LLC  
717 17<sup>th</sup> St., Suite 1500  
Denver, CO 80202

RE: Thunder Creek Gas Services Small Commercial Wastewater System, Campbell County  
Location: NW ¼ NW ¼, S10, T52N, R73W; Landeck Station; Permit # 09-408

Dear Mr. Miller:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

Please contact the Campbell County Building and Zoning Department at 307.682.1970 for compliance with any further county regulations. **Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.**

If you have any questions, please contact me at (307) 777.6941.

Sincerely,

Suzanne Pagorek  
WDEQ/WQD

SP/rm/9-0688

cc: IPS, Cheyenne  
WYDEQ Casper File  
Keith Bowar, Campbell County, 500 S. Gillette Ave, Ste 1500, Gillette, WY 82716  
Heath Turbiville, Stetson Engineering, PO Box 457, Gillette, WY 82717


Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

July 30, 2009

Mayor Robert Wood  
Town of Dayton  
P.O. Box 100  
Dayton, WY 82836

RE: Transfer of Ownership,  
Tongue River High School - Water and Wastewater Systems  
Sheridan County, Reference Permit #07-741  
Permit #09-409

Dear Mayor Wood:

The above Transfer of Ownership for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations (WWQRR) and for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Sewage Collection Systems in accordance with Chapter 3 and Chapter 11 of the WWQRR has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package.

If you have any questions, please contact me at (307) 777-6941.

Sincerely,

Suzanne Pagorek  
WDEQ/WQD

SP/rm/9-0663

Enclosures

cc: IPS, Cheyenne  
WDEQ File

Sue Belish, Sheridan County School District, P.O. Box 819, Ranchester, WY 82839  
Ryan R. Christensen, PE, Vista West Engineering, P.O. Box 785, Sheridan, WY 82801


Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

8/3/09

Mark D Haun, Mayor  
Town of Dubois  
P.O. Box 5559  
Dubois, WY - 82513

RE: Dubois Assisted Living Development Project Waterline. DEQ Permit #09-410, County of Fremont, Town of Dubois, T 41, R 106, Section 7, SE 1/4

Dear Mayor Haun,

This project consists of extending the existing 10-inch water main to serve the Dubois Assisted Living Facility, and the installation of an 8-inch water main loop, and the installation of several fire hydrants and service taps.

The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7, and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at:

[http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

If you have any questions, please contact Hannes Stueckler at 307-335-6964 or James Brough at 307-335-6961.

Sincerely,

Hannes E. Stueckler  
Assistant Northwest District Engineer  
Water Quality Division

James Brough, P.E.  
Northwest District Engineer  
Water Quality Division

xc: PDF to Cheyenne  
Matt Bowers, P.E., Nelson Engineering, P.O. Box 1599, Jackson, WY 83001

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES  
(307) 332-5085  
FAX 332-7726

AIR QUALITY  
(307) 332-6755  
FAX 332-7726

LAND QUALITY  
(307) 332-3047  
FAX 332-7726

SOLID & HAZARDOUS WASTE  
(307) 332-6924  
FAX 332-7726

WATER QUALITY  
(307) 332-3144  
FAX 332-7726





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 27, 2009

Herman Noe  
Cheyenne Board of Public Utilities  
P.O. Box 1469  
Cheyenne WY 82003

RE: Cheyenne BOPU 30 inch transmission pipeline;  
Relining and/or replacement project: Phase1  
Application No. **09-411**, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and or Existing Sewage Collection Systems described as relining approximately 9143 feet of existing old 30" cast iron main with the Insituform Pressure Pipe Liner, NE ¼ Section 16, T14N, R67W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 27, 2011.

This **Notice of Coverage** is covered under the General Permits on the Wyoming Department of Environmental Quality webpage. The General Permits can be viewed at the following path: [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp). Please reference Application No. **09-411** in any future correspondence.

If you have any questions, please contact me at 307-777-7075.

Sincerely,

Richard R. Cripe PE  
Southeast District Engineer  
Water Quality Division

RRC/bb/9-0757

cc: IPS, Cheyenne  
Jim Cavalli, Aspen Banner Engineering, 1575 N 4<sup>th</sup> St Suite 105, Laramie, WY 82072

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH  
(307) 777-7937  
FAX 777-3610

ABANDONED MINES  
(307) 777-6145  
FAX 777-6462

AIR QUALITY  
(307) 777-7391  
FAX 777-5616

INDUSTRIAL SITING  
(307) 777-7369  
FAX 777-5973

LAND QUALITY  
(307) 777-7756  
FAX 777-5864

SOLID & HAZ. WASTE  
(307) 777-7752  
FAX 777-5973

WATER QUALITY  
(307) 777-7781  
FAX 777-5973



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
PERMIT TO CONSTRUCT

PERMIT NO. 09-412

REFERENCE PERMIT NO. 06-823, 08-291

BAGGS WATER DISTRIBUTION AND SANITARY SYSTEM IMPROVEMENT PROJECT  
PWS WY5601604

This permit hereby authorizes the applicant:

TOWN OF BAGGS  
130 SOUTH PENLAND STREET  
BAGGS, WY 82321

to construct, install or modify a replacement of approximately 8700 feet of sanitary sewer line, manholes and construct two sanitary sewer lift stations according to the procedures and conditions of the application number 09-412. The facility is located in Section 5 T12N R91W; Carbon County, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed August 14, 2012.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7075, FAX 307-777-7610, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 The reduced pressure zone backflow device in the water fill station must be installed so that it cannot be bypassed. The floor drainage in the water fill station must be designed to accommodate the maximum relief flow from the backflow device.
- 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 A draft operation and maintenance manual for the wastewater system must be submitted at 50 percent completion of construction to the Southeast District Engineer of the Water Quality Division for approval. Approval of the final operation and maintenance manual is required prior to completion of construction.
- 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
John F. Wagner  
Administrator  
Water Quality Division

  
John V. Corra  
Director  
Department of Environmental Quality

Date of Issuance

8/12/09

RRC/rm/9-0719

## STATEMENT OF BASIS

1. Permit Number: 09-412
2. This application was reviewed for compliance with the applicable regulations ;  
Chapters 3, 11
3. Does the permit comply with all applicable regulations identified above?  
Yes
4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.
5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Richard Cripe, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on August 17, 2009. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

December 15, 2009

Lawrence Burnell  
Brush Creek Ranch  
Star Route 10  
Saratoga, WY 82331

RE: Brush Creek Ranch – Trail Head Lodge North, Application No. **09-413**  
Location: NW¼, Section 27, Township 16N, Range 82W, Carbon County

Dear Mr. Burnell:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for the Trail Head Lodge Chuck Wagon Restaurant and Blacksmith Motel in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

The approval granted under this Notification Of Coverage and the General Permit shall expire on December 15, 2011. Please reference Application Number **09-413** in any future correspondence.

If you have any questions, please contact me at (307) 777-6941.

Sincerely,

Suzanne Engels  
Consulting Engineer  
Water Quality Division

Rich Cripe, P.E.  
Southeast District Engineer  
Water Quality Division

SE/RRC/rm/9-1096

cc: IPS, Cheyenne  
Mark Butler, Inberg-Miller Engineers, 350 Parsley Blvd, Cheyenne, WY 82007  
Michael Jones, Carbon County Planning Director, Carbon Building, 215 West Buffalo Street, Suite 336, Rawlins, Wyoming 82301

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



**REVIEW OF PLANS & SPECIFICATIONS  
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION**

**PROJECT:** Brush Creek Ranch North and South Small Commercial Septic Systems

**LOCATION:** NW ¼, Section 27, Township 16N, Range 82W, Carbon County


**ENGINEER/ CONSULTANT:** Mark Butler, PE, Inberg-Miller Engineers, 350 Parsley Blvd, Cheyenne, WY 82007

**APPLICANT:** Lawrence Burnell, Star Route 10, Saratoga, WY 82331

**WATER QUALITY DIVISION APPLICATION NUMBER:** 09-413 and 09-414

**REVIEWING ENGINEER:** Suzanne Engels 307.777.6941 *SE*  
spagor@wyo.gov

**APPROVING ENGINEER:** Ron Ewald, P.E. 307.777.6183  
rewald@wyo.gov



**DATE OF REVIEW:** September 8, 2009

**ACTION:** **NOT AUTHORIZED FOR CONSTRUCTION.** In accordance with Section 12(a), Chapter 3, Wyoming Water Quality Rules and Regulations (WWQRR), this application is **not granted**. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 9 of Chapter 3 of the WWQRR. If the applicant fails to provide the requested information within one month, the incomplete application shall be returned.

1. Please explain in detail the following design load calculations:
  - a. How were 50 people determined for the restaurant? Please advise if the number of people from the Bunkhouse septic system application is included in this number.
  - b. What is the maximum occupancy of the restaurant?
  - c. How was the number of people using the spa and hot bath determined?
  - d. How was the number of people using the school/gym –showers determined?
  - e. Please provide the number of employees.
2. It appears that Brush Creek Ranch will host special events. Please provide details as to the type of events, frequency, and if these guests are included in the design load calculation.
3. A septic system consists of one septic tank and one leachfield. Since there is only one septic tank proposed with two leachfields, the proposed septic system is a UIC. The wastewater flows could be arranged such that two separate septic systems were created with a septic tank for each system and sited so that the two leachfields fields are not within the 5 acre separation. Please advise if the design will be modified.
4. Please provide the sizing calculations for the 3,000 gallon and the 1,500 gallon grease interceptor and the manufacturer specifications. The grease interceptor must be sized according to the WWQRR Chapter 11 Section 39 (c).
5. The septic tank must meet the design requirements in WWQRR Chapter 11 Section 39 (a). The septic tank capacity cannot be accounted for in the grease interceptor.

6. Leachfield trenches should be limited to less than 100 feet to insure proper infiltration and handling of wastewater. According to the design, the north leachfield is 148 feet long and the south leachfield is 160 feet long; please revise.
7. The overall site plan must show the following:
  - a. All buildings and facilities for the Brush Creek Ranch must be labeled accordingly.
  - b. Display the sewer line connections from each building to the appropriate septic system,
  - c. Location of all water lines (existing and future),
  - d. Identify parking areas,
  - e. The location of septic system Application Number 09-284 and associated buildings,
  - f. The location of the septic system for the Bunkhouse and associated buildings,

### **Brush Creek Ranch Water System**

Since Brush Creek Ranch is expanding the size and use of the facility, the water system may be a public water system. Please provide a summary and plan view of the water system that services the Ranch so that a determination can be made.

This is not a final review and additional information may be required. Please make the required corrections and return to Wyoming Department of Environmental Quality, Water Quality Division, 122 W 25<sup>th</sup> Street, Herschler Building 4-W, Cheyenne, Wyoming 82001.

RLE/SE/rm/9-0789



# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

December 15, 2009

Lawrence Burnell  
Brush Creek Ranch  
Star Route 10  
Saratoga, WY 82331

RE: Brush Creek Ranch – Trail Head Lodge South, Application No. **09-414**  
Location: NW¼, Section 27, Township 16N, Range 82W, Carbon County

Dear Mr. Burnell:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for the Trail Head Lodge Motel and Spa and Sports Center in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

The approval granted under this Notification Of Coverage and the General Permit shall expire on December 15, 2011. Please reference Application Number **09-414** in any future correspondence.

If you have any questions, please contact me at (307) 777-6941.

Sincerely,

Suzanne Engels  
Consulting Engineer  
Water Quality Division

Rich Cripe, P.E.  
Southeast District Engineer  
Water Quality Division

SE/RRC/rm/9-1097

cc: IPS, Cheyenne  
Mark Butler, Inberg-Miller Engineers, 350 Parsley Blvd, Cheyenne, WY 82007  
Michael Jones, Carbon County Planning Director, Carbon Building, 215 West Buffalo Street, Suite 336, Rawlins, Wyoming 82301

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



**REVIEW OF PLANS & SPECIFICATIONS  
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION**

**PROJECT:** Brush Creek Ranch North and South Small Commercial Septic Systems

**LOCATION:** NW ¼, Section 27, Township 16N, Range 82W, Carbon County


**ENGINEER/ CONSULTANT:** Mark Butler, PE, Inberg-Miller Engineers, 350 Parsley Blvd, Cheyenne, WY 82007

**APPLICANT:** Lawrence Burnell, Star Route 10, Saratoga, WY 82331

**WATER QUALITY DIVISION APPLICATION NUMBER:** 09-413 and 09-414

**REVIEWING ENGINEER:** Suzanne Engels 307.777.6941 *SE*  
spagor@wyo.gov

**APPROVING ENGINEER:** Ron Ewald, P.E. 307.777.6183  
rewald@wyo.gov



**DATE OF REVIEW:** September 8, 2009

**ACTION:** **NOT AUTHORIZED FOR CONSTRUCTION.** In accordance with Section 12(a), Chapter 3, Wyoming Water Quality Rules and Regulations (WWQRR), this application is **not granted**. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 9 of Chapter 3 of the WWQRR. If the applicant fails to provide the requested information within one month, the incomplete application shall be returned.

1. Please explain in detail the following design load calculations:
  - a. How were 50 people determined for the restaurant? Please advise if the number of people from the Bunkhouse septic system application is included in this number.
  - b. What is the maximum occupancy of the restaurant?
  - c. How was the number of people using the spa and hot bath determined?
  - d. How was the number of people using the school/gym –showers determined?
  - e. Please provide the number of employees.
2. It appears that Brush Creek Ranch will host special events. Please provide details as to the type of events, frequency, and if these guests are included in the design load calculation.
3. A septic system consists of one septic tank and one leachfield. Since there is only one septic tank proposed with two leachfields, the proposed septic system is a UIC. The wastewater flows could be arranged such that two separate septic systems were created with a septic tank for each system and sited so that the two leachfields fields are not within the 5 acre separation. Please advise if the design will be modified.
4. Please provide the sizing calculations for the 3,000 gallon and the 1,500 gallon grease interceptor and the manufacturer specifications. The grease interceptor must be sized according to the WWQRR Chapter 11 Section 39 (c).
5. The septic tank must meet the design requirements in WWQRR Chapter 11 Section 39 (a). The septic tank capacity cannot be accounted for in the grease interceptor.

6. Leachfield trenches should be limited to less than 100 feet to insure proper infiltration and handling of wastewater. According to the design, the north leachfield is 148 feet long and the south leachfield is 160 feet long; please revise.
7. The overall site plan must show the following:
  - a. All buildings and facilities for the Brush Creek Ranch must be labeled accordingly.
  - b. Display the sewer line connections from each building to the appropriate septic system,
  - c. Location of all water lines (existing and future),
  - d. Identify parking areas,
  - e. The location of septic system Application Number 09-284 and associated buildings,
  - f. The location of the septic system for the Bunkhouse and associated buildings,

### **Brush Creek Ranch Water System**

Since Brush Creek Ranch is expanding the size and use of the facility, the water system may be a public water system. Please provide a summary and plan view of the water system that services the Ranch so that a determination can be made.

This is not a final review and additional information may be required. Please make the required corrections and return to Wyoming Department of Environmental Quality, Water Quality Division, 122 W 25<sup>th</sup> Street, Herschler Building 4-W, Cheyenne, Wyoming 82001

RLE/SE/rm/9-0789



# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

December 15, 2009

Lawrence Burnell  
Brush Creek Ranch  
Star Route 10  
Saratoga, WY 82331

RE: Brush Creek Ranch - Bunkhouse, Application No. **09-415**  
Location: NW¼, Section 27, Township 16N, Range 82W, Carbon County

Dear Mr. Burnell:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a 22 person Motel and a 2 bedroom Cabin in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

The approval granted under this Notification Of Coverage and the General Permit shall expire on December 15, 2011. Please reference Application Number **09-415** in any future correspondence.

If you have any questions, please contact me at (307) 777-6941.

Sincerely,

Suzanne Engels  
Consulting Engineer  
Water Quality Division

Rich Cripe, P.E.  
Southeast District Engineer  
Water Quality Division

SE/RRC/rm/9-1098

cc: IPS, Cheyenne  
Mark Butler, Inberg-Miller Engineers, 350 Parsley Blvd, Cheyenne, WY 82007  
Michael Jones, Carbon County Planning Director, Carbon Building, 215 West Buffalo Street, Suite 336, Rawlins, Wyoming 82301

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



**REVIEW OF PLANS & SPECIFICATIONS  
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION**

**PROJECT:** Brush Creek Ranch Bunkhouse Small Commercial Septic System

**LOCATION:** NW ¼, Section 27, Township 16N, Range 82W, Carbon County

**ENGINEER/ CONSULTANT:** Mark Butler, PE, Inberg-Miller Engineers, 350 Parsley Blvd, Cheyenne, WY 82007

**APPLICANT:** Lawrence Burnell, Star Route 10, Saratoga, WY 82331

**WATER QUALITY DIVISION APPLICATION NUMBER: 09-415**

**REVIEWING ENGINEER:** Suzanne Engels 307.777.6941  
spagor@wyo.gov

**APPROVING ENGINEER:** Ron Ewald, P.E. 307.777.6183  
rewald@wyo.gov

**DATE OF REVIEW:** September 8, 2009



**ACTION:** **NOT AUTHORIZED FOR CONSTRUCTION.** In accordance with Section 12(a), Chapter 3, Wyoming Water Quality Rules and Regulations (WWQRR), this application is **not granted**. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 9 of Chapter 3 of the WWQRR. If the applicant fails to provide the requested information within one month, the incomplete application shall be returned.

1. Please clarify the Bunkhouse sizing. The Bunkhouse Usage describes a two story building with 7 bedrooms with laundry capabilities. The Septic Loading details 24 units and 40 gpd. The Brush Creek Ranch websites states that the Bunkhouse capacity is 28.
2. Please confirm the existing septic tank capacity. The worksheets state 1,500 gallons while the civil drawings do not state the capacity. Further, please advise of the septic tank material (concrete, steel, polyethylene).
3. Please submit a permit transfer request form for Application Number 94-488 and any other applicable permits.
4. Leachfield trenches should be limited to less than 100 feet to insure proper infiltration and handling of wastewater. According to the design, the leachfield is 120 feet long; please revise.
5. Please provide the depth of the percolation test holes.
6. The overall site plan must show the following:
  - a. All buildings and facilities for the Brush Creek Ranch must be labeled accordingly.
  - b. Display the sewer line connections from each building to the appropriate septic system,
  - c. Location of all water lines (existing and future),
  - d. Identify parking areas,
  - e. The location of each percolation test hole.

**Brush Creek Ranch Water System**

Since Brush Creek Ranch is expanding the size and use of the facility, the water system may be a public water system. Please provide a summary and plan view of the water system that services the Ranch so that a determination can be made.

This is not a final review and additional information may be required. Please make the required corrections and return to Wyoming Department of Environmental Quality, Water Quality Division, 122 W 25<sup>th</sup> Street, Herschler Building 4-W, Cheyenne, Wyoming 82001

RLE/SE/rm/9-0790



# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 12, 2009

Alan D. Palmer  
Project Manager  
3263 Fraser St., Suite 1  
Aurora, CO 80011

RE: Riverton LDS Church - 4-inch treated water service; Fire sprinkler line. DEQ Permit #09-417R, Fremont County, City of Riverton, Latitude 43.0297, Longitude 108.4313

Dear TITLE,

This project consists of the installation of approximately 270 linear feet of 4-inch AWWA C900 class 305 PVC treated water service line.

The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7, and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at:

[http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

If you have any questions, please contact Hannes Stueckler at 307-335-6964 or James Brough at 307-335-6961.

Sincerely,

Hannes E. Stueckler  
Assistant Northwest District Engineer  
Water Quality Division


James Brough, P.E.  
Northwest District Engineer  
Water Quality Division

xc: PDF to Cheyenne  
Gary L. Conner P.E., Engineering Associates, P.O. Box 1900, Cody, WY 82414





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 28, 2009

Carol Deckert  
77 Tate Lane  
Glendo, WY 82213

RE: Deckert Small Residential Wastewater System, Platte County; Permit # 09-418  
Location: NW ¼, Section 22, T30N, R68W

Dear Mrs. Deckert:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a one bedroom shop and a three bedroom house in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

Additionally, the following permit conditions apply:

1. Cleanouts are required every 100 feet and at all changes in direction 22.5 degrees and greater, both horizontal and vertical. This requirement includes both the pipeline from the house to the septic tank and from the septic tank to the leachfield.
2. Either a 6 inch diameter clean-out riser or the manway from each compartment of the septic tank must be extended to the ground surface.

**Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.** Please reference Application Number 09-418 in any future correspondence. If you have any questions, please contact me at (307) 777.6941.

Sincerely,

Suzanne Engels  
WDEQ/WQD

SE/rm/9-0760

cc: IPS, Cheyenne  
Jim Bohannon, P.O. Box 54, Glendo, WY 82213  
Platte County Planning Office, Dennis Becker, P.O. Box 728, Wheatland, WY 82001

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

September 2, 2009

Gary Boutweil  
Christian Community Church  
P.O. Box 264  
Encampment, WY 82325

RE: Christian Community Church Septic System Application No. **09-419**  
Location: NENW $\frac{1}{4}$ , Section 18, Township 15N, Range 83W, Carbon County

Dear Mr. Boutweil:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a **church with 50 seats and food preparation** in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific conditions also apply:

- A. Cleanouts are required every 100 feet and at all changes in direction 22.5 degrees and greater, both horizontal and vertical.
- B. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from each compartment of the septic tank must be extended to the ground surface.

The approval granted under this Notification Of Coverage and the General Permit shall expire on today's date + 2 years. Please reference Application Number **09-419** in any future correspondence. If you have any questions, please contact me at (307) 777-6941.

Sincerely,

Suzanne Engels  
Water Quality Division

SE/rm/9-0772

cc: IPS, Cheyenne  
Dana Ehnle, Ehnle Enterprises, P.O. Box 492, Encampment, WY 82325  
Michael Jones, Carbon County Planning Director, Carbon Building, 215 W Buffalo Street Ste 336, Rawlins, WY 82301


Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 3, 2009

Jacob Ochsner  
8049 Road 37  
Lingle, WY 82223

RE: Ochsner Small Residential Wastewater System, Weston County, Permit # **09-420**  
Location: SE ¼ SE ¼, S19, T47N, R60W;

Dear Mr. Ochsner:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

**Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.**

If you have any questions, please contact me at (307) 777.6941.

Sincerely,

Suzanne Pagorek  
WDEQ/WQD

SP/rm/9-0681

cc: IPS, Cheyenne  
WYDEQ Casper File  
Weston County Assessor, 1 W Main, Newcastle, WY 82701  
John Patik, Black Hills Plumbing, 1122 S. Summit, Newcastle, WY 82701





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 28, 2009

Nick Foye  
5059 HWY 34  
Wheatland, WY 82201

RE: Foye Small Residential Wastewater System Tank Replacement, Permit # 09-421  
Location: SE ¼ SE ¼, Section 15, T23N, R68W; Platte County

Dear Mr. Foye:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations (WQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

This Notification of Coverage is issued in response to the submission of the information for a septic tank replacement. The leach field at this site appears to be functioning properly at this time. However, if the leach field fails, a replacement field will need to be installed according to the current WQRR and a permit is required prior to construction. **Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.**

If you have any questions, please contact me at (307) 777.6941.

Sincerely,

Suzanne Engels  
WDEQ/WQD

SE/rm/9-0761

cc: IPS, Cheyenne  
Platte County Planning Office, Dennis Becker, P.O. Box 728, Wheatland, Wyoming  
82001

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





The State  
of Wyoming



## Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

### NOTIFICATION OF COVERAGE

August 14, 2009

City of Casper  
Andrew Beamer, P.E.  
200 North David Street  
Casper, WY 82601

RE: Wyoming Boulevard Waterline Replacement Project, WDEQ #09-422, Natrona County

Dear Mr. Beamer:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V. Section O. of the general permits.

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley, P.E.  
Northeast District Supervisor  
Water Quality Division

Enclosures: General Permits  
Certificate of Completion


cc: Nicholas Larsen, P.E., CEPI, 6080 Enterprise Drive, Casper, WY 82609  
WDEQ File  
IPS (Cheyenne)

SOLID & HAZARDOUS WASTE DIVISION  
(307) 473-3450  
Fax: (307) 473-3458


AIR QUALITY DIVISION  
(307) 473-3455  
Fax: (307) 473-3458

WATER QUALITY DIVISION  
(307) 473-3465  
Fax: (307) 473-3458





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 28, 2009

Frank Houk, Mayor  
Town of Greybull  
P.O. Box 271  
Greybull, WY 82476

RE: Greybull - Water Transmission pipeline upgrades. DEQ Permit #09-423, Big Horn County, Town of Greybull, Latitude 44.48 N, Longitude 108.05 W

Dear Mayor Houk,

This project consists of the replacement of existing water lines at the south end of Greybull with new 6-inch and 8-inch PVC pipe. Existing 8-inch and 10-inch VCP pipe will be replaced with new 8-inch and 10-inch PVC. Existing manholes will be replaced.

The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7, and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at:

[http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

If you have any questions, please contact Hannes Stueckler at 307-335-6964 or James Brough at 307-335-6961.

Sincerely,

Hannes E. Stueckler  
Assistant Northwest District Engineer  
Water Quality Division

James Brough, P.E.  
Northwest District Engineer  
Water Quality Division

xc: PDF to Cheyenne  
Brett Reed, P.E., Engineering Associates, P.O. Box 1900, Cody, WY 82414

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES  
(307) 332-5085  
FAX 332-7726

AIR QUALITY  
(307) 332-6755  
FAX 332-7726

LAND QUALITY  
(307) 332-3047  
FAX 332-7726

SOLID & HAZARDOUS WASTE  
(307) 332-6924  
FAX 332-7726

WATER QUALITY  
(307) 332-3144  
FAX 332-7726





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

December 1, 2009

Eric Quinney  
Uinta County Fire Protection  
Joint Powers Board  
P.O. Box 640  
Evanston, WY 82930

RE: Urie Fire Station - Waterline Extension - Permit Number 09-424R, NW ¼ NW ¼ Section 1, T15N, R115W, Uinta County

Dear Mr. Quinney:

The above application for coverage under General Permit to Construct the extension of a public water supply distribution system consisting of about 1224 linear feet (LF) of 8-inch and 120 LF of 6-inch PVC water main in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the General Permit. These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at :

[http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.  
Southwest District Engineer  
Water Quality Division

PDF to Cheyenne

Brent Sanders, P.E., Cook - Sanders Assoc., Inc., 105 Yellow Creek Road, Evanston, WY 82930

Page 1 of 1





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

September 1, 2009

Carbon County School District #1  
M. Neil Terhune, Superintendent  
P.O. Box 160  
Rawlins, WY 82301

RE: Rawlins Elementary School Complex Offsite Improvements,  
Application No. **09-425**, Carbon County

Dear Mr. Terhune:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and or Existing Sewage Collection Systems described as installing approximately 2,900 ft of 10 inch PVC C-900 water main, installing four new fire hydrants, one - 4 inch service connection, installing approximately 800 ft of 8 inch SDR 35 sanitary sewer main, installing five new manholes, and two- - 6 inch sewer services, SW ¼ SE ¼, NE1/4 SE ¼, & NW ¼ SE ¼, Section 4, T21N R 87W; Carbon County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by September 1, 2011.

This **Notice of Coverage** is covered under the General Permits on the Wyoming Department of Environmental Quality webpage. The General Permits can be viewed at the following path: [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp). Please reference Application No. **09-425** in any future correspondence.

If you have any questions, please contact me at 307-777-7075.

Sincerely,

Richard R. Cripe PE  
Southeast District Engineer  
Water Quality Division

RRC/rm/9-0771

Enclosure: Certificate of Completion

cc: IPS, Cheyenne  
James Murphy, AVI, 1103 Old Town Lane Suite 101, Cheyenne, WY 82009


Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 31, 2009

Herman Noe  
Cheyenne Board of Public Utilities  
P.O. Box 1469  
Cheyenne WY 82003

RE: Game & Fish Building Addition;  
Application No. **09-426**, Laramie County

Dear Mr. Noe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and or Existing Sewage Collection Systems described as installing approximately 247 ft of 8 inch PVC C- 900 fire hydrant, installing approximately 106 ft of 6 inch ductile iron fire line, and installing two 4 inch PVC SDR35 sewer services; Section 24, T14N, R67W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by August 28, 2011.

This **Notice of Coverage** is covered under the General Permits on the Wyoming Department of Environmental Quality webpage. The General Permits can be viewed at the following path: [http://deg.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deg.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp). Please reference Application No. **09-426** in any future correspondence.

If you have any questions, please contact me at 307-777-7075.

Sincerely,

Richard R. Cripe PE  
Southeast District Engineer  
Water Quality Division

RRC/rm/9-0767

cc: IPS, Cheyenne  
Ryan S. Rigg, AVI, 1103 Old Town Lane, Cheyenne, WY 82001

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deg.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
PERMIT TO CONSTRUCT

PERMIT NO. 09-427

WYDOT P.O.E. #1 - Water Well Construction  
PWS WY5601430

This permit hereby authorizes the applicant:

Wyoming Department of Transportation  
5300 Bishop Blvd  
Cheyenne, WY 82009

to construct, install or modify a Drilling, Construction, Developing and Testing the WYDOT POE #1 Well according to the procedures and conditions of the application number 09-427. The facility is located adjacent to US Highway 26/85 in SE ¼ SW ¼ Section 5, T24N R61W; Goshen County, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed September 3, 2011.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7075, FAX 307-777-7610, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
  
- 2 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
  
- 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
\_\_\_\_\_  
John F. Wagner  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
John V. Corra  
Director  
Department of Environmental Quality

Date of Issuance 9-14-09

RRC/rm/9-0787

## STATEMENT OF BASIS

1. Permit Number:       **09-427**
  
2. This application was reviewed for compliance with the applicable regulations ;  
  
      Chapters 3, 12
  
3. Does the permit comply with all applicable regulations identified above?  
  
      Yes
  
4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.  
  
      Public water supplies are exempted from review by Chapter 3, Section 17.
  
5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Richard Cripe P.E., Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on September 4, 2009. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



The State  
of Wyoming



## Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

### NOTIFICATION OF COVERAGE

September 29, 2009

Chris Knodel, P.E.  
City of Sheridan  
P.O. Box 848  
Sheridan, WY 82801

RE: Sugarland Utilities Project, WDEQ #09-429  
City of Sheridan, WY

Dear Mr. Knodel:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage,

[http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley, P.E.  
WDEQ/WQD, Northeast District Supervisor


Enclosures: Certificate of Completion

cc: Jeffrey Rosenlund, P.E., DOWL KHM, P.O. Box 7010, Sheridan, WY 82801  
WDEQ File  
IPS (Cheyenne)





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 12, 2009

Clyde Owen  
5100 Rocky Point Drive  
Gillette, WY 82718

RE: Owen Small Residential Wastewater System, Crook County  
Location: S1, T53N, R63W; Permit # 09-430

Dear Mr. Owen:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

Additionally, the following permit conditions apply:

1. Cleanouts are required every 100 feet and at all changes in direction 22.5 degrees and greater, both horizontal and vertical. This requirement includes both the pipeline from the house to the septic tank and from the septic tank to the lagoon.
2. Either a 6-inch diameter clean-out riser or a manway from each compartment of the septic tank must be extended to the ground surface from all septic tanks.

Please be advised that Crook County inspects all small wastewater systems permitted through WDEQ. Please contact Crook County Growth and Development at 307.283.4548 to arrange an inspection of the system. **Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.** If you have any questions, please contact me at (307) 777-6941.

Sincerely,

Suzanne Pagorek  
WDEQ/WQD

SP/rm/9-0702

cc: IPS, Cheyenne  
WYDEQ Casper File  
Tim Lyons, Crook County Growth and Development, P.O. Box 848, Sundance, WY 82729  
Russell Stinson, Stinson Backhoe, PO Box 23, Hulett, WY 82720


Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 6, 2009

Tom Farnsworth  
58 Fairgrounds Road  
Newcastle, WY 82701

RE: Farnsworth Small Residential Wastewater System, Weston County; Permit # **09-431**  
Location: NW 1/2 SE 1/4, Section 9, T45N, R61W

Dear Mr. Farnsworth:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

Additionally, the following permit conditions apply:

1. Cleanouts are required every 100 feet and at all changes in direction 22.5 degrees and greater, both horizontal and vertical. This requirement includes both the pipeline from the house to the septic tank and from the septic tank to the leachfield.

**Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.**

If you have any questions, please contact me at (307) 777.6941.

Sincerely,

Suzanne Pagorek  
WDEQ/WQD

SP/rm/9-0691

cc: IPS, Cheyenne  
WYDEQ Casper File  
Weston County Assessor, 1 W Main, Newcastle, WY 82701 (no enclosure)  
John Patik, Black Hills Plumbing, 1122 S Summit Ave, Newcastle, WY 82701

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 6, 2009

Walter Christensen  
P.O. Box 915  
Newcastle, WY 82701

RE: Christensen Small Residential Wastewater System, Weston County; Permit # **09-432**  
Location: SW 1/2 NW 1/4, Section 4, T48N, R61W

Dear Mr. Christensen:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

Additionally, the following permit conditions apply:

1. Cleanouts are required every 100 feet and at all changes in direction 22.5 degrees and greater, both horizontal and vertical. This requirement includes both the pipeline from the house to the septic tank and from the septic tank to the leachfield.

**Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.**

If you have any questions, please contact me at (307) 777.6941.

Sincerely,

Suzanne Pagorek  
WDEQ/WQD


SP/rm/9-0692

cc: IPS, Cheyenne  
WYDEQ Casper File  
Weston County Assessor, 1 W Main, Newcastle, WY 82701 (no enclosure)  
John Patik, Black Hills Plumbing, 1122 S Summit Ave, Newcastle, WY 82701





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

September 24, 2009

Brady West  
Buckskin Mining Co.  
9543 N US HWY 14-16  
Gillette, WY 82716

RE: Buckskin Mine Office Small Commercial Wastewater System, Campbell County  
Location: NW ¼ NW ¼, S4, T51N, R72W; Permit # 09-433

Dear Mr. West:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations (WWQRR) has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

Please contact the Campbell County Building and Zoning Department at 307.682.1970 for compliance with any further county regulations. **Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.**

If you have any questions, please contact me at (307) 777.6941.

Sincerely,

Suzanne Engels  
WDEQ/WQD

SE/rm/9-0850

cc: IPS, Cheyenne  
WYDEQ Casper File  
Corky Stetson, Stetson Engineering, PO Box 457, Gillette, WY 82717  
Keith Bowar, Campbell County, 500 S. Gillette Ave, Ste 1500, Gillette, WY 82716 (no encl)



REVIEW OF PLANS & SPECIFICATIONS  
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION

**PROJECT:** Buckskin Mine Small Commercial Septic System

**ENGINEER/ CONSULTANT:** Corky Stetson, Stetson Engineering, P.O. Box 457, Gillette, WY 82717

**APPLICANT:** Brady West, Buckskin Mining Co., 9543 N US HWY 14-16, Gillette, WY 82716

**INSTALLER:** Unknown

**WATER QUALITY DIVISION APPLICATION NUMBER: 09-433**

**REVIEWING ENGINEER:** Suzanne Pagorek 307.777.6941 or spagor@wyo.gov 

**DATE OF REVIEW:** August 13, 2009

**ACTION: NOT AUTHORIZED FOR CONSTRUCTION.** In accordance with Section 12(a), Chapter 3, Wyoming Water Quality Rules and Regulations (WWQRR), this application is **not granted**. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 9 of Chapter 3 of the WWQRR. If the applicant fails to provide the requested information within one month, the incomplete application shall be returned.

1. Please provide the number of current employees.
2. DEQ recommends that leachfields are not deeper than 5 feet and not longer than 100 feet. The proposed system is 6 feet deep and 167 feet long. Please address the leachfield depth and length.
3. Please explain how the holding pond will be decommissioned and its future use plans.
4. Chapter 12, Section 9(b)(i)(B)(I) provides the minimum distances between a well and sewer at 50'. It appears that the well is only about 25 feet from the sewer line, and less than 40 feet from the nearest manhole.
5. Traffic protection must be provided around the leachfield with bollards or another acceptable means of protection.
6. Please verify the depth of the waterlines, specifically at Station 2+58. The depth here is shown at approximately 16' which is rather deep.
7. Please reevaluate the design flow as leachfields are supposed to be designed for minimum peak flows. Based on the information submitted, this volume may be slightly greater.
8. Please explain why the 4" pipe is proposed at a 1% slope. A 4" pipe is typically installed at a 2% slope.

Please make the required corrections and return to Wyoming Department of Environmental Quality, Water Quality Division, 152 North Durbin Street, Suite 100, Casper, Wyoming 82601

---

cc: Phillip Giffin, Campbell County Engineering Services Manager, 500 S. Gillette Ave. Suite 145, Gillette, WY 82716

SP/rm/9-0714



# Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 7, 2009

David Coffee  
808 Oklahoma  
Hudson, WY 82515

RE: Coffee Septic System & Sewer Service Lateral, Permit Number: 09-435, T34N, R98W, Fremont County

Dear Mr. Coffee:

This project involves the installation of basically the following items: 200 linear feet of 4-inch PVC sewer line, clean outs at the house and 100 feet from the house, a dual chambered 1500-gallon septic tank, a submersible pump with float switches, 450 linear feet of 2-inch PVC pressurized and a connection to Hudson's sewage collection system. The above application for coverage under General Permit to construct a gravity flow septic tank and leachfield in accordance with Chapter 3, Section 7; and Chapter 11, Parts C and D of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved.

You are authorized to construct the facilities in accordance with the general permits and materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit which can be downloaded from the Wyoming Department of Environmental Quality webpage at:

[http://deq.state.wy.us/wad/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wad/www/Permitting/Pages/general_permits.asp)

If you have any questions, please contact me at 307-335-6961.

Sincerely,

James Brough, P.E.  
Northwest District Engineer  
Water Quality Division

xc: Mayor Jake Hamon, Town of Hudson, P.O. Box 56, Hudson, WY 82515  
Ray Price, Fremont County Planning, 450 North 2nd St., Lander WY 82520  
PDF IPS, Cheyenne

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES  
(307) 332-5085  
FAX 332-7726

AIR QUALITY  
(307) 332-6755  
FAX 332-7726

LAND QUALITY  
(307) 332-3047  
FAX 332-7726

SOLID & HAZARDOUS WASTE  
(307) 332-6924  
FAX 332-7726

WATER QUALITY  
(307) 332-3144  
FAX 332-7726





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

September 10, 2009

Duke Energy – Three Buttes Wind Farm  
Attn: Dirk A. Gard, Plant Manager  
1068 Cole Creek Road  
Glenrock, Wyoming 82637

RE: Three Buttes Wind Farm O&M Septic System,  
Location: SE¼ SE¼, Section 30, T35N, R76W,

Application No. **09-437**  
Converse County

Dear Mr. Gard:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility for a 10 employee office and maintenance operation facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 11, Part D of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway from **each compartment of the septic tank** must be extended to the ground surface.

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH  
(307) 777-7937  
FAX 777-3610

ABANDONED MINES  
(307) 777-6145  
FAX 777-6462

AIR QUALITY  
(307) 777-7391  
FAX 777-5616

INDUSTRIAL SITING  
(307) 777-7369  
FAX 777-5973

LAND QUALITY  
(307) 777-7756  
FAX 777-5864

SOLID & HAZ. WASTE  
(307) 777-7752  
FAX 777-5973

WATER QUALITY  
(307) 777-7781  
FAX 777-5973



The approval granted under this Notification Of Coverage and the General Permit shall expire on September 10, 2011. Please reference Application Number 09-437 in any future correspondence.

If you have any questions, please contact me at (307) 777-6183.

Sincerely,



Ronald L. Ewald  
Consulting Engineer  
Southeast District, Water Quality Division


RLE/rm/9-0801

Enclosures: GENERAL PERMIT - Small Wastewater Facility  
Certificate of Completion

cc: IPS, Cheyenne  
Russell Dahlgren, Dahlgren Consulting, Inc., 914 east 23<sup>rd</sup> Street, Cheyenne,  
Wyoming 82001  
Holly Richardson, Converse County Special Projects Office, 107 N. 5<sup>th</sup>, Suite B-6,  
Douglas, Wyoming 82633



# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 18, 2009

Shawn P. O'Malley  
Town of Jackson  
P.O. Box 1687  
Jackson, WY 83001

RE: Karns Hillside Addition Pressure Reducing Vault Replacement, Permit Number: 09-438, SW ¼, Section 33, T41N, R116W, Teton County

Dear Mr. O'Malley:

The project involves the replacement of the existing Karns Hillside pressure reducing vault (PRV) permitted under DEQ permit #99-071 with a new pressure reducing vault since the existing vault is difficult to access due to recent construction. This application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct the facilities in accordance with the general permits and materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit which can be downloaded from the Wyoming Department of Environmental Quality webpage at:

[http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

If you have any questions, please contact me at 307-335-6961.

Sincerely,

James Brough, P.E.  
Northwest District Engineer  
Water Quality Division

xc: Randy Schrauder, P.E., Rendezvous Engineering, P.O. Box 4858, Jackson, WY 83001  
PDF to Cheyenne

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES  
(307) 332-5085  
FAX 332-7726

AIR QUALITY  
(307) 332-6755  
FAX 332-7726

LAND QUALITY  
(307) 332-3047  
FAX 332-7726


SOLID & HAZARDOUS WASTE  
(307) 332-6924  
FAX 332-7726

WATER QUALITY  
(307) 332-3144  
FAX 332-7726





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

denthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

September 21, 2009

Douglas H. Weedin, President  
Pinnacle Bank  
1702 17<sup>th</sup> Street  
Cody, WY 82414

RE: Pinnacle Bank water service connection. DEQ Permit #09-439, Park County, Town of Cody, R 10W, T 53N, Section 32, SW1/4

Dear Mr. Weedin,

This project consists of the connection to the existing 6-inch diameter water main in East Sheridan Avenue with a 6-inch diameter fire line to the proposed bank building.

The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7, and Chapter 12, Section 14 of the Wyoming Water Quality Rules and regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at:

[http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

If you have any questions, please contact Hannes Stueckler at 307-335-6964 or James Brough at 307-335-6961.

Sincerely,

Hannes E. Stueckler  
Assistant Northwest District Engineer  
Water Quality Division

James Brough, P.E.  
Northwest District Engineer  
Water Quality Division

xc: PDF to Cheyenne  
Scott Nelson, P.E., CTA Architects Engineers, 119N. 3<sup>rd</sup> St., Livingston, MT, 59047

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES  
(307) 332-5085  
FAX 332-7726

AIR QUALITY  
(307) 332-6755  
FAX 332-7726

LAND QUALITY  
(307) 332-3047  
FAX 332-7726

SOLID & HAZARDOUS WASTE  
(307) 332-6924  
FAX 332-7726

WATER QUALITY  
(307) 332-3144  
FAX 332-7726



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
PERMIT TO CONSTRUCT

PERMIT NO. 09-440R

Kemmerer - Diamondville Joint Powers Board Wastewater Treatment Plant Screen Building

This permit hereby authorizes the applicant:

Truman Julian  
Kemmerer - Diamondville Joint Powers Board  
220 State Hwy 233  
Kemmerer, WY 83101

to construct a 3.5 million gallon per day (max flow) wastewater treatment plant screen building consisting of an automatic mechanical screen and a manual bar screen according to the procedures and conditions of the application number 09-440R. The facility is located just northeast of the Town of Kemmerer, within the SW ¼ of Section 13, T21N, R116W in the county of Lincoln, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by September 14, 2011.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3      The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3      Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
- a.      Date that construction of the facility was completed; and
  - b.      Date that the facility was placed in operation; and
  - c.      Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d.      Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3      The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
John F. Wagner  
Administrator  
Water Quality Division

  
John V. Corra  
Director  
Department of Environmental Quality

9-22-09  
Date of Issuance

MDB/rm/9-0812

## STATEMENT OF BASIS

1. Permit Number: 09-440R
2. Application reviewed for compliance with the following regulations:  
Chapter 11.
3. Does the permit comply with all applicable regulations identified above? No.
  - a. Chapter 11, Section 12 (b)(i) requires that the screen building shall be designed for hazardous location (National Electrical Code, Class 1, Groups C and D, Division 1 locations). Division 2 Standards are specified for the construction of the screen building components. The National Fire Protection Association (NFPA) Standard 820 allows for sewage screening buildings to be constructed to Division 2 Standards if the building is ventilated at 12 air changes per hour whenever the ventilation space is occupied, or supply air temperature is above 50°F and when activated by approved combustible gas detectors set to function at 10 percent of the lower flammable limit.
  - b. Chapter 11, Section 12 (b)(v) requires that the maximum approach velocity at average flows for a mechanically cleaned screen shall be 3.0 feet per second. Maximum velocity for a manually cleaned bar screen shall be 1.5 feet per second. Minimum velocities shall be 1.25 feet per second. Based on the mechanical screen manufacturer's recommendation to maintain one foot of water in the screen channel the velocity at average flow is 0.53 feet per second. In order to maintain enough width for cleaning the manual bar screen channel will have a velocity of 1.0 feet per second during average flow.
4. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.  
Sewerage systems are exempted from review by Chapter 3, Section 17.
5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Mark D. Baron, P.E., Southwest District Engineer, mbaron@wyo.gov, and completed on September 14, 2009. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."

---

cc: Jason Broome, P.E.; Forsgren Assoc.; 370 E. 500 South, Suite 200, Salt lake City, UT 84111

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY  
WATER QUALITY DIVISION  
PERMIT TO CONSTRUCT

PERMIT NO. 09-441

Thermopolis - Water Treatment Plant Pressurized Solution Feed pH Control System

This permit hereby authorizes the applicant:

William Malloy, Mayor  
Town of Thermopolis  
P.O. Box 603  
Thermopolis, WY 82443

to install a complete pressurized solution feed pH control system and appurtenances to replace the water treatment plant's existing submerged combustion recarbonation system; according to the procedures and conditions of the application number 09-441. The water treatment facility is within SW ¼, Section 1, T42N, R95W in the county of Hot Springs, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by October 1, 2011.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Northwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
  - a. Date that construction of the facility was completed; and
  - b. Date that the facility was placed in operation; and
  - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
  - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

  
John F. Wagner  
Administrator  
Water Quality Division

  
John V. Corra  
Director  
Department of Environmental Quality

9-22-09  
Date of Issuance

JSB/rm/9-0810

## STATEMENT OF BASIS

1. Permit Number: 09-441
2. Application reviewed for compliance with the following regulations:  
Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?  
Yes.
4. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.  
No.
5. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.  
Public water systems are exempted from review by Chapter 3, Section 17
6. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.


## CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by James S. Brough, james.brough@wyo.gov, Northwest District Engineer and completed on September 14, 2009. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."

cc: Heath Overfield, P.E., Engineering Associates, 429 Broadway, Thermopolis, WY 82443



# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 12, 2009

Jess Jimison  
PO Box 918  
Moorcroft, WY 82721

RE: Transfer of Ownership,  
Jimison Small Residential Septic System  
Crook County, Reference Permit #18-18-78  
Permit #09-442

Dear Mr. Jimison:

The above Transfer of Ownership for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package.

If you have any questions, please contact me at (307) 777-6941.

Sincerely,

Suzanne Pagorek  
WDEQ/WQD

SP/rm/9-0703

Enclosures

cc: IPS, Cheyenne  
WDEQ Casper File



## ROAD APPLICATION PERMIT

X New  
Renewal  
Modified

PERMIT NO. 09-443  
SPECIAL CONDITIONS  
REF/PERMIT

### **SIERRA CONSTRUCTION COMPANY 2009 ROAD APPLICATION PROJECT**

This permit hereby authorizes the applicant:

**SIERRA CONSTRUCTION COMPANY**  
P.O. BOX 210  
LINCH, WY 82640

to road apply a total of 2000 cubic yards crude oil tank bottom sludge from the Sierra Construction Oilfield commercial oilfield wastewater disposal facility for dust suppression on service roads according to the procedures and conditions of application number 09-443. The application area is located in Sections 1, 12, and 36, Township 43 North, Range 78 West, Johnson County, Wyoming. Crude oil tank bottoms were previously applied to these roads in 2007, under WDEQ Permit 07-577. This permit shall be effective until December 1, 2009.

The issuance of this permit confirms that the Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable standards. Compliance with DEQ standards is the responsibility of the permittee, owner, and/or operator.

Nothing in this permit constitutes an endorsement by the DEQ of the disposal method described herein. This permit verifies only that the submitted application meets the standards imposed by the DEQ statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance of, the permitted activity. The permittee, owner and/or operator are solely responsible for any liability arising from the waste disposal permitted. By issuing this permit, the state does not waive its sovereign immunity.

The permittee shall allow authorized representatives from the DEQ, Water Quality Division, to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and/or operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and/or operator shall comply with all of the following permit conditions:

- 1 of 7      The permittee shall notify representatives from the DEQ/WQD of the anticipated project commencement and completion dates. At least 48 hours advance notice is required. The authorized representative in your area can be contacted at the following address: DEQ/WQD, Casper WDEQ Field Office, 152 North Durbin Street, Suite 100, Casper, WY 82601, telephone (307) 473-3452; FAX (307) 473-3458.

- 2 of 7 The permittee shall provide immediate oral and/or written notice to the Casper WDEQ Field Office in accordance with the provisions of Section 9, Chapter III, Wyoming Water Quality Rules and Regulations of any changes or modifications to the approved permit package.
- 3 of 7 The permittee shall provide certification that the project was completed in accordance with the terms and conditions of the permit within sixty (60) days of the project completion to the Casper WDEQ Field Office on the attached Certification of Completion form.
- a. Date that the road application was completed; and
  - b. Certification the road application was done in accordance with the terms and conditions of the permit; or
  - c. Certification the road application was completed with changes or modifications. Submit the information necessary to clearly indicate the road application as actually performed. This information shall include a contour map depicting only those sections of road that actually received the sludge and soils.
- 4 of 7 The review and approval of this permit is based upon the items identified in the attached Statement of Basis.
- 5 of 7 The waste petroleum sludge shall be applied uniformly and incorporated into the road bed. The volume and rates of application will be as required for dust control.
- 6 of 7 The application site slope shall not exceed eight percent (8%) for vehicular application. The application of waste petroleum sludge shall be terminated within 300 feet of the definable high water mark of perennial and intermittent drainages, irrigation canals, lakes and reservoirs.
- 7 of 7 Only the roads designated in this permit are authorized for application of the waste petroleum sludge. Additional or alternate sections of road meeting the requirements of the application and this permit may be utilized if a written description and maps are received and approved by the WQD.

AUTHORIZED BY:

  
\_\_\_\_\_  
John F. Wagner  
Administrator  
Water Quality Division

  
\_\_\_\_\_  
John V. Corra  
Director  
Department of Environmental Quality

8/14/29  
\_\_\_\_\_  
Date of Issuance

JDL/KJM/rm/9-0706

cc: WDEQ Casper Field Office

STATEMENT OF BASIS

I. General information.

A. Permit Number: 09-443

II. Application reviewed for compliance with the following regulations. (Indicate yes or no for each section.)

A. Chapter XI. No

B. Chapter XII. No

III. Basis for issuing permit. (Indicate yes or no for each section.)

A. Review of application package indicates proposed facility will be in compliance with applicable regulations identified in Section II.

No

B. Permit includes deviation from applicable regulations in accordance with Section 5, Chapter XI, or XII.

No

C. Permit based on deviation from applicable regulations in accordance with approved policy statement.

No

IV. Facilities not specifically covered by regulations. (Indicate the section number of the regulations and briefly summarize the regulation.)

A. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.

There are no numeric standards or criteria in Chapter XI for road application. W.S. 35-11-301 (a)(iii) requires a permit to be issued when any disposal system capable of causing or contributing to pollution is constructed, installed, modified, or operated.

B. Briefly state the basis for the deviation.

Road application is permitted when DEQ authorized disposal facilities are not readily available, a beneficial use of the waste to be applied is possible, and significant impact to waters of the State is minimized.

C. Permit based on general or statewide deviation contained in approved policy statement (indicate the policy number and briefly summarize the nature of the deviation).

District Policy numbers 10.1 (4/9/91), 10.2 (10/17/86), 10.3 (8/91), 10.4 (10/24/91), and 10.6 (1/18/91) address the statutory authority to regulate the road application of waste, establish criteria for characterizing the waste, and determine acceptable conditions for the application of the waste to roadbeds to minimize impact to waters of the State.

District Policy 10.2 (10/17/86)

The landowner of the record, Mark Iberlin, has acknowledged and signed his acceptance of the proposed application of crude oil tank bottoms.

V. Application requires review to determine groundwater impacts in accordance with Section 15, Chapter III. (Indicate either applicable or not applicable. If not applicable delete all of section VI. from the Statement of Basis.)

NA

VI. If Section 15 of Chapter III is applicable, indicate the basis of determining groundwater will be protected. (Fill out only the applicable sections and indicate sections that are not applicable.)

A. Facility will not allow a discharge to groundwater. Briefly describe:

The opportunity for direct or indirect discharge, percolation, or filtration to groundwater is minimized by uniformly applying non-contact process water. Application is for dust control and as an aid in road construction (compaction).

B. Quality of waste is such that it will not cause a violation of groundwater standards. Briefly describe:

NA

C. Existing soils or geology will not allow a discharge to groundwater. Briefly describe:

NA

D. Basis of facility design is that it will be operated so as not to violate groundwater standards (example: maintenance of manure pack at animal waste treatment facility). Briefly describe:

NA

E. Discharge will result in groundwater concentrations in excess of standards but post discharge water quality can be returned to standards in accordance with Section 4 (d)(vi), Chapter VIII. Briefly describe:

NA

F. If water quality exceedances are allowed, briefly describe the parameter limits, property boundaries, places of withdrawal and any other information documenting that any users of affected aquifer will not be impacted.

NA

G. Briefly describe monitoring system (parameters, frequency, etc.). Clearly state the parameters to be utilized for determining compliance, what constitutes a violation and steps to be followed by the permittee in the event of a violation.

NA

VII. Documentation of Statement of Basis.


A. The archive file for this permit will include adequate documentation of all sections of this Statement of Basis.

#### CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Section 6, Chapter III, Wyoming Water Quality Rules and Regulations. This review was performed by Kim Medina, Senior Environmental Analyst, and completed on August 12, 2009. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 18, 2009

Dennis and Patricia Benington  
82 Fox Draw Road  
Newcastle, WY 82701

RE: Benington Small Residential Wastewater System,  
82 Fox Draw Road, Weston County  
As Built Permit # 09-444

Dear Mr. and Mrs. Benington:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

This Notification of Coverage is issued in response to the submission and completion of the required septic system information for an as-built permit. The system generally complies with Wyoming Department of Environmental Quality/Water Quality Regulations governing Small Wastewater Systems.

If you have any questions, please contact me at (307) 777-6941.

Sincerely,

Suzanne Pagorek  
WDEQ/WQD


SP/rm/9-0725

cc: IPS, Cheyenne  
WYDEQ File  
Weston County Assessor, 1 W Main, Newcastle, WY 82701 (w/o enclosure)





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

August 14, 2009

Eugene Ninnie, P.E.  
Town of Pinedale  
P.O. Box 709  
Pinedale, WY 82941

RE: Town of Pinedale - Phase V - Water and Sewer Rehabilitation - Permit Number 09-445, Section 34 & SW ¼ Section 3, T3N, R109W, Section 3 & NW ¼ Section 3, T33N, R109W, Sublette County

Dear Mr. Ninnie:

The above application for coverage under General Permits to Construct the replacement of a public water supply distribution system consisting of about 1165 linear feet (LF) of 8-inch and 576 LF of 6-inch ductile iron water main, five fire hydrants and the replacement of a sewer collection system consisting of about 1536 LF of 8-inch, 898 LF of 12-inch and 607 LF of 15-inch PVC sewer main, 15 manholes in accordance with Chapter 3, Section 7 and Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the General Permits. These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at :

[http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.  
Southwest District Engineer  
Water Quality Division

PDF to Cheyenne


Mark Eatinger, P.E., Rio Verde Engineering, P.O. Box 642, Pinedale, WY 82941

Page 1 of 1





# Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Dave Freudenthal, Governor

John Corra, Director

## NOTIFICATION OF COVERAGE

September 3, 2009

David Finnerty  
CityPlace One, Ste. 300  
St. Louis, MO 63141

RE: West Black Thunder Wastewater Holding Tank, WDEQ # 09-446  
Location: SENE ¼, Section 3, Township 43N, Range 71W; Campbell County

Dear Mr. Finnerty:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, [http://deq.state.wy.us/wqd/www/Permitting/Pages/general\\_permits.asp](http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp)

Additionally, the following permit condition applies:

1. All holding tanks shall be equipped with a high water level alarm. The device shall be an audible alarm or an indoor illuminated alarm. The alarm level shall be placed at 3/4 the depth of the tank.

Please contact the Campbell County Building and Zoning Department at 307.682.1970 for compliance with any further county regulations. If you have any questions, please contact me at (307) 777.6941.

Sincerely,

Suzanne Engels  
WDEQ/WQD

SE/rm/9-0781

cc: IPS, Cheyenne  
WYDEQ Casper File  
Mark Galambas, Thunder Basin Coal Company, PO Box 406, Wright, WY 82732  
Keith Bowar, Campbell County, 500 S. Gillette Ave, Ste 1500, Gillette, WY 82716


Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7937 FAX 777-3610	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-5973	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





The State  
of Wyoming



## Department of Environmental Quality

Dave Freudenthal, Governor

John Corra, Director

152 N. Durbin Street • Suite 100 • Casper, Wyoming 82601

February 22, 2010

Robert Swanson, P.E.  
PCA Engineering  
P.O. Box 2185  
Gillette, WY 82717

RE: Return of Bucyrus Septic System Application for 6500 Swanson Road, Campbell County  
WDEQ/WQD Tracking Number 09-447

Dear Mr. Swanson:

Our office received an application for a Permit to Construct on August 13, 2009, for the Bucyrus Septic System at 6500 Swanson Road in Campbell County. We performed a review of the application and sent this review via email on September 24, 2009. A response was provided to this office on November 2, 2009. A subsequent review was performed and sent on November 12, 2009. The review included a request for additional details associated with the construction proposed. As of today, February 22, 2010, we have not received the requested information. Therefore, in accordance with Wyoming Department of Environmental Quality/Water Quality Rules and Regulations Chapter 3, Section 14 – Denial of a Permit or Coverage under a General Permit, we are returning all of the application materials to you, as we are unable to process your application without the required information.

If you wish to pursue the acquisition of a Permit to Construct, a new and complete application will need to be submitted. At that time, a new DEQ tracking number will be assigned and will subsequently be reviewed by this office.

If you have any questions, please contact me at [kfarle@wyo.gov](mailto:kfarle@wyo.gov), or at (307) 473-3478.

Sincerely,

Karen L. Farley, P.E.  
WDEQ/WQD Northeast District Engineer

Enclosures: Bucyrus Septic System Application

cc: Jeff Dale, Bucyrus Field Services, Inc., 6500 Swanson Road, Gillette, WY 82718  
Phillip Giffin, P.E., Campbell County, 500 S. Gillette Ave., Suite 1400, Gillette, WY 82716  
John Boniface, III, Campbell County, 500 S. Gillette Ave., Suite 1400, Gillette, WY 82716  
IPS (Cheyenne)

