



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Matt Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

April 25, 2011

William Urbigit, Public Works Director
City of Riverton
816 N. Federal Blvd.
Riverton, WY 82501

RE: Sale Barn Waterline Project, Permit Number: 11-151, SW 1/4, Section 35, T. 1 N., R. 4 E., Fremont County

Dear Mr. Urbigit:

This project involves the installation of about 925 linear feet of 8-inch water line, 370 linear feet of 4-inch waterline and appurtenances to improve fire flow capacity and to serve 31 trailer lots. This application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct the facilities in accordance with the general permits and materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit which can be downloaded from the Wyoming Department of Environmental Quality webpage at:

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact me at 307-335-6961.

Sincerely,

James Brough, P.E.
Northwest District Engineer
Water Quality Division

xc: David Myers, Stetson Engineering, Inc., P.O. Box 1836, Riverton, WY 82501
C. Dawn Wilhelm, P.E., City of Riverton 816 N. Federal, Riverton, WY 82501
IPS, Cheyenne



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 11-152

Wastewater Treatment Plant Drying Beds Project

This permit hereby authorizes the applicant:

William Urbigit, Mayor
Town of Riverton
816 North Federal Blvd.
Riverton, WY 82501

to modify the existing sludge processing facility in accordance with the procedures and conditions of the application number 11-152. The facility is at Latitude 43.021° Longitude 108.35814° in the county of Fremont, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by September 31, 2013.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable water supply system permit conditions or other operational requirements. Compliance with drinking water standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Northwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 12, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

5/24/11
Date of Issuance

HES/rm/11-0482


STATEMENT OF BASIS

1. Permit Number: 11-152
2. Application reviewed for compliance with the following regulations:
Chapters 3 and 11 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?
Yes
4. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.
No.
5. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Significant dewatering is completed prior to application to the sludge drying beds; the sludge drying beds are concrete lined, and impermeable for all intents and purposes; system is sized to contain storm events.
6. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Hannes Stueckler, hannes.stueckler@wyo.gov, Assistant Northwest District Engineer and completed on May 20, 2011. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."

cc: Christina Dawn Wilhelm, P.E., City of Riverton, 816 N. Federal Blvd., Riverton, WY 82501



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
"AS-BUILT" PERMIT TO CONSTRUCT

PERMIT NO. 11-153
REFERENCE PERMIT NO. 08-704

Cat Creek Project: State 12-35-4878 Pit

This permit hereby authorizes the applicant:

Marlin Oil Company, LLC
Attn: Mr. Robert Vergnani
1121 Siouz Ave.
Gillette, WY 82718

to have installed five (5) compliance monitoring wells, previously permitted as 08-704, according to the procedures and conditions of the application number 11-153. The wells are proximal to an on-channel coalbed methane produced water impoundment located in Township 48N, Range 78W, Section 35, in the County of Johnson, in the State of Wyoming. All construction, installation, or modification allowed by this permit has been completed.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (WDEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Nothing in this permit constitutes an endorsement by WDEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The WDEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from WDEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1 of 4 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality/Water Quality Division, Groundwater Section, 2100 West 5th St., Sheridan, WY 82801, 307-673-9337, fax 307-672-2213, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 4 Monitoring Requirements:

Unless otherwise specified, monitoring and reporting of the groundwater beneath the impoundment shall be performed on a **semi-annual** basis until further notice and shall include the following information:

- Measurement of static water elevation in all monitoring wells: MW-1, MW-2, MW-3, MW-4 and MW-5;
- Sampling and analysis of groundwater in down-gradient monitoring well: MW-5;
- The parameters listed in the table below are required for groundwater compliance monitoring beneath the listed impoundment:

State 12-35-4878 Pit

Parameter	MW-5 Background Value (mg/L) (10/01/2008)	Class III Water Quality Standards (mg/L)
Selenium	ND	0.05
Sulfate	2070	3000
TDS	3260	5000
pH	8.1	6.5 – 8.5 (s.u)


- Reporting results of **semi-annual** monitoring and sampling are due to the department by January 15th and July 15th of each year. Samples may be collected at any time during the reporting period, but must be scheduled such that sampling events occur approximately six months apart;
- If a groundwater monitoring event reveals a pH measurement of 6.5 or less, the DEQ may require sampling and analysis of groundwater for the following additional parameters: aluminum, boron, cadmium, chromium, copper, lead and zinc.
- The analytical results for each sampling event, along with impoundment and monitor well location information must be submitted in the Excel spread sheet "Compliance

Monitoring Data Reporting", which can be found on the WDEQ website at the following address: (<http://deq.state.wy.us/wqd/groundwater/pollution.asp>). These data shall be submitted electronically on the due dates established above to the following department address: DEQ-CBMGroundwater@WYO.GOV. In addition, the accompanying analytical laboratory reports and field documentation must also be submitted either electronically (pdf format) or hard copy via mail to the WDEQ, Sheridan office at the address listed above.

3 of 4 The WDEQ may require a more frequent sampling schedule based on results of groundwater monitoring data analyses.

4 of 4 Any exceedence of the water quality standards listed above will be considered a violation of this permit. If an exceedence of groundwater standards occurs as a result of the operation of the impoundment, the WDEQ may require a more frequent monitoring schedule, further investigation of the groundwater impacts, remediation of the groundwater impacts, and cessation of discharge into the impoundment.

AUTHORIZED BY:



John F. Wagner
Administrator
Water Quality Division



John V. Corra
Director
Department of Environmental Quality

4/29/11

Date of Issuance

CS/rm/11-0424

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 11-154

REFERENCE PERMITS NO. 94-147, 95-314

BURNS ELEVATED WATER STORAGE TANK
PWS WY5600188

This permit hereby authorizes the applicant:

TOWN OF BURNS
327 SOUTH MAIN STREET
BURNS, WY 82053

to construct, install or modify a 200,000 gallon elevated storage tank, tank circulation equipment in new tank and existing 200,000 gallon elevated storage tank according to the procedures and conditions of the application number 11-154. The facility is located in Section 7; T14N R62W; Laramie County, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed June 27, 2014.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088, FAX 307-777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 A draft operation and maintenance manual for the water tank must be submitted at 50 percent completion of construction to the Southeast District Engineer of the Water Quality Division for approval. Approval of the final operation and maintenance manual is required prior to completion of construction.
- 4 **Construction of the elevated storage tank will not commence until DEQ has been provided the stamped and sealed structural and foundation designs for the tank and been given the opportunity to review and approve the designs.**
- 5 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

Date of Issuance 6/27/11

RRC/rm/11-0613

cc: Ryan D. Duve, Lidstone and Assoc., 4025 Automation Way, Bldg E., Fort Collins, CO

STATEMENT OF BASIS

1. Permit Number: **11-154**
2. This application was reviewed for compliance with the applicable regulations ;
Chapters 3, 12
3. Does the permit comply with all applicable regulations identified above?
Yes
4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.
Public water supplies are exempted from review by Chapter 3, Section 17.
5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Richard Cripe, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on June 27, 2011. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 11-155

REFERENCE PERMIT NO. 06-703

Dixon Sewage Lagoon Improvements Project

This permit hereby authorizes the applicant:

Town of Dixon
P. O. BOX 38
Dixon, WY 82323

to construct, install or modify improvements to weir structure, tablet chlorinator, contact chamber, tablet dechlorinator, floating baffles according to the procedures and conditions of the application number 11-155. The facility is located in NE ¼ SW ¼ and NW ¼ SE ¼, Section 5 T12N R90 W in the county of Carbon, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by June 3, 2014.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7075, FAX 307-777-7610 in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:

for
 Louis B. Harmon
John F. Wagner
Administrator
Water Quality Division

 John V. Corra
John V. Corra
Director
Department of Environmental Quality

 6-10-11
Date of Issuance

RRC/irm/11-0548

cc: Ryan D. Duve, Lidstone and Assoc., 4025 Automation Way, Bldg E., Fort Collins, CO

STATEMENT OF BASIS

Permit Number: 11-155

Application reviewed for compliance with the following applicable regulations :

Chapter(s) 3 and 11 of the Wyoming Water Quality Rules and Regulations

Does the permit comply with all applicable regulations identified above?

YES

A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.

Sewerage systems are exempted from review by Chapter 3, Section 17.

Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Richard Cripe PE, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on June 7, 2011. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality

To protect, conserve, and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

152 N. Durbin St., Suite 100 • Casper, WY 82601 • (307) 473-3450

John Corra, Director

NOTIFICATION OF COVERAGE

June 16, 2011

City of Casper
Jason Knopp, P.E.
200 North David Street
Casper, WY 82601

RE: 2011 Miscellaneous Water Main Improvements, City of Casper, WDEQ #11-156

Mr. Knopp:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage,

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley, P.E.
Northeast District Engineer, Water Quality Division

Enclosures: Certificate of Completion

cc: IPS, Cheyenne
{ Casper WDEQ File





Department of Environmental Quality

*To protect, conserve, and enhance the quality of Wyoming's
environment for the benefit of current and future generations.*



Matthew H. Mead, Governor

152 N. Durbin St., Suite 100 · Casper, WY 82601 · (307) 473-3450

John Corra, Director

NOTIFICATION OF COVERAGE

June 16, 2011

Stephen Spoonamore
ABS Materials, Inc.
770 Spruce Street
Wooster, OH 44691

RE: ABS Materials PW Unit #1, BPH002, Wamsutter Water Test, Red Desert Reclamation,
Sweetwater County, Wyoming
Permit to Construct #11-157

Dear Mr. Spoonamore:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Pilot Project in accordance with Section 5, Chapter 11, of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. **This permit expires 80 days from the date of issuance.**

Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit. The following items need to be submitted to WDEQ/WQD CBM Group:

- a. Date that the construction of the treatment facility will begin;
- b. Certification the construction of the treatment facility was done in accordance with the terms and conditions of the permit; or
Certification the construction of the treatment facility was completed with changes or modifications.
- c. All sampling will be conducted in accordance with the submitted sampling plan.
- d. Sampling of any waste products will be performed prior to disposal.
- e. A detailed report including on-site and lab analytical data relating to the facility's




performance for meeting the discharge requirements, treatment/discharge volumes, any problems with the system and what has been done to correct them, or a notification that the plant has not been operating, will be submitted within 30 days after end of treatment.

- f. Immediate notification to WDEQ/CBM Group of any violations, exceedences, upsets, or incidents relating to the facility and its operation.

Please notify WDEQ at least one week prior to start-up or initial processing of CBM water. If you have any questions, please contact Dennis Lamb or Kim Medina at 152 North Durbin, Casper, WY, 82601, (307) 473-3465. Thank you.

Sincerely,



Kim J. Medina
Geological Project Analyst
DEQ/WQD

Enclosures: Application for Permit to Construct
Certificate of Completion

cc: WDEQ File
IPS Cheyenne
Robert Desrosiers, Cate Street Capital, Inc., 286 BLM Road #3203, Wamsutter, WY 82336
Jon M. Williams, Williams Development, LLC, 1611 S. Walnut Street, Casper, WY 82601



Department of Environmental Quality

To protect, conserve, and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

152 N. Durbin St., Suite 100 · Casper, WY 82601 · (307) 473-3450

John Corra, Director

NOTIFICATION OF COVERAGE

May 12, 2011

Ivan Policky
227 Inyan Kara Rd.
Upton, WY 82730

RE: Policky Small Residential Wastewater System, Crook County
Location: Section 14, T50N, Range 65W; Permit # 11-158

Dear Mr. Policky:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

Additionally, the following permit condition applies:

1. Cleanouts are required every 100 feet and at all changes in direction 22.5 degrees and greater, both horizontal and vertical. This requirement includes both the pipeline from the house to the septic tank and from the septic tank to the leachfield.
2. Either a 6-inch diameter clean-out riser or a manway from each compartment of the septic tank must be extended to the ground surface from all septic tanks.

Please be advised that Crook County inspects all small wastewater systems permitted through WDEQ. Please contact Crook County Growth and Development at 307.283.4548 to arrange an inspection of the system. **Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.** Please contact me with questions at 307.777.6941.

Sincerely,

Suzanne Engels
WDEQ/WQD

cc: IPS, Cheyenne
WYDEQ Casper File
Tim Lyons, Crook County Growth and Development, PO Box 848, Sundance, WY 82729
Tri-City Excavation, 169 Thorn Divide Rd., Carlile, WY 82721





Department of Environmental Quality

*To protect, conserve, and enhance the quality of Wyoming's
environment for the benefit of current and future generations.*



Matthew H. Mead, Governor

152 N. Durbin St., Suite 100 • Casper, WY 82601 • (307) 473-3450

John Corra, Director

NOTIFICATION OF COVERAGE

July 27, 2011

Brian Sunwall
Motor Power Equipment Company
4941 Midland Road
Billings, MT 59101

RE: Motor Power 2" Domestic/6" Fire Water Service and 6" Sanitary Service Line, Bar Nunn, WY,
WDEQ #11-159

Mr. Sunwall:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations and for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Sewage Collection Systems in accordance with Chapter 3 and Chapter 11 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage,

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

This permit is valid until July 31, 2012.

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley, P.E.
Northeast District Engineer, Water Quality Division

Enclosures: Certificate of Completion


cc: William D. Johnston, P.E., Partner's Engineering, Inc. P.O. Box 941, Casper, WY 82602
Tim Pirtz, P.E., Sanderson Stewart, 1300 N. Transtech Way, Billings, MT 59102
Gloria Brainard, WWSD, P.O. Box 728, Mills Wyoming 82644
IPS, WYDEQ File





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 4, 2011

Sam Vieyra, Mayor
Town of Rock River
P.O. Box 280
Rock River, WY 82083

RE: Rock River Pretreatment Pilot Study,
Application No. 11-160, Albany County

Dear Mr. Vieyra:

The above application for coverage under General Permit to Construct and Operate a Pilot Plant in accordance with Chapter 3, Section 7 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct and operate the pilot plant in accordance with Chapter 12, Section 5 of the Water Quality Division Rules and Regulations, the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by November 4, 2011. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

This Notice of Coverage is covered under the General Permits on the Wyoming Department of Environmental Quality webpage. The General Permits can be viewed at the following path: http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp. Please reference Application No. 11-160 in any future correspondence.

The pilot study will replicate the exact operating conditions of the existing membrane water treatment plant in order to obtain data to support the proposed pre-treatment process. In general, the system is described as a Memcor (MF) Polypropylene pilot unit and a Clearlogx pilot unit. The Clearlogx process pilot will utilize two chemical feed systems; one for coagulant dosing and one for caustic dosing. In addition, it will include two Hach pH monitors, a probe assembly and one Milton Roy streaming current monitor. The current plan is to test polyaluminum chloride (PACL) and aluminum chlorohydrate based on previous jar testing and compatibility with existing membrane. All samples shall be collected as nearly as possible to "at the same time" to provide a consistent comparison for later evaluation. Water testing will include alkalinity, pH, temperature, TDS, TOC, total THM's, HAA5 and turbidity. The frequency of testing will follow the process described in the pilot study. Filtered water from the pilot unit will be sent to a floor drain that goes to the lagoon. The intent of this pilot study is to determine if the proposed pre-treatment process that eliminate meet the HAA5 MCL violation that was cited in the Administrative Order on June 18, 2009.

Sincerely,

Richard R. Cripe PE
Southeast District Engineer
Water Quality Division

RRC/rm/11-0439

cc: IPS, Cheyenne
Lynn Hill, Dowl HKM, P.O. Box 70, Laramie, WY 82072





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 24, 2011

United Western Corporation
Frank M. Cole, President
425 Cole Shopping Center
Cheyenne, WY 82001

RE: The Bluffs 8th Filing, Water and Sewer lines, Phase 1 Infrastructure Improvements
Application No. 11-161, Laramie County

Dear Mr. Cole:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modifications of Existing Public Water Supply Distribution Systems and or Existing Sewage Collection Systems described as installation of approximately 900 feet of 8 inch PVC water main, installation one new fire hydrant, installation of approximately 900 feet of 8 inch SDR-35 PVC sanitary sewer main, installation of twenty 4 inch sanitary sewer services, and installation of three 48 inch manholes, SW ¼ NW ¼, Section 21, T14N R 66W; Laramie County, in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the water distribution system in accordance with Chapter 12, Section 14 of the Water Quality Division Rules and Regulations, the sewage collection system in accordance with Chapter 11, Section 9 of the Water Quality Division Rules and Regulations, and both systems in accordance with the general permit and the materials submitted in your application package. All construction, installation, or modification allowed by this notification of coverage shall be completed by May 24, 2013.

This **Notice of Coverage** is covered under the General Permits on the Wyoming Department of Environmental Quality webpage. The General Permits can be viewed at the following path: http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp. Please reference Application No. 11-161 in any future correspondence.

If you have any questions, please contact me at 307-777-7075.

Sincerely,

Richard R. Cripe PE
Southeast District Engineer
Water Quality Division

RRC/rm/11-0506

Enclosure: Certificate of Completion

cc: IPS, Cheyenne
Kelly Hafner, Benchmark Engineers, 1920 Thomes Ave., Suite 620, Cheyenne, WY 82001
Herman Noe, Cheyenne Board of Public Utilities, P.O. Box 1469, Cheyenne WY 82003



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 11-162

REFERENCE PERMITS NO. 81-611, 87-242, 96-279, 11-006

TANK AND TRANSMISSION PROJECT
PWS WY5600065

This permit hereby authorizes the applicant:

TOWN OF ELK MOUNTAIN
P.O. BOX 17
ELK MOUNTAIN, WY 82324

to construct, install or modify two new 100,000 gallon glass-fused, bolted steel tanks, VFD'S, new tiered cascade aeration systems for both tanks, new chlorination building, SCADA, backup generator, new 6 inch transmission line, new 10 inch transmission line, upgrade chlorination system according to the procedures and conditions of the application number 11-162. The facility is located in Section 20; T20N R80W; Carbon County, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed May 27, 2014.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7088; FAX 307-777-5973, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 A draft operation and maintenance manual for the water system must be submitted at 50 percent completion of construction to the Southeast District Engineer of the Water Quality Division for approval. Approval of the final operation and maintenance manual is required prior to completion of construction.
- 4 The new tiered cascade aeration systems will require the vent openings covered with a 24 mesh corrosion-resistant screen.
- 5 Construction of the water storage tanks will not commence until DEQ has been provided the stamped and sealed structural and foundation designs for the tank and been given the opportunity to review and approve the designs.
- 6 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

Date of Issuance 4/3/11

RRC/rm/11-0525

cc: Keith Haskins, PMPC Civil Engineers, P.O. BOX 370, Saratoga, WY 82331

STATEMENT OF BASIS

1. Permit Number: **11-162**
2. This application was reviewed for compliance with the applicable regulations ;
Chapters 3, 12
3. Does the permit comply with all applicable regulations identified above?
Yes
4. A review to determine groundwater impacts in accordance with Section 17, Chapter 3 was not required.
Public water supplies are exempted from review by Chapter 3, Section 17.
5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.


CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Richard Cripe, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on June 1, 2011. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matt Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 9, 2011

Colleen Eifealdt
Town of Wamsutter
P.O. Box 6
Wamsutter, WY 82336

RE: Town of Wamsutter - 2011 Kelly Street Water and Sewer Project - Permit Number 11-163, SW ¼ Section 27 and NW ¼ Section 34, T20N, R94W, Sweetwater County

Dear Ms. Eifealdt:

The above application for coverage under General Permits to Construct the extension of a public water supply distribution system consisting of about 1400 linear feet of 12-inch PVC water main and the extension of a sewage collection system consisting of about 980 linear feet of 8-inch PVC sewer main in accordance with Chapter 3, Section 7, Chapter 12, Section 14 and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facilities in accordance with the general permits and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the General Permit. These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at :

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact me at 307-332-3144.

Sincerely,

Mark Baron, P.E.
Southwest District Engineer
Water Quality Division

PDF to Cheyenne
Jon Anderson, P.E., PMPC, P.O. Box 370, Saratoga, WY 82331





Department of Environmental Quality

*To protect, conserve, and enhance the quality of Wyoming's
environment for the benefit of current and future generations.*



Matthew H. Mead, Governor

152 N. Durbin St., Suite 100 · Casper, WY 82601 · (307) 473-3450

John Corra, Director

NOTIFICATION OF COVERAGE

June 14, 2011

Mayor Jerry Petty
Town of Bar Nunn
4820 North Wardwell Industrial Avenue
Bar Nunn, WY 82601

RE: Bar Nunn Sanitary Sewer Extension, Bar Nunn, WY, WDEQ #11-164

Mayor Petty:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Sewage Collection Systems in accordance with Chapter 3 and Chapter 11 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage,

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

This permit is valid until June 13, 2016.

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley, P.E.
Northeast District Engineer, Water Quality Division

Enclosures: Certificate of Completion

cc: William D. Johnston, P.E., Partner's Engineering, Inc. P.O. Box 941, Casper, WY 82602
IPS, WYDEQ File





Department of Environmental Quality

To protect, conserve, and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

152 N. Durbin St., Suite 100 • Casper, WY 82601 • (307) 473-3450

John Corra, Director

June 16, 2011

Homer R. Scott
Powder Horn Ranch, LLC
51 Powder Horn Road
Sheridan, WY 82801

RE: Return of the Powder Horn Ranch Water Reclamation Facility Expansion Permit Application, WDEQ #11-165

Dear Mr. Scott:

The Wyoming Department of Environmental Quality/Water Quality Division (DEQ) received an application for a Chapter 3 - Permit to Construct for the Powder Horn Ranch Water Reclamation Facility Expansion on April 13, 2011. The Department performed a review on May 6, 2011 and informed the consultant, Todd Kelley, P.E., with Sanderson Stewart, that no further action could be taken on the application until the infiltration problem was fully addressed. Subsequently, on May 20, 2011, this Department also informed Dwight Zemp with Santec that the permit application would not be processed without this issue being addressed. As of today, June 16, 2011, no further information has been provided; therefore, in accordance with Wyoming Department of Environmental Quality/Water Quality Rules and Regulations Chapter 3, Section 9 – Application Processing Procedures, DEQ is returning the permit application due to the application being incomplete.

If you have any questions, please contact me at (307) 473-3478 or karen.farley@wyo.gov

Sincerely,

Karen L. Farley, P.E.
WDEQ/WQD
Northeast District Supervisor


cc: Todd Kelley, P.E., Sanderson Stewart, 1300 N. Transtech Way, Billings, MT 59102
Dwight Zemp, Santec Corporation, 220 Malibu Street, Castle Rock, CO 80109
Lou Harmon, PE/PG, Cheyenne
WDEQ File
IPS





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 23, 2011

David and Teri Meyer
2938 Ten Mile Road
Casper, Wyoming 82604

RE: Meyer Residential Septic System,
Location: N½ NW¼ Section 14, T29N, R68W,
Lot 35, Lakeshore Tracts

Application No. 11-166
Platte County

Dear Mr. and Mrs. Meyer:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility consisting of a 1000 gallon concrete septic tank, a distribution box, and about 120 feet of chamber type leachfield divided into 4 approximately equal length trenches for a **2 bedroom mobile home** in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 25 of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific conditions also apply:

1. Distribution Box – Equal Effluent Distribution to Leaching Trenches - the D-box is good but it needs to be fully utilized. Instead of 3 outflow pipes, each with 1/3 of the outflow, 4 outflow pipes need to be used to divide the outflow into 4 equal flows. Therefore, **four outflow pipes shall be installed from the D-box, with one line going directly to each of the 4 leach trenches. No "equal flow T" is allowed** to split one of the outflows from the D-box. See correction on the Site Plan drawing.
2. NO Separation Fabric Allowed - the placement of separation fabric over the tops of the leachfield chambers is contrary to the design of the system, and will diminish the capability of the chambers to leach out wastewater. Therefore, **there SHALL be NO separation fabric placed over the leaching chambers.**
3. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway **from each compartment of the septic tank must be extended to the ground surface.**

Herschler Building · 122 West 25th Street · Cheyenne, WY 82002 · <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



The approval granted under this Notification Of Coverage and the General Permit shall expire on May 23, 2013. Please reference Application Number 11-166 in any future correspondence.

If you have any questions, please contact me at either ron.ewald@wyo.gov or by phone at (307) 777-6183.

Sincerely,



Ronald L. Ewald
Assistant Southeast District Engineer
Southeast District, Water & Wastewater Section
Water Quality Division

RLE/rm/11-0491

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Dennis Becker, Platte County Planning Office, PO. Box 728, Wheatland, WY 82201



Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 23, 2011

Cody Resources, LP, dba A-BAR-A Ranch
Attn: Justin Howe, Manager
P.O. Box 247
Encampment, Wyoming 82325

RE: A-BAR-A Ranch, Burta's Cabin Septic System,
Location: NE¼ Section 29, T14N, R81W,

Application No. **11-167**
Carbon County

Dear Mr. Howe:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility consisting of a 1000 gallon concrete septic tank and about 96 feet of chamber type leachfield divided into 3 equal length trenches for a **2 bedroom cabin** in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 25 of the Water Quality Division Rules and Regulations, the general permit, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

The approval granted under this Notification Of Coverage and the General Permit shall expire on May 23, 2013. Please reference Application Number **11-167** in any future correspondence.

If you have any questions, please contact me at either rewald@wyo.gov or by phone at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Assistant Southeast District Engineer
Southeast District, Water & Wastewater Section
Water Quality Division

RLE/rm/11-0496

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Kent Smith, Box 684, Saratoga, Wyoming 82331
Kristy Rowan, Carbon County Planning Office, Carbon Building, 215 West
Buffalo Street, Suite 336, Rawlins, Wyoming 82301





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 23, 2011

Pedro Mt. Outfitters, LLC
Attn: Thomas J. Clifford, Owner
1125 S. David Street
Casper, Wyoming 82601

RE: Pedro Mountain Outfitters Cabin – Septic System,
Location: NW¼ Section 26, T28N, R84W,

Application No. **11-168**
Carbon County

Dear Mr. Clifford:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility consisting of a 1050 gallon, two compartment polyethylene septic tank and about 130 feet of chamber type leachfield divided into 2 equal length trenches for a **2 bedroom cabin** in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 25 of the Water Quality Division Rules and Regulations, the general permit, the conditions listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific conditions also apply:

1. Minimum Leachfield Size - the **minimum leachfield size shall be at least 20 Infiltrator brand, standard High Capacity model, leachfield chamber units** – or equivalent. If equivalent chambers are used, enough units shall be used to total at least 857 square feet of equivalent chamber area.
2. Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway **from each compartment of the septic tank must be extended to the ground surface.**
3. Polyethylene Septic Tank Installation Requirements - To ensure structural integrity, the **manufacturer's instructions** regarding bedding the tank and filling the tank with water during burial **must be followed during installation.** Additionally, immediately after clean-outs, the tank must be refilled with water according to the manufacturer's instructions to maintain structural integrity.

Herschler Building · 122 West 25th Street · Cheyenne, WY 82002 · <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5816	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



The approval granted under this Notification Of Coverage and the General Permit shall expire on May 23, 2013. Please reference Application Number 11-168 in any future correspondence.

If you have any questions, please contact me at either ron.ewald@wyo.gov or by phone at (307) 777-6183.

Sincerely,



Ronald L. Ewald
Assistant Southeast District Engineer
Southeast District, Water & Wastewater Section
Water Quality Division

RLE/rm/11-0495


Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Kristy Rowan, Carbon County Planning Office, Carbon Building, 215 West
Buffalo Street, Suite 336, Rawlins, Wyoming 82301
Jon Weidbauer, Banger Brothers, 1800 So. Beverly #7, Casper, WY 82609



Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 10, 2011

Richard Kuhle and Janice Morton
132 Oregon Ave
Gillette, WY 82718

RE: Kuhle/Morton Small Residential Wastewater System, Crook County
Location: SW ¼, NE ¼, Section 30, T53N, Range 60W; Permit # 11-169

Dear Mr. Kuhle and Mrs. Morton:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

Additionally, the following permit condition applies:

1. Cleanouts are required every 100 feet and at all changes in direction 22.5 degrees and greater, both horizontal and vertical. This requirement includes both the pipeline from the house to the septic tank and from the septic tank to the leachfield.
2. Either a 6-inch diameter clean-out riser or a manway from each compartment of the septic tank must be extended to the ground surface from all septic tanks.

Please be advised that Crook County inspects all small wastewater systems permitted through WDEQ. Please contact Crook County Growth and Development at 307.283.4548 to arrange an inspection of the system. **Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.** Please contact me with questions at 307.777.6941.

Sincerely,

Suzanne Engels
WDEQ/WQD

SE/rm/11-0448

cc: IPS, Cheyenne
WYDEQ Casper File
Tim Lyons, Crook County Growth and Development, PO Box 848, Sundance, WY 82729
Lance Phillips, All B Excavating, 60 State HWY 335, Sheridan, WY 82801



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 11-170R

QEP Energy Company Well #1
No Public Water System Number Assigned

This permit hereby authorizes the applicant:

Kevin Williams
QEP Energy Company
P.O. Box 2125
Pinedale, WY 82941

to construct only water well #1 consisting of a pitless unit and about 80 lineal feet of 2-inch poly water main according to the procedures and conditions of the application number 11-170R. The facility is located just south of the Town of Pinedale in SW ¼ NE ¼ Section 15, T33N, R109W in the county of Sublette, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by May 24, 2013.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadow View Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

5/15/11
Date of Issuance

MDB/rm/11-0505


STATEMENT OF BASIS

1. Permit Number: 11-170R
2. Application reviewed for compliance with the following regulations:
Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?
Yes.
4. If a Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Not required.
5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Mark D. Baron, P.E., mark.baron@state.wy.us, Southwest District Engineer and completed on May 24, 2011. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

cc: Brian Gary, P.E., WLC Engineering, P.O. Box 1519, Pinedale, WY 82941



Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matt Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 10, 2011

Kreg Lombard, Mayor
City of Worland
P.O. Box 226
Worland, WY 82401

RE: Wastewater Treatment Facility Ultraviolet Bypass Line Project, Permit Number: 11-171, SE ¼, Section 13, T. 47 N., R. 93 W., Washakie County

Dear Mayor Lombard:

This project involves the installation of 63 linear feet of 18-inch sewer line with gate valve to serve as a bypass line to the UV building when maintenance or replacement is required. This application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; and Chapter 11, Section 9 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct the facilities in accordance with the general permits and materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit which can be downloaded from the Wyoming Department of Environmental Quality webpage at:

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact me at 307-335-6961.

Sincerely,

James Brough, P.E.
Northwest District Engineer
Water Quality Division

xc: Mike Donnell, P.E., Donnell & Allred, Inc., P.O. Box 638, Worland, WY 82401
IPS, Cheyenne

Lander Field Office • 510 Meadowview Drive • Lander, WY 82520 • <http://deq.state.wy.us>

ABANDONED MINES
(307) 332-6085
FAX 332-7726

AIR QUALITY
(307) 332-6755
FAX 332-7726

LAND QUALITY
(307) 332-3047
FAX 332-7726


SOLID & HAZARDOUS WASTE
(307) 332-6924
FAX 332-7726

WATER QUALITY
(307) 332-3144
FAX 332-7726





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Matt Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 11, 2011

Scott Shepherd, Managing Member
Too Buds, LLC
P.O. Box 3393
Jackson, WY 83002

RE: Too Buds, LLC; Tract 3-A Water Main. DEQ Permit #11-172, Teton County, Latitude 43.43°, Longitude 110.78°

Dear Mr. Shepherd,

This project consists of the installation of 1263 linear feet of water Main serving 3 residential lots.

The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7, and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at:

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact Hannes Stueckler at 307-335-6964 or James Brough at 307-335-6961.

Sincerely,


Hannes E. Stueckler, P.E.
Assistant Northwest District Engineer
Water Quality Division

xc: PDF to Cheyenne
Brian T. Lenz P.E., Jorgensen Associates, P.C., P.O. Box 9550, Jackson, WY 83002





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Matt Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 11, 2011

Robert Kaiser, WDOC Facilities Manager
Wyoming Department of Corrections
40 Honor Farm Road
Riverton, WY 82501

RE: Wyoming Department of Corrections Honor Farm Sewer Line Replacement Project. DEQ Permit #11-173, Fremont County, Township 1N, Range 4E, Section 14

Dear Mr. Kaiser,

This project consists of installing 410 linear feet of 6 inch sanitary sewer, bursting 195 linear feet of existing 4 inch clay pipe 26 inch PVC sanitary sewer, installing 5 sanitary sewer manholes, rehabilitating 1 existing sanitary manhole, and replacing 180 lineal feet of 4 inch sanitary sewer service Line.

The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; and Chapter 11, Part B of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at:

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact Hannes Stueckler at 307-335-6964 or James Brough at 307-335-6961.

Sincerely,

Hannes E. Stueckler, P.E.
Assistant Northwest District Engineer
Water Quality Division

xc: PDF to Cheyenne
David G. Myers P.E., Stetson Engineering, Inc. P.O. Box 1836, Riverton, WY 82501





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 17, 2011

George Nichols
755 Gilchrist Street
Wheatland, Wyoming 82201

RE: Nichols Building Septic System,
Location: SW¼ NE¼ Section 13, T24N, R68W,

Application No. **11-174**
Platte County

Dear Mr. Nichols:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility consisting of a 1000 gallon single compartment concrete septic tank and at least 11 units of "BioDiffuser" ARC 24 model leachfield chambers divided into 2 equal trenches of about 35 feet each for a **5 employee shop/office building** in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 25 of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Inspection Required - The construction of the septic system must meet the Town of Wheatland "Building Code Requirements" and shall be overseen and inspected by the Wheatland Town Building Inspector before the final cover is placed over the construction.

The approval granted under this Notification Of Coverage and the General Permit shall expire on May 17, 2013. Please reference Application Number **11-174** in any future correspondence.

If you have any questions, please contact me at either rewald@wyo.gov or (307) 777-6183.

Sincerely,

Ronald L. Ewald
Assistant Southeast District Engineer
Southeast District, Water & Wastewater Section
Water Quality Division

RLE/rm/11-0469

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Platte County Planning Office, Dennis Becker, PO. Box 728, Wheatland, WY 82201
Russell Schamel, Town of Wheatland Engineer, Wheatland, WY 82201
Town of Wheatland Building Inspector, Wheatland, WY 82201

Herschler Building · 122 West 25th Street · Cheyenne, WY 82002 · <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 10, 2011

Ione Hauber
190 Mule Creek Rd.
Hulett, WY 82720

RE: Hauber Small Residential Wastewater System, Crook County
Location: SW ¼, SE ¼, Section 12, T55N, Range 67W; Permit # 11-175

Dear Mrs. Hauber:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

Additionally, the following permit condition applies:

1. Cleanouts are required every 100 feet and at all changes in direction 22.5 degrees and greater, both horizontal and vertical. This requirement includes both the pipeline from the house to the septic tank and from the septic tank to the leachfield.
2. Either a 6-inch diameter clean-out riser or a manway from each compartment of the septic tank must be extended to the ground surface from all septic tanks.

Please be advised that Crook County inspects all small wastewater systems permitted through WDEQ. Please contact Crook County Growth and Development at 307.283.4548 to arrange an inspection of the system. **Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.** Please contact me with questions at 307.777.6941.

Sincerely,



Suzanne Engels
WDEQ/WQD

SE/rm/11-0449


cc: IPS, Cheyenne
WYDEQ Casper File
Tim Lyons, Crook County Growth and Development, PO Box 848, Sundance, WY 82729
Randy Gantz, Gantz Backhoe Service Inc, PO Box 280, Hulett, WY 82720





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 10, 2011

Thomas and Tamara Preston
606 N Plains Drive
Gillette, WY 82716

RE: Preston Small Residential Wastewater System, Campbell County
Location: SE ¼, Section 9, T50N, Range 72W; Permit # 11-176

Dear Mr. and Mrs. Preston:

The above application for coverage under General Permit to Construct, Install, Modify, or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

Additionally, the following permit condition applies:

1. Cleanouts are required every 100 feet and at all changes in direction 22.5 degrees and greater, both horizontal and vertical. This requirement includes both the pipeline from the house to the septic tank and from the septic tank to the leachfield.
2. Either a 6-inch diameter clean-out riser or a manway from each compartment of the septic tank must be extended to the ground surface from all septic tanks.

Please contact the Campbell County Building and Zoning Department at 307.682.1970 for compliance with any further county regulations. **Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.** Please contact me with questions at 307.777.6941.

Sincerely,

Suzanne Engels
WDEQ/WQD

SE/bb/11-0453

cc: IPS, Cheyenne
WYDEQ Casper File
John Boniface, Campbell County Public Works, 500 S Gillette Avenue, Suite 1400, Gillette, WY 82716





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 23, 2011

Vincent L. and Billie Rae Tripi
6910 South Lovers Lane Rd.
Franklin, Wisconsin 53132-1440

RE: Tripi Residential Septic System,
Location: Section 25, T26N, R70W,
Laramie Peak Ranch Phase III Subdivision, Lot 37

Application No. **11-177**
Platte County

Dear Mr. and Mrs. Tripi:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility consisting of a 1000 gallon, one compartment, concrete septic tank and about 120 feet of chamber type leachfield divided into two equal length trenches for a **3 bedroom house** in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 25 of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway **from each compartment of the septic tank must be extended to the ground surface.**

The approval granted under this Notification Of Coverage and the General Permit shall expire on June 23, 2013. Please reference Application Number **11-177** in any future correspondence.

If you have any questions, please contact me at either ron.ewald@wyo.gov or by phone at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Assistant Southeast District Engineer
Southeast District, Water & Wastewater Section
Water Quality Division

RLE/rm/11-0597

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Platte County Planning Office, Dennis Becker, PO. Box 728, Wheatland, WY 82201
Aaron Wilson, A&A EarthWorks, 580 grange Road, Wheatland, Wyoming 82201

Herschler Building • 122 West 25th Street • Cheyenne, WY 82002 • <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
Herschler Bldg., 4 West
Cheyenne, Wyoming 82002

PROJECT: Tripi Residential Septic System

LOCATION: Section 25, T26N, R70W, **Platte County**
Laramie Peak Ranch Phase III, Lot 37

CONTRACTOR: Aaron Wilson
A&A Earth Works
580 Grange Road
Wheatland, Wyoming 82201
Ph: (307) 331-8833


APPLICANT: Vincent L. and Billie Rae Tripi
6910 South Lovers Lane Rd.
Franklin, Wisconsin 53132-1440
Ph: (414) 425-0970

WATER QUALITY DIVISION REFERENCE #:

11-177

REVIEWING ENGINEER: Ronald L. Ewald
Phone: (307) 777-6183

DATE OF REVIEW: May 27, 2011



ACTION: **NOT AUTHORIZED FOR CONSTRUCTION.** In accordance with Section 14 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 9. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. Site Plan Needs More Information and Detail - the site plan provided is a little bit unclear on some points. First, the site plan seems to indicate that "North" is towards the bottom of the page, and that Sheep Mountain Road runs east/west to the north of the house. My reference maps show Sheep Mountain Road being at least ½ mile away from Section 25 and running more in a north/south direction. Secondly, the distance from the house to the water well is not indicated. Which direction does the ground slope?

Please provide a better location map for this lot. Perhaps a plat of the subdivision showing your lot, and section numbers and lines. Also, please indicate the direction of surface slope (pointing downhill) on the revised site plan. Is north and the location of Sheep Mountain Road correctly indicated on the site plan? And lastly, what quarter section (NW, SW, SE, NE) of section 25 is this property in?

2. Trench Layout Restrictions - the application proposes a single chamber unit trench of 110 feet long. This is much too long for chamber leachfield systems. The leachfield needs to be split into at least 2 trench rows of chamber units. See "Two Trench Chambered Leachfield" detail sheet included.

RLE/rm/11-0515

Attachments: One set of the original application package for reference
 Two trench Chambered Leachfield detail sheet

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 11-178

SPECIAL CONDITIONS
WYPDES # WY0094617

ROMERO PARK DRAINAGE SUMP

This permit hereby authorizes the applicant:

CITY OF CHEYENNE
PARKS & RECREATION DEPARTMENT
2101 O'NEIL AVE., Room 302
CHEYENNE, WY 82009

to construct, install or modify a Granular Activated Carbon (GAC) Treatment System according to the procedures and conditions of the application number 11-178. The facility is located in SW ¼, Section 6, T13N R66W; Laramie County, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed May 25, 2013.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 The applicant will provide immediate oral or written notice to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002, Phone 307-777-7075, FAX 307-777-7610, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southeast District, Water Quality Division, Herschler Building 4 West, Cheyenne, WY, 82002 a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 An operation and maintenance manual for the GAC system must be submitted to the Southeast District Engineer of the Water Quality Division for approval. The operation and maintenance manual for the wastewater system should meet the requirements of Section 24, Chapter 11, Wyoming Water Quality Rules and Regulations.
- 4 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

Date of Issuance

5/25/11

RRC/rm/11-0509

cc: Anthony Griego, ERM-WEST, 7272 Indian School Rd. Suite 100, Scottsdale, AZ 85295

ec: Bill DiRienzo, Leah Coleman, Marcia Porter

STATEMENT OF BASIS

1. Permit Number: **11-178**
2. This application was reviewed for compliance with the applicable regulations ;
Chapters 3, 11
3. Does the permit comply with all applicable regulations identified above?
NO
4. The permit approval is based upon a deviation from applicable regulations in accordance with Section 5. of Chapter 11.
 - a. Identify specific sections of the regulations for which a deviation is approved and briefly summarize the regulation.
Chapter 12, Section 10 lists Granular activated carbon (GAC) as a water treatment option.
 - b. Briefly state the basis for the deviation.

Data supplied by the Engineer and the manufacture indicates the raw water will be treated to meet or exceed the WYPDES permit.
5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Richard Cripe, Southeast District Engineer, Water and Wastewater Section, Wyoming Department of Environmental Quality /Water Quality Division, and completed on May 25, 2011. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality

*To protect, conserve, and enhance the quality of Wyoming's
environment for the benefit of current and future generations.*



Matthew H. Mead, Governor

152 N. Durbin St., Suite 100 • Casper, WY 82601 • (307) 473-3450

John Corra, Director

NOTIFICATION OF COVERAGE

June 13 2011

Mr. Robert McPherson, Public Works Director
Town of Mills
PO Box 789
Mills, WY 82644

RE: Town of Mills - Highway 20-26 water line replacement, Application No. 11-179

Dear Mr. McPherson:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O. of the general permit. The general permit is available for download at http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp.

If you have any questions, please contact me at 307-473-3471.

Sincerely,

Kevin J. Frank

Kevin J. Frank
Project Engineer
Water Quality Division

cc: - IPS, Cheyenne
✓ - Matt Williams, PE; WLC Engineering, Surveying & Planning;
200 Pronghorn; Casper, WY 82601



REVIEW OF PLANS AND SPECIFICATIONS
WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION


Herschler Bldg., 4 West
Cheyenne, Wyoming 82002

PROJECT: Mickelsen Residential Septic System
LOCATION: SW¼, SW¼, Section 2, T24N, R68W, **Platte County**
ENGINEER: None
APPLICANT: Levi Mickelsen
87 Preuit Road
Wheatland, Wyoming 82201
Ph: (307) 331-8033

WATER QUALITY DIVISION REFERENCE #: **11-180**

REVIEWING ENGINEER: Ronald L. Ewald
Phone: (307) 777-6183
email: ron.ewald@wyo.gov

DATE OF REVIEW: June 2, 2011



ACTION: **NOT AUTHORIZED FOR CONSTRUCTION.** In accordance with Section 14 (a), Chapter III, Wyoming Water Quality Rules and Regulations, the application is denied because it is incomplete or does not meet applicable minimum design and construction standards. Please address the comments outlined below and submit the requested information in order that the application process may be completed in accordance with Section 9. If the applicant fails to provide the requested information within six months the incomplete application shall be returned.

COMMENTS, INADEQUACIES, AND QUESTIONS:

1. Percolation Rate and Loading Rate Factor Used are Incorrect - In item B.5.a., you report the percolation(perc) rate as 40 minutes per inch(mpi), which lead you to use the loading rate factor of 0.35 in item D.2. The perc test was done well and the correct perc rate of 60mpi was determined at the bottom of the perc test data sheet. The 60mpi value is what should have been used in the calculations and the loading rate factor of 0.30 that goes with it.
2. Minimum Leachfield Size Inadequate - the use of the wrong perc rate and associated loading rate factor resulted in to small of a minimum required infiltrative surface area. The calculations need to be redone starting from this point. Plus – Please Note – the minimum surface area calculated here needs to be carried through the rest of the calculations as a consistent number; ie. – Items E.4.a, and E.4.d.
3. Leachfield Trench Lengths too Long - the proposed two trench chamber system is already 140 feet long per trench, which is much too long for chamber systems. DEQ/WQD will not permit beyond 100 foot long chamber trenches, and strongly recommends that chamber trenches be kept less than 75 feet long. The leachfield layout needs to be redesigned to be at least a four(4) trench system.
4. Site Plan Questions - both the primary leachfield and future leachfield appear to have two trenches that are connected at the head of the leachfield at right angles to each other. Also, the effluent pipes out of the septic tank connect to these header junctions at odd angles. How are these connections actually to be made? With a junction box, or flow splitter tees, or what. Please provide more detail.
5. Please Clarify Construction Status - most of the application indicates a proposed septic system being submitted for approval. However, there is a statement on the “Two Trench Chambered Leachfield” detail sheet which is “**I installed 44 units in a double trench, 22 units/trench**” that makes me think that some part or all of the system may have already been constructed. Please clarify the current construction status of all of the components of the system; ie. – covered pipe or open trench, or not installed yet.


If you have any questions about these comments, please contact me either by email or phone as listed on the cover page.

RLE/rm/11-0534

The approval granted under this Notification Of Coverage and the General Permit shall expire on July 6, 2013. Please reference Application Number **11-180** in any future correspondence.

If you have any questions, please contact me at ron.ewald@wyo.gov or (307) 777-6183.

Sincerely,

A handwritten signature in cursive script that reads "Ronald L. Ewald".

Ronald L. Ewald
Assistant Southeast District Engineer
Southeast District, Water & Wastewater Section
Water Quality Division

RLE/rm/11-0631

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Platte County Planning Office, Dennis Becker, PO. Box 728, Wheatland, WY 82201

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

PERMIT NO. 11-181

Pinedale-Wastewater Treatment Facility Aerated Lagoon Rehabilitation Project

This permit hereby authorizes the applicant:

Eugene Ninnie, P.E.
Town of Pinedale
P.O. Box 709
Pinedale, WY 82941

to construct a lined aerated lagoon cell with leak detection system according to the procedures and conditions of the application number 11-181. The facility is located approximately 1 mile south of The Town of Pinedale within NW 1/4, Section 10, T33N, R109W in the county of Sublette, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by May 17, 2013.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;
or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

5/19/11
Date of Issuance

MDB/rm/11-0471

cc: Bernard E. Poppenga, P.E., Stantec Consulting Services, Inc., 2000 S. Colorado Blvd., Suite 2-300, Denver, CO 80222

STATEMENT OF BASIS

1. Permit Number: 11-181
2. Application reviewed for compliance with the following regulations:
3. Chapters 3, and 11 of the Wyoming Water Quality Rules and Regulations.
4. Does the permit comply with all applicable regulations identified above?

Yes.

5. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.

NA

6. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.

Groundwater will be protected by the bottom and sides of the aerated lagoon cell will being lined with 45 mil reinforced polypropylene. Four leak detection sumps along with leak collection piping will also be installed.

7. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron P.E. Southwest District Engineer, mark.baron@wyo.gov and completed on May 17, 2011. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality

*To protect, conserve, and enhance the quality of Wyoming's
environment for the benefit of current and future generations.*



Matthew H. Mead, Governor

152 N. Durbin St., Suite 100 · Casper, WY 82601 · (307) 473-3450

John Corra, Director

July 7, 2011

Chairman
Campbell County Board of Commissioners
500 South Gillette Ave, Suite 212
Gillette, WY 82716

RE: Donkey Creek Subdivision No. 2, WDEQ Application 11-182
Wyoming DEQ has - **NO ADVERSE** - Recommendations

Dear Commissioners:

The Wyoming Department of Environmental Quality has completed the review of the proposed Donkey Creek No. 2 Subdivision, located in the NW ¼, NE ¼ of Section 5, Township 49 North, Range 72 West, Campbell County, approximately 2 miles southwest of the City of Gillette, Wyoming. The information was submitted by Wester-Wetstein and Associates, Inc., and signed by John Wetstein, P.E./P.G., a Wyoming Licensed Professional Engineer and Professional Geologist. This letter represents the recommendations of the Wyoming Department of Environmental Quality as required by W.S. §18-5-306 (c).

Findings as to the safety and adequacy of the proposed sewage system:

The proposed sewage system is the use of individual on-site septic systems consisting of conventional septic tanks and leachfields. There are two existing septic systems within this subdivision, one of which was permitted through Campbell County and installed in 2002. It was not made clear whether or not the other system had a permit in place; however, the consultant performed additional percolation tests on this area and has determined that a conventional system is also feasible for the new lot. The information submitted addresses the safety and adequacy of the proposed sewage system.

Findings as to the safety and adequacy of the proposed water system:

The proposed water system is to utilize an existing domestic well that is currently in use by Lot 20A and 20B. The addition of Lot 20C will increase the demand on this well. The consultant states that the well can discharge at a rate in excess of what the demand of three households would be; therefore, it appears that the well is adequate for this additional use. The water well and the existing water system is not considered a public water system; therefore, no permitting through DEQ or EPA will be required. The developer is encouraged, however, to contact the State Engineer's Office and Campbell County Public Works for any additional requirements for the water system. WDEQ has reviewed the information submitted and is satisfied that the proposed connection to the existing water system is feasible.



Conclusions:


The Wyoming Department of Environmental Quality has "No Adverse" recommendations applicable to the Donkey Creek Subdivision No. 2

Disclaimer:

The Non-Adverse recommendation provided above has nothing to do with, nor has any bearing on the water rights associated with the Donkey Creek No. 2 Subdivision. Any questions or concerns about the water rights for the Donkey Creek No. 2 Subdivision should be directed to the State Engineer's Office.

Nothing in Wyoming Department of Environmental Quality recommendations or comments regarding the Wester-Wetstein and Associates, Inc. proposal for the Donkey Creek Subdivision No. 2 shall be construed to relieve Donald Cale of the obligation to obtain any permits or additional approval from any local, state, or federal agencies as required by law, rules, regulations, or ordinances. Nothing in these recommendations commits the Wyoming Department of Environmental Quality or Campbell County to the issuance of required permits for construction, operation, or modification of septic systems or water supply.

Sincerely,



Karen L. Farley, P.E.
Northeast District Supervisor
Water and Wastewater Program, Wyoming Water Quality Division

cc: Donald Cale, P.O. Box 157, Gillette, WY 82717
John Wetstein, P.E./P.G., Wester-Wetstein and Associates, Inc., P.O. Box 2202, Laramie, WY 82073
Campbell County Planning Office, 500 S. Gillette Ave., Suite 1500, Gillette, WY 82716
WDEQ Subdivision file
(IPS) Cheyenne



Department of Environmental Quality

To protect, conserve, and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

152 N. Durbin St., Suite 100 • Casper, WY 82601 • (307) 473-3450

John Corra, Director

NOTIFICATION OF COVERAGE

May 12, 2011

Robert Smith
705 Rifle Pit Rd
Beulah, WY 82712

RE: Ingrid House Small Residential Wastewater System, Crook County
Location: SW ¼, NE ¼, Section 22, T52N, Range 61W; Permit # 11-183

Dear Mr. Smith:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

Additionally, the following permit condition applies:

1. Cleanouts are required every 100 feet and at all changes in direction 22.5 degrees and greater, both horizontal and vertical. This requirement includes both the pipeline from the house to the septic tank and from the septic tank to the leachfield.
2. Either a 6-inch diameter clean-out riser or a manway from each compartment of the septic tank must be extended to the ground surface from all septic tanks.

Please be advised that Crook County inspects all small wastewater systems permitted through WDEQ. Please contact Crook County Growth and Development at 307.283.4548 to arrange an inspection of the system. **Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.** Please contact me with questions at 307.777.6941.

Sincerely,

Suzanne Engels
WDEQ/WQD

cc: IPS, Cheyenne
WYDEQ Casper File
Tim Lyons, Crook County Growth and Development, PO Box 848, Sundance, WY 82729



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 11-184

Shoshoni Municipal Water Sodium Permanganate Upgrade
PWS ID#WY5601198

This permit hereby authorizes the applicant:

Craig Barsness, Manager
Shoshoni Municipal Water Joint Powers Board
P.O. Box 488
Cody, WY 82414

to replace the existing potassium permanganate system with a new sodium permanganate system in accordance with the procedures and conditions of the application number 11-184. The facility is at Section 3, Range 102 W., Township 52 N. in the county of Park, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by August 31, 2013.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable water supply system permit conditions or other operational requirements. Compliance with drinking water standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit.


This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Northwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 12, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;
or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

6/3/11
Date of Issuance

HES/rm/11-0524

STATEMENT OF BASIS

1. Permit Number: 11-184
2. Application reviewed for compliance with the following regulations:
Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?
Yes
4. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.
No.
5. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Not Applicable.
6. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Hannes Stueckler, hannes.stueckler@wyo.gov, Assistant Northwest District Engineer and completed on June 1, 2011. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."

Xc: Ed Nowak P.E., Camp Creek Engineering, 410 E. Grand Ave., Suite 205, Laramie, WY 82070

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 11-185

1,000-Gallon Potable Water Tank & Backflow Prevention Project

This permit hereby authorizes the applicant:

Ronald Hix, Plant Manager
Georgia-Pacific Gypsum LLC.
P.O. Box 756
Lovell, WY 82431

to install a 1,000-gallon potable water storage tank in an configuration to eliminate a cross connection between the potable water supply and four non-contact process heat exchangers, according to the procedures and conditions of the application number 11-185. The potable water supply serves about 60 employees. This project is located at Township 55 North, and Range 94 West in the county of Big Horn, in the state of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by May 31, 2012.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:


- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Northwest District Engineer, 510 Meadowview Dr., Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

5/24/11
Date of Issuance

JSB/rm/11-0490

STATEMENT OF BASIS

1. Permit Number: 11-185
2. Application reviewed for compliance with the following regulations:
Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above? Yes
4. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.

No
5. If Section 17 of Chapter 3 is applicable, indicate the basis of determining groundwater will be protected.

Public water supplies are exempted from review by Chapter 3, Section 17.
6. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.


CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by James Brough, jbroug@state.wy.us, Northwest District Engineer and completed on May 19, 2011. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents, permit conditions, and the items identified in this "Statement of Basis."

cc: Willie Bridges, P.E., Pryor Mountain Engineering, P.O. Box 671, Cowley, WY 82420



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Matt Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 24, 2011

Milan Vinich
1017 Falls Court
Riverton, WY 82501

RE: Vinich Sewer Extension. DEQ Permit #11-186, Fremont County, Latitude 42.9067°, Longitude 108.585°

Dear Mr. Vinich

This project consists of the the installation of the 540 linear feet of sewer line to extend the mains of the town of Hudson to serve the property owned by the Vinich family.

The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; and Chapter 11, Part B of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at:

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact Hannes Stueckler at 307-335-6964 or James Brough at 307-335-6961.

Sincerely,


Hannes E. Stueckler, P.E.
Assistant Northwest District Engineer
Water Quality Division

xc: PDF to Cheyenne
David Knoepke P.E., James Gores and Associates, P.C., 111 N. 3rd St. E., Riverton, WY 82501





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 17, 2011

Cathleen Stalcup
Crump Land & Livestock LLC
501 Westside Dr
Gillette, WY 82718

RE: Crump Land & Livestock LLC, Mobile Home Small Wastewater System, Crook County
Location: NW ¼, SE ¼, Section 29, T49N, Range 68W; Permit # 11-187

Dear Mrs. Stalcup:


The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install, or modify the facility in accordance with general permit and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage, http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

Additionally, the following permit condition applies:

1. Cleanouts are required every 100 feet and at all changes in direction 22.5 degrees and greater, both horizontal and vertical. This requirement includes both the pipeline from the house to the septic tank and from the septic tank to the leachfield.
2. Either a 6-inch diameter clean-out riser or a manway from each compartment of the septic tank must be extended to the ground surface from all septic tanks.

Please be advised that Crook County inspects all small wastewater systems permitted through WDEQ. Please contact Crook County Growth and Development at 307.283.4548 to arrange an inspection of the system. **Septic systems shall not be installed during adverse weather. This includes rain, snow, severely cold temperatures, or excessively moist soils.** Please contact me with questions at 307.777.6941.

Sincerely,


Suzanne Engels
WDEQ/WQD

SE/rm/11-0468

cc: IPS, Cheyenne
WYDEQ Casper File
Tim Lyons, Crook County Growth and Development, PO Box 848, Sundance, WY 82729
Karey Cook, Medicine Lodge, LLC, 8 Medicine Lodge Rd, Gillette, WY 82718



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

PERMIT NO. 11-188

River Bend Meadows Subdivision Well #2 and Well House
No Public Water System Number Assigned

This permit hereby authorizes the applicant:

Dan Olsen
River Bend Meadows, LLC
190 Newport Center Dr., Suite 100
Newport Beach, CA 92660

to construct a water well, well house with chlorination system and an alternative power system to serve the River Bend Meadows Subdivision according to the procedures and conditions of the application number 11-188. The facility is located approximately 1 miles north of The Town of Thayne within NE 1/4, Section 10, T34N, R119W in the county of Lincoln, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by May 13, 2013.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not


relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

3/19/11
Date of Issuance

MDB/rm/11-0467

cc: Ryan J. Erickson, P.E., Sunrise Engineering, Inc., P.O. Box 609, Afton, WY 83110

STATEMENT OF BASIS

1. Permit Number: 11-188
2. Application reviewed for compliance with the following regulations:
3. Chapters 3, and 12 of the Wyoming Water Quality Rules and Regulations.
4. Does the permit comply with all applicable regulations identified above?
Yes.
5. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.
NA
6. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
Not Required
7. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron P.E. Southwest District Engineer, mark.baron@wyo.gov and completed on May 13, 2011. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO 11-189

Granger - Water Treatment Plant
PWS WY5600020

This permit hereby authorizes the applicant:

Lenore Siedentop Perry
Town of Granger
P.O. Box 42
Granger, WY 82934

to construct a 720,000 gallon per day (24 hours of operation at 500 gpm) two train surface water treatment plant consisting of a building with lab, chemical treatment, tube clarification, adsorption clarification, conventional mixed media filtration, ultraviolet light disinfection, chlorine disinfection, a 89,221 gallon clearwell/contact tank, 56,000 gallon backwash waste storage tank, high service pumps, transfer pumps, back wash waste pumps, reclaim pump, backwash supply pumps and raw water supply pumps according to the procedures and conditions of the application number 11-189. The facility is located within the Town of Granger within SE ¼, Section 29, T19N, R111W and NE ¼ Section 32, T19N, R111W and NW ¼ Section 32, T19N, R111W in the county of Sweetwater, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by December 29, 2014.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.

a. Date that construction of the facility was completed; and


b. Date that the facility was placed in operation; and


c. Certification the facility was constructed in accordance with the terms and conditions of the permit;
or

d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

1-6-2012
Date of Issuance

MDB/rm/12-0001

STATEMENT OF BASIS

1. Permit Number: 11-189
2. Application reviewed for compliance with the following regulations:
Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.
3. Does the permit comply with all applicable regulations identified above?

No. Chapter 12 does not contain regulations and rules that cover the proposed water treatment system. The proposed Trident HS Multi-Barrier system consists of 4 barriers. Barrier I consists of a tube clarifier with 60 degree tubes. Barrier II is an up-flow adsorption clarifier. Barrier III is a conventional mixed media gravity filter. Barrier IV is a UV disinfection system.
4. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.

Not Required
5. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron P.E. Southwest District Engineer, mark.baron@wyo.gov and completed on December 29, 2011. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."

WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION

PERMIT NO. 11-190

Jim Bridger Power Plant - FGD Pond 2 Interior Slope Repair

This permit hereby authorizes the applicant:

Robert P. Arambel
PacifiCorp
P.O. Box 158
Point of Rocks, WY 82942

to construct interior slope repair using turf reinforcement mats consisting of segment 1 (1700 feet), segment 2 (1900 feet) segment 3 (550 feet) , two 10-inch HDPE effluent pipeline extensions 1950 lineal feet in length, one 12-inch HDPE effluent pipeline extension 500 lineal feet in length from each FGD pond pig catcher, two pig catchers and a new boat ramp according to the procedures and conditions of the application number 11-190. The facility is located approximately 35 miles east of the City of Rock Springs and 8 miles north of Point of Rocks within Sections 25, 26 and 35, T21N, R101W in the county of Sweetwater, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by May 17, 2013.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.


The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.


The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.

In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.
- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Northwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit; or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.
- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

5/19/11
Date of Issuance



MDB/rm/11-0472

cc: Kenneth Temme, P.E., Tetra Tech, Inc., 605 North Warehouse Road, Casper, WY 82601

STATEMENT OF BASIS


1. Permit Number: 11-190
2. Application reviewed for compliance with the following regulations:
3. Chapters 3, and 11 of the Wyoming Water Quality Rules and Regulations.
4. Does the permit comply with all applicable regulations identified above?
Yes.
5. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.
NA
6. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.
FDG Pond #2 has an existing groundwater monitoring and remediation system.
7. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION

The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron P.E. Southwest District Engineer, mark.baron@wyo.gov and completed on May 17, 2011. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Matt Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 24, 2011

Ronald G. Vaughn
EP-RSAL, LLC
1215 Monaco Parkway
Denver, CO 80220

RE: Rock Springs - Deer Trail Assisted Living Complex Water Main Project - Permit Number 11-191R, Reagan Summit Subdivision Lot 1, Long: 109.2553, Lat: 41.5952, Sweetwater County

Dear Mr. Vaughn:

The above application for coverage under General Permit to Construct the extension of a public water supply distribution system consisting of about 680 linear feet of 8-inch PVC water main and about 61 linear feet of 6-inch PVC water main to serve an Assisted Living Complex in accordance with Chapter 3, Section 7, Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the General Permit. These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at :

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact me at 307-332-3144.

Sincerely,


Mark Baron, P.E.
Southwest District Engineer
Water Quality Division

PDF to Cheyenne
Patricia Kroetch, P.E., North Star Design, Inc., 700 Automation Drive, Windsor, CO 80550





Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Matt Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 17, 2011

Bob Martin, Owner
Skate-Away
96 Sunset Rim,
Cody, WY 82414

RE: Fire sprinkler line for the skate away building in the City of Cody. DEQ Permit #11-193, Park County, Latitude 44.53333°, Longitude 109.01997°

Dear Mr. Martin,

This project consists of the installation of approximately 100 linear feet of 4 inch water line south of US Highway 16 to provide fire protection to the Skate-Away building in the city of Cody.

The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7, and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at:

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact Hannes Stueckler at 307-335-6964 or James Brough at 307-335-6961.

Sincerely,

Hannes E. Stueckler, P.E.
Assistant Northwest District Engineer
Water Quality Division

xc: PDF to Cheyenne
Cody A. Schatz P.E., Engineering Associates, P.O. Box 1900, Cody, WY 82414



WYOMING DEPARTMENT OF ENVIRONMENTAL QUALITY
WATER QUALITY DIVISION
PERMIT TO CONSTRUCT

PERMIT NO. 11-194RR

Sweetwater County Picnic Grounds - Water Treatment Plant
PWS Number WY5600635

This permit hereby authorizes the applicant:

Eric Bingham
Sweetwater County Recreation Board
731 "C" Street
Rock Springs, WY 82901

to construct a 15 gpm membrane filtration package water treatment plant to serve a picnic grounds according to the procedures and conditions of the application number 11-194RR. The facility is located approximately 1/2 mile southwest of Jamestown within SE ¼, Section 7, T18N, R107W in the county of Sweetwater, in the State of Wyoming. All construction, installation, or modification allowed by this permit shall be completed by September 29, 2013.

The issuance of this permit confirms that the Wyoming Department of Environmental Quality (DEQ) has evaluated the application submitted by the permittee and determined that it meets minimum applicable construction and design standards. The compliance with construction standards and the operation and maintenance of the facility to meet the engineer's design are the responsibility of the permittee, owner, and operator.

Granting this permit does not imply that DEQ guarantees or ensures that the permitted facility, when constructed, will meet applicable discharge permit conditions or other effluent or operational requirements. Compliance with discharge standards remains the responsibility of the permittee.

Nothing in this permit constitutes an endorsement by DEQ of the construction or the design of the facility described herein. This permit verifies only that the submitted application meets the design and construction standards imposed by Wyoming statutes, rules and regulations. The DEQ assumes no liability for, and does not in any way guarantee or warrant the performance or operation of the permitted facility. The permittee, owner and operator are solely responsible for any liability arising from the construction or operation of the permitted facility. By issuing this permit, the State of Wyoming does not waive its sovereign immunity.

The permittee shall allow authorized representatives from DEQ to enter and inspect any property, premise or place on or at which the facility is located or is being constructed or installed for the purpose of investigating actual or potential sources of water pollution, and for determining compliance or non-compliance with any rules, regulations, standards, permits or orders.

Nothing in this permit shall be construed to preclude the institution of any legal action or other proceeding to enforce any applicable provision of law or rules and regulations. It is the duty of the permittee, owner and operator to comply with all applicable federal, state and local laws or regulations in the exercise of its activities authorized by this permit.

The issuance of this permit does not convey any property rights in either real or personal property or any invasion of personal rights, or any infringement of federal, state or local laws or regulations.

The permittee shall construct and operate the permitted facility in accordance with the statements, representations, procedures, terms and conditions of the permit application, supporting documents and permit. This permit does not relieve the permittee from any duty to obtain any other permit or authorization that may be required by any provision of federal, state or local laws.


In carrying out its activities authorized by this permit, the permittee, owner and operator shall comply with all of the following permit conditions:

- 1 of 3 The applicant will provide immediate oral or written notice to the Wyoming Department of Environmental Quality, Water Quality Division (WQD), Southwest District Engineer, 510 Meadowview Drive, Lander, WY 82520, 307-332-3144, FAX 307-332-3183, in accordance with the provisions of Section 11, Chapter 3, Wyoming Water Quality Rules and Regulations of any changes or modifications which are not consistent with the terms and conditions of this permit.

- 2 of 3 Within sixty days of completion of construction of the authorized facility, the applicant will submit to the Southwest District a certification of completion signed by the Engineer of Record or the owner. A form titled "Certificate of Completion" has been provided.
 - a. Date that construction of the facility was completed; and
 - b. Date that the facility was placed in operation; and
 - c. Certification the facility was constructed in accordance with the terms and conditions of the permit;
or
 - d. Certification the facility was completed with changes or modifications. Submittal of as-constructed plans and specifications for the system as it was constructed, certified by an engineer if appropriate is required. All modifications or deviations from the authorized plans must be highlighted.

- 3 of 3 The review and approval of this permit is based upon the items identified in the attached "Statement of Basis".

AUTHORIZED BY:


John F. Wagner
Administrator
Water Quality Division


John V. Corra
Director
Department of Environmental Quality

10-4-11
Date of Issuance
MDB/mdb

MDB/bb/11-0897

xc: Gary Cahoon, P.E., Westech Engineering, 3625 South West Temple, Salt Lake City, UT 84115

STATEMENT OF BASIS

1. Permit Number: 11-194RR
2. Application reviewed for compliance with the following regulations:
3. Chapters 3 and 12 of the Wyoming Water Quality Rules and Regulations.
4. Does the permit comply with all applicable regulations identified above?

No. Chapter 12 does not contain regulations and rules that cover membrane filtration. The proposed package water treatment plant is to have 6 log removal/inactivation of cryptosporidium, 7 log removal/inactivation of Giardia and 4 log removal/inactivation of Viruses. The plant will be treated as a cartridge filtration system under the Long Term 2 Enhanced Surface Water Treatment Rule.

5. Facilities include components not specifically covered by regulations and approval is based upon a deviation from applicable regulations in accordance with Section 5 of applicable regulations.

NA.

6. If Section 17 of Chapter 3 review is required indicate the basis for determining groundwater will be protected.

Not Required.

7. Documentation of Statement of Basis: The archive file for this permit includes adequate documentation of all sections of this Statement of Basis.

CERTIFICATION


The issuance of this permit is based upon a review of the application package submitted in accordance with the requirements of Chapter 3, Section 6, Wyoming Water Quality Rules and Regulations. This review was performed by Mark Baron P.E. Southwest District Engineer, mark.baron@wyo.gov and completed on September 29, 2011. Permit issuance is recommended based upon statements, representations, and procedures presented in the permit application and supporting documents permit conditions, and the items identified in this "Statement of Basis."

MDB/bb/11-0897



Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

June 6, 2011

Rod & Lori Bennett
P.O. Box 1162
Saratoga, Wyoming 82331

RE: Bennett Residential Septic System,
Location: a Portion of Section 29, 30, and 32, T13N, R85W,
St. Clair Lode Mining Claim, Lot No. 205

Application No. **11-195**
Carbon County

Dear Mr. and Mrs. Bennett:

The above application for coverage under General Permit to Construct, Install, Modify or Operate a Small Wastewater Facility consisting of a 1000 gallon, two compartment, concrete septic tank and about 130 feet of chamber type leachfield divided into two equal length trenches for a **3 bedroom house** in accordance with Chapter 3, Section 9 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the small wastewater system in accordance with Chapter 25 of the Water Quality Division Rules and Regulations, the general permit, the condition listed below, and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit. Additionally, the following project specific condition also applies:

Septic Tank Clean-Out Riser Requirement - Either a 6 inch diameter clean-out riser or the manway **from each compartment of the septic tank must be extended to the ground surface.**

The approval granted under this Notification Of Coverage and the General Permit shall expire on June 6, 2013. Please reference Application Number **11-195** in any future correspondence.

If you have any questions, please contact me at either ron.ewald@wyo.gov or by phone at (307) 777-6183.

Sincerely,

Ronald L. Ewald
Assistant Southeast District Engineer
Southeast District, Water & Wastewater Section
Water Quality Division

RLE/rm/11-0543

Enclosures: GENERAL PERMIT - Small Wastewater Facility
Certificate of Completion

cc: IPS, Cheyenne
Kristy Rowan, Carbon County Planning Office, Carbon Building, 215 West
Buffalo Street, Suite 336, Rawlins, Wyoming 82301

Herschler Building · 122 West 25th Street · Cheyenne, WY 82002 · <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---





Department of Environmental Quality

*To protect, conserve, and enhance the quality of Wyoming's
environment for the benefit of current and future generations.*



Matthew H. Mead, Governor

152 N. Durbin St., Suite 100 · Casper, WY 82601 · (307) 473-3450

John Corra, Director

NOTIFICATION OF COVERAGE

June 13, 2011

Sinclair Transportation Company
Randall Hall
6173 West Zero Road
Casper, WY 82604

RE: Sinclair Transportation Company – Water and Sewer Line Extension,
Evansville, WY, WDEQ #11-196

Dear Mr. Hall:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations and for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Sewage Collection Systems in accordance with Chapter 3 and Chapter 11 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility(ies) in accordance with the general permits and the materials submitted in your application package. The General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage,

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact me at 307-473-3478.

Sincerely,

Karen L. Farley, P.E.
Northeast District Engineer, Water Quality Division

Enclosures: Certificate of Completion

cc: Lowell Fleenor, P.E., State of Wyoming, 900 Bryan Stock Trail, Casper, WY 82602
Matt Williams, P.E., WLC, 200 Pronghorn, Casper, WY 82601
April Gindulis, Natrona County Health Department
IPS
Casper WDEQ File





Department of Environmental Quality

*To protect, conserve, and enhance the quality of Wyoming's
environment for the benefit of current and future generations.*



Matthew H. Mead, Governor

152 N. Durbin St., Suite 100 · Casper, WY 82601 · (307) 473-3450

John Corra, Director

NOTIFICATION OF COVERAGE

June 17, 2011

Mr. Leslie I. Hook, Public Works Director
City of Buffalo
46 N. Main St.
Buffalo, WY 82834

RE: City of Buffalo - 18" Treated Water Transmission Pipeline, Application No. 11-197

Dear Mr. Hook:

The above application for coverage under General Permit to Construct, Install, Modify or Operate Extensions to or Modification of Existing Public Water Supply Distribution Systems in accordance with Chapter 3 and Chapter 12 of the Wyoming Water Quality Rules and Regulations has been reviewed and is hereby approved. You are authorized to construct, install or modify the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O, of the general permit. The general permit is available for download at http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp.

If you have any questions, please contact me at 307-473-3471.

Sincerely,

Kevin J. Frank

Kevin J. Frank
Project Engineer
Water Quality Division

cc: - IPS, Cheyenne
- Brandon L. Gebhart, PE; States West Water Resources Corporation
1904 E. 15th St; Cheyenne, WY 82001
✓ - Keenan Hendon, PE; Water Development Office
6920 Yellowtail Rd, Cheyenne WY 82002





Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



Matthew H. Mead, Governor

John Corra, Director

July 13, 2011

Laramie County Board of Commissioners
300 West 19th Street
Cheyenne, Wyoming 82001

RE: Adverse Recommendation, Bison Crossing 8th Filing Subdivision
Laramie County
WDEQ/WQD Application #11-198

Dear Commissioners:

The Wyoming Department of Environmental Quality has completed the review of the proposed Bison Crossing 8th Filing Subdivision located in a portion of Sections 30 and 31, T13N, R66W, 6th P.M. in Laramie County, Wyoming. The Bison Crossing 8th Filing Subdivision will create 24 lots out of approximately 74.9 acres. The information was submitted by Dahlgren Consulting, Inc. signed by Russell Dahlgren, P.E., P.G. This letter represents the recommendations of the Wyoming Department of Environmental Quality as required by W.S. 18-5-306(c).

Findings as to the safety and adequacy of the proposed sewage system:

The proposed sewage system is the use of individual on-site septic tanks and leach fields permitted by and constructed to Wyoming Department of Environmental Quality, Water Quality Rules and Regulations. The information submitted addresses the safety and adequacy of the proposed sewage system. A non-adverse recommendation for the proposed sewage system can be issued.

Findings as to the safety and adequacy of the proposed water system:

Adequate information has not been provided to determine the adequacy of the water supply. Therefore an adverse recommendation must be issued for the proposed water system. Before a non-adverse recommendation can be issued there must be more definitive evidence submitted of the reliability and sustainable yield of the three major water supply wells for the Winchester Hills Utility Water System. Sufficiently long time period yield and drawdown raw test data must be submitted for each of the three wells to confirm the sustainable steady-state yield rates of each well. The yield and drawdown test requirements are found in Chapter 12, Section 9(b)(ii). The three wells are the Winchester Hills No. 1, the Winchester Hills No. 2, and the Rosenblum No. 2 wells.

Herschler Building · 122 West 25th Street · Cheyenne, WY 82002 · <http://deq.state.wy.us>

ADMIN/OUTREACH (307) 777-7758 FAX 777-7682	ABANDONED MINES (307) 777-6145 FAX 777-6462	AIR QUALITY (307) 777-7391 FAX 777-5616	INDUSTRIAL SITING (307) 777-7369 FAX 777-6937	LAND QUALITY (307) 777-7756 FAX 777-5864	SOLID & HAZ. WASTE (307) 777-7752 FAX 777-5973	WATER QUALITY (307) 777-7781 FAX 777-5973
--	---	---	---	--	--	---



Additionally, Section 9(b)(i) "Groundwater Source Development" states that "the sources shall be capable of equaling or exceeding the design average daily demand with the largest producing well out of service". With this in mind, the remaining two wells will produce only 135 gpm maximum. We used the peak month of July 2008 divided by 31 days to determine the average daily demand. The two remaining wells will not meet this demand. Based on the information provided, a 135 gpm supply is not enough to safely provide uninterrupted service to the existing community, let alone the additional 24 proposed lots. One or more wells may need to be added to the system to bring it up to standards. The design rate for the entire system, as well as the sustainable yield, both need to be more thoroughly analyzed and documented in any response submittal.

Conclusions:

The Department of Environmental Quality is therefore issuing an overall "Adverse" recommendation applicable to the Bison Crossing 8th Filing Subdivision.

Disclaimer:

The Adverse recommendation provided above has nothing to do with, nor has any bearing on the water rights associated with the Bison Crossing 8th Filing Subdivision. Any questions or concerns about the water rights for the Bison Crossing 8th Filing Subdivision should be directed to the State Engineer's Office.

Nothing in Department of Environmental Quality recommendations or comments regarding the Dahlgren proposal for the Bison Crossing 8th Filing Subdivision shall be construed to relieve T.F.S. II, LLC, Limited liability Company, Winchester Hills Utility of the obligation to obtain any permits or additional approval from any local, state or federal agencies as required by law, rules, regulations, or ordinances. Nothing in these recommendations commits the Department of Environmental Quality or Laramie County to the issuance of required permits for construction, operation, or modification of any water supply or sewage systems.

Sincerely,




Rich Cripe, P.E.
Southeast District Engineer
Water and Wastewater Program, DEQ/Water Quality Division

RRC/RLE/rm/11-0648

cc: Brett A. Vizina, Managing Member, T.F.S. II, LLC, 1124 Dunn Avenue, Cheyenne, Wyoming 82001
Russ Dahlgren, Dahlgren Consulting Inc., 914 East 23rd Street, Cheyenne, WY 82001
John Himmelreich & Associates, 1010 S. Sierra Madre St., Colorado Springs, CO 80903
Laramie County Planning and Development Office, 309 West 20th, Cheyenne, WY 82001
Mike Ebsen, SEO



Department of Environmental Quality



To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.

Matt Mead, Governor

John Corra, Director

NOTIFICATION OF COVERAGE

May 23, 2011

John H. Lawson, Area Manager, Great Plains Region
United States Bureau of Reclamation
P.O. Box 1630
Mills, WY 82644-1630

RE: Buffalo Bill State Park Campground Utilities Project. DEQ Permit #11-199, Park County, Latitude 44.501111°, Longitude 109.236389°; and Latitude 44.483611° Longitude 109.336944°

Dear Mr. Lawson,

This project consists of the installation of recreational vehicle potable water hookups within the North Shore and North Fork campgrounds within The Buffalo Bill State Park. There will be 7 hookups in the North Shore campground and 8 hookups in the North Fork campground.

The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7, and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at:

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp


If you have any questions, please contact Hannes Stueckler at 307-335-6964 or James Brough at 307-335-6961.

Sincerely,

Hannes E. Stueckler, P.E.
Assistant Northwest District Engineer
Water Quality Division

xc: PDF to Cheyenne
William L. Harris P. E., GDA Engineers, P.O. Box 338, Cody, WY 82414






Matt Mead, Governor

Department of Environmental Quality

To protect, conserve and enhance the quality of Wyoming's environment for the benefit of current and future generations.



John Corra, Director

NOTIFICATION OF COVERAGE

May 24, 2011

Neil Miller, Board Chairman
South Thermopolis Water and Sewer District
P.O. Box 204
Thermopolis, WY 82443

RE: South Thermopolis Water and Sewer District: Lane 3 - Treated Water and Sanitary Sewer.
DEQ Permit #11-200, Hot Springs County, Latitude 43.6328°, Longitude 108.2211°

Dear Mr. Miller,

This project consists of the replacement of 90 linear feet of 8 inch AC TW pipe with 8 inch PVC, installation of a new 1480 linear foot, 8 inch PVC treated water line, and 690 linear foot 8 inch PVC sanitary sewer extension.

The above application for coverage under General Permit has been reviewed in accordance with Chapter 3, Section 7; Chapter 11, Part B; and Chapter 12, Section 14 of the Wyoming Water Quality Rules and Regulations and is hereby approved.

You are authorized to construct, the facility in accordance with the general permit and the materials submitted in your application package. Your attention is directed to the mandatory reporting requirements outlined in Part V, Section O of the general permit.

These General Permit requirements can be downloaded from the Wyoming Department of Environmental Quality webpage. The General Permits can be found under the Water Quality Division Water and Wastewater Program, Engineering and Technical Services at:

http://deq.state.wy.us/wqd/www/Permitting/Pages/general_permits.asp

If you have any questions, please contact Hannes Stueckler at 307-335-6964 or James Brough at 307-335-6961.

Sincerely,

Hannes E. Stueckler, P.E.
Assistant Northwest District Engineer
Water Quality Division

xc: PDF to Cheyenne
Ian Sporkin-Morrison P.E., Engineering Associates, P.O. Box 1900, Cody, WY 82414

